

Contents

Vol. 65, No. 3, 2018

A simultaneous English language translation of this journal is available from Pleiades Publishing, Inc.
Distributed worldwide by Springer. *Thermal Engineering* ISSN 0040-6015.

Steam-Turbines, Gas-Turbines, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Steam Turbine Flow Path Seals (a Review)

V. M. Neuimin

Computational Study on the Effect of Shroud Shape on the Efficiency
of the Gas Turbine Stage

I. V. Afanas'ev and A. V. Granovskii

Patterns of the Rotor-over-Stator Rolling under Change in the Damping Components

V. F. Shatokhin

Energy Conservation, New and Renewable Energy Sources

Technologies for the Comprehensive Exploitation of the Geothermal Resources
of the North Caucasus Region

A. B. Alkhasov

Heat Exchangers for Utilization of the Heat of High-Temperature Geothermal Brines

A. B. Alkhasov and D. A. Alkhasova

Heat and Mass Transfer, Properties of Working Fluids and Materials

Accounting for the Effect of Noncondensing Gases on Interphasic Heat and Mass Transfer
in the Two-Fluid Model Used in the KORSAR Code

Yu. V. Yudov

Water Treatment and Water Chemistry

Qualitative and Quantitative Analysis of Organic Impurities in Feedwater
of a Heat-Recovery Steam Generator

A. A. Chichirov, N. D. Chichirova, A. A. Filimonova, and A. A. Gafiatullina

Steam Turbine Flow Path Seals (a Review)

V. M. Neuimin

OOO Process Protective Coating Systems, Moscow, 105484 Russia

e-mail: neva333@yandex.ru

Received May 5, 2017; in final form, August 30, 2017

Abstract—Various types of shroud, diaphragm, and end seals preventing idle leak of working steam are installed in the flow paths of steam turbine cylinders for improving their efficiency. Widely known labyrinth seals are most extensively used in the Russian turbine construction industry. The category of labyrinth seals also includes seals with honeycomb inserts. The developers of seals with honeycomb inserts state that the use of such seals makes it possible to achieve certain gain due to smaller leaks of working fluid and more reliable operation of the system under the conditions in which the rotor rotating parts may rub against the stator elements. However, a positive effect can only be achieved if the optimal design parameters of the honeycomb structure are fulfilled with due regard to the specific features of its manufacturing technology and provided that this structure is applied in a goal-seeking manner in the seals of steam and gas turbines and compressors without degrading their vibration stability. Calculated and preliminary assessments made by experts testify that the replacement of conventional labyrinth seals by seals with honeycomb inserts alone, due to which the radial gaps in the shroud seal can be decreased from 1.5 to 0.5 mm, allows the turbine cylinder efficiency to be increased at the initial stage by approximately 1% with the corresponding gain in the turbine set power output. The use of rectangular-cellular seals may result, according to estimates made by their developers, in a further improvement of turbine efficiency by 0.5–1.0%. The labor input required to fabricate such seals is six to eight times smaller than that to fabricate labyrinth seals with honeycomb inserts. Recent years have seen the turbine construction companies of the United States and Germany advertising the use of abrasible (sealing) coatings (borrowed from the gas turbine construction technology) in the turbine designs instead of labyrinth seals. The most efficient performance of such seals in the turbine flow path is achieved with the sealing material-to-blade linear wear ratio equal to 10 : 1. According to estimates of the developers, application of abrasible (sealing) coatings to all problem surfaces (resulting in the power output increased by 0.5–1.0%) is economically profitable even if this procedure is carried out under field conditions at a thermal power plant.

Keywords: steam leak, labyrinth seals, honeycomb inserts, abrasible (sealing) coatings, materials, efficiency, repair

Computational Study on the Effect of Shroud Shape on the Efficiency of the Gas Turbine Stage

I. V. Afanas'ev and A. V. Granovskii*

Lyulka Development Design Bureau, Moscow, 129301 Russia

**e-mail: andrey.granovskiy@yandex.ru*

Received July 5, 2017; in final form, August 30, 2017

Abstract—The last stages of powerful power gas turbines play an important role in the development of power and efficiency of the entire plant as well as in the distribution of the flow parameters behind the last stage, which determines the efficient operation of the exhaust diffusers. Therefore, much attention is paid to improving the efficiency of the last stages of gas turbines as well as the distribution of flow parameters. Since the long blades of the last stages of multistage high-power gas turbines could fall into the resonant frequency range in the course of operation, which results in the destruction of the blades, damping wires or damping bolts are used for turning out of resonant frequencies. However, these damping elements cause additional energy losses leading to a reduction in the efficiency of the stage. To minimize these losses, dampening shrouds are used instead of wires and bolts at the periphery of the working blades. However, because of the strength problems, designers have to use, instead of the most efficient full shrouds, partial shrouds that do not provide for significantly reducing the losses in the radial gap between the blade and the turbine housing. In this paper, a computational study is performed concerning an effect that the design of the shroud of the turbine-working blade exerted on the flow structure in the vicinity of the shroud and on the efficiency of the stage as a whole. The analysis of the flow structure has shown that a significant part of the losses under using the shrouds is associated with the formation of vortex zones in the cavities on the turbine housing before the shrouds, between the ribs of the shrouds, and in the cavities at the outlet behind the shrouds. All the investigated variants of a partial shrouding are inferior in efficiency to the stages with shrouds that completely cover the peripheral section of the working blade. The stage with a shroud-free working blade was most efficient at the values of the relative radial gap less than 0.9%.

Keywords: efficiency of last turbine stage, damping shroud, efficiency of full and partial shrouds, flow structure in the radial gap

Patterns of the Rotor-over-Stator Rolling under Change in the Damping Components

V. F. Shatokhin

Kaluga Turbine Works, Kaluga, 248010 Russia

e-mail: shatokhin_vf@ktz.power-m.ru

Received May 5, 2017; in final form, August 30, 2017

Abstract—As experimental studies show, the rubbing of the rotor against the structure usually excites harmonics of different frequencies. In high-frequency regions, the power of the vibration signal appears to be considerable. The rotor—supports—stator system is in an unstable equilibrium state during the contact interaction between the rotor and the stator. The forces exerted on the rotor facilitate the excitation of the asynchronous rolling and its damping. The forces have been determined that facilitate the excitation of the progressive and retrograde rotor precession. The consideration of these forces in the algorithm for modeling the rotor-over-stator rolling development allows investigation of the impact of the components of the above forces on the behavior of the rotor system. The initial excitation—disturbance of the normal operation—of the rotor and subsequent unsteady oscillations of it result from sudden imbalance in the second span. The results of numerical modeling of the rubbing in the second span and the rotor-over-stator rolling upon change in the damping components of secondary (gyroscopic) components b_{ij} ($i \neq j$) of the damping matrix are presented for the rotor on three bearing-supports considering the synergetic effect of the forces of various types exerted on the rotor. It is shown that change in one of the parameters of the excitation forces leads to ambiguity of the pattern (manifestation form) of the asynchronous rotor-over-stator rolling and proves the existence of more than one states towards which the rotor—supports—stator system tends. In addition to the rolling with a constant rotor—stator contact, oscillations of the rotor develop in the direction perpendicular to the common trajectory of the precession motion of the rotor's center with transition to the vibro-impact motion mode. The oscillations of the rotor tend towards the symmetry center of the system (the stator bore center). The reason is the components of the stiffness and damping forces that act in the direction transverse to the rotor's motion trajectory. Recommendations are given for eliminating dangerous consequences of the development of the asynchronous rolling fraught with great financial losses.

Keywords: rotor, stator, asynchronous rolling, rolling-exciting forces, contact stiffness coefficients, gyroscopic forces, motion trajectory of the rotor section's center, angular velocity of the rotor precession, normal pressure force exerted on the stator

Technologies for the Comprehensive Exploitation of the Geothermal Resources of the North Caucasus Region

A. B. Alkhasov

*Institute for Geothermal Research, Dagestan Science Center (DNTs), Russian Academy of Sciences,
Makhachkala, 367030 Dagestan, Russia*

e-mail: alibek_alhasov@mail.ru

Received July 3, 2017; in final form, August 30, 2017

Abstract—Technology for the integrated development of low-temperature geothermal resources using the thermal and water potentials for various purposes is proposed. The heat of the thermal waters is utilized in a low-temperature district heating system and for heating the water in a hot water supply system. The water cooled in heat exchangers enters a chemical treatment system where it is conditioned into potable water quality and then forwarded to the household and potable water supply system. Efficient technologies for removal of arsenic and organic contaminants from the water have been developed. For the uninterrupted supply of the consumers with power, the technologies that use two and more types of renewable energy sources (RESs) have the best prospects. Technology for processing organic waste using the geothermal energy has been proposed. According to this technology, the geothermal water is divided into two flows, one of which is delivered to a biomass conversion system and the other is directed to a geothermal steam–gas power plant (GSGP). The wastewater arrives at the pump station from which it is pumped back into the bed. Upon drying, the biogas from the conversion system is delivered into the combustion chamber of a gas-turbine plant (GTP). The heat of the turbine exhaust gases is used in the GSGP to evaporate and reheat the low-boiling working medium. The working medium is heated in the GSGP to the evaporation temperature using the heat of the thermal water. High-temperature geothermal brines are the most promising for the comprehensive processing. According to the proposed technology, the heat energy of the brines is utilized to generate the electric power at a binary geothermal power station; the electric power is then used to extract the dissolved chemical components from the rest of the brine. The comprehensive utilization of high-temperature brines of the East-Precaucasian Artesian Basin will allow to completely satisfy the demand of Russia for lithium carbonate and sodium chloride.

Keywords: geothermal energy, low-temperature thermal water, geothermal well, arsenic, salinity, lithium carbonate

Heat Exchangers for Utilization of the Heat of High-Temperature Geothermal Brines

A. B. Alkhasov* and D. A. Alkhasova

Institute for Geothermal Research, Dagestan Science Center (DNTs), Russian Academy of Sciences, Makhachkala, 367030 Dagestan, Russia

**e-mail: alibek_alkhasov@mail.ru*

Received July 3, 2017; in final form, August 30, 2017

Abstract—The basic component of two-circuit geothermal systems is the heat exchanger. When used in geothermal power systems, conventional shell-and-tube and plate heat exchangers cause problems related to the cleaning of the latter from salt-deposition and corrosion products. Their lifetime does not exceed, as a rule, 1 year. To utilize the heat of high-temperature geothermal brines, a heat exchanger of the “tube-in-tube” type is proposed. A heat exchanger of this design has been operated for several years in Ternair geothermal steam field; in this heat exchanger, the thermal potential of the saline thermal water is transferred to the fresh water of the secondary circuit of the heating system for apartment houses. The reduction in the weight and size characteristics of the heat exchangers is a topical problem that can be solved with the help of heat transfer enhancers. To enhance the heat transfer process in the heat exchanger, longitudinal ribbing of the heat exchange surface is proposed. The increase in the heat exchange surface from the heat carrier side by ribbing results in an increase in the amount of the heat transferred from the heating agent. The heat exchanger is easy to manufacture and is assembled out of components comprised of two concentrically positioned tubes of a definite length, 3–6 m, serially connected with each other. The method for calculation of the impact of the number and the size of the longitudinal ribs on the heat transfer in the well heat exchanger is presented and a criterion for the selection of the optimal number and design parameters of the ribs is formulated. To prevent the corrosion and salt deposition in the heat exchanger, the use of an effective OEDFK (oxyethylenediphosphonic acid) agent is proposed. This agent has a long-lasting corrosion-inhibiting and antiscaling effect, which is explained by the formation of a strongly adhesive chelate layer difficult to wash off the surface. The passivating OEDFK layer is restored by periodical pulsed introduction of the agent solution into the brine at the heat exchanger inlet.

Keywords: geothermal resources, high-temperature brines, heat exchanger, heat transfer, heat transfer enhancement, salt deposition

Accounting for the Effect of Noncondensing Gases on Interphasic Heat and Mass Transfer in the Two-Fluid Model Used in the KORSAR Code

Yu. V. Yudov

Aleksandrov Scientific-Research Technological Institute (NITI), Leningrad oblast, 188540 Russia

e-mail: yudov@niti.ru

Received July 5, 2017; in final form, August 30, 2017

Abstract—A model is presented of the interphasic heat and mass transfer in the presence of noncondensable gases for the KORSAR/GP design code. This code was developed by FGUP NITI and the special design bureau OKB Gidropress. It was certified by Rostekhnadzor in 2009 for numerical substantiation of the safety of reactor installations with VVER reactors. The model is based on the assumption that there are three types of interphasic heat and mass transfer of the vapor component: vapor condensation or evaporation on the interphase under any thermodynamic conditions of the phases, pool boiling of the liquid superheated above the saturation temperature at the total pressure, and spontaneous condensation in the volume of gas phase supercooled below the saturation temperature at the vapor partial pressure. Condensation and evaporation on the interphase continuously occur in a two-phase flow and control the time response of the interphase heat and mass transfer. Boiling and spontaneous condensation take place only at the metastable condition of the phases and run at a quite high speed. The procedure used for calculating condensation and evaporation on the interphase accounts for the combined diffusion and thermal resistance of mass transfer in all regimes of the two-phase flow. The proposed approach accounts for, in a natural manner, a decrease in the rate of steam condensation (or generation) in the presence of noncondensing components in the gas phase due to a decrease (or increase) in the interphase temperature relative to the saturation temperature at the vapor partial pressure. The model of the interphase heat transfer also accounts for the processes of dissolution or release of noncondensing components in or from the liquid. The gas concentration at the interphase and on the saturation curve is calculated by the Henry law. The mass transfer coefficient in gas dissolution is based on the heat and mass transfer analogy. Results are presented of the verification of the interphase heat and mass transfer used in the KORSAR code based on the data on film condensation of steam-air flows in vertical pipes. The proposed model was also tested by solving a problem of nitrogen release from a supersaturated water solution.

Keywords: noncondensing gases, interphasic heat and mass transfer, vapor-gas mixture, two-fluid model, numerical code, verification

Qualitative and Quantitative Analysis of Organic Impurities in Feedwater of a Heat-Recovery Steam Generator

A. A. Chichirov, N. D. Chichirova, A. A. Filimonova*, and A. A. Gafiatullina

Kazan State Power Engineering University, Kazan, 420066 Russia

**e-mail: aachichirova@mail.ru*

Received March 22, 2017; in final form, August 30, 2017

Abstract—In recent years, combined-cycle units with heat-recovery steam generators have been constructed and commissioned extensively in the European part of Russia. By the example of the Kazan Cogeneration Power Station no. 3 (TETs-3), an affiliate of JSC TGK-16, the specific problems for most power stations with combined-cycle power units that stem from an elevated content of organic impurities in the feedwater of the heat-recovery steam generator (HRSG) are examined. The HRSG is fed with highly demineralized water in which the content of organic carbon is also standardized. It is assumed that the demineralized water coming from the chemical water treatment department of TETs-3 will be used. Natural water from the Volga River is treated to produce demineralized water. The results of a preliminary analysis of the feedwater demonstrate that certain quality indices, principally, the total organic carbon, are above the standard values. Hence, a comprehensive investigation of the feedwater for organic impurities was performed, which included determination of their structure using IR and UV spectroscopy techniques, potentiometric measurements, and element analysis; determination of physical and chemical properties of organic impurities; and prediction of their behavior in the HRSG. The estimation of the total organic carbon revealed that it exceeded the standard values in all sources of water comprising the feedwater for the HRSG. The extracted impurities were humic substances, namely, a mixture of humic and fulvic acids in a 20 : 80 ratio, respectively. In addition, an analysis was performed of water samples taken at all intermediate stages of water treatment to study the behavior of organic substances in different water treatment processes. An analysis of removal of the humus substances in sections of the water treatment plant yielded the concentration of organic substances on the HRSG condensate. This was from 100 to 150 $\mu\text{g}/\text{dm}^3$. Organic impurities in boiler water can induce internal corrosion and deposits containing products of their degradation.

Keywords: heat-recovery steam generator, feedwater, IR and UV spectroscopy, potentiometry