

---

---

# Contents

---

---

**Vol. 65, No. 9, 2018**

A simultaneous English language translation of this journal is available from Pleiades Publishing, Inc.  
Distributed worldwide by Springer. *Thermal Engineering* ISSN 0040-6015.

---

---

## **Steam Turbine, Gas Turbine, and Combined-Cycle Plants and Their Auxiliary Equipment**

Ways for Improving Efficiency and Reliability of Steam Turbines at Nuclear Power Stations

*G. A. Filippov and E. B. Yurchevskii*

The Impact of Design Deviations on Dynamic Characteristics of a Flexible Multispan Rotor  
on Complete Electromagnetic Suspension

*V. F. Ovchinnikov, M. Ya. Nikolaev, V. N. Litvinov, N. G. Kodochigov, and I. V. Drumov*

The Conceptual Process Arrangement of a Steam--Gas Power Plant  
with Fully Capturing Carbon Dioxide from Combustion Products

*A. S. Kosoi, Yu. A. Zeigarnik, O. S. Popel', M. V. Sinkevich,  
S. P. Filippov, and V. Ya. Shterenberg*

---

## **Heat and Mass Transfer and Properties of Working Fluids and Materials**

Investigation of Hydrodynamics and Heat Transfer of an Upward Liquid Metal Flow  
in a Rectangular Channel under a Coplanar Magnetic Field

*P. V. Kostychev, N. G. Razuvanov, and V. G. Sviridov*

An Efficient Unified Approach for Performance Analysis of Functionally Graded Annular Fin  
with Multiple Variable Parameters

*R. Ranjan and A. Mallick*

---

## **Nuclear Power Plants**

The EUCLID/V1 Integrated Code for Safety Assessment of Liquid Metal Cooled  
Fast Reactors. Part 2: Verification

*V. M. Alipchenkov, A. V. Boldyrev, D. P. Veprev, Yu. A. Zeigarnik, P. V. Kolobaeva,  
E. V. Moiseenko, N. A. Mosunova, E. F. Seleznev, V. F. Strizhov, E. V. Usov,  
S. L. Osipov, V. S. Gorbunov, D. A. Afremov, and A. A. Semchenkov*

Treatment of the Equations of Metal Oxidation Rates at Nuclear Power Plants  
and Thermal Power Plants in Terms of Thermodynamics

*V. G. Kritskii, I. G. Berezina, A. V. Gavrilov, E. A. Motkova, and N. A. Prokhorov*

---

## **Metals and Strength Analysis**

Flow-Accelerated Corrosion Wear of Power-Generating Equipment: Investigations,  
Prediction and Prevention: Part 3. Managing the Flow-Accelerated Corrosion  
of Pipelines and Equipment

*G. V. Tomarov, A. A. Shipkov, and D. V. Aflitonov*

---

## **Water Treatment and Water Chemistry**

Studies on the Deposit Structure in the Cooling Systems of Steam Turbines at TPPs

*N. D. Chichirova, S. M. Vlasov, A. A. Chichirov, A. A. Filimonova, and A. Yu. Vlasova*

---

## **District Heating And Heat Network**

Fuel Efficiency of Energy Sources in Heat Supply Systems

*B. A. Semenov and E. A. Larin*

---

---

# Ways for Improving Efficiency and Reliability of Steam Turbines at Nuclear Power Stations

G. A. Filippov<sup>a</sup> and E. B. Yurchevskii<sup>a, \*</sup>

<sup>a</sup>AO OKB GIDROPRESS, Podolsk, 142103 Russia

\*e-mail: [aquachim@yandex.ru](mailto:aquachim@yandex.ru)

Received January 19, 2018; in final form, February 21, 2018

**Abstract**—The current state and ways for improving the effectiveness of steam turbine units at nuclear power stations (NPS) are examined. The specifics of NPS turbines is described. The comparison of NPS steam turbine performance with the performance of steam turbines at thermal power stations (TPS) demonstrates that power units of NPSs are much poorer in effectiveness due to relatively low steam conditions at the inlet and the presence of wet steam already in the first stages of turbines. A decrease in the relative internal efficiency of NPS turbines results from the enhanced negative effect of wetness in the expansion process: in modern NPS turbines, more than two-thirds of the heat drop is spent in the two-phase region, while less than one fourth in TPS turbines. It is demonstrated that the effectiveness of NPS steam turbine units can be increased drastically in the future only through a considerable rise in the turbine inlet steam conditions. This can be achieved by using a heat carrier at supercritical conditions in the NPS reactor. The dependence of the effectiveness of NPS modern turbines on the turbine inlet steam conditions in the applicable pressure ranges of the saturated steam and vacuum in the condenser, as well as on the turbine exhaust area, is examined. For a 1000 MW turbine, increasing the inlet pressure from 6.0 to 8.0 MPa raises the turbine power and efficiency by 3.5%. At a condensing turbine outlet pressure ranging from 2.5 to 7.5 kPa and a constant velocity downstream of the last stage, the turbine power and efficiency can be increased by 7%. The importance of the exhaust area for the turbine effectiveness is revealed. Alternative designs of the flowpath in a low-pressure cylinder are analyzed. A unique configuration of a steam turbine unit with two-stage moisture separation is proposed. The comparison of high-speed turbines with low-speed ones was performed. It is demonstrated that the efficiency of the examined turbines is nearly the same within the accuracy of design calculations and the test results, and it is slightly higher for low-speed turbines due to lower losses with outlet velocity.

**Keywords:** nuclear power stations, steam turbine unit efficiency, promising ways for improving efficiency, heat carriers parameters, moisture separation, exhaust area, blade length

# The Impact of Design Deviations on Dynamic Characteristics of a Flexible Multispan Rotor on Complete Electromagnetic Suspension

V. F. Ovchinnikov<sup>a</sup>, M. Ya. Nikolaev<sup>a,\*</sup>, V. N. Litvinov<sup>a</sup>, N. G. Kodochigov<sup>b</sup>, and I. V. Drumov<sup>b</sup>

<sup>a</sup>Research Institute of Mechanics, Lobachevskii State University, Nizhny Novgorod, 603950 Russia

<sup>b</sup>JSC "Afrikantov OKBM", Nizhny Novgorod, 603074 Russia

\*e-mail: minick@mech.unn.ru

Received October 26, 2017; in final form, February 21, 2018

**Abstract**—The paper presents a study of dynamics of rotors on complete electromagnetic suspension, a characteristic feature of which is a relatively low stiffness of the support system. The experience of balancing the rotors of this type shows that deviations of geometrical parameters, although the latter are within design tolerance limits, may have a significant impact on the rotor dynamics. The analysis of the impact of design deviations caused by the nonorthogonality of the disk plane of the axial active magnetic bearings (AMBs) to the rotation axis and noncoaxiality of the rotor shafting in the elastic clutch section on the dynamics of the flexible multispan rotors was made. The model of the dynamics of the rotor was refined considering the above deviations. The resulting model of the dynamics of a rotor on the complete electromagnetic suspension comprises a mechanical model, models of forces of different physical nature, and a model of the AMB control system. The model takes into consideration the effects of forces in the radial and axial active magnetic bearings, imbalance, gyroscopic forces, the force of gravity, and the frequency-independent inner damping; it also describes circulation impacts and tension forces caused by electromagnetic interactions in the generator and exciter as well as gas-dynamic forces in turbines, compressors, and labyrinth seals of their shafts. It is shown in the paper that the considered design deviations caused by nonorthogonality of the disk plane of the axial AMB to the rotation axis and noncoaxiality of the rotor shafting in the elastic clutch section lead to amplitude-constant harmonic influences on the rotor, whose frequency coincides with the rotational speed of the rotor. The verification of the refined computer model was conducted on a scale-modeling test bench for the vertical flexible rotor of a high-temperature gas-cooled reactor. The testing of the model demonstrated qualitative identity of the numerical and experimental results that describe the rotor dynamics in the running-down mode. The proposed mathematical model of the flexible rotor allows for enhancing the precision of the method for identification of unknown parameters, in particular, the residual imbalance, based on solving the inverse dynamics problem.

*Keywords:* active magnetic bearings, design deviations, flexible rotor, high-temperature gas-cooled reactor, rotor dynamics model

# The Conceptual Process Arrangement of a Steam–Gas Power Plant with Fully Capturing Carbon Dioxide from Combustion Products

A. S. Kosoi<sup>a,\*</sup>, Yu. A. Zeigarnik<sup>a</sup>, O. S. Popel<sup>a,\*\*</sup>, M. V. Sinkevich<sup>a</sup>,  
S. P. Filippov<sup>b</sup>, and V. Ya. Shterenberg<sup>a</sup>

<sup>a</sup>*Joint Institute of High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

<sup>b</sup>*Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia*

*\*e-mail: kosoyas@gmail.com*

*\*\*e-mail: O\_Popel@mail.ru*

Received June 23, 2017; in final form, February 21, 2018

**Abstract**—The article proposes a new concept for designing power plants operating on natural gas and involving means for fully removing carbon dioxide from the cycle in the liquid phase form in order to subsequently bind or bury it for reducing the emissions of greenhouse gases into the atmosphere. In contrast to means used in the conventional power plant process arrangements for capturing CO<sub>2</sub> from the combustion products, the proposed concept involves the need to develop fundamentally new power engineering technologies, in which the CO<sub>2</sub> utilization system is intrinsically built into the cycle structure already at the initial stage of power plant design and optimization of its parameters. As an example, the process flow diagram of a natural gas fired power plant generating electricity and heat is considered. The integral indicators characterizing the thermal efficiency of such a power plant are given and compared with the similar indicators of the operating or newly designed plants fitted with CO<sub>2</sub> capturing systems, the process arrangement of which implies direct emission of carbon dioxide into the atmosphere. The comparison is carried out for the average ratio between the generated electricity and heat that has historically been established in the climatic zone of central Russia. It is shown that the proposed cycle features high thermodynamic efficiency and competitiveness with respect to the same indicators of alternative systems for combined generation of electricity and heat. The article suggests versions of the CO<sub>2</sub> capturing system configuration that allows, with the modern technological level of equipment, the carbon dioxide emissions to be reduced down to 0.5–5.0% of the total amount produced in firing natural gas.

*Keywords:* environmentally clean power plant, steam–gas power plant, carbon dioxide, carbon dioxide extraction

# Investigation of Hydrodynamics and Heat Transfer of an Upward Liquid Metal Flow in a Rectangular Channel under a Coplanar Magnetic Field

P. V. Kostychev<sup>a, \*</sup>, N. G. Razuvanov<sup>a</sup>, and V. G. Sviridov<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: KostychevPV@yandex.ru*

Received November 3, 2017; in final form, February 21, 2018

**Abstract**—Hydrodynamics and heat transfer were investigated of an upward liquid metal flow through a rectangular channel having an aspect ratio of approximately 3/1 and one-sided heating under a coplanar magnetic field (MF). The flow in the cooling system's cooling channel for a liquid metal blanket module of a Tokamak type thermonuclear reactor is simulated. Experiments were carried out in the mercury magnetohydrodynamic (MHD) test facility. Local heat transfer characteristics were measured using a probe technique. Two types of thermocouple probes were used: a lever-type pivoted probe for detailed measurements of velocity and temperature fields in a channel cross-section and a longitudinal probe for taking measurements along the heated zone in the channel. A correlation method was used for measuring local velocity. The distributions of averaged velocity and temperature, the distributions of dimensionless wall temperature along the channel perimeter, and characteristics of flow temperature fluctuations are presented. The distributions of averaged and instantaneous wall temperatures along the channel were obtained. The effects caused by an increase in the intensity of temperature fluctuations in a coplanar magnetic field were revealed. It is the authors' opinion that natural convection is responsible for formation and separation of large-scale vortex structures, the axis of which is parallel to the magnetic field induction vector, at the heated wall. These vortices bring about temperature fluctuations that often exceed the level of turbulent fluctuations. The data on heat transfer should be considered in designing MHD cooling channels of a fusion reactor.

*Keywords:* magnetic hydrodynamics, natural convection, heat transfer, velocity and temperature measurement

# An Efficient Unified Approach for Performance Analysis of Functionally Graded Annular Fin with Multiple Variable Parameters

R. Ranjan<sup>a,\*</sup> and A. Mallick<sup>a,\*\*</sup>

<sup>a</sup>*Department of Mechanical Engineering, Indian Institute of Technology (ISM), Dhanbad, 826004 India*

<sup>\*</sup>*e-mail: rajivranjan050@gmail.com*

<sup>\*\*</sup>*e-mail: mal123\_us@yahoo.com*

Received November 1, 2017; in final form, February 21, 2018

**Abstract**—The present work investigates the performance of an annular fin of constant thickness, made up of a functionally graded material (FGM). The fin surfaces are exposed in an environment where the heat loss occurs through convection and radiation. The various parameters, describing the fin performances, are considered to be varying with the local temperature and fin radius. An efficient and unified approach, homotopy perturbation method (HPM), is applied for obtaining the closed form solution from the non-linear heat transfer equation of equilibrium. The effects of key thermal parameters, i.e. thermo-geometric, conduction—radiation, thermal conductivity variation, heat generation, exponent of heat transfer co-efficient and the parameter of surface emissivity are explored on the temperature field leading to an overall investigation of thermal performance. And, the effects of such parameters on heat transfer rate, efficiency, effectiveness and temperature distributions are found to be significant. The accuracy of the present closed form solution is measured when its results are verified with the results of FEM and FDM solutions. The present results agree very well with those of FDM results and FEM results which is obtained using COMSOL software.

**Keywords:** FGM, HPM, annular fin, variable thermal parameters

# The EUCLID/V1 Integrated Code for Safety Assessment of Liquid Metal Cooled Fast Reactors. Part 2: Verification

V. M. Alipchenkov<sup>a</sup>, A. V. Boldyrev<sup>a</sup>, D. P. Veprev<sup>a</sup>, Yu. A. Zeigarnik<sup>a</sup>, P. V. Kolobaeva<sup>a</sup>,  
E. V. Moiseenko<sup>a</sup>, N. A. Mosunova<sup>a,\*</sup>, E. F. Seleznev<sup>a</sup>, V. F. Strizhov<sup>a</sup>, E. V. Usov<sup>a</sup>, S. L. Osipov<sup>b</sup>,  
V. S. Gorbunov<sup>b</sup>, D. A. Afremov<sup>c</sup>, and A. A. Semchenkov<sup>c</sup>

<sup>a</sup>*Nuclear Safety Institute, Russian Academy of Sciences, Moscow, 115191 Russia*

<sup>b</sup>*Afrikantov Experimental Design Bureau for Mechanical Engineering, Nizhny Novgorod, 603074 Russia*

<sup>c</sup>*Dollezhal Research and Development Institute of Power Engineering, Moscow, 107140 Russia*

*\*e-mail: nam@ibrae.ac.ru*

Received December 28, 2017; in final form, February 21, 2018

**Abstract**—The article presents information on the verification of the first version (V1) of the EUCLID integrated code intended for safety analysis of operating or designed liquid metal (sodium, lead, or lead–bismuth) cooled reactors under normal operation and under anticipated operational occurrences by carrying out interconnected neutronics, thermal–mechanical, and thermal–hydraulic calculations. The list of processes and phenomena that have to be modeled in the integral code for correctly describing the above-mentioned operating conditions is given. Based on this list, the most high-quality experimental data are selected for carrying out the verification. It is shown that, for sodium cooled reactors, a significant number of experiments was carried out around the world on studying individual thermal–hydraulic processes and phenomena, which made it possible to perform verification of the thermal–hydraulic module. The verification of the code—as applied to description of processes that take place in fuel rods with oxide or nitride fuel and gas gap—is carried out against the results of post-pile investigations of fuel rods irradiated in fast sodium cooled research and power-generating reactors. The obtained results opened up the possibility to determine the errors of calculating such fuel rod parameters as release of gaseous fission products from the fuel and sizes of pellet and cladding in a limited range of burnup values. To perform verification of the neutronics module as applied to calculation of such parameters as power density distribution over the core and decay heat release, a sufficient number of experiments and benchmarks were selected. The results obtained from experimental operating conditions of a BN-600 reactor and startup conditions of a BN-800 reactor made it possible to estimate how correctly the integral code performs calculations of interconnected thermal–hydraulic and neutronic processes. Only a limited set of experimental investigations is available for heavy liquid metal cooled reactors. In view of this circumstance, programs for obtaining the lacking data are developed. To estimate the quality with which the experiments are modeled by means of the EUCLID/V1 integrated code, a procedure for evaluating the errors of calculation results is developed. In accordance with this procedure, the error of calculating the parameters playing the main role in analyzing the reactor safety is evaluated.

*Keywords:* integrated code, safety assessment, fast reactor, liquid metal coolant, verification, error, uncertainty

# Treatment of the Equations of Metal Oxidation Rates at Nuclear Power Plants and Thermal Power Plants in Terms of Thermodynamics

V. G. Kritskii<sup>a, \*</sup>, I. G. Berezina<sup>a</sup>, A. V. Gavrilov<sup>a</sup>, E. A. Motkova<sup>a</sup>, and N. A. Prokhorov<sup>a</sup>

<sup>a</sup>*Atomproekt Scientific Research and Design Construction Institute of Power Technologies, St. Petersburg, 197183 Russia*

*\*e-mail: kritsky@atomproekt.com*

Received April 26, 2017; in final form, January 23, 2018

**Abstract**—The results of the thermodynamic analysis of experimental data and the kinetics equations of high-temperature steam oxidation of iron-based alloys (in the process of a thermal power plant operation) and of zirconium and iron alloys applied in manufacturing of fuel element cladding (at loss-of-coolant accident (LOCA)) are presented. The method of sorting data on the Arrhenius equation parameters and criteria of their reliability are proposed. The dependence of the Arrhenius equation parameter variance depends on the alloy composition and concentration of oxidants (oxygen, steam). The results of isothermal tests in one medium allow relating the activation energy of alloy oxidation to their chemical composition in order to study the process of their oxidation. The algorithm for calculation of oxidation rates and the thermodynamic model of alloy steam oxidation dependence on their composition are developed. The simulation engages the exponential dependence of the molecule collision frequency factor on the entropy of reaction activation in the Arrhenius equation for reactions proceeding on the surfaces of different alloys according to a uniform mechanism and the notion of pseudobinary of alloys when all dopes in the alloy behave as a single second alloy component, each with its own stoichiometrical coefficient. The verification of the model is accomplished using the plausible experimental data, and the kinetics of steam oxidation is determined (the temperature interval is 1073–1473 K) for zirconium alloys E110opt, E635 on the sponge base, and comparison with the kinetics of M5 alloy oxidation is carried out. For iron–chrome alloys with different contents of the latter, the results of calculations by the proposed model are compared to the data of the experiment on oxidation of alternative cladding alloys. The established laws can be used as a basis to develop the calculation code module for changing the physical state of iron–zirconium alloy fuel element cladding during the failure. The changes can be caused by such phenomena as oxidation, creep strain, and rupture of cladding.

**Keywords:** zirconium alloys, iron-based alloys, LOCA, oxidation kinetics, thermodynamics, model development and verification

# Flow-Accelerated Corrosion Wear of Power-Generating Equipment: Investigations, Prediction and Prevention:

## Part 3. Managing the Flow-Accelerated Corrosion of Pipelines and Equipment

G. V. Tomarov<sup>a,\*</sup>, A. A. Shipkov<sup>a</sup>, and D. V. Aflitonov<sup>a</sup>

<sup>a</sup>*OOO Geoterm-M, Moscow, 111250 Russia*

*\*e-mail: geotom.m@gmail.com*

Received November 8, 2017; in final form, January, 23, 2018

**Abstract**—The third part of this review discusses matters concerned with managing the flow-accelerated corrosion of power-generating equipment's and pipelines' components. The importance of these matters tends to increase with increasing the capacity of power plant units and the time for which they have been in operation. The article considers the capabilities of object-oriented software packages aimed at providing information support to the personnel (PSSPs) in regard to scheduling in-service inspections for timely revealing cases of close-to-inadmissible flow-accelerated corrosion-induced thinning. The prospects of using PSSPs for minimizing the carryover of iron-containing products of general flow-accelerated corrosion into the process circuit of NPP units are shown. The list of parameters and characteristics necessary for numerically estimating the thinning rates and residual life of pipelines and equipment susceptible to flow-accelerated corrosion is determined. The possibility of using some PSSPs to predict the thinning of process circuit component walls taking into account the effect of cavitation and droplet impingement erosion on the metal is pointed out. The need to optimize the scheduling of in-service inspections of near-seam zones of welded connections used in the pipelines of the condensate—feedwater and wet steam paths of power units is substantiated. It is pointed out that work is underway for fitting the Russian NPP units with PSSPs able to define—based on calculation results, data of in-service inspections, and other information—a priority list of components to be subjected to first-priority or next scheduled in-service inspection and to schedule repair (or replacement) of components susceptible to intense thinning. It is shown that the use of stainless steels for making the components of pipelines and equipment operating in the secondary circuit of NPP power units is often an excessive measure for preventing the occurrence of inadmissible local flow-accelerated corrosion-induced thinning and for minimizing the concentration of iron in feed water. The prospects for comprehensively solving the flow-accelerated corrosion problems by implementing appropriate measures at the designing, construction, and operation stages are considered. The main topical practical objectives for coping with the problem of flow-accelerated corrosion in power engineering are formulated.

**Keywords:** NPP units, power-generating equipment, pipelines, flow-accelerated corrosion, in-service inspection, iron concentration, selection of metal, water chemistry

# Studies on the Deposit Structure in the Cooling Systems of Steam Turbines at TPPs

N. D. Chichirova<sup>a,\*</sup>, S. M. Vlasov<sup>a</sup>, A. A. Chichirov<sup>a</sup>, A. A. Filimonova<sup>a</sup>, and A. Yu. Vlasova<sup>a</sup>

<sup>a</sup>*Kazan State Power Engineering University, Kazan, 420066 Russia*

*\*e-mail: aachichirova@mail.ru*

Received September 11, 2017; in final form, February 21, 2018

**Abstract**—When untreated natural water is used in the reverse cooling systems with tower-shaped evaporative cooling stacks of thermal power plants, negative processes occur, namely sparingly soluble substance deposition onto heat-exchange surfaces, corrosion, sludging of flow paths, bio-fouling, etc., which significantly worsens the thermal efficiency of TPPs as a whole, leads to equipment deterioration, and worsening hydrodynamic performance. This paper is devoted to the study of the physicochemical structure of deposits formed in reverse cooling systems of thermal power plants using IR spectroscopy and elemental analysis. At the Kazan TPP-3 with a conjugated reverse cooling system, samples of deposits have been taken from the rotary chamber and the condenser tubes of a turbine as well as from the sprayers of a tower-shaped evaporative cooling stack. The analysis of IR spectra of the samples showed that the base of deposits in the tower-shaped evaporative cooling stack consists of calcium carbonate that includes iron compounds (mainly hematite  $\text{Fe}_2\text{O}_3$ ), inorganic sulfates, silicates, magnesium carbonate. Dense parts of the deposits in the condenser of turbines consist of iron silicate with the impurities of other substances. The deposits in the reverse cooling system are most intensely formed in the areas with the highest heating temperature, such as turbine condensers and spraying nozzles in the tower-shaped evaporative cooling stack. At the Naberezhnye Chelny TPP, the deposits have been taken from a forechamber gate of the reverse cooling system. In total, four different samples of deposits that differ in appearance from each other have been chosen. As shown by infrared spectroscopy, the main part of deposits is formed by the corrosion products of metal structures coated with the layers of sparingly soluble compounds, including calcium and magnesium carbonates, iron oxides, silicates, and organic compounds, such as humic substances.

**Keywords:** IR spectroscopy, chemical analysis, deposits, steam turbine condenser, reversible cooling system with tower-shaped evaporative cooling stacks, thermal power plant

# Fuel Efficiency of Energy Sources in Heat Supply Systems

B. A. Semenov<sup>a,\*</sup> and E. A. Larin<sup>a,\*\*</sup>

<sup>a</sup>*Gagarin Saratov State Technical University, Saratov, 410054 Russia*

<sup>\*</sup>*e-mail: borissemyonov@sstu.ru*

<sup>\*\*</sup>*e-mail: larin@sstu.ru*

Received March 30, 2017; in final form, February 21, 2018

**Abstract**—The imperfection of the approach to the fuel efficiency assessment of energy sources with the combined generation of electrical and thermal energy based on the specific fuel consumptions is shown; it is caused by the fact that the use of different methods for the separation of the total fuel consumption leads to ambiguous results. A simple and feasible technique for the comparative assessment of the system fuel efficiency of existing energy sources of different types is proposed. The technique is based on the combined use of two dimensionless criteria that are calculated based on the CHPP production activity parameters provided in the yearly reports. These criteria have a clear physical sense and do not require the separation of the CHPP total fuel expenses into components. Analytical calculation dependences that relate the values of the proposed criteria and the actual relative fuel conservation, which is calculated for each individual energy source with respect to the average fuel efficiency level that is actually achieved in the considered energy system, are presented. The proposed approach and the technique based on it make it possible to objectively assess and compare the actual fuel efficiencies of energy sources of different types in terms of relative fuel conservation. The practical importance of the developed technique is demonstrated for a specific case: the comparative analysis of the actual fuel efficiency at all heat supply sources of the Saratov branch of PAO T Plus is performed based on the available reported data on the results of the production activity. The results are visualized in the form of a diagram representing the actual fuel efficiency of each CHPP (for each year) with respect to the average level achieved in this energy system during the operating period of 8 years. The presented materials can serve as a basis for the choice of rational ways to improve the CHPP fuel efficiency.

*Keywords:* energy source, thermal and electrical energy, combined generation, fuel conservation, system efficiency, assessment technique, influencing factors, maximum effect