
Contents

Vol. 65, No. 11, 2018

A simultaneous English language translation of this journal is available from Pleiades Publishing, Inc.
Distributed worldwide by Springer. *Thermal Engineering* ISSN 0040-6015.

General Subjects of Power Engineering

CHP Plants in Russia: the Necessity for Technological Renovation

S. P. Filippov and M. D. Dilman

Energy Conservation, New and Renewable Energy Sources

A Fuel-Free Trigeneration Plant at Stations for Technological Reduction
of Transported Natural Gas Pressure

A. V. Klimenko, V. S. Agababov, P. N. Borisova, S. N. Petin, and A. V. Koryagin

Matters Concerned with Development of Autonomous Cogeneration Energy Complexes
on the Basis of Microhydropower Plants

*A. V. Volkov, A. V. Ryzhenkov, A. G. Parygin, A. V. Naumov, A. A. Druzhinin,
A. A. Vikhlyantsev, J. Šoukal, M. Sedlař, M. Komárek, F. Pohylý, P. Rudolf, and S. Fialová*

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Study of Sequential Two-Stage Combustion in a Low-Emission Gas Turbine Combustion Chamber

L. A. Bulysova, A. L. Berne, V. D. Vasil'ev, M. N. Gutnik, and M. M. Gutnik

Steam Boilers, Power-Generating Fuel, Burners, and Boiler Auxiliary Equipment

Effect of Dust-Collecting Stem Structure on its Productivity

S. I. Shuvalov, A. A. Verenin, and O. A. Voroshilov

Environment Protection

Development of an Environmentally Safe Process for Medical Waste Disposal
based on Pyrolysis: Part I

N. A. Zroychikov, S. A. Fadeev, and P. P. Bezruky

Effect of Regional Climatic Factors on Reducing Noise Level from Power Equipment

V. B. Tupov, A. A. Taratorin, and V. S. Skvortsov

Heat and Mass Transfer and Properties of Working Fluids and Materials

Comparative Estimation of the Effect from Using Different Coolants
in Panel-Type Radiators of Spacecrafts

*N. N. Volkov, L. I. Volkova, A. L. Grigor'ev, D. N. Il'mov, A. V. Karevskii,
Yu. N. Mamontov, V. V. Mironov, V. V. Sobolev, and N. I. Filatov*

Water Treatment and Water Chemistry

An Analysis of the Behavior of Zinc Compounds in the Primary Coolant Circuit
at a Nuclear Power Station with VVER Power Reactors

N. L. Kharitonova and V. F. Tyapkov

The Measurement of pH in Superpure Condensate and Feedwater of Power Units

A. B. Larin, B. M. Larin, A. Ya. Sorokina, and S. V. Kiet

CHP Plants in Russia: the Necessity for Technological Renovation

S. P. Filippov^{a, b, *} and M. D. Dilman^{a, b}

^a*Institute of Energy Studies, Russian Academy of Sciences, Moscow, 117186 Russia*

^b*National Research University, Higher School of Economics, Moscow, 101000 Russia*

**e-mail: fil@eriras.ru*

Received April 16, 2018; in final form, April 25, 2018

Abstract—The role of combined heat and power (CHP) plants in the electric power industry of Russia is shown. The operational efficiency analysis of public service CHP plants and the fuel, power, and age structure of the existing CHP plants are carried out. Their main problems, such as underuse of generating equipment, excessive production in the condensing mode, high degree of equipment wear, and technological heterogeneity, are identified. The necessity of technological renovation of the CHP plants is shown. The energy efficiency of the combined production of electric and thermal energy by the existing CHP plants is compared to modern technologies for their separate gas and coal production. It is shown that the thermal capacity of the CHP plants in Russia exceeds the required capacity by almost two times. Estimates of the CHP plant thermal capacity necessary to cover the current heat loads are obtained for Russian regions. Main directions of the CHP plants' renewal based on the use of competitive domestic equipment and operation according to the heat load schedule are determined. Systemic impacts achieved by technological renewal are determined for gas-fired CHP plants with allowance for the climatic and load features of the Russian regions. It is shown that the technological renewal of gas-fired CHP plants will allow saving up to 16% of today's fuel consumption, reducing the total CHP thermal capacity by 47.5% with the same volume and heat supply mode. The operation of a CHP plant according to the heat load schedule leads to a reduction in the electric capacity of the CHP plant by 20% with an increase in electricity generation by 11%. As a result, the consumption of the installed electric and thermal capacity of the CHP plant increases dramatically as does the fuel efficiency and the annual loading balance of external gas-fired condensing power plants. The needs for GTPs and CCGTs required for the technological renovation of the CHP plants is assessed. The necessity for developing competitive domestic medium and high power GTPs is considered.

Keywords: electric power industry, combined heat and power plant, gas-turbine plant, combined-cycle gas turbine plant, steam-turbine plant, electric capacity, cogeneration, efficiency, installed capacity utilization factor

A Fuel-Free Trigeneration Plant at Stations for Technological Reduction of Transported Natural Gas Pressure

A. V. Klimenko^a, V. S. Agababov^{a, *}, P. N. Borisova^a, S. N. Petin^a, and A. V. Koryagin^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: agababovvs@yandex.ru*

Received April 11, 2018; in final form, April 25, 2018

Abstract—A new original basic process circuit of a fuel-free trigeneration plant simultaneously producing electricity, heat, and cold is considered. The plant can be used at technological transported gas pressure reduction stations instead of throttle devices conventionally used for this purpose. The plant process circuit involving, as its key components, an expander–generator unit and a vapor compression thermotransformer (VPTT) configured for simultaneously producing heat and cold, along with its operating principle, is described. The flow of transported gas (without combusting it) serves as the primary energy carrier supporting the plant operation. The gas flow energy is converted in mechanical work (as its pressure is decreased in the expander from the initial level at which gas arrives at the technological gas pressure reducing station to the level necessary according to the requirements of the gas utilization technology at the consumer end), and the generator connected to the expander converts this work into electricity. Part of the produced electricity is supplied to an external consumer, and its other part is used for driving the VPTT. The gas flow downstream of the expander supplied to the consumer and the flow of the VPTT working fluid, which takes heat from the cold carrier in the VPTT evaporator as it is transferred from a liquid to a gaseous state serve as the sources of cold in the plant. The working fluid downstream of the VPTT compressor serves as the source of heat; part of this is supplied to the consumer and its other part is used for heating gas upstream of the expander. The article presents the results from studying the effect the temperature to which gas upstream of the VPTT expander is heated by the heat of the VPTT working fluid has on the plant thermodynamic efficiency. The exergetic efficiency is taken as the thermodynamic efficiency criterion. The processes occurring in the plant when changing the gas heating temperature are subjected to a qualitative analysis. The results of calculations carried out using the plant mathematical model described in the article are presented. The obtained calculation results made it possible to determine the effect that the gas heating temperature upstream of the VPTT expander has on the specific (per unit flowrate of transported gas) electric, heating, and refrigeration capacities of the plant; on the specific exergy values of the same flows; and on the exergetic efficiency subject to the conditions adopted in the calculations.

Keywords: transported natural gas, pressure reduction station, fuel-free trigeneration, electric energy, heat, cold

Matters Concerned with Development of Autonomous Cogeneration Energy Complexes on the Basis of Microhydropower Plants

A. V. Volkov^{a,*}, A. V. Ryzhenkov^a, A. G. Parygin^a, A. V. Naumov^a, A. A. Druzhinin^a, A. A. Vikhlyantsev^a, J. Šoukal^{b,**}, M. Sedlař^b, M. Komárek^b, F. Pohylý^c, P. Rudolf^{c,***}, and S. Fialová^c

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*Centrum hydraulického výzkumu spol. s r.o. Sigma (Hydraulic Research Center Sigma), Lutín, Česká republika*

^c*Vysoké učení technické v Brně (Brno Technical University), Brno, Česká republika*

**e-mail: volkovav@mpei.ru*

***e-mail: v.liskova@sigma.cz*

****e-mail: rudolf@fme.vutbr.cz*

Received March 26, 2018; in final form, April 25, 2018

Abstract—In connection with the depletion of the world reserves of fuel resources and growing environmental safety requirements for power-generating facilities, the article presents a review analysis of the present state of conventional power supply systems in Russia and in the European Union countries (for the latter, the Czech Republic is taken as an example). We consider promising lines of research in the fields of energy conservation and development of efficient and environmentally clean energy sources and specific features of their process circuit solutions and technical embodiment as well as solutions necessary for putting new technologies into use in the real energy sector. In the conventional power industry, facilities implemented according to the principle of combined generation of electricity and heat—so-called cogeneration—have received wide use. Such facilities can be constructed not only on the basis of fuel engine units (gas turbines, diesel—generators, etc.) but also using renewable energy sources. It is pointed out that, with the modern scientific-technical level, the line involving the use—within combined power supply systems—of power-generating facilities having minimal negative impact on the environment has been developed to an insufficient extent. The article considers the modern state of hydraulic power engineering for estimating the possibility of using hydropower resources for development of investigations in this field. Prerequisites for constructing combined, first of all, autonomous energy sources of the micro power capacity class (up to 100 kW), in particular, a cogeneration power complex on the basis of a microhydropower plant, are considered. The results from design-theoretical and experimental investigations into the cogeneration complex structural components are outlined; a basic circuit solution for such energy source aimed at independently supplying electricity and heat for a consumer is shown, and promising ways for further improving the proposed technical solution and making it more efficient are pointed out.

Keywords: energy conservation, energy efficiency, combined power supply, environmentally clean technologies, cogeneration energy complex, microhydropower plant, development trends, Smart Grids, plug&play

Study of Sequential Two-Stage Combustion in a Low-Emission Gas Turbine Combustion Chamber

L. A. Bulysova^{a, *}, A. L. Berne^a, V. D. Vasil'ev^a, M. N. Gutnik^a, and M. M. Gutnik^a

^aAll-Russia Thermal Engineering Institute, Moscow, 115280 Russia

*e-mail: bulysov@mail.ru

Received March 26, 2018; in final form, April 25, 2018

Abstract—In this paper, we analyzed advanced ground-based power gas turbine units with low-emission combustion chambers used for consecutive two-stage fuel combustion. Such low-emission combustion chambers have a wide range of stable performance modes with reduced emission of harmful substances. The two-stage combustion chambers used in gas turbine units of various capacities—small (for example, M7A-03 with a capacity of approximately 8–10 MW), medium (L20A and L30A with a capacity of 18–30 MW) and large (9HA and GT36 with a capacity of over 300 MW)—showed their universality, efficiency, and good possibilities for scaling. The designs of low-emission combustion chambers for gas turbine units of different capacities are fundamentally similar. They consist of two sequentially located combustion volumes (stages), and each of them has its own burner unit. The first burner unit is typical for low-emission combustion chambers with the combustion of the premixed air-fuel mixture and consists of swirlers, mixing zone, fuel injectors, and igniters. The second burner unit is located downstream, and air-fuel mixtures of a different composition are supplied into it through special holes. The combustion of the mixtures occurs at a lower oxygen content and higher temperature. The ignition, work until idling, and loading before switching to the low-emission mode and switching to it are performed by the operation regulation of the first burner unit. Fuel in the second burner unit is supplied when a certain temperature of the gases arriving from the first combustion stage is achieved, which ensures its self-ignition. The further load is regulated by the fuel supply to the second burner unit. The design implementation of the sequential two-stage combustion scheme and approaches to regulating fuel and air distribution over the stages that ensures stable nonpulsating combustion are different and so they are of great scientific and practical interest.

Keywords: gas turbine, low-emission combustion, air-fuel mixture, burner, combustion noise, automatic control

Effect of Dust-Collecting Stem Structure on Its Productivity

S. I. Shuvalov^{a,*}, A. A. Verenin^{b,**}, and O. A. Voroshilov^c

^aIvanovo State Power Engineering University, Ivanovo, 153003, Russia

^bPAO Inter RAO, Moscow, 119435, Russia

^cOAO Nazarovo TPP, 662200, Krasnoyarsk krai, Nazarovo, Russia

*e-mail: Shuvalovs@rambler.ru

**e-mail: verenin_aa@interra.ru

Received March 19, 2013; in final form, April 25, 2018

Abstract—The effect of particle classification efficiency exerted on the productivity of dust-collecting systems with a ball-drum mill is considered. By using a mathematical model, the maximum productivity of dust-collecting systems with different equipment and structure has been determined, and the boundary particle size classification in a separator providing the production of dust with a preset fineness has been found. For each of the considered schemes of a dust-collecting system, a quantitative relationship is established between the system productivity, the fineness of the finished dust, and the particle classification efficiency inherent in the separators. It is shown that, for a preset fineness of the finished dust, the repeated separation of the recycled material is allowed only when the classification boundary of the particles in the main separator decreases. It is proven that the scheme with a winnowing of recycled material up to the fineness of the finished dust is unpromising since the use of a separator with an efficiency of particle classification lower than that inherent in the main separator leads to a decrease in the productivity of the dust-collecting system. In the scheme winnowing recycled material up to the fineness of the mill product wherein one can use winnowing separators having a less efficient particle separation, the productivity of the dust-collecting system depends on the dust circulation in the “main separator—winnowing separator” circuit. The productivity of the dust-collecting system depending on the fineness of the finished dust and the classification efficiency separators is determined. Schemes are recommended with a modernized main separator and with winnowing recycled material up to the size of the mill product or with a joint application of these schemes. The replacing of the main separator by a more efficient one should provide an increase in the dust-collecting system productivity by 19.2% with obtained dust having the fineness $R_{90} = 7\%$ and by 5.2% at $R_{90} = 25\%$. The application of a scheme of winnowing up to the fineness of the mill product with a main separator should provide an increase in the productivity of a dust-collecting system by 14.0–19.4% at $R_{90} = 7\%$ and by 5.3–6.6% at $R_{90} = 25\%$. Replacing the main separator and the winnowing of the recycled material should provide an increase in the productivity of a dust-collecting system by 28–33% at $R_{90} = 7\%$ and by 6.6–7.9% at $R_{90} = 25\%$.

Keywords: ball-drum mill, dust separator, efficiency of particle classification process, recycled material winnowing, boundary particle size classification in a separator

Development of an Environmentally Safe Process for Medical Waste Disposal Based on Pyrolysis: Part I

N. A. Zroychikov^{a,*}, S. A. Fadeev^{a,**}, and P. P. Bezruky^{a,***}

^a*Krzhizhanovsky Power Engineering Institute (AO ENIN), Moscow, 119991 Russia*

^{*}*e-mail: zna@eninnet.ru*

^{**}*e-mail: sergey.a.fadeev@gmail.com*

^{***}*e-mail: bezruky@yandex.ru*

Received April 18, 2018; in final form, April 25, 2018

Abstract—Upon analyzing the methods for processing epidemiologically hazardous medical waste (MW), it has been shown that the problem of safe disposal of MW with respect to the formation of polychlorinated dibenzo-para-dioxins and dibenzofurans (dioxins and furans) is acute and requires scientifically sound solutions. The typical morphological and elemental composition of the MW classes *F* and *B* and their thermal properties were determined, and the modern literature on the processes of thermal detoxification of dangerous MW was analyzed. It has been found that the process of pyrolysis is the most adaptive to various types of solid waste. Currently, pyrolysis attracts special attention due to its flexibility in treating various combinations of wastes only by changing the operating parameters of the process, such as temperature and heating rate. Pyrolysis is particularly important in connection with the growing amount of polymers in the waste of medical institutions, including those containing chlorine. In this case, the pyrolysis method presents the possibility of using a number of circuit solutions to prevent the formation of dioxins and furans. It has been shown that the use of the pyrolysis method ensures, along with full satisfaction of the requirements of sanitary and hygienic standards, the environmental safety of the MW detoxification process as compared to other high temperature methods (combustion and gasification). Next, possible directions of utilization of secondary resources received in the process under consideration were analyzed. In the proposed scheme of the installation for safe disposal of medical waste on the basis of the pyrolysis process, its products (excess gas, heat of the products of combustion, etc.) are expected to be used to generate electrical and thermal energy; semicoke as a solid residue of the process will be converted to activated carbon.

Keywords: medical waste, furnace, incineration, scheme, installation, pyrolysis, gas, chlorine, dioxins, furans, emissions, thermal potential, electricity

Effect of Regional Climatic Factors on Reducing Noise Level from Power Equipment

V. B. Tupov^{a,*}, A. A. Taratorin^a, and V. S. Skvortsov^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250, Russia*

**e-mail: TupovVB@mpei.ru*

Received March 31, 2013; in final form, May 30, 2018

Abstract—The effect of regional climatic factors exerted on noise reduction from power equipment is considered based on data processing results for 210 cities over the territory of Russia. The value of the required noise reduction determines the capital and operating costs of silencers, shields, and other facilities designed to reduce the noise produced by power equipment. At the same time, the regional climatic factors exert a different effect on the required noise reduction from power equipment: they can be neglected at low frequencies on the one hand, while this influence can be crucial at high frequencies on the other hand. It is shown that the influence of climatic factors in different regions significantly differs at the same geometrical-mean frequency, and this difference can amount to several dozen decibels. With increasing geometrical-mean frequency, this difference increases. For example, at a geometrical-mean frequency amounting to 8 kHz, the greatest change ranges from 60–100 dB/km for the European part of Russia to 160 dB/km for northeastern Siberia. It is shown that an incorrect determination of the sound attenuation coefficient α in the atmosphere can lead, on the one hand, to an excess expenditure of energy resources at higher real α values, and, on the other hand, to the absence of any expected effect after the implementation of environmental measures at lower real α values. Thus, in developing measures for the attenuation of power equipment noise, it is necessary to take into account the effect of regional climatic factors, especially at high frequencies.

Keywords: noise reduction, regional climatic factors, energy efficiency

Comparative Estimation of the Effect from Using Different Coolants in Panel-Type Radiators of Spacecrafts

N. N. Volkov^a, L. I. Volkova^a, A. L. Grigor'ev^a, D. N. Il'mov^{a,*}, A. V. Karevskii^a, Yu. N. Mamontov^a,
V. V. Mironov^a, V. V. Sobolev^a, and N. I. Filatov^a

^a*State Scientific Center Keldysh Research Center, Moscow, 125438 Russia*

**e-mail: ilmov@kerc.msk.ru*

Received February 12, 2018; in final form, April 25, 2018

Abstract—A radiant cooling heat exchanger is one of key components in a closed-cycle power installation and is the bulkiest structural part of a spacecraft. The most well-elaborated version of a cooler, known as a panel-type radiator (PR), is made according to the process arrangement of radiating panels. Selecting the optimal coolant is one of important issues in designing a PR. A liquid metal coolant in the form of molten Na–K mixture is presently regarded to be the most preferred one for these purposes. It features thermal stability, resistance to radiation, and a very high thermal conductivity. The main negative feature of Na–K melt is its explosion hazard when exposed to air, a circumstance due to which difficulties are encountered in experimentally perfecting the PR design under on-land conditions. We consider high-temperature organic coolants as an alternative to a liquid metal coolant. The aim of this study was to compare the effectiveness of using different coolants for the class of PR systems whose properties and geometrical characteristics are close to the prototypes developed at the State Scientific Center (SSC) Keldysh Research Center from composite materials on the basis of carbon fibers with high thermal conductivity. To this end, a mathematical model and relevant calculation procedure have been developed. The results from the performed calculations testify that, in view of a low specific heat of liquid metal coolant, its mass flowrate should be a factor of 2–2.5 higher than the flowrate of high-temperature organic coolant, which entails essential loss of energy for pumping. Thus, the use of high-temperature organic coolants is more preferable for a certain class of PRs with parameters close to the considered ones. Turbulent flow of coolant is an important condition, due to which significant requirements are posed to its viscous characteristics. A diphenyl mixture can be regarded as the most efficient high-temperature coolant for the considered class of PRs.

Keywords: radiant heat exchanger, panel-type radiator, heat-conducting radiating fin, liquid metal coolant, high-temperature organic coolants, diphenyl mixture, tetracresoxysilane

An Analysis of the Behavior of Zinc Compounds in the Primary Coolant Circuit at a Nuclear Power Station with VVER Power Reactors

N. L. Kharitonova^{a,*} and V. F. Tyapkov^{b,**}

^a*Scientific and Engineering Center for Nuclear and Radiation Safety, Moscow, 107140 Russia*

^b*All-Russia Research Institute for Nuclear Power Plants Operation (OAO VNIIAES), Moscow, 109507 Russia*

**e-mail: kharitonova@secnrs.ru*

***e-mail: vftiapkov@vniiaes.ru*

Received April 11, 2018; in final form, April 25, 2018

Abstract—Technology of zinc metering into the coolant has already been used for more than 20 years at foreign nuclear power stations (NPS) with PWR reactors for reducing radiation fields on the equipment and suppressing corrosion cracking of nickel-rich alloys. The most likely forms in which zinc compounds can exist in the primary coolant circuit of water-cooled power reactors (such as VVER, PWR, or BWR) were assessed, and the data on their solubility were analyzed. It is demonstrated that zinc oxides and silicates feature the minimum solubility under the primary coolant circuit conditions. The conditions for crystallization of compounds on the surface of fuel rod cladding in the core in case of local boiling (i.e., subcooled liquid boiling) were analyzed. A review is presented of foreign publications with the assessment of the risk that zinc compounds are contained in zinc deposits on the surface of fuel rods when zinc is metered into the coolant of PWR power units with a thermally stressed core. The predictions are presented of the limit thickness of the deposits at which zinc oxides and silicates can precipitate into them in case of local subcooled boiling on the fuel rod surface. The predictions are presented for the effect of the concentration of boric acid, silica, and zinc in the coolant on the limit thickness of depositions at which zinc compounds can crystalize. It is demonstrated that, in the presence of boric acid, zinc can interact with borates with the formation of borate complexes, which reduce the risk of deposition of zinc silicates in the layer of deposits on the fuel rod surface. The calculated results confirm that increasing the thickness of oxide film on fuel rods increases the risk of crystallization of zinc compounds in the core.

Keywords: zinc metering technology, zinc compounds, solubility, crystallization, deposits

An Analysis of the Behavior of Zinc Compounds in the Primary Coolant Circuit at a Nuclear Power Station with VVER Power Reactors

N. L. Kharitonova^{a,*} and V. F. Tyapkov^{b,**}

^aScientific and Engineering Center for Nuclear and Radiation Safety, Moscow, 107140 Russia

^bAll-Russia Research Institute for Nuclear Power Plants Operation (OAO VNIIAES), Moscow, 109507 Russia

*e-mail: kharitonova@secnrs.ru

**e-mail: vftiapkov@vniiaes.ru

Received April 11, 2018; in final form, April 25, 2018

Abstract—Technology of zinc metering into the coolant has already been used for more than 20 years at foreign nuclear power stations (NPS) with PWR reactors for reducing radiation fields on the equipment and suppressing corrosion cracking of nickel-rich alloys. The most likely forms in which zinc compounds can exist in the primary coolant circuit of water-cooled power reactors (such as VVER, PWR, or BWR) were assessed, and the data on their solubility were analyzed. It is demonstrated that zinc oxides and silicates feature the minimum solubility under the primary coolant circuit conditions. The conditions for crystallization of compounds on the surface of fuel rod cladding in the core in case of local boiling (i.e., subcooled liquid boiling) were analyzed. A review is presented of foreign publications with the assessment of the risk that zinc compounds are contained in zinc deposits on the surface of fuel rods when zinc is metered into the coolant of PWR power units with a thermally stressed core. The predictions are presented of the limit thickness of the deposits at which zinc oxides and silicates can precipitate into them in case of local subcooled boiling on the fuel rod surface. The predictions are presented for the effect of the concentration of boric acid, silica, and zinc in the coolant on the limit thickness of depositions at which zinc compounds can crystallize. It is demonstrated that, in the presence of boric acid, zinc can interact with borates with the formation of borate complexes, which reduce the risk of deposition of zinc silicates in the layer of deposits on the fuel rod surface. The calculated results confirm that increasing the thickness of oxide film on fuel rods increases the risk of crystallization of zinc compounds in the core.

Keywords: zinc metering technology, zinc compounds, solubility, crystallization, deposits

The Measurement of pH in Superpure Condensate and Feedwater of Power Units

A. B. Larin^{a, *}, B. M. Larin^a, A. Ya. Sorokina^a, and S. V. Kiet^b

^aIvanovo State Power Engineering University (IGEU), Ivanovo, 153003 Russia

^bOOO Scientific and Production Enterprise (NPP) Technopribor, Moscow, Russia

*e-mail: yaandy_81@mail.ru

Received March 16, 2018; in final form, April 25, 2018

Abstract—The change-over to the European standards for the quality of water coolant in power units of thermal and nuclear power stations makes the requirements for the feedwater quality stricter and brings about problems in the measurement of pH. The conventional calibration of a pH-meter against buffer solutions does not yield the measurement accuracy during measurements in infinitely diluted water solutions with electrical conductivity below 0.3 $\mu\text{S}/\text{cm}$. Reliability and validity of pH measurements can be improved by using the readings of automatic conductivity meters and calibration of analyzer in a superpure medium. The first method is implemented in foreign-made instruments, such as FAM Deltacon pH and AMI Deltacon Power. The second method has not yet been developed and is waiting for its implementation in practice. The investigation of the possibility for implementation of these methods using domestic equipment was carried out in the laboratory at the ion-exchange membrane test facility with metering ammonia or carbonic acid solution into deeply demineralized water and was verified under actual operating conditions at the Petrozavodsk Cogeneration Power Station (TETs) and the Kostroma District Power Station (GRES). This investigation resulted in the design of a prototype of a Lider-APK industrial analyzer intended for measurement of pH and concentration of impurities (such as ammonia, sodium, or chlorides) in condensate type waters in the range of pH = 6.0–10.0, and the development of a calibration procedure of industrial bench test pH-meters using ammonia or carbonic acid solutions. The Lider-APK analyzer outperforms its import equivalents and can be used in the automatic chemical monitoring at thermal power stations (TPS). A procedure for calibration of pH-meters in ultradiluted solutions has been first developed and should be verified at industrial facilities. The results of investigation suggest that both methods can improve the reliability of pH measurements in a superpure water coolant using automatic analyzers.

Keywords: electrical conductivity, pH, ammonia concentration, power unit feedwater, calibration of automatic analyzers