
Contents

Vol. 65, No. 12, 2018

A simultaneous English language translation of this journal is available from Pleiades Publishing, Inc.
Distributed worldwide by Springer. *Thermal Engineering* ISSN 0040-6015.

Energy Conservation, New and Renewable Energy Sources

Fuel Cell Based Power-Generating Installations: State of the Art and Future Prospects

O. S. Popel', A. B. Tarasenko, and S. P. Filippov

Steam Boilers, Power-Generating Fuel, Burners, and Boiler Auxiliary Equipment

Modern State and Topical Issues of Studying Solid Fuel Particle Primary
Fragmentation Processes (Review)

D. S. Litun and G. A. Ryabov

Steam Turbine, Gas Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

A Model of the Motion of Erosion-Hazardous Droplets in Steam Turbines' Interblade Channels

V. A. Tishchenko, R. A. Alekseev, and I. Yu. Gavrilov

Experimental Studies of Honeycomb Seals with Wavy Ridges on the Rotor

S. S. Dmitriev, B. N. Petrunin, and M. E. A. E. Ahmed

Investigation of Technical and Economic Viability of the 450-MW CCGT Unit's Operation
in the GTU Based CHP Mode

E. K. Arakelyan, A. V. Andryushin, S. Yu. Burtsev, and K. A. Andryushin

Heat and Mass Transfer and Properties of Working Fluids and Materials

Investigation of Heat Transfer of Liquid Metal in a Rectangular Vertical Channel
in a Coplanar Magnetic Field Applied for Cooling System of a Tokamak Reactor

I. A. Belyaev, I. A. Mel'nikov, N. Yu. Pyatnitskaya, N. G. Razuvanov, and E. V. Sviridov

Steam Condensation from a Moving Steam-Gas Mixture

O. O. Mil'man, V. S. Krylov, A. V. Ptakhin, A. V. Kondratiev, and G. G. Yan'kov

Water Treatment and Water Chemistry

Possibility of Electromembrane Softening Treatment of Network Water
at a Thermal Power Station

V. G. Mykhaylenko, O. V. Antonov, O. I. Lukyanova, and T. O. Berezka

Environment Protection

Solutions for Gas-Air Flow Paths and Environmental Protection from Harmful Power-Plant Emissions in the Framework of the Scientific School Created by L. A. Rikhter
[on the centenary of the birth of L. A. Rikhter]

V. B. Prokhorov, S. L. Chernov, and B. G. Tuvalbaev

Errata

Fuel Cell Based Power-Generating Installations: State of the Art and Future Prospects

O. S. Popel^{a,*}, A. B. Tarasenko^a, and S. P. Filippov^b

^aJoint Institute of High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

^bEnergy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia

*e-mail: O_Popel@mail.ru

Received June 18, 2018; in final form, June 26, 2018

Abstract—Specific features of power-generating installations constructed using different types of fuel cells are considered. Problems and trends of their development in Russia and abroad are analyzed. Fuel cell commercialization lines, their application niches, and the most well-known projects of constructing and exploiting fuel cell-based power-generating installations are described. Special attention is paid to analyzing the specific features pertinent to the domestic market of fuel cells and prospects of different lines of their application taking into account competition from other energy sources. Conclusions about the most topical development lines of the considered technologies under the conditions of Russia are drawn with due regard to the available groundwork as well as technical and economic aspects. It is pointed out that the main application field of fuel cells in Russia may be distributed generation of electricity, including off-grid supply of power to consumers on the basis of network and liquefied natural gas, liquefied hydrocarbon gases, and also renewable energy sources. In this regard, installations involving combined generation of electricity and heat, including small ones with a capacity of a few tens or hundreds of kilowatts, are of special interest. Prospective market niches for using fuel cells may include pipeline cathodic protection stations, utilization of biogas obtained, e.g., in reprocessing domestic waste, emergency and uninterruptible power supply systems, propulsion power installations of air drones, auxiliary power installations with a capacity of 1–3 kW, and utilization of hydrogen rejected from chemical production facilities. In view of existing groundwork and cooperation, concentration of efforts aimed at developing solid oxide, solid polymeric, and alkaline fuel cells in Russia seems to be the most topical issue. The use of molten carbonate fuel cells may be of considerable practical interest for reclaiming landfill gas at solid domestic waste landfills and at aeration fields, a problem that is an issue for many cities in the country; such cells can also be used for concentrating and extracting CO₂ from fuel gases.

Keywords: fuel cells, electrochemical generators, direct energy conversion, fuel cell-based power-generating installations, fuel cell market, distributed generation

Modern State and Topical Issues of Studying Solid Fuel Particle Primary Fragmentation Processes (Review)

D. S. Litun^{a,*} and G. A. Ryabov^a

^aAll-Russia Research Institute of Thermal Engineering, Moscow, 115280 Russia

*e-mail: DSLitoun@vti.ru

Received April 25, 2018; in final form, May 30, 2018

Abstract—It is shown that it is important to take into account the variation of particle sizes due to their fragmentation in firing biomass in a fluidized bed. The present state of investigations into the fragmentation process is analyzed. It is shown that primary fragmentation, a process involving cracking and disintegration of initial fuel particles into two or more parts due to thermal stresses and growth of pressure in the particles during their rapid heating at the drying and devolatilization stages is the most essential issue. Factors causing the cracking of fuel particles and the nature of this process are considered. The particle fragmentation quantitative characteristics and criteria are analyzed. It is shown that the particle critical diameter is the simplest criterion for estimating the susceptibility of different fuels to fragmentation. The main factors influencing the occurrence of primary fragmentation, namely, particle size, heating rate, bed temperature, and fuel characteristics, are considered. The list of fuel's main characteristics affecting its primary fragmentation includes the content of volatiles, porosity, content of moisture and ash, susceptibility of particles to swelling or shrinking, and the organic part composition. Matters concerned with predicting primary fragmentation of fuels are considered. Information about the interrelation between the main characteristics of fuels, their susceptibility to primary fragmentation, and its nature is presented. In view of biomass properties and its combustion conditions, both of the primary fragmentation mechanisms, namely due to devolatilization induced stresses and thermal stresses, are supposed to take place. It can be expected that the domination of one or another mechanism will depend on the combination of particle size and heating temperature. The lines of and methods for studying the nature of primary fragmentation of biofuel particles and its quantitative characteristics under different conditions are outlined. The data obtained as a result of such fundamental investigations will form the basis for elaborating methods for designing furnace devices and gasifiers operating on biomass taking into account the effect of particle fragmentation on the combustion, gasification, carryover, and heating surface contamination processes.

Keywords: biomass, fluidized bed, fragmentation, temperature stresses, critical diameter, investigation methods

A Model of the Motion of Erosion-Hazardous Droplets in Steam Turbines' Interblade Channels

V. A. Tishchenko^{a,*}, R. A. Alekseev^a, and I. Yu. Gavrilov^a

^a*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

**e-mail: tishchenkova@mpei.ru*

Received April 4, 2018; in final form, May 30, 2018

Abstract—A model is discussed describing the interaction of liquid droplets with interblade channel walls in condensing steam turbines. It is based on the experimental data on the impact of individual droplets on a surface that are presented in the form of statistical models with free empirical parameters. The motion of liquid particles is simulated using individual flows of droplets under the action of aerodynamic drag force from the steam. Their interaction with the interblade channel surface is determined by the kinetic energy of impingement affecting the subsequent process. The proposed numerical approach deals with two droplet impact cases, i.e., a droplet deposits on the generatrix of the blade airfoil or becomes a source of secondary moisture leaving the surface. Arrays of liquid droplets formed in the latter case are also simulated using streams. The empirical coefficients of the model were selected based on the results of experimental investigation of the motion of liquid particles in a plane vane cascade. Parameters of wet steam flow in an interblade channel were determined using a laser flow diagnostic system and the particle tracking velocimetry (PTV) method implemented on its basis. The investigations were performed in a two-dimensional flow. The measured patterns of liquid particles' motion were compared with predicted ones. The velocity distributions of primary and secondary droplets were examined in six characteristic regions of the plane cascade. Causes responsible for disagreement between the experiment and the predictions were outlined. It has been found that the angle at which droplets impinge on the interblade channel wall has a considerable effect on characteristics of the formed secondary droplets. Verification of the model demonstrated a satisfactory agreement of the experiment with the predictions.

Keywords: wet steam, liquid phase, steam turbine, PTV method, two-phase flow gas dynamics

Experimental Studies of Honeycomb Seals with Wavy Ridges on the Rotor

S. S. Dmitriev^{a,*}, B. N. Petrunin^a, and M. E. A. E. Ahmed^a

^a*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

**e-mail: dmitriyevss@mpei.ru*

Received April 16, 2018; in final form, May 30, 2018

Abstract—During steam turbine operation in transient modes, contact in labyrinth seals is possible. To avoid such contact in the regular stepped labyrinth seals, specialists of the Ural Turbine Works upgraded the end seals during major repairs in several T-250/300–23.5 type turbines of PAO Mosenergo: the regular seals on the rotor were replaced by straight-flow honeycomb seals with wavy ridges. After this upgrading, there were a reduction of air suction through the end seals of low-pressure cylinder, the normalization of the ejector operation, and oil watering reducing. However, by these indirect indices, it is impossible to evaluate the actual change of leakages through upgraded seals. Therefore, the comparative experimental studies of flow and dynamic characteristics of the straight-flow seals with classic straight and wavy ridges were implemented. According to the investigation results, the flow characteristics of all studied models of straight-flow seals during transition from classical straight ridges to wavy ones deteriorated. The measurements of nonconservative components of the force in the seal models also revealed a deterioration of dynamic characteristics of the models of straight-flow seals during transition from straight ridges to wavy ones. In the end seals, increasing the nonconservative forces capable to cause a self-excited vibration of the shafting of the steam-turbine plant (STP) does not pose a threat owing to their low magnitude. However, in diaphragm seals, especially in the high-pressure section of STP to the supercritical steam parameters, using new honeycomb straight-flow seals with wavy ridges requires special caution, since these forces reach the highest values in the region of high pressures and are capable, in combination with the overbandage forces and forces arising in the oil layer of bearings, to cause low-frequency self-excited vibrations of shaftings. Taking into account that the level of nonconservative forces in the regular stepped seals is by 20% less than in the straight-flow seals, the transition to the straight-flow honeycomb seals with wavy ridges on the rotor in the diaphragm seals appears inappropriate.

Keywords: end seal, straight-flow seal, stepped seal, leakage, radial clearance, wear, cellular seal, nonconservative force

Investigation of Technical and Economic Viability of the 450-MW CCGT Unit's Operation in the GTU Based CHP Mode

E. K. Arakelyan^{a,*}, A. V. Andryushin^a, S. Yu. Burtsev^b, and K. A. Andryushin^a

^aNational Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

^bAll-Russian Scientific Research Institute for Physical-Engineering and Radiotechnical Metrology (VNIIFTRI),
pos. Mendeleevo, Solnechnogorskii raion, Moscow oblast, 141570 Russia

*e-mail: Edik_arakelyan@inbox.ru

Received April 10, 2013; in final form, May 5, 2018

Abstract—Technical viability and economic feasibility of improving the technology of a 450-MW CCGT unit's participation in power load leveling of the power system operating in a GTU based CHP mode by transferring a 450-MW CCGT T-125/150 steam turbine to the driving mode instead of its shutdown are considered. It is shown that the shutdown of the steam turbine is associated with increased fuel consumption under start-up conditions, delayed steam turbine loading and the CCGT unit as a whole, and a loss of steam turbine life characteristics. The technology of transferring the 450-MW CCGT unit to the GTU based CHP mode, possible schemes of high- and low-pressure steam distributions between line water heaters, and methods and results of calculation of power parameters of the 450-MW CCGT unit with the turbine shutdown and transferring it to the driving mode in the absence and presence of peak-load heaters in the heat balance are presented. It is shown that switching the 450-MW CCGT unit from the base 290 MW electric load and 1006 GJ/h heat production to the GTU based CHP mode leads to a decrease in electric capacity of the CCGT unit by 90 MW and an increase in heat production by 335–348 GJ/h. Comparative graphs of the steam turbine start-up and the CCGT unit rated loading in the comparable variants after its operation in the GTU based CHP mode for 8–10 h are given. Evaluation techniques and results of the economic efficiency of the generator driving mode are compared with the shutdown of the steam turbine. Based on the performed calculations, it is shown that, for various combinations of fuel equivalent and electricity costs and heating tariffs, the expedient time for switching the steam turbine to the driving mode is 10–18 h. Additional advantages of the driving mode are noted, such as improvement of the steam turbine reliability due to the elimination of cyclic temperature variations of its steam-inlet elements and vibrational oscillations in the final stages of the low-pressure cylinder and the possibility of the steam turbine generator to operate as a synchronous condenser.

Keywords: GTU based CHP mode, steam turbine, driving mode, steam distribution schemes, power indicators, control range, plant flexibility, power plant profits

Investigation of Heat Transfer of Liquid Metal in a Rectangular Vertical Channel in a Coplanar Magnetic Field Applied for Cooling System of a Tokamak Reactor

I. A. Belyaev^a, I. A. Mel'nikov^a, N. Yu. Pyatnitskaya^{a, b, *}, N. G. Razuvanov^a, and E. V. Sviridov^a

^a*Joint Institute of High Temperatures, Moscow, 125412 Russia*

^b*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

**e-mail: PiatnitskyaNY@mpei.ru*

Received February 19, 2018; in final form, May 30, 2018

Abstract—The results of experimental studies of liquid metal flow under conditions typical for channels of the heat exchanger for a prospective thermonuclear reactor ITER (International Thermonuclear Experimental Reactor) were presented. A descending flow in a rectangular channel with a ratio of sides 1 : 3 in a coplanar magnetic field at the two-side heating was considered. Such a configuration of flow is typical for Russian–Indian development of a blanket test module of ITER. This article analyzes the experimental results obtained on the unique mercury stand RK-2 on the evolution of temperature pulsation under a magnetic field. The regimes at the absence of low-frequency high-amplitude pulsations with a low effect of thermogravitational convection were implemented. As in the case of flow in a round pipe, the secondary flows take place at the full suppression of turbulence due to the influence of free convections and at the flowing in a round pipe. The secondary flows were found in the rectangular channel. The shape of pulsations' intensity profiles obtained in a transverse section of channel has a clearly observed M-shaped form, which is preserved under application of a magnetic field. Therefore, it was concluded that the degree of suppression of pulsations depends not on the distance to wall but is determined only by regime parameters. This conclusion made it possible to formulate the exponential dependence characterizing the degree of suppression of turbulence pulsations by the coplanar magnetic field for the flat channel and also the boundaries of its applicability on the basis of results of analysis and treatment of experimental data. Accounting for the influence of pulsations' suppression by the coplanar magnetic field is performed by the correction of the formula for determination of the turbulent viscosity in corresponding Reynolds equations.

Keywords: liquid metals, magnetic hydrodynamics, magnetic field, thermogravitational convection, ITER, Tokamak

Steam Condensation from a Moving Steam-Gas Mixture

O. O. Mil'man^{a, b, *}, V. S. Krylov^{a, b}, A. V. Ptakhin^{a, c}, A. V. Kondratiev^{a, c}, and G. G. Yan'kov^{b, d}

^aZAO NPVP Turbokon, Kaluga, 248010 Russia

^bTsiolkovskii Kaluga State University, Kaluga, 248023 Russia

^cKaluga Branch of the National Research University Bauman MSTU, Kaluga, 248000 Russia

^dNational Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250, Russia

*e-mail: turbocon@kaluga.ru

Received April 28, 2018; in final form, May 30, 2018

Abstract—To date, heat exchange has been studied to the greatest extent for the case of the condensation of pure still and moving steam as well as for the case of condensation from a still steam-gas mixture. There are hardly any papers available wherein a moving steam-gas mixture with a substantial content of noncondensable gases is considered. To investigate this process, an experimental workbench of the working area has been developed, which makes it possible to determine the local values of the heat transfer coefficient from the steam-gas mixture to the walls of cooled heat-exchange tubes at different parameters and velocities of the gas-steam mixture. In the first four rows of tubes of the working section, there is no cooling, and their function consists in a hydraulic stabilization of the flow. In the fifth and the sixth row of tubes, the wall temperature of the cooled heat-exchange tubes is measured for determining the heat transfer coefficients from the moving steam to the tube walls. The seventh row of tubes is also not under cooling. Measuring tubes with temperature sensors have been manufactured that make it possible to obtain the wall temperature for determining the heat transfer coefficient. The adopted scheme of steam motion and the measurement system make it possible to obtain correct results of the heat and mass transfer investigation in the course of steam condensation from a gas-steam mixture with a significant content of noncondensing gases. The studies on steam condensation from a moving steam-gas mixture have been carried out in the range of parameter $\rho w^2 = 9.5 - 66$ Pa and at a volume concentration of air in the steam amounting up to $v_{\text{air}} = 0.18$. Heat transfer coefficient values for the heat transfer from a moving steam-gas mixture to the wall of a cooling tube were obtained. At small values of parameter $\rho w^2 = 9.5$ Pa and the volume fraction of the air content $v_{\text{air}} = 0.06$ in the steam, the average heat transfer coefficient exhibits a decrease by a factor of two as compared with that inherent in the condensation of almost pure steam. At the values of parameter $\rho w^2 = 66$ Pa and at $v_{\text{air}} = 0.06$, the average heat transfer coefficient decreases by 1.3 times. The studies on almost pure steam are in good agreement with Berman's dependence.

Keywords: condensation, gas-steam mixture, noncondensable gases, thermal load, heat transfer coefficient

Possibility of Electromembrane Softening Treatment of Network Water at a Thermal Power Station

V. G. Mykhaylenko^{a,*}, O. V. Antonov^a, O. I. Lukyanova^a, and T. O. Berezka^b

^aPodgorny Institute for Mechanical Engineering Problems, National Academy of Sciences of Ukraine, Kharkiv, 61046 Ukraine

^bNational Technical University Kharkiv Polytechnic Institute, Kharkiv, 61002 Ukraine

*e-mail: port342017@gmail.com

Received March 23, 2018; in final form, May 30, 2018

Abstract—The possibility of electromembrane softening treatment of network water at a thermal power station is shown. Technology for the manufacturing of an inert anode free from noble metals or their compounds is proposed. Performed resource tests have demonstrated that such an anode can be in operation in chloride–sulfate solutions for several years almost without wear. A mathematical model describing the electrical current utilization efficiency as a function of process parameters and electrolysis regimes in the electromembrane softening of water has been developed. The results of calculating the current utilization efficiency coefficient by this model are in satisfactory agreement with experimental results. The current utilization coefficient in the formation of NaOH does not depend on the anolyte composition but appreciably decreases with increasing catholyte concentration and slightly grows with increasing current density at a constant catholyte concentration. Experiments have not disclosed any essential dependence between the specific water and CO_3^{2-} ion transports and the process parameters. Experiments on estimating the depth of the electromembrane softening of initial water for the heat supply networks of Kharkiv have demonstrated that the electromembrane method provides the residual hardness of 0.3–0.4 mEq/dm³, which is almost four times lower than for water subjected to soda–lime treatment. The experiments performed on a test bench setup have confirmed that the application of heterogeneous cation-exchange membranes (both MK-40 (OAO Shchekinoazot) and CMI 9000 (Membrane International)) provides the possibility to attain a high current utilization ratio above 88%. The carbonate index of water after electromembrane softening corresponds to the normative requirements to water for heat supply networks with a heat transfer agent temperature below 150°C (no higher than 0.4 (mEq/dm³)²). This provides the possibility to use the treated water immediately in heat supply networks without further ion-exchange softening. Some technical and economic parameters of the softening process and the technical parameters of an industrial electromembrane softener are given, and the possibilities of the utilization of wastes and byproducts are considered.

Keywords: electromembrane softening, current utilization efficiency, inert anodes, water hardness

Solutions for Gas-Air Flow Paths and Environmental Protection from Harmful Power-Plant Emissions in the Framework of the Scientific School Created by L. A. Rikhter [on the centenary of the birth of L. A. Rikhter]

V. B. Prokhorov^a, S. L. Chernov^{a, *}, and B. G. Tuvalbaev^b

^a *National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

^b *OOO ENIV, Moscow, 107023, Russia*

**e-mail: chernovser@gmail.com*

Received December 29, 2017; in final form, March 21, 2018

Abstract—The paper considers the main scientific activities of the doctor of Technical Science, such as optimizing the shape of gas-air flow paths of thermal power plants, protecting the environment from harmful emissions, and identifying stack failures, which are currently being developed by his followers. For a systematic study of gas-air flow path components, L.A. Richter applied a technique based on the theory of complex variable and conformal mapping, which makes it possible to find optimal aerodynamic configuration of the gas-air flow path components. By means of the methodology developed by him, gas-air flow path research is currently carried out using Solid Works and Flow Vision application packages. Examples of optimizing the design of flue gas ducts with allowance for aerodynamic forces are given. The professor formulated the reasons and described the mechanism of structural collapse of reinforced concrete and brick stack constructions based on a theory of the occurrence of static pressures in the gas exhaust duct under certain conditions, which contribute to the penetration of aggressive substances of flue gas to the outer structural surface. In the last decade, works that additionally consider the flue gas mass transfer effect on the stack have become widespread. L.A. Richter proved that the problem of estimating the concentrations of impurities in TPP stack emissions is much more complicated under real conditions. This is due to the need to take into account the actual state of the atmosphere and its heterogeneous turbulent structure as well as the obligatory allowance for the rise of the stack plume over the stack mouth. Studies of his followers have shown that the scattering region of harmful substances is significantly reduced when a self-envelopment phenomenon occurs under certain conditions. The professor's contribution to the development of the methodology for finding economically optimal rates in various gas-air flow path components, as well as the creation of new structural components of electrostatic precipitators, which are currently widely used in practice, is also shown.

Keywords: gas-air flow path, static pressure, electrostatic precipitator, stack, conformal mapping

ПОПРАВКА

DOI: 10.1134/S0040363618140011

В статье Э. М. Фархадзаде, А. З. Мурадалиева, Ю. З. Фарзалиева, С. А. Абдуллаевой “СРАВНЕНИЕ И РАНЖИРОВАНИЕ ПАРОТУРБИННЫХ УСТАНОВОК ЭНЕРГОБЛОКОВ ТЭС ПО ЭФФЕКТИВНОСТИ РАБОТЫ”, опубликованной в журнале “Теплоэнергетика” (№ 10, 2018 г.) состав авторов в аннотации на английском языке, размещенной в конце статьи, и в содержании на английском языке следует читать так:

E. M. Farhadzadeh*, A. Z. Muradaliyev, Y. Z. Farzaliyev, and S. A. Abdullayeva