

---

---

# СОДЕРЖАНИЕ

---

---

Номер 4, 2018

---

---

## Автоматизация и тепловой контроль в энергетике

Сравнительный анализ динамических свойств вариантов систем автоматического регулирования частоты и мощности паросиловых энергоблоков с прямоточными котлами

*В. А. Биленко, В. В. Жигунов* 5

Опыт использования удаленного доступа и предсказательной аналитики состояния энергетического оборудования

*С. А. Наумов, А. В. Крымский, М. А. Липатов, Д. Н. Скрабатун* 21

---

## Электрическая часть тепловых и атомных станций

Расширение области применения вакуумных выключателей на генераторы мощностью до 400 МВт

*К. Венна, Ю. П. Гусев, Е. П. Окнин, Г. Ч. Чо* 34

---

## Атомные электростанции

Графический экспресс-метод оценки остаточного тепловыделения при циклической эксплуатации исследовательского реактора бассейнового типа

*S. H. Kadalev* 43

Перспективы применения слабодиссоциирующих ионитов в системах спецводоочистки АЭС с ВВЭР для снижения объема образующихся радиоактивных отходов

*В. А. Винницкий, А. С. Чугунов, А. Ф. Нечаев* 48

Влияние гидразина на перераспределение отложений продуктов коррозии в I контуре транспортных ядерных энергетических установок на остановленном реакторе

*С. Н. Орлов, А. А. Змитродан, С. Г. Мысик* 54

---

## Водоподготовка и водно-химический режим

Отечественные и международные документы по использованию реагентов, содержащих пленкообразующие амины, для организации водно-химического режима на ТЭС

*Т. И. Петрова, Ф. В. Дяченко, К. А. Орлов* 60

Эффективность очистки воды от растворенных газов при слабом и сильном взаимодействии фаз в пленочных аппаратах

*А. Г. Лантев, Е. А. Лантева, Г. К. Шагиева* 65

---

## Паровые котлы, энергетическое топливо, горелочные устройства и вспомогательное оборудование котлов

Особенности эксплуатации дымовых труб в условиях воздействия ветра

*П. В. Росляков, И. Л. Ионкин, И. В. Морозов* 72

---

## **Металлы и вопросы прочности**

Подход к оценке ресурсных характеристик сталей в условиях ползучести с использованием критериев механики разрушения

*А. А. Ланин, Е. А. Гринь*

---

---

80

---

---

# Contents

---

---

## Vol. 65, No. 4, 2018

A simultaneous English language translation of this journal is available from Pleiades Publishing, Inc.  
Distributed worldwide by Springer. *Thermal Engineering* ISSN 0040-6015.

---

---

### Automation and Heat Control in Power Engineering

Comparative Analysis of the Dynamic Properties of Variants of Automatic Frequency  
and Power Control Systems for Steam Power Plants Equipped with Once-Through Boilers

*V. A. Bilenko and V. V. Zhigunov* 5

Experience in Use of Remote Access and Predictive Analytics for Power Equipment's Condition

*S. A. Naumov, A. V. Krymskii, M. A. Lipatov, and D. N. Skrabatun* 21

---

### Electrical Part of Thermal and Nuclear Power Plants

Extending the Application Field of Vacuum Circuit Breakers to Generators  
for Capacities Up to 400 MW

*K. Venna, Yu. P. Gusev, E. P. Oknin, and G. Ch. Cho* 34

---

### Nuclear Power Plants

Graphical Toolkit for Easy and Rapid Evaluation of the Residual Heat Generation  
at Cyclic Operation of a Pool Type Research Reactor

*S. H. Kadalev* 43

Prospects for Using Weakly Dissociated Ion Exchange Resins in Active Water Treatment Systems  
at VVER-Based Nuclear Power Plants for Reducing the Amount of Radioactive Waste Generated

*V. A. Vinnitskii, A. S. Chugunov, and A. F. Nechaev* 48

Effect of Hydrazine on Redistribution of Corrosion Product Deposits in the Primary Circuit  
of a Shutdown Reactor in Propulsion-Type Nuclear Power Plants

*S. N. Orlov, A. A. Zmitrodan, and S. G. Mysik* 54

---

### Water Treatment and Water Chemistry

National and International Guidelines for the Use of Reagents Containing Film-Forming Amines  
for the Organization of TPP Water Chemistry Regime

*T. I. Petrova, F. V. Dyachenko, and K. A. Orlov* 60

Efficiency of Water Purification from Dissolved Gases under Weak and Strong Phase Interaction  
in Film Degassers

*A. G. Laptev, E. A. Lapteva, and G. K. Shagieva* 65

---

### Steam Boilers, Power-Generating Fuel, Burner Devices, and Boiler Auxiliary Equipment

Peculiarities of Smoke Stack Operation under Wind Effect Conditions

*P. V. Roslyakov, I. L. Ionkin, and I. V. Morozov* 72

---

## **Metals and Strength Analysis**

An Approach to Assessment of the Lifetime Characteristics of Steels under Creep Conditions  
Using Fracture Mechanics Criteria

*A. A. Lanina and E. A. Grin'*

---

---

---

---

**АВТОМАТИЗАЦИЯ И ТЕПЛОВОЙ КОНТРОЛЬ  
В ЭНЕРГЕТИКЕ**

---

---

**СРАВНИТЕЛЬНЫЙ АНАЛИЗ ДИНАМИЧЕСКИХ СВОЙСТВ ВАРИАНТОВ  
СИСТЕМ АВТОМАТИЧЕСКОГО РЕГУЛИРОВАНИЯ ЧАСТОТЫ  
И МОЩНОСТИ ПАРОСИЛОВЫХ ЭНЕРГОБЛОКОВ  
С ПРЯМОТОЧНЫМИ КОТЛАМИ**

© 2018 г. В. А. Биленко\*, В. В. Жигунов

*ЗАО “Интеравтоматика”, 115280, Россия, Москва, Автозаводская ул., д. 14*

*\*e-mail: bilenko@ia.ru*

Поступила в редакцию 29.08.2017 г.

Принята в печать 27.09.2017 г.

Существенное усложнение решаемых российскими энергоблоками энергосистемных задач и вызванная этим необходимость обеспечения полностью автоматической работы энергоблока в режиме рабочих нагрузок потребовали усовершенствования структурных схем систем автоматического регулирования частоты и мощности (САРЧМ). Оказалось, что далеко не всегда принятые исходно в 80-х годах прошлого века решения, в частности применение классических вариантов САУМ-1 и САУМ-2 (САУМ – система автоматического управления мощностью), обеспечивают требуемое качество отработки энергосистемных возмущений. В данной статье выполнен сравнительный анализ шести вариантов САРЧМ, соответствующих как классическим САУМ-1 и САУМ-2, так и их комбинациям. Исследование проведено на математической модели при характерных видах возмущений: частотой сети, заданным значением мощности энергоблока и нагрузкой котла. Модель получена путем аппроксимации экспериментальных кривых разгона энергоблока мощностью 300 МВт с прямоточным котлом (Каширская ГРЭС, энергоблок № 3). Анализ качества регулирования выполнен путем сравнения амплитудно-частотных характеристик и кривых переходных процессов сопоставляемых вариантов САРЧМ, а также значений интегральных квадратичных критериев и максимальных отклонений регулируемых величин и регулирующих воздействий в ходе этих процессов. Наиболее предпочтительными оказались комбинированная САРЧМ и усовершенствованная САУМ-2. Варианты комбинированной САРЧМ имеют преимущество в качестве поддержания давления пара, а усовершенствованная САУМ-2 – в качестве регулирования мощности энергоблока, причем в первом случае преимущество несколько больше, чем во втором. Схемы обоих вариантов успешно применяются в течение долгого времени на многих энергоблоках страны.

*Ключевые слова:* система автоматического регулирования частоты и мощности, энергосистемные задачи, энергоблок, прямоточный котел, амплитудно-частотная характеристика, интегральный квадратичный критерий, возмущения

**DOI:** 10.1134/S004036361804001X

## Comparative Analysis of the Dynamic Properties of Variants of Automatic Frequency and Power Control Systems for Steam Power Plants Equipped with Once-Through Boilers

V. A. Bilenko\* and V. V. Zhigunov

*ZAO Interavtomatika, Moscow, 115280 Russia*

*\*e-mail: bilenko@ia.ru*

Received August 29, 2017; in final form, September 27, 2017

**Abstract**—Considerably complicated power-system problems that have to be solved by the Russian power-generating units and, consequently, the need to ensure the fully automated operation of the power-generating units under working loads necessitated improving the structure of the automatic frequency and power control systems (AFPCSs). Not all solutions adopted in the 1980s, in particular, the use of the classical variants of the automatic power control systems (APCS-1 and APCS-2), ensure the required quality of suppressing power-system disturbances. In this work, the authors performed comparative analysis of six AFPCS variants that correspond to both the classical APCS-1 and APCS-2 and their combinations. The research was carried out using a mathematical model under disturbances of characteristic types, viz., those caused by network frequencies, unit power settings, and boiler loads. The model was developed by approximating experimental step response curves of the 300-MW power-generating unit 3 equipped with a once-through boiler at Kashirskaya State District Power Station. The quality of control was analyzed by comparing the amplitude-frequency characteristics and the curves of the transient processes of the compared AFPCS variants and the integral quadratic criterion values and the maximum deviations of the controlled variables and control actions in the course of the above processes. The combined AFPCS and advanced APCS-2 proved to be the most preferable. The combined AFPCS variants offer advantages in terms of maintaining the steam pressure, while the advanced APCS-2 has an advantage as a means for controlling the unit power with the gain in the first case being somewhat greater than that in the second case. Both variants have been successfully used for a long time at numerous power-generating units of the country.

**Keywords:** Automatic frequency and power control system, power-system problems, power-generating unit, once-through boiler, amplitude-frequency characteristic, integral quadratic criterion, disturbances

---

---

**АВТОМАТИЗАЦИЯ И ТЕПЛОВОЙ КОНТРОЛЬ  
В ЭНЕРГЕТИКЕ**

---

---

**ОПЫТ ИСПОЛЬЗОВАНИЯ УДАЛЕННОГО ДОСТУПА  
И ПРЕДСКАЗАТЕЛЬНОЙ АНАЛИТИКИ СОСТОЯНИЯ  
ЭНЕРГЕТИЧЕСКОГО ОБОРУДОВАНИЯ**

**© 2018 г. С. А. Наумов\*, А. В. Крымский, М. А. Липатов, Д. Н. Скрабатун**

*Акционерное общество РОТЕК, 119049, Россия, Москва, ул. Большая Якиманка, д. 33/13, стр. 2*

*\*e-mail: s.naumov@zaorotec.ru*

Поступила в редакцию 29.06.2017 г.

Принята в печать 27.09.2017 г.

Цифровые технологии, программное обеспечение предсказательной аналитики и новейшее оборудование позволят сделать генерацию электроэнергии более экономичной, надежной и безопасной. Промышленный интернет начинается с внедрения систем, основанных на взаимном проникновении информационных технологий и средств автоматизации технологического оборудования, каковыми являются системы удаленного мониторинга и диагностики. Один из методов контроля состояния оборудования – его непрерывный мониторинг, служащий необходимым условием перехода на систему обслуживания по техническому состоянию. С помощью традиционных методов моделирования возможно получить лишь весьма приближенные данные о поведении промышленных систем и объектов даже в тех случаях, когда известны все факторы, влияющие на их работу и техническое состояние, из-за необходимости решения для осуществления такого моделирования сложных математических задач. По этой причине в последние десятилетия для контроля технического состояния промышленных систем нашло применение статистическое моделирование таких систем, основанное на эмпирических закономерностях, определяемых по выборкам значений технологических параметров, фиксируемых в считающийся эталонным период работы объекта. Статистические методы контроля позволяют обнаружить изменения в техническом состоянии системы на ранних стадиях, а также указать наиболее важные факторы, влияющие на них. В статье дан обзор представленных в России систем предсказательной аналитики и положенных в их основу математических методов, а также рассмотрена система прогнозирования и удаленного мониторинга ПРАНА, реализованная на ГТУ V94.2 Siemens Пермской ТЭЦ-9, Владимирской ТЭЦ-2, Ижевской ТЭЦ-1, Кировской ТЭЦ-3 ПАО “Т Плюс”. Показана эффективность ПРАНА для обнаружения негативного изменения технического состояния до фактического проявления неисправностей, что позволяет определять остаточный ресурс изделия и его деталей, планировать оптимальные сроки, длительность останова оборудования и подготовки его к ремонту, оценивать качество выполненных ремонтных работ. Рассмотрены состояние промышленного интернета в энергетике России и проблемы, сдерживающие его развитие.

*Ключевые слова:* цифровые технологии, киберфизические системы, промышленный интернет, предсказательная аналитика, прогнозирование, остаточный ресурс

**DOI:** 10.1134/S0040363618040057

## Experience in Use of Remote Access and Predictive Analytics for Power Equipment's Condition

S. A. Naumov\*, A. V. Krymskii, M. A. Lipatov, and D. N. Skrabatun

*AO ROTEC, Moscow, 119049 Russia*

*\*e-mail: s.naumov@zaorotec.ru*

Received June 29, 2017; in final form, September 27, 2017

**Abstract**—Digital technologies, software of predictive analytics, and advanced equipment will make it possible to improve economy, reliability, and safety of electricity generation. The industrial Internet begins with the introduction of systems based on mutual penetration of information technologies and automation devices of manufacturing equipment, such as the systems of remote monitoring and diagnostics. One of the inspection methods of the equipment's condition is its continuous monitoring, which is a necessary condition for the transition to a service system on the operating condition. Using traditional modeling methods, it is possible to obtain only approximate data about the behavior of industrial systems and objects even in the cases when all factors influencing their work and operating condition are known, owing to the necessity to solve complex mathematical problems to carry out this modeling. For this reason, to monitor the operating condition of industrial systems, the statistical modeling of such systems based on empirical regulations defined by the samples of values of technological parameters recorded in the object operation period, which is considered by reference, found application in recent decades. The statistical methods of monitoring makes it possible to detect the changes in the operating condition of the system at early stages as well as to reveal the most important factors influencing them. The work presents a review of Russian systems of predictive analytics and mathematical methods on which they are based and also the PRANA system of prediction and remote monitoring that is implemented at the gas-turbine plant of V 94.2 Siemens type installed in the Perm TPP-9 (thermal power plant), the Vladimir TPP-2, the Izhevsk TPP-1, and the Kirov TPP-3, which are branches of PAO T Plyus. The efficiency of PRANA to detect the negative change of operating conditions before actual fault events was shown, which makes it possible to determine the residual life of a product and its components, schedule the optimal terms, the duration of equipment stop and preparation for its repair, and evaluate the quality of fulfilled repairs. The condition of the industrial Internet in Russian power engineering and the problems delaying its development are considered.

*Keywords:* digital technologies, cyber-physical systems, industrial Internet, predictive analytics, prediction, residual life



---

---

ЭЛЕКТРИЧЕСКАЯ ЧАСТЬ  
ТЕПЛОВЫХ И АТОМНЫХ СТАНЦИЙ

---

---

**РАСШИРЕНИЕ ОБЛАСТИ ПРИМЕНЕНИЯ ВАКУУМНЫХ  
ВЫКЛЮЧАТЕЛЕЙ НА ГЕНЕРАТОРЫ МОЩНОСТЬЮ ДО 400 МВт**

© 2018 г. К. Венна<sup>a, \*</sup>, Ю. П. Гусев<sup>b, \*\*</sup>, Е. П. Окнин<sup>b</sup>, Г. Ч. Чо<sup>b</sup>

<sup>a</sup>Siemens, 13629 Germany, Berlin, Nonnendammallee, 104

<sup>b</sup>Национальный исследовательский университет “Московский энергетический институт”,  
111250, Россия, Москва, Красноказарменная ул., д. 14

\*e-mail: karthikreddy.venna@siemens.com

\*\*e-mail: gusevyp@mpei.ru

Поступила в редакцию 07.09.2017 г.

Принята в печать 27.09.2017 г.

Современные достижения в области разработки и производства вакуумных выключателей позволяют более широко использовать их на электростанциях, в том числе и в качестве генераторных. Увеличение отключающей способности, большой коммутационный ресурс современных вакуумных выключателей способствуют повышению их конкурентоспособности с элегазовыми выключателями для генераторов мощностью до 400 МВт. В статье рассмотрены проблемные аспекты процессов отключения коротких замыканий в цепях генераторного напряжения, отключения токов несинхронных включений и токов холостого хода блочных трансформаторов. Рассмотрены условия, приводящие к задержке прохождения коммутируемого тока через нуль. Отмечено, что ГОСТ Р 52565-2006, в отличие от IEC/IEEE 62271-37-013, регламентирует требования к генераторным выключателям не в полном объеме. Приведены значения падения напряжения на дуге для разных конструктивных исполнений контактов вакуумного выключателя, а также показано, как влияет дуга в вакуумном выключателе на задержку прохождения тока через нуль. Выполнена оценка нормированных значений параметров переходных восстанавливающихся напряжений на контактах генераторного выключателя и обеспечиваемых современными вакуумными дугогасительными камерами скоростей восстановления электрической прочности межконтактного промежутка. Проведен анализ коммутационных перенапряжений при отключении вакуумными выключателями токов коротких замыканий и токов холостого хода блочных трансформаторов. Рассмотрены наиболее вероятные причины коммутационных перенапряжений: срезы тока, повторные пробой межконтактного промежутка выключателя и виртуальные срезы тока. Выявлено, что срез тока не приводит к образованию опасных коммутационных перенапряжений, в отличие от повторных пробоев и виртуальных срезов тока. Определены границы области применения вакуумных выключателей, в которой возможно образование опасных коммутационных перенапряжений, требующих дополнительных мер по их ограничению.

*Ключевые слова:* вакуумный генераторный выключатель, коммутационное перенапряжение, переходное восстанавливающееся напряжение, срез тока, задержка прохождения тока через нуль, падение напряжения на дуге

DOI: 10.1134/S0040363618040094

## Extending the Application Field of Vacuum Circuit Breakers to Generators for Capacities Up to 400 MW

K. Venna<sup>a,\*</sup>, Yu. P. Gusev<sup>b,\*\*</sup>, E. P. Oknin<sup>b</sup>, and G. Ch. Cho<sup>b</sup>

<sup>a</sup>*Siemens, Berlin, 13629 Germany*

<sup>b</sup>*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

<sup>\*</sup>*e-mail: karthikreddy.venna@siemens.com*

<sup>\*\*</sup>*e-mail: gusevyp@mpei.ru*

Received September 7, 2017; in final form, September 27, 2017

**Abstract**—The progress that has been achieved in the development and manufacture of vacuum circuit breakers opens the possibility of using them for a wider range of applications at power plants, including as generator circuit breakers. Such characteristics of modern vacuum circuit breakers as increased breaking capacity and high switching life are factors that make them closer in competitiveness to SF6 circuit breakers for generators with capacities up to 400 MW. The article considers problem aspects relating to clearing of short-circuit faults in the generator voltage circuits and interruption of out-of-phase making currents and no-load currents of generator transformers. Conditions leading to a longer period of time to the moment at which the switched current crosses zero are considered. It is pointed out that, unlike the IEC/IEEE Standard 62271-37-013, GOST (State Standard) R 52565-2006 does not specify the requirements for generator circuit breakers in full. The article gives the voltage drop values across the arc for different design versions of vacuum circuit breaker contacts and shows the effect the arc in a vacuum circuit breaker has on the time delay to the moment at which the current crosses zero. The standardized parameters of transient recovery voltage across the generator circuit breaker contacts are estimated along with the contact gap electric strength recovery rates ensured by modern arc quenching chambers. The switching overvoltages arising when vacuum circuit breakers interrupt short-circuit currents and no-load currents of generator transformers are analyzed. The article considers the most probable factors causing the occurrence of switching overvoltages, including current chopping, repeated breakdowns of the circuit breaker contact gap, and virtual current chopping. It is found that, unlike repeated breakdowns and virtual current chopping, an actual current chopping does not give rise to dangerous switching overvoltages. The article also determines the vacuum circuit breaker application field boundaries in which dangerous switching overvoltages may occur that would require additional measures for limiting them.

**Keywords:** vacuum generator circuit breaker, switching overvoltage, transient recovery voltage, current chopping, time delay to the current zero crossing moment, voltage drop across the arc

## ГРАФИЧЕСКИЙ ЭКСПРЕСС-МЕТОД ОЦЕНКИ ОСТАТОЧНОГО ТЕПЛОВЫДЕЛЕНИЯ ПРИ ЦИКЛИЧЕСКОЙ ЭКСПЛУАТАЦИИ ИССЛЕДОВАТЕЛЬСКОГО РЕАКТОРА БАССЕЙНОВОГО ТИПА

© 2018 г. S. H. Kadalev

*Nuclear Scientific Experimental and Educational Centre, Institute for Nuclear Research and Nuclear Energy,  
Bulgarian Academy of Science, BG 1784, Bulgaria, Sofia, Tsarigradsko chaussee Boulevard, 72*

*e-mail: kadalev@inrne.bas.bg, stoyan.kadalev@gmail.com*

Поступила в редакцию 06.06.2017 г.

Принята в печать 30.08.2017 г.

Представлена удобная методика быстрой оценки остаточного тепловыделения в активной зоне исследовательского реактора бассейнового типа после его останова с учетом предшествующих рабочих циклов при постоянных эксплуатационных параметрах. Обоснована выбранная математическая модель процесса. Определены рабочие параметры и принятые допущения. Рассмотрены рабочий уровень мощности 2000 кВт и графики работы реактора эксплуатация/простой: 4/20, 6/18, 8/16, 10/14 и 12/12 ч – в течение пяти рабочих дней с остановом на выходные дни. Проведены расчеты для первых 180 с и первых 120 мин после гашения реакции деления системой аварийного останова реактора. Графически представлены результаты расчета остаточного тепловыделения в активной зоне реактора при различных эксплуатационных режимах в процентах номинальной мощности. В каждом рабочем режиме учитывается количество предшествующих рабочих недель. Значения поправочного коэффициента и доля предшествующих рабочих циклов в уровне мощности остаточного тепловыделения представлены в таблицах. Обсуждены расчетные данные для оценки результатов анализа безопасности и управления ядерным топливным циклом. Обозначены и определены некоторые возможные направления дальнейших исследований.

*Ключевые слова:* остаточное тепловыделение, циклический режим эксплуатации, анализ и оценка безопасности

**DOI:** 10.1134/S0040363618040021

# Graphical Toolkit for Easy and Rapid Evaluation of the Residual Heat Generation at Cyclic Operation of a Pool Type Research Reactor

S. H. Kadalev

*Nuclear Scientific Experimental and Educational Centre, Institute for Nuclear Research and Nuclear Energy,  
Bulgarian Academy of Science, Bulgaria, BG 1784 Sofia*

*e-mail: kadalev@inrne.bas.bg; stoyan.kadalev@gmail.com*

*Received June 06, 2017; in final form, August 30, 2017*

**Abstract**—The present paper considers the approach to easy and rapid evaluation of the residual heat generation in the reactor core of a pool type research reactor after shutdown taking into account the previous operation cycles at constant operating cycle parameters. The selected mathematical model of the process is well-founded. The frames of the operational parameters and assumptions of the study are defined. The operating power level of 2000 kW and operation/shutdown schedules of 4/20, 6/18, 8/16, 10/14 and 12/12 hours per day during the five working days of the week and shutdown for the weekend are considered. The calculations are prepared for the first 180 seconds and the first 120 minutes after the fission reaction is stopped by the reactor scram system. The calculation results for the power of the residual heat generation in the reactor core at different work schedule are presented graphically as a percentage of the nominal power. For each particular work schedule the number of previous working weeks taken into account, the value of the correction coefficient and the share of the previous operating cycles in the residual heat generation power are presented in tables. The calculation results are discussed from the point of view of the safety analyses assessment and the nuclear fuel cycle management. Some possible directions for further research works are outlined and defined as particular tasks.

*Keywords:* residual heat generation; cyclic operational mode; safety analyses and assessments

## ПЕРСПЕКТИВЫ ПРИМЕНЕНИЯ СЛАБОДИССОЦИИРУЮЩИХ ИОНИТОВ В СИСТЕМАХ СПЕЦВОДООЧИСТКИ АЭС С ВВЭР ДЛЯ СНИЖЕНИЯ ОБЪЕМА ОБРАЗУЮЩИХСЯ РАДИОАКТИВНЫХ ОТХОДОВ<sup>1</sup>

© 2018 г. В. А. Винницкий\*, А. С. Чугунов, А. Ф. Нечаев

*Санкт-Петербургский государственный технологический институт (технический университет),  
190013, Россия, Санкт-Петербург, Московский просп., д. 26*

*\*e-mail: ivinnicciy@gmail.com*

Поступила в редакцию 23.06.2017 г.

Принята в печать 30.08.2017 г.

Одной из важных задач повышения безопасности и экономичности атомной энергетики является минимизация объема жидких радиоактивных отходов, образующихся при эксплуатации АЭС. С этой целью проектными организациями предлагается использовать ионообменные материалы в системах спецводоочистки новых энергоблоков с реакторами типа ВВЭР однократно (без регенерации). При этом необходимо резко сократить потребности в ионитах благодаря применению материалов с более высокой обменной емкостью, чем у используемых в настоящее время универсальных ионообменных смол, и совершенствованию технологии ионирования в целях повышения наполняемости сорбентов целевыми компонентами, в первую очередь – подлежащими захоронению радионуклидами. В этом контексте рассмотрены свойства слабодиссоциирующих ионитов на основе сополимеров акриловой кислоты и дивинилбензола. Приводятся теоретическое обоснование выбранного направления и результаты лабораторных исследований по очистке модельных потоков, в том числе отработке режимов регенерации слабодиссоциирующих ионитов, позволяющих зафиксировать биологически опасные компоненты в минералоподобных структурах с минимальным объемом подлежащих захоронению компаундов. Показано, что применение последовательного катионирования щелочных радиоактивно загрязненных потоков в системе карбоксильный катионит–сильнокислотный сульфокатионит приводит к деалкализации раствора карбоксильным катионитом с последующим удалением радионуклидов цезия сульфокислотным катионитом. Такое перераспределение функций способствует снижению концентрации конкурирующих за сорбционные места с радионуклидами <sup>134</sup>Cs, <sup>137</sup>Cs ионов щелочных металлов и аммония, благодаря чему достигается максимальная степень наполняемости подлежащего захоронению сорбента радиоактивными веществами и, следовательно, снижается объем образующихся радиоактивных отходов.

*Ключевые слова:* жидкие радиоактивные отходы, спецводоочистка, карбоксильный катионит, слабоосновный анионит, дезаминирование, борсодержащие воды

**DOI:** 10.1134/S0040363618040100

## Prospects for Using Weakly Dissociated Ion Exchange Resins in Active Water Treatment Systems at VVER-Based Nuclear Power Plants for Reducing the Amount of Radioactive Waste Generated

V. A. Vinnitskii\*, A. S. Chugunov, and A. F. Nechaev

*St. Petersburg State Technological Institute (Technical University), St. Petersburg, 190013 Russia*

*\*e-mail: ivinnicciy@gmail.com*

Received June 23, 2017; in final form, August 30, 2017

**Abstract**—Minimizing the amount of liquid radioactive waste generated during operation of nuclear power plants is among the important problems that have to be solved to enhance the nuclear power industry safety and economic indicators. For this purpose, it is proposed that the ion-exchange materials applied in the active water treatment systems of new power units equipped with VVER-type reactors be used only once (without regenerating them). In so doing, measures should be taken to dramatically reduce the consumption of ion-exchange resins by using materials having a higher ion-exchange capacity than the currently used universal ion-exchange resins. In addition, it is necessary to improve the ion-exchange treatment technology to achieve a higher extent of filling sorbents with the target components, primarily, with radionuclides to be buried. In this context, the properties of weakly dissociated ion-exchange resins made on the basis of acrylic acid and divinylbenzene copolymers are considered. The selected line of research is theoretically substantiated, and the results from laboratory investigations on treating model flows are presented, including those for elaborating the regeneration modes of weakly dissociated ion-exchange resins, the use of which makes it possible to fix biologically dangerous components in mineral-like structures with the minimal amount of compounds to be buried. It is shown that sequential subjecting of alkali flows contaminated with radionuclides to ion-exchange treatment in the carbonaceous resin–sulfonic cation resin system results in that the solution becomes dealcalized under the effect of carbonaceous resin, after which cesium radionuclides are removed by means of sulfonic cation resin. Such redistribution of functions helps to decrease the concentration of alkali-metal and ammonium ions that compete with  $^{134, 137}\text{Cs}$  radionuclides for sorption vacancies, due to which the sorbent to be buried is filled with radioactive substances to the maximal extent, thus resulting in a smaller amount of generated radioactive waste.

*Keywords:* liquid radioactive wastes, active water treatment, carbonaceous resin, weak-base anion resin, deamination, boron-containing water

## ВЛИЯНИЕ ГИДРАЗИНА НА ПЕРЕРАСПРЕДЕЛЕНИЕ ОТЛОЖЕНИЙ ПРОДУКТОВ КОРРОЗИИ В I КОНТУРЕ ТРАНСПОРТНЫХ ЯДЕРНЫХ ЭНЕРГЕТИЧЕСКИХ УСТАНОВОК НА ОСТАНОВЛЕННОМ РЕАКТОРЕ

© 2018 г. С. Н. Орлов\*, А. А. Змитродан, С. Г. Мысик

*Научно-исследовательский технологический институт им. А. П. Александрова,  
188540, Россия, Ленинградская обл., г. Сосновый Бор, Копорское шоссе, д. 72*

*\*e-mail: Orlov.S.N.1989@yandex.ru*

Поступила в редакцию 21.07.2017 г.

Принята в печать 27.09.2017 г.

Рассмотрен процесс перераспределения отложений продуктов коррозии (ПК) в I контуре ядерной энергетической установки (ЯЭУ) транспортного назначения. Показано, что после останова ЯЭУ происходит значительный рост активности активированных продуктов коррозии (АПК) и концентрации стабильных продуктов коррозии в теплоносителе за счет их поступления из отложений, образовавшихся на поверхностях оборудования I контура. Продукты коррозии поступают в теплоноситель преимущественно в форме нерастворимых соединений — доля взвешенных частиц с размерами более 0.4 мкм в суммарном содержании ПК в теплоносителе составляет не менее 90%. При этом концентрация ПК в теплоносителе увеличивается примерно в 10 раз, суммарная активность АПК возрастает более чем в 300 раз по сравнению с начальным значением, полученным при работе реактора. Установлено, что ввод гидразина способствует перераспределению продуктов коррозии и ассоциированных с ними радионуклидов между поверхностями конструкционных материалов и объемом контура: продукты коррозии переходят в теплоноситель, скорость их повторного осаждения снижается в 10 раз, что позволяет увеличить долю высокоактивных отложений АПК, удаляемых из контура штатной системой очистки. Также при вводе гидразина вследствие смещения равновесия наблюдается более высокий уровень активности АПК в теплоносителе после завершения процессов осаждения и очистки на штатной системе поступивших в объем контура ПК. Равновесное значение активности АПК примерно в 10 раз выше характерного для расхоленной установки без введения гидразина. Снижение данного показателя в теплоносителе до стабильно низких значений наблюдается только после ввода реактора в действие.

*Ключевые слова:* ядерные энергетические установки транспортного назначения, I контур, продукты коррозии, водно-химический режим теплоносителя, гидразин

**DOI:** 10.1134/S0040363618040069

## Effect of Hydrazine on Redistribution of Corrosion Product Deposits in the Primary Circuit of a Shutdown Reactor in Propulsion-Type Nuclear Power Plants

S. N. Orlov\*, A. A. Zmitrodan, and S. G. Mysik

*Aleksandrov Scientific-Research and Technological Institute, Sosnovyi Bor, 188540 Russia*

*\*e-mail: Orlov.S.N.1989@yandex.ru*

Received July 21, 2017; in final form, September 27, 2017

**Abstract**—A redistribution process of corrosion product (CP) deposits in the primary circuit of nuclear power plants (NPP) with propulsion service is examined. It is demonstrated that, after a shutdown of the NPP, the activity of activated corrosion products (ACP) and the concentration of stable corrosion products in the coolant increase considerably due to their entering the coolant from the deposits on surfaces of the primary circuit equipment. The corrosion products enter the coolant principally in the form of insoluble compounds, and the suspended solid particles above  $0.4\ \mu\text{m}$  in size account for a minimum of 90% of the total content of CPs in the coolant. This increases the CP concentration in the coolant by a factor of approximately 10, and the total activity of ACPs becomes more than 300 times the initial value determined during reactor operation. It was established that injection of hydrazine facilitated redistribution of the corrosion products and radionuclides associated with them between the surface of construction materials and the coolant: the corrosion products went into the coolant and the rate of their redeposition decreased by a factor of ten. This enables us to increase the fraction of highly active ACPs removed from the circuit by the normal cleaning system. In addition, a shift in the equilibrium on injection of hydrazine gives a higher activity of ACPs in the coolant after completion of the deposition process and removal of CPs that entered the circuit in the normal treatment system. The equilibrium activity of ACPs is approximately ten times the value specific for the installation that is cooled down without introduction of hydrazine. A decrease in this characteristic to stable low values is observed only after the reactor is put into operation.

*Keywords:* propulsion-type nuclear power installations, primary circuit, corrosion products, coolant water chemistry, hydrazine



---

---

**ВОДОПОДГОТОВКА  
И ВОДНО-ХИМИЧЕСКИЙ РЕЖИМ**

---

---

**ОТЕЧЕСТВЕННЫЕ И МЕЖДУНАРОДНЫЕ ДОКУМЕНТЫ  
ПО ИСПОЛЬЗОВАНИЮ РЕАГЕНТОВ, СОДЕРЖАЩИХ  
ПЛЕНКООБРАЗУЮЩИЕ АМИНЫ, ДЛЯ ОРГАНИЗАЦИИ  
ВОДНО-ХИМИЧЕСКОГО РЕЖИМА НА ТЭС<sup>1</sup>**

© 2018 г. Т. И. Петрова, Ф. В. Дяченко, К. А. Орлов\*

*Национальный исследовательский университет “Московский энергетический институт”,  
111250, Россия, Москва, Красноказарменная ул., д. 14*

*\*e-mail: OrlovKA@mpei.ru*

Поступила в редакцию 29.05.2017 г.

Принята в печать 27.09.2017 г.

На надежность и экономичность работы оборудования тепловых электростанций, в том числе парогазовых установок, оказывают влияние коррозия конструкционных материалов и образование отложений в пароводяном тракте. Для снижения скорости этих процессов применяют коррекционную обработку теплоносителя. При этом традиционно в качестве реагентов используют аммиак, гидразин, фосфаты и др. В последнее время большое внимание уделяется применению водно-химических режимов с дозированием комплексных реагентов на основе пленкообразующих аминов не только для защиты оборудования во время устоявшегося режима работы, но и при пусках/остановах, а также для консервации. Такие водно-химические режимы используются не только в России, но и в других странах на паротурбинных и парогазовых ТЭС, в том числе ТЭС со сжиганием биомассы. Международной ассоциацией по свойствам воды и водяного пара, объединяющей специалистов со всего мира, на основании теоретических исследований и многолетнего опыта эксплуатации энергетического оборудования в 21 стране в 2016 г. был разработан технический документ по использованию таких реагентов. Приведен обзор отечественных и международных документов, в которых содержатся условия применения пленкообразующих аминов и реагентов на их основе для организации водно-химических режимов на ТЭС с паротурбинными и парогазовыми установками.

*Ключевые слова:* водно-химические режимы, тепловые электрические станции, паротурбинная установка, парогазовая установка, пленкообразующие амины

**DOI:** 10.1134/S0040363618040070

## National and International Guidelines for the Use of Reagents Containing Film-Forming Amines for the Organization of TPP Water Chemistry Regime

T. I. Petrova, F. V. Dyachenko, and K. A. Orlov\*

*Moscow Power Engineering Institute (MPEI), Moscow 111250 Russia*

*\*e-mail: OrlovKA@mpei.ru*

Received May 29, 2017; in final form, September 27, 2017

**Abstract**—The reliability and economy of thermal power plant equipment, including combined-cycle plants, are affected by corrosion of structural materials and deposit formation in the water-steam circuit. To reduce the rate of these processes, coolant treatment is used. Ammonia, hydrazine, phosphates, etc. have been traditionally used as reagents. Recently, much attention has been paid to the use of water chemistry with the addition of complex reagents based on film-forming amines, not only for the equipment protection during the established operation mode but also for start-stops and preservation. Such water chemistry regimes are used not only in Russia but also in other countries for steam turbine and combined-cycle TPP, including biomass TPPs. In addition, there has been some experience of use at foreign ultra supercritical power units. The International Association for the Properties of Water and Steam, uniting specialists from all over the world, developed a guideline in 2016 for the use of such reagents based on theoretical studies and years of operational experience in power equipment in 21 countries. The review of domestic and international guidelines containing conditions for the use of film-forming amines and amine-based reagents for the organization of TPP water chemistry regimes for steam turbines and combined-cycle plants is presented.

**Keywords:** water chemical regimes, thermal power plants, steam turbine plant, combined-cycle plant, film-forming amines

---

---

**ВОДОПОДГОТОВКА  
И ВОДНО-ХИМИЧЕСКИЙ РЕЖИМ**

---

---

**ЭФФЕКТИВНОСТЬ ОЧИСТКИ ВОДЫ ОТ РАСТВОРЕННЫХ ГАЗОВ  
ПРИ СЛАБОМ И СИЛЬНОМ ВЗАИМОДЕЙСТВИИ ФАЗ  
В ПЛЕНОЧНЫХ АППАРАТАХ**

© 2018 г. А. Г. Лаптев\*, Е. А. Лаптева, Г. К. Шагиева

*Казанский государственный энергетический университет, 420066, Россия, г. Казань, Красносельская ул., д. 51*

*\*e-mail: tvt\_kgeu@mail.ru*

Поступила в редакцию 07.08.2017 г.

Принята в печать 27.09.2017 г.

Рассмотрены процессы очистки воды в пленочных декарбонизаторах и термических деаэраторах с различными контактными устройствами в режимах слабого и сильного взаимодействия фаз. Слабое взаимодействие характеризуется раздельным движением фаз, при котором газовый или паровой поток практически не влияет на гидродинамику пленки жидкости. Такой режим чаще всего реализуется при противотоке фаз. При скорости газа или пара более 8 м/с и атмосферном давлении газовый поток увлекает пленку жидкости в восходящем или нисходящем потоке. В этом режиме процессы массо- и теплопередачи значительно интенсифицируются. Рассмотрены режимы на примере удаления агрессивно-коррозионных газов на ТЭС и промышленных предприятиях. Даны выражения для расчета массообменных характеристик аппаратов и эффективности очистки воды от кислорода и диоксида углерода. Показано, что сильное взаимодействие происходит в трубках с дискретно-шероховатыми стенками и ленточным завихрителем, слабое – в нерегулярных насадках и регулярных гофрированных насадках с шероховатой поверхностью. Для расчета эффективности массопередачи (извлечения растворенных газов из воды) использованы модели структуры потоков – диффузионная и ячеечная с объемными источниками массы. Представлены выражения для расчета параметров моделей: коэффициентов перемешивания, количества ячеек, коэффициентов массоотдачи в жидкой фазе. Даны результаты расчетов эффективности массопередачи в насадочных колоннах и каналах с дискретно-шероховатыми стенками и закруткой потоков. Приведен пример установки насадки в деаэраторе ДСА-300. Сделаны выводы о наиболее рациональных конструкциях и режимах работы термических деаэраторов и декарбонизаторов.

*Ключевые слова:* десорбция, водоподготовка, интенсификация, массообмен, моделирование, пленочные аппараты

**DOI:** 10.1134/S0040363618040045

## Efficiency of Water Purification from Dissolved Gases under Weak and Strong Phase Interaction in Film Degassers

A. G. Laptev\*, E. A. Lapteva, and G. K. Shagieva

*Kazan State Power Engineering University, Kazan, 420066, Russia*

*\*e-mail: tvt\_kgeu@mail.ru*

Received August 7, 2017; in final form, September 27, 2017

**Abstract**—Water purification processes in film decarbonizers and thermal deaerators with different contact arrangements in the modes of weak and strong interaction between phases are considered. Weak interaction is characterized by a separate movement of phases, wherein a gas or vapor flow hardly affects the hydrodynamics of a liquid film. Such a mode is most often implemented in the case of countercurrent phases. At a gas or vapor velocity greater than 8 m/s and an atmospheric pressure, the gas flow carries the liquid film in an ascending or descending flow. In this mode, mass and heat transfer processes are greatly intensified. The modes are considered by the example of removal of aggressive corrosive gases at TPPs and industrial enterprises. Expressions are given for the calculation of the mass exchange characteristics of degassers and for the efficiency of water purification from oxygen and carbon dioxide. It is shown that a strong interaction occurs in the tubes with discrete-rough walls and a ribbon swirler, whereas a weak one takes place in irregular (chaotic) packed beds and regular corrugated packed beds with a rough surface. To calculate the efficiency of mass transfer (the extraction of dissolved gases from water), we used such flow structure models as a diffusion model and a cell model with bulk mass sources. Expressions for the calculation of model parameters—dispersion coefficients, number of cells, mass transfer coefficients in the liquid phase—are presented. The results of calculations of the mass transfer efficiency in packed columns and channels with discrete-rough walls and swirling flows are given. An example for mounting a packed bed in a DSA-300 deaerator is presented. Conclusions are drawn concerning the most rational designs and operating modes of thermal deaerators and decarbonizers.

*Keywords:* desorption, water treatment, intensification, mass transfer, simulation, film degassers

---

**ПАРОВЫЕ КОТЛЫ, ЭНЕРГЕТИЧЕСКОЕ ТОПЛИВО,  
ГОРЕЛОЧНЫЕ УСТРОЙСТВА  
И ВСПОМОГАТЕЛЬНОЕ ОБОРУДОВАНИЕ КОТЛОВ**

---

**ОСОБЕННОСТИ ЭКСПЛУАТАЦИИ ДЫМОВЫХ ТРУБ  
В УСЛОВИЯХ ВОЗДЕЙСТВИЯ ВЕТРА**

© 2018 г. П. В. Росляков\*, И. Л. Ионкин, И. В. Морозов

*Национальный исследовательский университет “Московский энергетический институт”,  
111250, Россия, Москва, Красноказарменная ул., д. 14*

*\*e-mail: RoslyakovPV@mpei.ru*

Поступила в редакцию 27.07.2017 г.

Принята в печать 27.09.2017 г.

В процессе эксплуатации дымовых труб ТЭС часто происходит фильтрация дымовых газов через ствол в окружающую среду, что вызывает их интенсивное разрушение. Причиной этого является разность давлений на внутренней и внешней поверхностях дымовой трубы при ее обтекании потоком атмосферного воздуха. Авторами исследованы условия эксплуатации дымовой трубы в зависимости от ее нагрузки и ветрового воздействия, в том числе проведена оценка избыточного давления в стволе дымовой трубы по критерию Рихтера, выполнены расчеты статического давления по высоте трубы, а также трехмерное моделирование отдельных и совместных процессов движения продуктов сгорания в стволе дымовой трубы и ее обтекания поперечным потоком атмосферного воздуха при различных значениях расхода дымовых газов и скорости ветра. Результаты исследований показали, что оценка условий избыточности давления в дымовой трубе по критерию Рихтера не является достаточно объективной, так как не учитывает разрежение снаружи дымовой трубы, создаваемое ветром. Численные исследования, проведенные с помощью трехмерных моделей, показали наличие обширных зон разрежения на внешней поверхности дымовой трубы при ее обтекании потоком атмосферного воздуха. При этом наибольшее значение разрежения наблюдается на боковых (относительно направления ветра) поверхностях дымовой трубы. При определенной скорости ветра разрежение снаружи становится больше разрежения внутри ствола дымовой трубы, в результате чего на поверхности трубы образуются зоны, в которых возникает фильтрация дымовых газов через ствол в окружающую среду. Анализ полученных данных показал, что интенсивность фильтрации увеличивается с ростом скорости ветра. В то же время площадь таких зон и перепад статического давления в них уменьшается при снижении расхода дымовых газов.

*Ключевые слова:* дымовая труба, ствол трубы, разрежение, статическое давление, фильтрация дымовых газов, ветровое воздействие

**DOI:** 10.1134/S0040363618040082

# Peculiarities of Smoke Stack Operation under Wind Effect Conditions

P. V. Roslyakov\*, I. L. Ionkin, and I. V. Morozov

*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

*\*e-mail: RoslyakovPV@mpei.ru*

Received July 27, 2017; in final form, September 27, 2017

**Abstract**—Seepage of flue gases into the environment through the shaft of thermal power plant smoke stacks often occurs during their operation, causing intensive damage to them. This phenomenon occurs due to the difference of pressure between the smoke stack inner and outer surfaces when the stack is streamlined by the flow of atmospheric air. The smoke stack operating conditions as a function of the stack load and wind conditions was studied. In particular, the excess pressure in the smoke stack shaft is estimated according to L.A. Rikhter's criterion, and the static pressure along the stack height is calculated. The motion of combustion products in the smoke stack shaft and streamlining of the shaft by cross flow of atmospheric air are simulated in separate and combined statements using 3D models at different values of flue gas flowrate and wind velocity. It is shown from the study results that assessment of excess pressure conditions in a smoke stack according to Rikhter's criterion is not sufficiently correct, because it does not take into account the wind-induced underpressure outside of the smoke stack. Numerical investigations carried out using 3D models showed that quite extensive zones with underpressure exist at the smoke stack outer surface when the stack is streamlined by atmospheric airflow. The greatest underpressure is observed under such conditions on the smoke stack lateral surfaces with respect to the wind direction. At a certain wind velocity, the underpressure outside of the stack becomes greater than it is inside of the stack, as a result of which zones appear on the stack surface in which flue gases seep through the shaft into the environment. An analysis of the obtained data showed that the seepage intensity increases with the wind velocity. On the other hand, the area of these zones and the difference of static pressures in them decreases with decreasing the flue gas flowrate.

*Keywords:* smoke stack, stack shaft, underpressure, static pressure, seepage of flue gases, wind effect

---

---

**МЕТАЛЛЫ  
И ВОПРОСЫ ПРОЧНОСТИ**

---

---

**ПОДХОД К ОЦЕНКЕ РЕСУРСНЫХ ХАРАКТЕРИСТИК СТАЛЕЙ  
В УСЛОВИЯХ ПОЛЗУЧЕСТИ С ИСПОЛЬЗОВАНИЕМ КРИТЕРИЕВ  
МЕХАНИКИ РАЗРУШЕНИЯ**

© 2018 г. А. А. Ланин<sup>а</sup>, Е. А. Гринь<sup>б, \*</sup>

<sup>а</sup> Научно-производственное объединение по исследованию и проектированию энергетического оборудования им. И.И. Ползунова, 191167, Россия, Санкт-Петербург, Атаманская ул., д. 3/6

<sup>б</sup> Всероссийский теплотехнический институт, 115280, Россия, Москва, Автозаводская ул., д. 14

\*e-mail: lkpotviti@mail.ru

Поступила в редакцию 23.06.2017 г.

Принята в печать 27.09.2017 г.

Охарактеризована сложившаяся на текущее время ситуация с проведением оценки состояния и перспектив продления сроков службы длительно эксплуатируемого оборудования ТЭС. Кратко изложена история создания и развития отраслевой системы диагностики и продления ресурса тепломеханического оборудования. Основой для создания этой системы послужили результаты исследований длительной прочности и ползучести жаропрочных сталей, а в структуре системы сформировалась и постоянно совершенствовалась нормативная база, регулирующая ее эффективное функционирование. Отмечается, что по мере углубления исследований предпринимались попытки расширить критериальную базу прочности путем использования критериев трещиностойкости, в том числе локальных критериев разрушения при ползучести. Проанализированы преимущества и недостатки наиболее распространенного локального метода контроля – метода реплик. Предложено использовать при анализе процесса разрушения сталей в условиях ползучести критерии механики разрушения и, в частности, пороговый коэффициент интенсивности напряжений (КИН), ниже которого не происходит развития трещин ползучести. Показано, что значение порогового КИН для конкретного материала функционально зависит не только от температуры, но и от времени выдержки под нагрузкой. С учетом этого в рамках концепции порогового КИН предложено учитывать накопление как локальной (в вершине трещины), так и общей поврежденности металла. Аналогичный подход справедлив и для описания процесса докритического развития трещин ползучести, в связи с чем диаграммы скорости роста трещин предложено строить по принципу изохронных кривых для заданных длительностей испытаний. Для конкретных условий эксплуатации показана возможность рассчитывать размеры допускаемых дефектов, при которых трещины не распространяются. Проведен анализ ситуаций, возникающих при получении различных результатов контроля элемента конструкции, работающего в условиях ползучести, для составления прогноза размеров допускаемых (неразвивающихся) трещиноподобных дефектов. Этот анализ продемонстрировал, что применение критерия пороговых КИН и изохронных диаграмм скорости роста трещин при ползучести является эффективным средством для обоснованного назначения периодичности контроля высокотемпературного оборудования и установления сроков продления его ресурса.

*Ключевые слова:* тепломеханическое оборудование, диагностика, ползучесть, длительная прочность, ресурс, локальный критерий разрушения, трещиноподобный дефект, механика разрушения, пороговый коэффициент интенсивности напряжений, скорость роста трещины

**DOI:** 10.1134/S0040363618040033

## An Approach to Assessment of the Lifetime Characteristics of Steels under Creep Conditions Using Fracture Mechanics Criteria

A. A. Lanin<sup>a</sup> and E. A. Grin'<sup>b, \*</sup>

<sup>a</sup>*Polzunov NPO Central Boiler-Turbine Institute, St. Petersburg, 191167 Russia*

<sup>b</sup>*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: lkpomvti@mail.ru*

Received June 23, 2017; in final form, September 27, 2017

**Abstract**—The current status of activities associated with the assessment of conditions and prospects for prolonging the service life of equipment operating for a long time at thermal power stations (TPS) is described. The history of the creation and development of an industry system for diagnosing and prolonging the lifetime of heat-generating and mechanical equipment is briefly outlined. The core of the system was the results of investigations into long-term strength and creep of heat-resistant steels, and a regulatory base governing effective application of the system was formed and continuously improved within the system framework. It is noted that more and more extensive investigations resulted in the attempts to extend the criterial strength base using the cracking resistance criteria, including local creep fracture criteria. The advantages and disadvantages of the most-used local control method, i.e., the replica method, are analyzed. It is proposed to use the fracture mechanics criteria and, in particular, the threshold stress intensity factor (SIF) below which creep cracking does not occur in analyzing the process of steel creep fracture. It is demonstrated that the threshold SIF for a specific material depends functionally not only on the temperature but also on the loading time. Considering this fact, it is proposed to account for the accumulation of local (at the crack tip) and total damageability of the metal in the concept of threshold SIF. A similar approach can also be used for describing the subcritical crack growth. Therefore, it is proposed to construct crack growth diagrams using isochronous curves for the specified test times. It is demonstrated that dimensions of allowable flaws that do not lead to crack propagation can be predicted for given operating conditions. The cases were analyzed that occurred while obtaining results of examination of a structural member operating under creep conditions for prediction of the size of allowable (nonpropagating) crack-like flaws. This analysis has revealed that the application of the threshold SIF criterion and isochronous creep crack growth rate diagrams can be useful for setting forth the substantiated frequency of examinations for high-temperature equipment and establishing the time by which the equipment service life can be prolonged.

*Keywords:* heat generating and mechanical equipment, diagnostics, creep, long-term strength, lifetime, local rupture criterion, crack-like flaw, fracture mechanics, threshold stress intensity factor, crack growth rate