
Contents

Vol. 66, No. 7, 2019

Nuclear Power Plants

Verification of the TIGRSP Computer Code as Applied to a 19-Rod Fuel Assembly
Using CFD Computations

O. E. Stepanov, I. Yu. Galkin, S. S. Melekh, M. M. Kurnosov, and A. A. Pronin

Longitudinal Displacement of a Fuel Rod Nonfixed in the Support Grid under the Conditions
of Hydromechanical Vibration of VVER-440 Reactor Fuel Assemblies

V. I. Solonin and V. V. Perevezentsev

Achieving More Efficient Removal of α -Emitting Radionuclides from the Primary Coolant
in Propulsion Reactors

S. N. Orlov, A. A. Zmitrodan, and S. G. Mysik

Heat and Mass Transfer and Properties of Working Fluids and Materials

Experimental and Calculated Investigation of a Natural Circulation Loop's
Thermal-Hydraulic Characteristics

V. V. Yagov, N. O. Zubov, O. N. Kaban'kov, and L. A. Sukomel

Steam Turbine, Gas Turbine, Steam-Gas Plants and Their Accessory Equipment

Specific Features of the Vortex Flow Patterns in the Vicinity of a Single-Knife-Edge Tip Shroud

I. V. Afanas'ev, A. V. Granovskii, E. Yu. Marchukov, I. A. Manaev, and A. E. Shunin

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Experimental Investigation of NO_x Emission from a Sequential Combustor
with the Kinetic Second Zone

L. A. Bulysova, V. D. Vasilev, M. N. Gutnik, and A. L. Berne

An Approximate Model of Heat Treatment and Ignition of Coal in Small Cyclones

P. A. Shchinnikov, A. A. Frantseva, and A. I. Dvortsevoi

Environment Protection

Developing the Cost-Estimation Technique when Switching to Best Available Power Technologies

*O. E. Kondratieva, P. V. Roslyakov, D. O. Skobelev, T. V. Guseva,
O. A. Loktionov, and Mikaelsson Åke*

Improving the Efficiency of Biowaste Torrefaction

*R. L. Is'emin, A. V. Mikhalev, N. S. Muratova, V. S. Kokh-Tatarenko, Yu. S. Teplitskii,
E. K. Buchilko, A. Zh. Greben'kov, and E. A. Pitsukha*

Water Treatment and Water Chemistry

Laboratory Investigations of Processing Highly Mineralized Alkali Solutions
by Means of Electromembrane Technology

A. A. Chichirov, N. D. Chichirova, A. A. Filimonova, A. I. Minibaev, and R. V. Buskin

Verification of the TIGRSP Computer Code as Applied to a 19-Rod Fuel Assembly Using CFD Computations

O. E. Stepanov^{a,*}, I. Yu. Galkin^a, S. S. Melekh^a, M. M. Kurnosov^a, and A. A. Pronin^a

^a*OKB Hidropress, Podolsk, Moscow oblast, 142103 Russia*

**e-mail: stepanov_oe@grpress.podolsk.ru*

Received April 10, 2018; revised January 11, 2019; accepted January 30, 2019

Abstract—For assessing the core critical heat flux ratio in VVER-type nuclear reactors, the lattice computation code TIGRSP (steady-state thermal and hydraulic analysis of parameters in fuel rod bundles) is used. Despite the fact that quite a large amount of verification studies has been accomplished and that the code has passed the certification procedure, work on improving the code capabilities is still being continued. One of the modern tendencies is the wide-scale involvement of CFD codes for studying local parameters in fuel assemblies (FAs). Along with comparison with experimental data, it is advisable to carry out cross verification of lattice codes with the results of 3D thermal-hydraulic computations for conditions for which experimental data are either lacking or limited for some or other reasons. This article considers thermal-hydraulic processes during coolant flow in a 19-rod assembly with parameters close to the nominal conditions in the FAs of a VVER-1000 reactor. The 3D model is verified with respect to empirical formulas and experimental data. Based on the results of test and verification computations, we determined the mesh and turbulence model parameters using the ANSYS CFX code by means of which it is possible to obtain reliable results in estimating the hydraulic characteristics of FAs fitted with spacer grids, heat transfer in the single-phase region, and coolant flow distribution over the FA cross section. The CFD computation of coolant flow for the 19-rod assembly is carried out, and the coolant mass velocity and temperature in different sections over the length and corresponding cells of the TIGRSP code are calculated. The TIGRSP code has been verified against experimental data and taking into account the CFD simulation of the 19-rod FA, and a software module for graphically visualizing the lattice code output results has been developed. The presented data can be used for verification of thermal-hydraulic codes and in elaborating the design of FAs for VVER-type reactors.

Keywords: TIGRSP, CFD, FA, VVER, nuclear reactor, friction loss, heat transfer

Longitudinal Displacement of a Fuel Rod Nonfixed in the Support Grid under the Conditions of Hydromechanical Vibration of VVER-440 Reactor Fuel Assemblies

V. I. Solonin^a and V. V. Perevezentsev^{a, *}

^a*Bauman Moscow State Technical University, Moscow, 105005 Russia*

**e-mail: perevezentsev@bmstu.ru*

Received October 18, 2018; revised October 18, 2018; accepted December 19, 2018

Abstract—Experiments aimed at studying the effect of fuel rod vibration in a turbulent coolant flow has on the effort of moving and longitudinal displacement of a fuel rod in the system of VVER-440 reactor fuel assembly (FA) spacer grids (SGs) for the case when the fuel rod is not fixed in the lower support are carried out. It has been found that the fuel rod longitudinal displacement force becomes essentially (by approximately 30%) higher in a coolant flow than it is in stagnant water. The fuel rod's longitudinal displacement force decreases with an increase in the water flow velocity and, hence, with an increase in the fuel rod bundle vibration intensity. At the water flow velocity equal to approximately 3.8 m/s, which is close to the its nominal value in the VVER-440 reactor FAs, the displacement force decreases by approximately 10% as compared with its value at the velocity equal to 0.8 m/s. The regularities relating to the change with time in the fuel rod's longitudinal displacement speed and acceleration testify that the force resisting its motion in the spacer grid system has a periodic pattern. During vibration (flexural oscillations) of a fuel rod bundle, the stiffness in the fuel rod—SG cell system changes its value, and the axes of SG cells shift relative to one another for the characteristic period of one vibration cycle. It is particularly the above-mentioned effects connected with fuel rod bundle vibration that lead to a growth in the fuel rod's longitudinal displacement force. The results from the accomplished calculated assessments show that the algebraic sum of the Archimedean force, gravity force, force due to pressure loss across the fuel bundle, and inertial forces with the water velocity values up to 4.81 m/s do not exceed 6% of the minimal fuel rod longitudinal displacement force. In turn, this means that the system of honeycomb-type spacer grids reliably secures the VVER-440 reactor fuel rods that are not fixed in the FA lower support grid.

Keywords: VVER-440, fuel assembly, fuel rod vibration, spacer grids, fuel rod moving effort and longitudinal displacement force

Achieving More Efficient Removal of α -Emitting Radionuclides from the Primary Coolant in Propulsion Reactors

S. N. Orlov^{a, *}, A. A. Zmitrodan^a, and S. G. Mysik^a

^a*Aleksandrov Research Institute of Technology, Leningrad oblast, Sosnovyi Bor, 188540 Russia*

**e-mail: Orlov.S.N.1989@yandex.ru*

Received November 21, 2018; revised December 28, 2018; accepted January 30, 2019

Abstract—The processes through which the α -emitting radionuclides contained in the primary circuit of a propulsion reactor are transferred in the circuit and removed from it in the standard ion-exchange filters are studied. The correlation between the behavior of transuranium elements and iron-containing corrosion product compounds in the primary circuit is considered. During reactor operation at steady power levels, α -emitting radionuclides reside, like iron compounds, predominantly in deposits on the circuit equipment surfaces. When hydrodynamic disturbances occur, these deposits transfer into coolant in the form of insoluble particles, thus intensifying the transfer of α -emitting radionuclides over the circuit. It has experimentally been found that the average deposition time of particles containing α -emitting radionuclides is larger than that of iron-containing particles (their deposition constants are equal to 0.6 h^{-1} and 0.9 h^{-1} , respectively). This fact gives grounds to suppose that α -emitting radionuclides are nonuniformly distributed in corrosion product deposits and transfer into the coolant predominantly in the composition of particles having a smaller mean radius than that of iron-containing particles. As a result, the reactor's standard ion-exchange filters show a relatively poor purification efficiency of α -emitting radionuclides (the purification constant is approximately 0.1 h^{-1} vs. 0.2 h^{-1} for corrosion product particles as a whole). The metering of hydrazine into the coolant results in that the repeated deposition rate of particles containing α -emitting radionuclides decreases by a factor of seven, due to which up to half of α -emitting radionuclides transferred into the coolant under the effect of hydrodynamic disturbance can be removed from it in the filters.

Keywords: propulsion reactor, primary coolant circuit, α -emitting radionuclides, corrosion products, activated corrosion products, hydrazine, ion-exchange filters

Experimental and Calculated Investigation of a Natural Circulation Loop's Thermal-Hydraulic Characteristics

V. V. Yagov^{a, *}, N. O. Zubov^a, O. N. Kaban'kov^{a, **}, and L. A. Sukomel^a

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail:yagovvv@gmail.com

**e-mail:kon09.tiger@yandex.ru

Received December 5, 2018; revised December 19, 2018; accepted December 19, 2018

Abstract—The results from experimental investigation into hydrodynamics and heat transfer in a two-phase natural circulation loop (NCL) under atmospheric pressure are presented. The experiments were carried out for liquids having essentially different properties: water, ethanol, and perfluorohexane C₆F₁₄ (the product trademark is FC-72). The circulation velocity in the NCL is not known in advance but is a complex function of the specified parameters (heat flux and liquid temperature at the heated segment inlet) and of the two-phase flow internal characteristics. The liquid temperatures at the heated segment inlet, the wall temperature over the segment height, and also the circulation velocity were measured in the experiments at a specified heat flux; in addition, the two-phase flow at the loop riser leg outlet was filmed on video. The experiments and analysis have shown that flow hydrodynamic instability (circulation velocity pulsations) is really unavoidable in a two-phase NCL. Hydrodynamic instability with a high circulation velocity amplitude and with the occurrence of backward flows is typical for regimes involving significant liquid subcooling values at the heated segment inlet and for NCLs containing an extended part with single-phase convection. This instability, which is characteristic for experiments with water, is due to the displacement of the boiling incipience section over the section height; the instability also persists at small subcooling values but with a low pulsation amplitude. Under the developed saturated liquid nucleate boiling conditions (at high heat flux values), the circulation velocity and wall temperature pulsations have small amplitudes, and the flow can be regarded as stable. In the experiments with perfluorohexane, the smallest wall temperature and circulation velocity pulsations were pointed out, which is attributed to a relatively high value of reduced pressure. In the experiments with ethanol, instability occurs in the developed nucleate boiling region ($q > 35 \text{ kW/m}^2$); this instability is caused by periodically alternating two-phase flow structure (regime). A procedure for calculating a low-pressure NCL is developed, in which the two-phase flow's local parameters (void fraction, phase velocities, and pressure) are calculated according to a modified homogeneous model (taking into account the phase distribution factor and phase slipping) and a dispersed-annular flow model taking into account the droplet entrainment and deposition phenomena. A comparison of the NCL calculation results with the experimental data obtained for three different liquids has shown that they are in good agreement with each other.

Keywords: void fraction, homogeneous model, dispersed-annular flow, instability, pulsations, boiling inception

Specific Features of the Vortex Flow Patterns in the Vicinity of a Single-Knife-Edge Tip Shroud

I. V. Afanas'ev^a, A. V. Granovskii^{a, *}, E. Yu. Marchukov^a, I. A. Manaev^a, and A. E. Shunin^a

^a*Lyul'ka Experimental Design Bureau, Moscow, 129301 Russia*

**e-mail: andrey.granovskiy@yandex.ru*

Received October 8, 2018; revised December 19, 2018; accepted December 20, 2018

Abstract—Modern gas turbines have high efficiency. A further increase in their economic efficiency can be achieved, on the one hand, by enhancing the accuracy of the parameter prediction at the design stage and, on the other hand, by the possibility of improving the design for different components of the flow path based on the results of calculating the complicated viscous spatial structure of the flow. One of the tools for enhancing the efficiency of gas turbines is the minimization of the rotor-tip leakage, the rate of which is reduced by shrouding the rotor blades. In particular, using numerical methods and software tools based on the former, one can perform thorough computational analysis of the vortex structure of the flow in the vicinity of the tip shroud and sufficiently accurately determine the rotor-tip leakage rates and other parameters of the stage. Such an approach allows a more accurate assessment of the leakage than semiempirical approaches used in practice. In particular, the assessment by the correlation dependence showed that the leakage rate for the tip shroud design in question with a tip clearance of 5 mm exceeded the leakage rate calculated using the method that considers the specific features of the tip shroud design and the vortex structure of the flow in the vicinity of it by 8.65%. As exemplified by the last-stage rotor blade of a stationary gas turbine, the possibility of controlling the leakage of the main flow through the tip clearance is demonstrated based on results of a numerical experiment.

Keywords: vortex structure, tip shroud, partial shroud, economic efficiency, gas turbine, tip clearance

Experimental Investigation of NO_x Emission from a Sequential Combustor with the Kinetic Second Zone

L. A. Bulysova^{a, *, **}, V. D. Vasilev^a, M. N. Gutnik^a, and A. L. Berne^a

^aAll Russia Thermal Engineering Institute (OAO VTI), Moscow, 115280 Russia

*e-mail: bulysov@mail.ru

**e-mail: kc-vti@bk.ru

Received December 6, 2018; revised December 18, 2018; accepted December 19, 2018

Abstract—This is the fourth paper in a series of publications on the experimental investigation of fuel-air mixture combustion in a combustion chamber (CC) with two combustion zones set in a series with an outlet temperature ranging from 1550 to 1700°C and meeting the requirements for NO_x and carbon oxide emissions. The results of the experimental investigation into combustion of gaseous fuel CS comprising two combustion zones set in a series, each with its own burner unit, are presented. The first burner unit (BU1) is typical for low-emission combustors. It has swirlers, a premixing zone, and pilot and main burners. The premixed fuel-air mixture (FAM) is fed to the BU1 inlet. The second burner unit (BU2) is located downstream of the first combustion zone and is fed with FAM with a fuel concentration equal to or higher than the fuel concentration in the first combustion zone. The kinetic fuel combustion whose rate depends on the kinetics of the fuel oxidation reaction rather than on the rate of migration of the reacting components to the flame surface by molecular or kinetic diffusion (as in case of diffusion combustion) occurs in the first and second zones. The second burner unit has its own premixer. In the second zone, the fuel burns in a high-temperature environment at a reduced oxygen content. Four CS configurations with different lengths of the first and second combustion zones were investigated experimentally. The first configuration with single-zone fuel burning is the base one. In the other three configurations, the length of the first and the second zone varied (with the total length of the liner being the same). The results of optimization of the FAN between two sequential combustion zones are presented. The best length of the second zone minimizing NO_x and CO emissions at a CC outlet temperature from 1550 to 1700°C was found.

Keywords: low-emission combustion chamber, gas-turbine unit, two-zone combustion, fuel-air mixture, nitrogen oxides, carbon oxides, numerical investigation, experimental investigation

An Approximate Model of Heat Treatment and Ignition of Coal in Small Cyclones

P. A. Shchinnikov^a, A. A. Frantseva^{a, *}, and A. I. Dvortsevoi^a

^a Novosibirsk State Technical University, Novosibirsk, 630073 Russia

* e-mail: frantsevaalina@gmail.com

Received November 5, 2018; revised December 3, 2018; accepted December 20, 2018

Abstract—An approximate physical model of coal heat pretreatment with external heat input in a cyclone-type unit is presented and its governing principles are examined. The model makes it possible to predict the time of moisture release from the fuel (or evaporation), the temperature of gas suspension and of fuel combustion, and the composition and volume of the combustion products. This enables one to determine the design and layout of the furnace extension for various process conditions. The model is based on the following assumptions: the processes are quasi-stationary, the heat capacities and heat transfer coefficients are constant and determined at an average process temperature, coal particles are isothermal, the gas suspension is uniform, ash components are inert, and the flow is one-dimensional. In addition, the model includes only the reactions governing the combustion processes. Heat transfer from gas to a particle by convection and conduction prevails over heat transfer by radiation. By an example of Kansk-Achinsk coal's heat treatment, it has been established that the yield of combustible volatiles can be 30–40% (by mass) at a gasification degree of 0.35–0.60. The time of solid phase ignition is approximately 0.8 s from the onset of the process. In all cases, the products of heat treatment of coals at different phases of metamorphism contain at least 25% of combustible volatiles, thereby securing ignition of the solid phase. Basic design features of a small-size furnace extension acting as a boiler burner for steam-turbine power units are determined.

Keywords: gasification, model, cyclone, furnace extension, engineering method, power industry, heat treatment, combustion products

Developing the Cost-Estimation Technique when Switching to Best Available Power Technologies

O. E. Kondratieva^{a,*}, P. V. Roslyakov^{a,**}, D. O. Skobelev^b, T. V. Guseva^b,
O. A. Loktionov^a, and Mikaelsson Åke^c

^a*Moscow Power Engineering Institute (MPEI), Moscow, 111250 Russia*

^b*Environmental Industrial Policy Centre (EIPC), Moscow oblast, Mytishchi, 141006 Russia*

^c*Swedish Environmental Protection Agency, Naturvårdsverket, Stockholm, SE-106 48 Sweden*

**e-mail: KondratyevaOYe@mpei.ru*

***e-mail: RoslyakovPV@mpei.ru*

Received October 9, 2018; revised December 17, 2018; accepted December 20, 2018

Abstract—The Federal Law of July 21, 2014, no. 219-FZ “On Amendments to the Federal Law ‘On Environmental Protection’ and individual legislative acts of the Russian Federation” established new principles of environmental policy providing for a substantial reduction of the negative anthropogenic impact on the environment. For this purpose, objects of Category I have been identified that have a significant negative impact on the environment and are related to the areas of best available technologies (BATs). For the methodological support of switching heat and power enterprises to BATs, a BAT reference document (BREF) 38-2017 “Combustion of Fuel in Large Plants for the Purpose of Energy Production” has been approved. Its task is to determine a list of marker pollutants, technological indicators of pollutant emissions, and best available technologies recommended for introduction at thermal power plants (TPPs) in order to reduce harmful emissions into the atmosphere. The article is devoted to the cost estimation when switching to best available technologies—one of the most acute issues of the power industry. The article presents the main provisions of the methodology for estimating capital and operating costs in switching thermal power plants to BATs, which were developed during joint research of the EIPC and MPEI. The approach proposed in the framework of the developed methodology can significantly reduce the amount of information analyzed and ensure the high reliability of estimates at the same time. The volume of representative samples necessary for a correct cost estimation of implementing measures to reduce power plants' harmful emissions at facilities that fail to meet the BAT requirements is calculated. The range of total costs for the implementation of environmental-protection measures at existing power facilities that do not comply with the BAT principles in the wider heat and power industry has been determined.

Keywords: best available technologies, power industry, pollutants, reduction of emissions, technological indicators, BAT information and technical reference book, cost estimation when switching to BAT

Improving the Efficiency of Biowaste Torrefaction

R. L. Is'emin^{a,*}, A. V. Mikhalev^{a,*}, N. S. Muratova^b, V. S. Kokh-Tatarenko^{b,**}, Yu. S. Teplitskii^{c,***},
E. K. Buchilko^c, A. Zh. Greben'kov^c, and E. A. Pitsukha^c

^a*OOO Clean Energy, Tambov, 392032 Russia*

^b*Tambov State Technical University, Tambov, 392000 Russia*

^c*Lykaiu Institute of Heat and Mass Transfer, National Academy of Sciences of Belarus, Minsk, 220072 Republic of Belarus*

**e-mail: penergy@list.ru*

***e-mail: vadim6873@yandex.ru*

****e-mail: tep@hmti.ac.by*

Received November 8, 2018; revised December 25, 2018; accepted December 30, 2018

Abstract—Russia faces an important environmental challenge associated with the accumulation of a large amount of biowaste due to the lack of technologies for their efficient processing. In particular, the intensive development of aviculture in Russia, including poultry farming, in the coming years will lead to the need of processing significant amounts of poultry manure and poultry litter. One of the options for litter disposal is its processing into biofuel, suitable for the production of heat energy for the needs of poultry farms themselves and for outside consumers. However, with this option, the disposal of litter requires its disinfection, for example, by the method of torrefaction. However, the existing torrefaction technologies are characterized by a considerable process duration. A new method of torrefaction has been proposed and comparative studies have been carried out on the process of poultry litter torrefaction in a dense bed under a nitrogen blanket (dry torrefaction) and in a fluidized manure bed pretreated in superheated steam (wet torrefaction). After both methods following heat treatment, manure samples are obtained, the mass of which is decreased twice due to an almost threefold decrease in the oxygen content, which, along with an increase in the carbon content and a decrease in the amount of moisture, causes the fuel efficiency of the manure after treatment. The manure torrefaction in a fluidized bed also makes it possible to significantly (four times) speed up the process. Technical solutions are proposed to solve the issues of full or partial recovery of energy costs related to the production of superheated steam due to the processing of gaseous torrefaction products into syngas using hot biochar thermal cracking.

Keywords: poultry manure, torrefaction, fluidized bed, solid torrefaction products, gaseous torrefaction products, thermal cracking

Laboratory Investigations of Processing Highly Mineralized Alkali Solutions by Means of Electromembrane Technology

A. A. Chichirov^a, N. D. Chichirova^a, A. A. Filimonova^{a, *}, A. I. Minibaev^a, and R. V. Buskin^a

^a*Kazan State Power Engineering University, Kazan, 420066 Russia*

**e-mail: aachichirova@mail.ru*

Received July 16, 2018; revised December 20, 2018; accepted December 20, 2018

Abstract—An analysis of water utilization systems at thermal power plants (TPPs) shows that highly mineralized effluent waters are mainly generated at these facilities by their water-treatment plants. Highly mineralized alkali liquid waste is presented by the products from continuous and periodic blowdowns of thermal demineralization systems and drum boilers, by spent anion exchange filter regeneration solutions, and by alkali concentrates from reverse osmosis plants. In view of the fact that the alkali used in technological processes has quite a high cost, it is economically expedient to subject alkali effluents to processing with the extraction of alkali for repeatedly using it in the production cycle. The article presents the results obtained at a TPP from experimental investigations into processing of highly mineralized alkali–salt solutions by means of electromembrane technology. The experimental investigations were carried out using the EMA-100 laboratory electromembrane apparatus and included two series of tests: a sequential diffusion–dialysis extraction with concentration by electrodialysis and a single-stage concentration by electrodialysis. As a result, a concentrated alkali solution and partially demineralized softened water were obtained. An analysis of the qualitative and quantitative compositions of the obtained products has shown the effectiveness of the proposed electromembrane processing arrangements, because an alkali solution suitable for its repeated use in the TPP water-treatment cycle was obtained in both series of tests. However, it should be borne in mind that single-stage concentration by electrodialysis is a more economically efficient and simple method, which provides high throughput and yields solutions containing satisfactorily separated alkali and salt components.

Keywords: thermal power plant, electromembrane technologies, electrodialysis separation, recycling of highly mineralized alkali solutions