
Contents

Vol. 66, No. 12, 2019

Happy New Year, Dear Readers!

General Subjects of Power Engineering

Distributed Generation of Electricity and Sustainable Regional Growth

S. P. Filippov, M. D. Dilman, and P. V. Ilyushin

Heat and Mass Transfer and Properties of Working Fluids and Materials

A Review of Modern Methods for Enhancing Nucleate Boiling Heat Transfer

A. V. Dedov

Two Phase Flows: Hydrodynamics and Heat-and-Mass Transfer
(Based on the Materials of IHTC-16 and RNKT-7 Conferences)

B. G. Pokusaev and D. A. Nekrasov

Numerical Simulation of Steam Condensation in a Steam-Gas Mixture Flow
in a Variable-Section Channel with a Bundle of Smooth Horizontal Tubes

K. B. Minko, V. I. Artemov, G. G. Yan'kov, and V. S. Krylov

Experimental Studies on the Distribution of Air Flows in Air Vapor Condensers

O. O. Mil'man, A. V. Kondrat'ev, A. V. Ptakhin, and M. O. Korlyakova

Energy Saving, New and Renewable Energy Sources

Enhancing the Efficiency of Small-Scale and Microhydroturbines Using Nature-Imitation
Technologies for the Development of Autonomous Energy Sources

*A. A. Druzhinin, E. S. Orlova, A. V. Volkov, A. G. Parygin, A. V. Naumov, A. V. Ryzhenkov,
A. A. Vikhlyantsev, J. Šoukal, M. Sedlař, M. Komárek, F. Pochylý, P. Rudolf, and S. Fialová*

Nuclear Power Plants

Cross-Verification of 1D and 3D Models for a VVER-1000 Reactor's Pressure Chamber Simulated
by the KORSAR/CFD Computation Code in the Modes with Asymmetric Loop Operation

Yu. V. Yudov, I. G. Petkevich, and V. G. Artemov

*Дорогие авторы, рецензенты и читатели журнала “Теплоэнергетика”!
От всей души поздравляем вас
с Новым 2020 годом!*

За прошедший год журнал существенно улучшил свои показатели в международной наукометрической базе данных Scopus и сохранил лидирующее место по тематике “Энергетика” в рейтинге SCIENCE INDEX.

В 2020 г. мы продолжим работу, направленную на укрепление позиций журнала как в России, так и за рубежом. Планируем расширить тематическую направленность журнала, так как журнал уже давно перешагнул границы “чистой” теплоэнергетики; увеличить количество публикаций, поступивших от зарубежных авторов; оперативно освещать результаты исследований, проводимых в различных научных, проектных и учебных организациях. Рассчитываем на вашу всестороннюю поддержку в решении этих довольно непростых задач.

Хочется отметить, что 2020 г. станет годом 100-летнего юбилея Государственного плана электрификации России (ГОЭЛРО), одобренного VIII Всероссийским съездом Советов в 1920 г. Этот план стал первым перспективным планом развития энергетики, реализованным в нашей стране. Мы планируем разместить на страницах журнала материалы, посвященные этому знаменательному событию.

Желаем Вам в Новом году больших творческих успехов, ярких впечатлений, приятных встреч, искренних улыбок, исполнения желаний. Пусть 2020 г. откроет новые горизонты в вашей жизни и наполнит ее множеством удивительных сюрпризов! Счастья, любви, благополучия Вам и всем Вашим родным и близким!

*С наилучшими пожеланиями,
Редакционная коллегия,
редакция журнала “Теплоэнергетика”*

Distributed Generation of Electricity and Sustainable Regional Growth

S. P. Filippov^{a,*}, M. D. Dilman^a, and P. V. Ilyushin^b

^a*Institute of Energy Research, Russian Academy of Sciences, Moscow, 117186 Russia*

^b*St. Petersburg Institute for Advanced Training in Energy, St. Petersburg, 196135 Russia*

**e-mail: fil@eriras.ru*

Received May 27, 2019; revised May 27, 2019; accepted May 29, 2019

Abstract—The rather high distributed generation (DG) ramp-up observed in the world is largely associated with the progress in low-power generation technologies and the measure of state support for renewable energy sources. Distributed generation delivers sustainable development of low electricity demand areas where centralized power supply is too expensive. In Russia, the installed electrical capacity of DG has reached 37 GW and its contribution to the country's electric power industry turns out to be very significant: approximately 13.7%. Moreover, more than half of the available facilities are used as stand-by, peak-load, and seasonal sources of electricity. The technological basis of the DG in the country is thermal power plants. The article considers in detail the possible options for operating DG plants. It is shown that the priority areas for the DG application are areas with low density of electrical loads, including rural and low population areas. The presence of infrastructural restrictions for connecting new consumers to the electrical network favors the use of DG in the centralized power supply zone as well. Prospects for the further DG application in the world are associated with the development of renewable energy and the improvement of electrochemical technologies, primarily electricity storage devices. In Russia, apparently, DG technologies based on fossil fuels will prevail for a long time. The country's great demand for thermal energy will contribute to the widespread use of co-generation plants. A significant reserve for DG development is the reconstruction of the country's numerous gas boilers in small CHP plants with a potential of 41 GW of electrical capacity.

Keywords: distributed generation, sustainable development, electric network, microgrid, electric power system, electric load, electrical generating plant, renewable energy sources, power demand density

A Review of Modern Methods for Enhancing Nucleate Boiling Heat Transfer

A. V. Dedov*

National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

**e-mail: dedovav@mpei.ru*

Received April 22, 2019; revised June 11, 2019; accepted June 26, 2019

Abstract—The main results obtained for the last decade in studying the possibilities of enhancing boiling heat transfer and increasing critical heat fluxes are reviewed. Heat transfer enhancement methods involving the use of a modified/structured boiling surface obtained by means of mechanized processing, electrochemical technologies, plasma and ion deposition, laser emission, and subcooled liquid boiling are considered.

Keywords: nucleate boiling, enhancement, critical heat fluxes, surface roughness, nanoliquids, nucleation sites, wettability, temperature drop, convection, evaporation

Two Phase Flows: Hydrodynamics and Heat-and-Mass Transfer (Based on the Materials of IHTC-16 and RNKT-7 Conferences)

B. G. Pokusaev^a and D. A. Nekrasov^{a, *}

^a*Moscow Polytechnic University, Moscow, 107023 Russia*

^{*}*e-mail: nekrasov55@yandex.ru*

Received March 25, 2019; revised May 7, 2019; accepted May 29, 2019

Abstract—A review of the results from experimental and theoretical studies on fundamental, scientific, technical, and applied orientation are presented for two-phase flows with different structures according to materials of two significant and already traditional scientific forums: the Russian National Conference on Heat Transfer (RNKT-7) and the International Heat Transfer Conference (IHTC 16). Particular attention therein was paid to the classification of gas-liquid and vapor-liquid flows, bubble flows, gas-droplet and gas-dust (gas + solid particles) structures, and plotting flow-pattern diagrams for flowing both in the channels of traditional shape and size and in minichannels of a capillary type. Problems are considered concerning the hydrodynamics and heat-and-mass transfer, increasing heat-transfer efficiency under cooling heated solid surfaces by impact jets. Modern noncontact optical experimental methods for measuring the local characteristics of flows are described in detail, which make it possible to determine, for example, phase slip coefficients, local gas (vapor) content, liquid film thickness, especially in the areas of triple phase contact, etc. Theoretical approaches are also considered wherein analytical and numerical methods are used to describe the stability of bubble and film flows, cavitation phenomena, acoustics, and the gas dynamics of two-phase flows, including gas + solid particles. A significant number of reports are devoted to the urgent problems of power engineering, chemical technologies, studies on heat-and-mass transfer in cooling towers, cryogenic equipment under regasification, absorbers, jet cooling systems for heat-transfer surfaces, snow generators, and ultra-modern and highly efficient capillary-type heat exchangers.

Keywords: multiphase flows, hydrodynamics, heat-and-mass transfer, experimental methods, numerical simulation

Numerical Simulation of Steam Condensation in a Steam-Gas Mixture Flow in a Variable-Section Channel with a Bundle of Smooth Horizontal Tubes

K. B. Minko^{a, b, *}, V. I. Artemov^{a, b}, G. G. Yan'kov^{a, b}, and V. S. Krylov^{a, c}

^a*Tsiolkovsky Kaluga State University, Kaluga, 248023 Russia*

^b*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^c*ZAO Turbokon Research and Production Implementation Enterprise, Kaluga, 248010 Russia*

**e-mail: minkokb@gmail.com*

Received May 28, 2019; revised June 11, 2019; accepted June 26, 2019

Abstract—In this paper, the results from calculations of heat and mass transfer in a variable-cross-section channel with a bundle of smooth horizontal tubes, on the surface of which steam from a moving steam-gas mixture (SGM) condenses, are presented. The decrease in the channel's cross section and, accordingly, the number of tubes in the vertical rows along the SGM movement provides the mixture with approximately constant velocity as the steam condenses. The mathematical model used in this study is described in detail in our previous publications. The two-dimensional equations of single-phase hydrodynamics, energy, and diffusion are solved for the external SGM flow. The condensation process is modeled at the level of the boundary conditions on the tube surface, taking into account a moving laminar condensate film. The heat transfer through the tube wall from the film to the cooling water is described using a one-dimensional model of the wall. To account for the irrigation of the bundle's lower tubes with condensate formed on the upper tubes, a simplified model is used. The data on the velocity fields and impurity concentration in the condenser and the heat transfer characteristics are presented. The calculation results of the heat transfer coefficients on the tubes of the first vertical row of the bundle and the heat transfer coefficients for individual sections of the simulated condenser containing several tube rows at a 0–8.5% volume fraction of air in the SGM at the inlet to the apparatus are compared with experimental data. A quite satisfactory agreement between the calculated and experimental data is obtained, which confirms the efficiency of the used model. The calculated data on the local velocity fields and the composition of the steam-air mixture indicate a significant heterogeneity of these characteristics. This complicates the development of relatively simple engineering methods for calculating the heat load of condensers at high air concentrations. The calculations were performed using our developed ANES CFD code.

Keywords: condensation, steam-gas mixture, forced flow, horizontal tube bundle, mathematical modeling, heat transfer coefficients

Experimental Studies on the Distribution of Air Flows in Air Vapor Condensers

O. O. Mil'man^{a, b, *}, A. V. Kondrat'ev^{a, b}, A. V. Ptakhin^{a, b}, and M. O. Korlyakova^c

^aZAO Turbokon Research and Production Implementation Enterprise, Kaluga, 248010 Russia

^bTsiolkovsky Kaluga State University, Kaluga, 248023 Russia

^cKaluga Branch, Bauman Moscow State Technical University, Kaluga, 248000 Russia

*e-mail: turbocon@kaluga.ru

Received April 22, 2019; revised May 28, 2019; accepted May 29, 2019

Abstract—The uniformity degree of the air distribution over the heat-exchange surface of an air condenser (AC) plays an important role since it determines the efficiency of this surface's usage. In this paper, this factor at a special stand, where all the main processes of an air flow were simulated, is studied. The typical design of the tent AC was chosen as the basis for the study. Two AC models differing from one another by the presence of a diffuser after the fan were studied. Each of the models was tested in two versions: with a low-speed electric motor and a high-speed electric motor with a gearbox. In the AC models, heat transfer surfaces were simulated by a set of flat metal grids with a uniform distribution of square cells. The aerodynamic drag of a set of grids was preliminarily selected so that the Euler criteria were equal for the full-scale object and model. During the tests, the air velocities in front of and behind the grids were measured by traversing, and the velocity fields (isotachs) of the cooling air in these sections were plotted. A condenser with a low-speed electric motor provides the most uniform distribution of cooling air over the heat-exchange surface, while condensers with a high-speed electric motor and gearbox and with a diffuser have significantly greater irregularity in the air supply. During the “suction” operation, the flow distribution is more uniform but worse than that for the version with a low-speed electric motor. The effect of the nonuniform velocity field of cooling air on the heat transfer of AC is estimated. The real capacitor module was calculated for various flow and velocity distributions along the tube length. Losses of heat removal due to the nonuniformity of the air flow of the considered circuits can be estimated within 1–3% at a $\pm 50\%$ deviation of the flow rate from the average value.

Keywords: air condenser, heat transfer, irregularity, velocity field, hydraulic resistance, pressure loss, dry cooler, diffuser

Enhancing the Efficiency of Small-Scale and Microhydropower Turbines Using Nature-Imitation Technologies for the Development of Autonomous Energy Sources

A. A. Druzhinin^a, E. S. Orlova^a, A. V. Volkov^{a, *}, A. G. Parygin^a, A. V. Naumov^a,
A. V. Ryzhenkov^a, A. A. Vikhlyantsev^a, J. Šoukal^{b, **}, M. Sedlař^b, M. Komárek^b,
F. Pochylý^c, P. Rudolf^{c, ***}, and S. Fialová^c

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b Sigma Centrum hydraulického výzkumu spol. s r.o., Lutín, 783 49 Česká republika

^c Vysoké učení technické v Brně, Brno, 601 90 Česká republika

*e-mail: volkovav@mpei.ru,

**e-mail: v.liskova@sigma.cz

***e-mail: rudolf@fme.vutbr.cz

Received May 29, 2019; revised June 11, 2019; accepted June 26, 2019

Abstract—The issues of developing small-scale and microhydropower generation under present-day conditions as one of the renewable energy sources that do not aggravate environmental problems are considered. Some of the most effective approaches to designing microhydropower plants and small-scale and microhydropower turbines that meet the environmental friendliness and high-energy efficiency requirements are outlined. The results of a computational study of a microturbine prototype with a blade system modified according to a principle of biomimetics (nature-imitation technologies) have been validated experimentally. Two modified configurations of the blade system are considered and compared with the original version under identical conditions. To increase the reliability of the findings, the experiment with the original and modified impellers of the microhydropower turbine was repeatedly conducted. The energy characteristics of a microhydropower turbine based on experimental data that demonstrate the best repeatability with an error not exceeding 10% are presented. Based on the calculated and experimental data, a comparative assessment of the turbine's energy characteristics with the original and modified impellers is made. It has been established that the use of the so-called “growths” on the entrance edge of the impeller blades contributes to streamlining the flow pattern in the interblade channel. This, in turn, leads to a decrease in hydraulic drag and, consequently, to a decrease in hydraulic losses when flowing around the blade system. As shown by quantitative assessment of the energy characteristics, the energy efficiency of a microhydropower turbine is increased by 20%, which proves the viability of the chosen direction for developing smallscale and microhydropower generation as well as the effectiveness of the approaches used in the design of the working bodies of microhydropower turbines. Further ways of improving the approaches under study and obtaining new developments in this field of hydropower generation are scheduled and set forth.

Keywords: energy saving, energy efficiency, environmentally friendly technologies, hydropower generation, microhydropower turbine, blade system, nature-imitation technologies, biomimicry, biomimetics

Cross-Verification of 1D and 3D Models for a VVER-1000 Reactor's Pressure Chamber Simulated by the KORSAR/CFD Computation Code in the Modes with Asymmetric Loop Operation

Yu. V. Yudov^{a,*}, I. G. Petkevich^b, and V. G. Artemov^a

^a*Aleksandrov Scientific Research Institute of Technology, Sosnovy Bor, Leningrad oblast, 188540 Russia*

^b*Gidropress, Podolsk, Moscow oblast, 142103 Russia*

**e-mail: yudov@niti.ru*

Received March 13, 2019; revised May 7, 2019; accepted May 29, 2019

Abstract—The KORSAR/CFD code results from the development of the KORSAR/GP system code certified in 2009 by the Rostekhnadzor (Federal Service for Ecological, Technological, and Nuclear Supervision) as applied to the calculated justification of the safety for VVER reactors. One of the important aspects of the development consists in the introduction of the CFD-module code into functional content for the simulation of spatial turbulent flows in the mixing chambers of reactors using a nested boundary method in the RANS-approximation. The CFD module is combined with a 1D model according to a semi-implicit scheme as a standard code element. Based on the calculations performed for three modes with an asymmetrical equipment operation in the heat-transfer loops of the VVER-1000 reactor, cross-verification has been performed for a 3D model in the CFD approximation, and a quasi-3D-multichannel model of the KORSAR/CFD computation code for the reactor pressure chamber. For cross-verification, the following modes have been chosen: breaking steam pipeline in a steam generator, connecting the main circulation pump while initially operating three pumps at the reactor power of 71% with respect to the nominal value, connecting a pump while initially operating two opposite pumps at the reactor power of 52% with respect to the nominal value. The scenario of the chosen modes is characterized by a decrease in the heat-carrier temperature at the entry into the pressure chamber from a single loop, which leads to an asymmetric increase in the reactor power with respect to the fuel assemblies owing to a negative reactivity effect. It is shown that, because of the artificial increase in the resistance to the downward heat-carrier flow along the channels that represent a pressure chamber in the multichannel calculation scheme, the reproduction of a spatial in-chamber flow pattern obtained using the 3D model of the chamber and its effect exerted on temperature change in the course of the heat-carrier stirring have been gained. The results of calculation using this scheme are in good agreement with data obtained by means of the 3D simulation of the pressure chamber in the CFD approximation in all the considered modes. A sensitivity of the calculation results with respect to changes in the calculation scheme under using the quasi-3D multichannel model of the reactor chamber is demonstrated.

Keywords: reactor unit, thermohydraulics, 1D model, 3D model, cross-verification