
Contents

Vol. 67, No. 1, 2020

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

An Overview on Generation and Suppression of NO_x and N₂O Emissions
in the Oxy-Fuel Combustion Process with Recycled CO₂

*Khalid El Sheikh, G. A. Ryabov, Mahar Diana Hamid,
T. V. Bukharkina, and Mohamad Azlan Hussain*

5

Experience of Burning Sunflower Husks in the Kumertau CHP Pulverized Coal-Fired Boilers

D. V. Sosin, D. S. Litun, I. A. Ryzhii, A. V. Shtegman, and N. A. Shaposhnikov

15

Nuclear Power Plants

Thermodynamic Analysis of the Existing Forms of Iron Oxides
in Neutral Oxygen-Containing Aqueous Media of the NPP Power-Generating Units

N. L. Kharitonova and V. F. Tyapkov

23

Steam Turbine, Gas Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Diagnostics of Shaft Trains of Large Turbine Sets for Integrity
using Torsional Vibration Measurements

A. L. Nazolin, V. I. Polyakov, and S. G. Gnezdilov

32

Heat and Mass Transfer and Properties of Working Fluids and Materials

Heat Transfer Enhancement in the Fields of Mass Forces, Pressure Gradients,
Velocity Fluctuations, and Impinging Jets

*A. V. Ilinkov, A. V. Shchukin, V. V. Takmoltsev, I. I. Khabibullin,
I. Sh. Zaripov, and D. I. Enizerkin*

44

Automation and Heat Control in Power Engineering

Controlling the Superheated Steam Temperature during Buffer Consumption
of Gaseous Production Waste through Adjusting the Injection and Flame Position

V. F. Kuzishchin and S. K. Ismatkhodzhaev

53

A Combined Discrete-and-Continuous Multipoint Model of a Countercurrent Heat Exchanger

G. A. Pikin, T. S. Nguen, and F. F. Pashchenko

63

Metals and Strength Analysis

The Influence of Wet-Steam Flow Electrization on the Surface Strength
of Turbine Blade Materials

A. A. Tarelin, N. V. Surdu, and A. V. Nechaev

72

Water Treatment and Water Chemistry

Studying the Efficiency of Inhibitors in Chemical Cleaning of Heat-and-Power Equipment by Citric Acid Solutions

R. T. Burganov, A. R. Gilmullina, M. A. Kirilova, and E. A. Kovrizhnykh

82

Evaluating Deposit Formation of Iron-Corrosion Products in High- and Low-Pressure Evaporative Circuits When Starting a Combined-Cycle Plant

T. I. Petrova, O. V. Egoshina, V. N. Voronov, and Yu. V. Isaeva

87

An Overview on Generation and Suppression of NO_x and N₂O Emissions in the Oxy-Fuel Combustion Process with Recycled CO₂

Khalid El Sheikh^{a, c}, G. A. Ryabov^{b, *}, Mahar Diana Hamid^c,
T. V. Bukharkina^a, and Mohmad Azlan Hussain^c

^a*Mendeleeev University of Chemical Technology of Russia, Moscow, 125047 Russia*

^b*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

^c*University of Malaya, Kuala Lumpur, 50603, Malaysia*

**e-mail: GARyabov@vti.ru*

Received March 18, 2019; revised May 27, 2019; accepted May 29, 2019

Abstract—It is shown that combustion of solid fuels in an oxygen atmosphere with recycled flue gases is an efficient method for capture of CO₂. The use of the circulating fluidized bed (CFB) technology in the oxy-fuel combustion process reduces the CO₂ capture costs and nitrogen oxide emissions compared with flare combustion. The mechanisms of generation and suppression of nitrogen and nitrous oxides during CFB combustion of solid fuels are considered. The basic reactions that occur during the exit and burning of volatiles and combustion of char resulting in generation of NO, N₂O, and N₂ are indicated. The effect of the secondary air delivery on nitrogen oxide emissions is studied. It is shown that the degree of converting fuel nitrogen into N₂O is reduced when the degree of converting nitrogen into NO_x is increased. Comparative analysis that the effect of flue gas recycling and other process factors has on generation of NO and N₂O during combustion in air, oxygen, and CO₂ has been made. It is shown that, owing to recycling, the fractions of NO_x and N₂O generated from fuel nitrogen during oxy-fuel combustion are significantly lower than those during combustion in air. Mathematical simulation of various complicated processes related to generation and suppression of hazardous pollutant emissions has recently become a generally accepted method that allows the prediction at relatively low costs of such processes during the combustion of various fuels. However, as applied to new technologies for combustion of various biomass types and cofiring of coal and biomass, these methods have not yet been properly developed. The most preferable mathematical models for calculating nitrogen oxide emissions are provided, and the predicted results are compared with experimental data. The lines of further research, predominantly in the simulation of cofiring of coal and biomass, are outlined. It is shown that comprehensive investigations of generation and suppression of hazardous pollutant emissions during cofiring of coals and biomass of various kinds, in particular, during oxy-fuel combustion with recycled CO₂ are of topical interest.

Keywords: oxy-fuel combustion, circulating fluidized bed, nitrogen oxides, biomass, cofiring, mathematical simulation

Experience of Burning Sunflower Husks in the Kumertau CHP Pulverized Coal-Fired Boilers

D. V. Sosin^{a,*}, D. S. Litun^a, I. A. Ryzhii^a, A. V. Shtegman^a, and N. A. Shaposhnikov^b

^aAll-Russia Thermal Engineering Institute, Moscow, 115280 Russia

^bKumertau TPP, Branch of AO "SEGC", Kumertau, Republic of Bashkortostan, 453300 Russia

*e-mail: Sosin_work@mail.ru

Received May 20, 2019; revised May 29, 2019; accepted May 29, 2019

Abstract—One of the TPP's electricity cost price components is the fuel cost. An increase in the performance of TPPs is possible by using cheaper alternative coal, the main characteristics of which are close to those of standard quality coal. Recently, there has been a tendency for using other types of coal and nonstandard types of fuel in pulverized coal-fired boilers. Thermal power plants in Finland, France, and Denmark use wood raw-material and paper waste, as well as other biofuels, to generate electricity. The simplest and least costly way of cofiring coal and biomass is to mix them and then feed them into the furnace of a pulverized coal-fired, dry-bottom boiler. In this way, it is possible to burn approximately 5% of biomass in the mixture. In cyclone-furnace boilers, it is possible to burn at least approximately 20% of biomass; however, this will require significant boiler reconstruction. In grate stokers, 100% of the biomass can be burned, but fluidized bed combustion is only suitable for small TPPs. In Russia, oil extraction waste, namely sunflower husks, can be used as biofuel in the form of pellets. The article discusses the experience of burning nonconventional solid fuels in pulverized coal-fired boilers, the advantages and disadvantages of this type fuel, and the problems of arising in its utilization.

Keywords: boiler, pulverized coal-fired burning, alternative fuel, sunflower husks, pilot burning, ligneous coal, burner, boiler efficiency, coal pulverization system, fuel efficiency

Thermodynamic Analysis of the Existing Forms of Iron Oxides in Neutral Oxygen-Containing Aqueous Media of the NPP Power-Generating Units

N. L. Kharitonova^{a,*} and V. F. Tyapkov^{b,**}

^a*Scientific and Engineering Center for Nuclear and Radiation Safety, Moscow, 107140 Russia*

^b*All-Russia Research Institute for Operation of Nuclear Power Plants, Moscow, 109507 Russia*

**e-mail: kharitonova@secnrs.ru*

***e-mail: VFTiapkov@vniiaes.ru*

Received June 11, 2019; revised June 26, 2019; accepted June 26, 2019

Abstract—Foreign and domestic software products designed for quantitative description of the erosive–corrosive wear (ECW) rate and modeling erosion–corrosion use physicochemical computational models based on the assumption that the oxide film that protects the surface of steel consists of magnetite. Investigations of the phase composition and structural characteristics of oxide films on the inner surfaces of pipelines and equipment of coolant-circulation circuits of the NPP power-generating units with RBMK high-power channel-type reactors or the third circuits of the BN-800 fast reactors in which correction-free or oxygenated water chemistry conditions are implemented have revealed the presence on the steels’ surface of not only magnetite but also other iron oxide forms. At present, the presence of the forms of iron oxides and hydroxides other than magnetite is considered in the computational modeling of the ECW by the introduction of empirical dependences. In the work, thermodynamic analysis of the existence forms of solid iron oxide and hydroxide phases in contact with the aqueous coolant in neutral oxygen-containing solutions has been made for temperatures of 25–200°C. To solve the problem set, the method of minimization of free energies of the system was used that allows one to determine which of the solid phases—iron oxides or hydroxides—will be thermodynamically stable in aqueous process media. On the assumption that the free energy of a system is minimal in the equilibrium state, the method allows determining the composition of the solid phase that is thermodynamically stable under the given conditions. The dependence of the phase composition of the oxide film on the temperature and chemical composition of the aqueous medium in contact with the oxide in question is shown. It is suggested to use the calculated results for refining the physicochemical models of the dependence of the ECW on the temperature for estimation of changes in the solubility of the iron oxides on the temperature and the thermodynamic stability regions of the basic phases in which iron oxides exist in the presence of oxygen and hydrogen.

Keywords: nuclear power plants, water chemistry, erosion–corrosion, solubility, erosive–corrosive wear, iron oxides, magnetite, hematite, lepidocrocite

Diagnostics of Shaft Trains of Large Turbine Sets for Integrity using Torsional Vibration Measurements

A. L. Nazolin^{a, b, c, *}, V. I. Polyakov^c, and S. G. Gnezdilov^a

^a*Bauman Moscow State Technical University (BMSTU), Moscow, 105005 Russia*

^b*Blagonravov Mechanical Engineering Research Institute, Russian Academy of Sciences (IMASH RAS), Moscow, 101990 Russia*

^c*Resurs Research and Engineering Center, Moscow, 105043 Russia*

^{*}*e-mail: nazolin72@mail.ru*

Received April 26, 2019; revised June 26, 2019; accepted June 26, 2019.

Abstract—A promising solution to the problem of early detection for the growth of fatigue cracks in shaft trains of large turbine units at nuclear and thermal power stations based on the results of torsional vibration monitoring by the method of time intervals is considered. It has been demonstrated in the laboratory that this method enables us to detect the growth of fatigue cracks in the shafts of rotor systems from a decrease in the value on natural frequencies of torsional oscillations. However, attempts to use it in the industry were not so successful due to a slight influence of fatigue cracks on the values of the natural frequencies of torsional oscillations as compared with the effect of other factors. Nevertheless, the data obtained in the study of torsional oscillations of the shaft train in a turbine installation of an operating 300-MW power unit using a high-precision optoelectronic monitoring system enabled the establishment and consideration of the effect that the turbine operating conditions has on the natural frequencies of torsional oscillations for the first time. A modal finite-element analysis of the turbine installation shaft train's most dangerous annular fatigue crack, which cannot be detected at an early stage of development using standard or special vibration-monitoring systems during steady state operation of the turbine installation, has been performed. The analysis yielded the dependence of the torsional natural frequencies on the cross-sectional area and location of the fatigue crack. Monitoring of fatigue crack development has been demonstrated to be performed by measuring the natural frequencies of torsional oscillations (or vibrations) during steady state operation of the turbine set considering the effect of its operating conditions.

Keywords: turbine set, shaft train, fatigue crack, time interval method, torsional oscillations, natural frequency, operating conditions

Heat Transfer Enhancement in the Fields of Mass Forces, Pressure Gradients, Velocity Fluctuations, and Impinging Jets

A. V. Ilinkov^a, A. V. Shchukin^{a, *}, V. V. Takmoytsev^a, I. I. Khabibullin^{a, **},
I. Sh. Zaripov^a, and D. I. Enizerkin^a

^a*Tupolev Kazan Research Technical University (KAI), Kazan, 420111 Russia*

**e-mail: a.v.shchukin@rambler.ru*

***e-mail: rim3li490@mail.ru*

Received February 11, 2019; revised June 26, 2019; accepted June 26, 2019

Abstract—Results are discussed of the experimental investigations into the effect of mass forces, longitudinal pressure gradient, and other factors on convective heat transfer enhancement in a turbulent flow. Heat transfer intensifiers include protrusions on and dimples in a heat transfer surface. It has been demonstrated that, depending on the intensifier type, the affecting factors have different effects on the convective heat transfer. The investigated combinations of affecting factors and intensifiers yield enhancement, deterioration, or no change in heat transfer. In a flow over concave or convex surfaces of moderate curvature with semispherical dimples, the centrifugal mass forces have the same effect on heat transfer as they do in the flow over smooth curvilinear surfaces. At the same time, in a flow over concave or convex surfaces with semispherical protrusions or transverse ribs, the mass forces do not affect the heat transfer. The investigation of the effect of a streamwise pressure gradient in a separation flow over spherical dimples has demonstrated that relaxation processes in the return flow in a spherical dimple results in a change in the of heat transfer rate opposite in sign compared to the effect pressure gradient in a flow without heat transfer intensifiers. It has been established that with the same relative dimensions of dimples and the same experimental conditions, the array of diffuser-type dimples can enhance heat transfer by a factor of 1.4 as compared with heat transfer in a flow over dimples with separation. The same heat transfer augmentation can be obtained in the array of spherical dimples from the imposition of periodic velocity fluctuations on a turbulent flow. It is shown that calculation of heat transfer for a flow over a surface with heat transfer intensifiers under the effect of disturbing factors sometimes requires correction to the used correlations that consider the effect of these factors.

Keywords: heat transfer enhancement, affecting factors, heat exchanger, gas-turbine engine cooling system, vortex structures, turbine blade, heat transfer, hydraulic resistance, near-wall intensifier

Controlling the Superheated Steam Temperature during Buffer Consumption of Gaseous Production Waste through Adjusting the Injection and Flame Position

V. F. Kuzishchin^{a,*} and S. K. Ismatkhodzhaev^{b,**}

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*Institute of Power Engineering and Automatics, Academy of Sciences of the Republic of Uzbekistan, Tashkent, 700143 Uzbekistan*

**e-mail: Kuzishchinv@yandex.ru*

***e-mail: isk1934@mail.ru*

Received May 6, 2019; revised June 23, 2019; accepted June 26, 2019

Abstract—The article considers the possibility of achieving more efficient performance of a TP-13B industrial steam boiler fitted with a spray desuperheater and operating in the mode of buffer consumption of blast-furnace gas as applied to the superheated steam temperature automatic closed-loop control system. The main problem stems from the fact that the superheated steam temperature increases essentially due to large blast-furnace gas flowrates and displacement of the flame when shifting to operation with a large fraction of blast-furnace gas (with respect to the natural gas fraction). The usual injection adjustment range turns out to be insufficient for stabilizing the steam temperature downstream of the second-stage convection steam superheater (CSS₂). In addition, the steam temperature downstream of the first-stage convection steam superheater (CSS₁) increases significantly, because this section is not protected by injections. For solving the problem, it is proposed to use a combined system, which uses, in addition to the conventional steam temperature controller downstream of the CSS₂, which adjusts the injection, a controller of steam temperature downstream of the CSS₁, which adjusts the flame position by turning the air-control registers. With the steam temperature downstream of the CSS₁ stabilized by adjusting the air-control registers, it becomes possible to pose less demanding requirements to the injections; in addition, with such stabilization, the CSS₁ metal is protected from overheating. This is an advantage in comparison with the well-known arrangement in which such control is only performed when the injection valve position approaches the specified limit values. The functional and structural diagrams of the proposed control system are given. The parameters of the plant model channels' transfer functions are determined proceeding from the known experimental data for the TP-13B boiler. The system has been studied by carrying out computations in the environment of the MathCad software system and the MatLab/Simulink modular simulation software package. The simulation model includes nonlinearities typical for the automation equipment used in thermal power engineering. The effectiveness of the proposed combined control system during operation with essential variations of the blast-furnace gas flowrate has been demonstrated. The information presented in the article can be used in fitting the industrial steam boilers operating with buffer consumption of gaseous production waste with means for automatic control of superheated steam temperature.

Keywords: automatic closed-loop control system, steam boiler, blast-furnace gas, steam superheater, steam temperature, injection, burners, air-control registers

A Combined Discrete-and-Continuous Multipoint Model of a Countercurrent Heat Exchanger

G. A. Pikina^{a, c, *}, T. S. Nguen^{b, **}, and F. F. Pashchenko^{c, d, ***}

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bHanoi University of Science and Technology, Hanoi, Vietnam

^cTrapeznikov Institute for Control Sciences, Russian Academy of Sciences, Moscow, 117997 Russia

^dMoscow Physicotechnical Institute, Dolgoprudnyi, 141701 Russia

*e-mail: PikinaGA@mail.ru

**e-mail: tiensang.mpei@gmail.com

***e-mail: pif-70@yandex.ru

Received February 28, 2019; revised April 8, 2019; accepted June 26, 2019

Abstract—The article addresses matters concerned with developing the linear theory of constructing multipoint models intended for synthesizing automatic closed loop control systems of thermal power facilities. The multipoint approximation models are oriented at solving practical problems to an extent greater than the models with distributed parameters. The transfer functions of multipoint linear models can be obtained using the signal graph method; however, this method is not always suitable for being used without additional simplifications, in particular, the assumption about “independent heating.” In this study, for obtaining the dynamic characteristics of countercurrent heat exchangers involving longitudinal motion of coolants, it is proposed to use the discrete-continuous Laplace transform method. The method is developed taking the boiler economizer as an example. The article shows the way in which a shift can be made to the process circuit with longitudinal countercurrent motion by using the method of decomposing the economizer surface with cross flow of coolants into segments. Analytical expressions for the model’s transfer functions of an arbitrary order are obtained. Complex frequency responses for eight economizer channels are calculated. The characteristics of multipoint models and models with distributed parameters only for water and for both coolants are compared with each other. Recommendations for selecting the minimally admissible order depending on the input disturbance kind are given. The possibility of using a model with lumped parameters for the external coolant is revealed. It is shown that simplification of the external coolant model down to the first order has hardly any effect on the characteristics of only the internal coolant’s two temperature channels connected with its own input actions in terms of flowrate and temperature. However, such simplification cannot be applied for the remaining six channels.

Keywords: multipoint models, discrete-continuous Laplace transform, countercurrent heat exchanger, model order

The Influence of Wet-Steam Flow Electrization on the Surface Strength of Turbine Blade Materials

A. A. Tarelin^{a,*}, N. V. Surdu^a, and A. V. Nechaev^a

^a*Podgorny Institute for Mechanical Engineering Problems, National Academy of Sciences of Ukraine, Kharkiv, 61046 Ukraine*

**e-mail: tarelin@ipmach.kharkov.ua*

Received April 22, 2019; revised May 30, 2019; accepted June 26, 2019

Abstract—The phenomenon of droplet impingement erosion of a wet-steam turbine’s last-stage blades is conditionally considered in the aspect of two “opposing” processes: the force impact of droplets on metal and “resistance” of the metal to this impact. The article places its focus on “resistance” of the metal surface layer to the force impact of the droplets condensing from electrified steam and on the influence of concomitant electro-physical phenomena on its mechanical properties. It has been established that the electrophysical phenomena accompanying wet-steam flow electrization facilitate saturation of the metal with hydrogen (6–10 times higher in comparison with a neutral flow) and have a significant effect on its microhardness (the changes toward its decreasing may be as much as 50%). These changes take place in a thin surface layer, and their extent and nature depend on the flow polarity and also on the frequency and polarity of the electric field induced on the turbine blade. The decrease of microhardness observed in the thin surface layer can be attributed to the phenomenon of local microplasticization, which occurs as a result of facilitating the incipience of microshears when hydrogen cations interact with the dislocation nuclei generated in introducing an indenter. Such plasticization at the microlevel facilitates the development of hydrogen brittleness at the macrolevel. It has been established that, as far as the maximal erosion-induced strength degradation of blade materials is concerned, a positively charged wet steam flow is the most dangerous factor, which most frequently takes place in the case of using water chemistry with $\text{pH} > 9$ (ammonia water chemistry). It is shown that it is possible to alter the development kinetics of destruction caused by droplet impingement erosion by changing the physicochemical properties of thin surface layers of metals.

Keywords: steam turbine, electrization, droplet impingement erosion, microhardness, hydrogen saturation, adsorption-plasticization effect

Studying the Efficiency of Inhibitors in Chemical Cleaning of Heat-and-Power Equipment by Citric Acid Solutions

R. T. Burganov^{a,*}, A. R. Gilmullina^a, M. A. Kirilova^a, and E. A. Kovrizhnykh^a

^aPAO Nizhnekamskneftekhim, Nizhnekamsk, Republic of Tatarstan, 423574 Russia

*e-mail: BurganovRT@nknh.ru

Received February 4, 2019; revised April 3, 2019; accepted June 26, 2019

Abstract—The results of laboratory studies concerning corrosion inhibitors that make it possible to decelerate the metal dissolution in heat-and-power equipment during its chemical cleaning are presented. The features of the decrease in the carbon steel corrosion rate using commonly known corrosion inhibitors, such as urotropin, captax, and thiourea, as well as an imported reagent based on alkylbenzene dimethylammonium chloride (hereinafter referred to as IK), are considered. An effect of the process temperature and the concentration of inhibitors exerted on their protective properties and the kinetics of metal corrosion is analyzed. In the first part of the paper, it is shown—based on the gravimetric method for corrosion testing—that the efficiency of captax, captax with neonol AF 9-12, thiourea (0.05 wt %), and reagent IK (0.2 wt %) at a temperature of 70–80°C for the protection of carbon steel from corrosion in a 5% solution of ammonium monocrylate amounts to 60–77%, which is higher than that with the use of urotropin. The high efficiency of inhibitors in the deceleration of steel corrosion in the 5% solution of ammonium monocrylate is caused by a strong inhibition of both electrode reactions of the metal. The results of corrosion tests using a polarization resistance technique are presented. Two parts of a decrease in the steel corrosion rate are clearly distinguished on the curves of an instantaneous corrosion rate. The decrease is caused by the formation of a protective film with the participation of an inhibitor and a subsequent stabilization of this film. The results of corrosion tests in the solutions of ammonium monocrylate with added inhibitors, such as captax, captax + AF 9-12, and reagent IK, that confirm the low instantaneous corrosion rate of carbon steel are discussed. These compositions could be used for chemical cleaning of heat-and-power equipment as well as for increasing its efficiency and reducing repair costs.

Keywords: chemical washing, acid corrosion, corrosion inhibitor, protective efficiency, corrosion rate, captax, citric acid

Evaluating Deposit Formation of Iron-Corrosion Products in High- and Low-Pressure Evaporative Circuits When Starting a Combined-Cycle Plant

T. I. Petrova^a, O. V. Egoshina^{a,*}, V. N. Voronov^a, and Yu. V. Isaeva^a

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: yegoshinaov@gmail.com

Received July 2, 2018; revised May 8, 2019; accepted May 29, 2019

Abstract—One of the main causes of equipment damage at TPPs is corrosion of structural materials and deposit formation on the heat-transfer surfaces of the steam-water tract. This process occurs during stationary operation of the equipment and during start-ups and shutdowns of the power unit. In this paper, we assess the deposit formation of corrosion products in the evaporative circuits during the start-up of a combined cycle plant with the subsequent prediction of the number of starts after which it is necessary to carry out a chemical washing of the boiler-utilizer. The changes in the product concentration of iron corrosion in water and steam when starting a 450-MW power unit from a cold state are shown. The probability for the deposit formation of iron-corrosion products is estimated based on the experimental data obtained at start-up, with the subsequent calculation of the material balance for iron-corrosion products for low- and high-pressure circuits. A comparative analysis of the probability for deposit formation of iron-corrosion products in the high- and low-pressure circuits during the start-up period and at nominal operating parameters is performed. As a result of studies, it was found that the iron concentration in the feed and boiler water and saturated steam of the high- and low-pressure circuit significantly exceeds the normalized values by the time when the boiler-utilizer reaches its operating parameters. The specific amount of iron-corrosion products that can be deposited on heat-transfer surfaces in one start for the low- and high-pressure circulation circuit is determined. To reduce the probability for deposits of corrosion products during start-up, it is proposed to use feed water with a lower iron concentration or to increase the purge of the boiler-utilizer. Recommendations on the shutdown of the boiler-utilizer for washing when the maximal specific deposit amount of 200 g/m² is reached taking into account the number of permissible starts for the low-pressure circuit are given.

Keywords: thermal power plants, combined-cycle plant, waste heat boiler, start-up of a power unit, water-chemical mode, chemical control, iron-corrosion products, deposits