

Contents

Vol. 67, No. 3, 2020

Energy Conservation, New and Renewable Energy Sources

Geothermal Heat Supply in Russia

V. A. Butuzov, R. A. Amerkhanov, and O. V. Grigorash

Steam Boilers, Power Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

A General-Purpose Procedure for the Calculation of the Optimum Gas Velocity
in Gas Exhaust Ducts of Stacks at Thermal Power Stations

N. A. Zroichikov, A. M. Gribkov, M. I. Saparov, and K. M. Mirsalikhov

Thermal Analysis of Coals from Kazakhstan Deposits

A. R. Bogomolov, I. Ya. Petrov, and U. K. Zhalmagambetova

Protective Oxidation of Boiler Equipment Heating Surfaces with Concurrently
Removing Ash Deposits

L. N. Moskvina, A. A. Efimov, and B. A. Gusev

Steam Turbine, Gas Turbine, Combined-Cycle Power Plants and Their Auxiliary Equipment

Optimization of Minimum Temperature Differences in the Steam Reheater of a Turbine
at a Nuclear Power Station

A. S. Shamarokov, V. M. Zorin, and S. V. Bosenko

Electrical Part of Thermal and Nuclear Power Plants

Improving the Performance of Transformer Oil Using Individual Sulfides

L. R. Gainulina and V. P. Tutubalina

Geothermal Heat Supply in Russia

V. A. Butuzov^{a, *}, R. A. Amerkhanov^a, and O. V. Grigorash^a

^a*Trubilin Kuban State Agrarian University, Krasnodar, 350044 Russia*

**e-mail: ets@nextmail.ru*

Received April 2, 2019; revised August 27, 2019; accepted August 28, 2019

Abstract—Geothermal heat supply occupies the second place among the renewable energy sources around the world in installed capacity (70.3 GW) and in the amount of generated thermal energy (163 (TW h)/year). It is outperformed only by solar heat supply (480 GW and 395 (TW h)/year). The use of geothermal heat involves the need to drill wells and fulfill special requirements for development of geothermal fields and construction of heat-supply systems. There are deep (more than 400-m deep) and shallow geothermal heat-supply systems (GHSSs). More than 66 geothermal fields have been explored in 11 regions of Russia, and the operating reserves total more than 300000 m³/day. The installed capacity of Russian GHSSs totals 310 MW. Differences between open- and closed-loop GHSSs are pointed out. For open-loop GHSSs, their typical process circuit arrangements implemented in Krasnodar krai and in the cities of Kizlyar and Makhachkala are presented. The GHSS process circuits with the use of heat pumps (HPs) for recovering the heat of spent geothermal water and systems operating in combination with solar units are considered. Systems that use highly mineralized geothermal heat carriers from different geological horizons with heating of sweet water, as well as GHSSs with pumpless circulation of heat carrier, are described. The article gives examples of GHSSs equipped with geothermal circulation systems (GCSs) implemented in the Khankala geothermal field in the city of Grozny, including the double GCS with the design capacity equal to 8.7 MW and the GCS in the Medvedevka settlement in the Dzhankoi raion of Crimea, a distinctive feature of which is that it uses wellhead methane for generating electricity and for additionally heating the heat carrier in the peaking modes of operation. In constructing open- and closed-loop surface GHSSs, heat pumps are commonly used. In the first case, the heat of underground or surface water bodies is used, while horizontal or vertical heat exchangers are applied in the second case. Examples of geothermal heat-supply systems are given: the surface GHSS in the city of Makhachkala, in which ground heat exchangers in combination with solar units are used, and the GHSS in the city of Krasnodar, which serves for heating an administrative building and for cooling it in summer. The key scientific-technical problems requiring further investigations and development for constructing efficient and competitive geothermal heat-supply systems in different regions of the country are formulated.

Keywords: geothermal heat supply, reinjection, heat pump, solar unit, geothermal well

A General-Purpose Procedure for the Calculation of the Optimum Gas Velocity in Gas Exhaust Ducts of Stacks at Thermal Power Stations

N. A. Zroichikov^{a, *}, A. M. Gribkov^{b, **}, M. I. Saparov^{a, ***}, and K. M. Mirsalikhov^{b, ****}

^a*Krzhizhanovskii Energy Research Institute, Moscow, 119991 Russia*

^b*Kazan State Power Engineering University, Kazan, 420066 Russia*

**e-mail: zna@eninnet.ru*

***e-mail: gribkovalmi@mail.ru*

****e-mail: saparov@eninnet.ru*

*****e-mail: mirsalihovkm@gmail.com*

Received July 15, 2019; revised September 25, 2019; accepted September 25, 2019

Abstract—The regulations on stack designs at thermal power stations (TPS) has been analyzed. It is demonstrated that the applicable guidelines do not consider all the actual problems encountered in designing stacks for TPSs, such as optimization of the stack construction cost and its effective operation. The stack cost depends on its height and diameter, which, at a given connected capacity, are affected by the gas velocity in the stack channel. At present, the effective stack design procedures do not contain the notion of this economically feasible, cost-effective index, and the stack diameter is selected based on the engineering-and-cost estimation calculation procedures, which have not been approved as mandatory standards. These procedures are supported by the planning-and-distribution model of the country's economic development. The article announces a universal method developed by the authors for calculating the optimal flue gas velocity for any model of economic development irrespective of the trend in prices and expenditures for the production of goods and services. To calculate the optimal flue gas velocity, one should only input initial data valid at the present stage. The calculated results of the price factors' effect on the optimal flue gas velocity for single-flue and multiple-flue stacks are presented. Verification of the procedure against the initial data as of 1975 yields acceptable results.

Keywords: stack, thermal power station, economics, computational method, optimal velocity, ecology, flue gas

Thermal Analysis of Coals from Kazakhstan Deposits

A. R. Bogomolov^{a, d, *}, I. Ya. Petrov^{b, **}, and U. K. Zhalmagambetova^c

^a*Gorbachev Kuzbass State Technical University, Kemerovo, 650000 Russia*

^b*Federal Research Center of Coal and Coal Chemistry, Siberian Branch, Russian Academy of Sciences, Kemerovo, 650000 Russia*

^c*Almaty University of Power Engineering and Telecommunications, Almaty, 050013 Republic of Kazakhstan*

^d*Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

**e-mail: barom@kuzstu.ru*

***e-mail: ipetrov@kemcity.ru*

Received July 19, 2019; revised September 24, 2019; accepted September 25, 2019

Abstract—Coals from the Ekibastuz, Maikuben, and Karazhyra deposits in Kazakhstan were subjected to thermal analysis for determining the temperature ranges suitable for producing high-calorific gaseous fuel with optimal characteristics. Thermal experiments were performed using the thermogravimetric (TG and DTG) and differential thermal analysis (DTA) methods in oxidizing (air) and inert (helium) media in the temperature range from room temperature to 700–900°C at a linear heating rate of approximately 10°C/min. The results obtained from the TG, DTA, and DTG analyses made it possible to identify three main thermal decomposition intervals of the studied coals in air and in oxygen-free medium: at a temperature below 140°C (in air) and below 160°C (in helium flow), the water adsorbed in the coal is removed from it; at 280–480°C, low-molecular volatile coal pyrolysis products release and burn (in air); the temperature range 340–530°C corresponds to the stage of primary or rapid pyrolysis of coal (in helium flow); the char derived from coal burns (in air) at temperatures higher than 480°C; and temperatures above 510°C correspond to the stage of secondary or slow pyrolysis of coals (in helium flow). The maximum yield of volatile products (16.2%) is obtained from the pyrolysis of coal from the Maikuben deposit, and their minimum yield (7.1%) is obtained from the pyrolysis of Ekibastuz coal. The reactions of intensive release of volatile products at the rapid pyrolysis stages of the studied coals end with exothermic (500–550°C) and endothermic (at approximately 650°C) condensation of emerging aromatic structures and formation of char residues. The data presented in the article can be used in searching for raw coal material most suitable for obtaining high-calorific fuel and for selecting the conditions for its industry-grade devolatilization.

Keywords: coal, thermal decomposition, oxidation, pyrolysis, thermal analysis, volatiles, metamorphism

Protective Oxidation of Boiler Equipment Heating Surfaces with Concurrently Removing Ash Deposits

L. N. Moskvina^{a, b, *}, A. A. Efimov^a, and B. A. Gusev^{a, **}

^a*Aleksandrov Scientific Research Technological Institute, Sosnovyi Bor, 188540 Russia*

^b*Institute of Chemistry, St. Petersburg State University, St. Petersburg, 198504 Russia*

**e-mail: moskvln@yandex.ru*

***e-mail: gusev@niti.ru*

Received May 21, 2018; revised July 12, 2019; accepted August 28, 2019

Abstract—The problem of removing ash deposits appearing on the heating surfaces during fuel combustion has presently been solved only for boilers equipped with a steam- or water-assisted surface treatment system. However, the treatment with steam (water) does not guarantee efficient removal of deposits from the heating surfaces nor does it guarantee efficient protection of the cleaned heating surfaces from corrosion. According to the applied technology, ash deposits are removed from the heating surfaces by subjecting the latter to steam blasting with concurrent thermochemical oxidation of the cleaned surfaces. In the framework of searching for ways of making both stages of this process more efficient, the possibility of treating the equipment surfaces that need cleaning with vapor–aerosol compositions containing ammonium acetate solution in the aerosol phase is considered. Such treatment yields a double effect: first, ash deposits are more efficiently loosened during thermal decomposition of ammonium acetate and, second, the cleaned metal surfaces are uniformly oxidized during the thermolysis of acetate iron complexes generated in the solution film that is produced on the metal surface when aerosols precipitate on it. The protective oxide film produced on the surface smooths the metal surface roughness, thereby weakening the cohesion of ash and tar deposits with it, due to which it becomes possible to increase the boiler operation time between its treatment outages.

Keywords: boiler equipment, heating surfaces, pearlitic steels, ash deposits, vapor–aerosol-assisted removal, ammonium acetate, protective oxidation

Optimization of Minimum Temperature Differences in the Steam Reheater of a Turbine at a Nuclear Power Station

A. S. Shamarokov^a, V. M. Zorin^{b, *}, and S. V. Bosenko^{b, **}

^a*All-Russia Research and Design Institute of Nuclear Power Machine Building (VNIAM), Moscow, 115088 Russia*

^b*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

**e-mail: ZorinVM@mpei.ru*

***e-mail: Bosenko-sv@mail.ru*

Received June 24, 2019; revised September 18, 2019; accepted September 25, 2019

Abstract—The effectiveness of nuclear power stations (NPS), alongside with their safety, is critical. Improving the quality in designing new power units is related closely with their economic effectiveness and competitiveness. A substantiated selection in the values of many controlled variables of the process (or thermal) scheme is of great importance in this case. It is essential that the value of controlled variables should correspond to the economic conditions of NPS operation, which will become effective a long time after selection of these values. The paper presents an optimization procedure for a long-term period of controlled variables for the thermal scheme of a steam turbine unit (STU). The equipment item to be optimized is a live-steam reheater of an STU. A header-type, two-stage platen reheater, which is a part of the separator-superheater (SSH) developed at AO VNIAM, has been selected. The design of the reheater is described and its distinguishing features are outlined. The particularity of the proposed procedure is that it yields the results in the form of a complex parameter, including both external economic and operating parameters. Having found the values of these parameters timed to operation of a newly designed NPS, the obtained correlation enables one to determine specific values of the minimum temperature differences. The results for optimization of the minimum pressure difference in an SSH designed for a K-1200-6.8/50 steam turbine unit by this procedure are presented. The criterion of the optimal temperature difference was a change in the annual reduced expenditure at an NPS as compared to those in the reference case. The optimization problem was solved by the coordinate decent method. The data required for the optimization were calculated by the options of the thermal scheme of K-1200-6.8/50 STU using the SKHEMA software code developed at the Nuclear Power Station Department of NRU MPEI. The predicted minimum temperature differences can be used as the reference in designing new SSHs for power units at NPSs with a thermal scheme similar to that used in the considered problem.

Keywords: nuclear power station, steam turbine unit, effectiveness, separator-superheater, header-type platen tube system, optimization problem, optimality criterion, change in annual reduced expenditures, complex parameter

Improving the Performance of Transformer Oil Using Individual Sulfides

L. R. Gainulina^{a,*} and V. P. Tutubalina^a

^a*Kazan State Power Engineering University, Kazan, 420066 Russia*

**e-mail: gainullina7819@mail.ru*

Received October 26, 2018; revised May 18, 2019; accepted August 28, 2019

Abstract—The stability of transformer oil against oxidation affects the operating reliability and the service life of oil-filled electrical equipment. To improve the performance of transformer oil, an IONOL antioxidant is added to the oil fractions during transformer oil's production. The quality of this antioxidant is affected by organic sulfur compounds contained in sour oils. An investigation was carried out into the effect of individual sulfides, namely, decylcyclohexylsulfide and decylphenylsulfide, injected into transformer oil after adsorption treatment, TAp, on its stability against oxidation and the amount of air absorbed by oil in a 30 kV/cm strength electrical field. Sulfides were added to oil to attain their concentration as high as 1.0 wt %. It has been demonstrated that the amount of air absorbed by oil decreases at a sulfide concentration of 0.5% and the oil's stability against oxidation in oil-filled electrical equipment at power facilities becomes better. Decylcyclohexylsulfide has been found to be a more effective oxidation inhibitor than decylphenylsulfide. At its optimal concentration, the amount of air absorbed by the transformer oil decreased by six times, the acid number by 8.33 times, the yield of volatile acids by 3.5 times, and the amount of formed deposit by ten times compared to the original oil.

Keywords: transformer oil, electrical equipment, stability against oxidation, individual sulfides, decylcyclohexylsulfide, decylphenylsulfide