

Contents

Vol. 67, No. 4, 2020

Energy Conservation, New and Renewable Energy Sources

Will Hydrogen Be Able to Become the Fuel of the Future?

V. A. Kulagin and D. A. Grushevenko

Heat and Mass Transfer and Properties of Working Fluids and Materials

Nonlinear Convection in Micropolar Fluid Flow Past a Non-Isothermal Exponentially Permeable Stretching Sheet in Presence of Heat Source/Sink

I. C. Mandal and S. Mukhopadhyay

Steam Boilers, Power Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Assessment of Boiler Units' Technical State Based on Quality Indicators

M. N. Maidanik, A. N. Tugov, and V. A. Vereshchetin

Investigation into Operating Conditions of a Dry Mechanical Draft Cooling Tower at the TETs-12 Cogeneration Power Station of PAO Mosenergo

O. O. Mil'man, S. N. Lenev, P. V. Golov, A. V. Ptakhin, A. V. Kondrat'ev, and V. S. Krylov

Numerical Estimation of the Heat and Mass Transfer Efficiency Considering Nonuniformity in Water and Air Distribution

E. A. Lapteva, E. Yu. Stolyarova, and A. G. Laptev

Steam Turbine, Gas Turbine, and Combined Cycle Power Plants and Their Auxiliary Equipment

The Influence of Fuel–Air Mixture Preparation Quality in the Burner on the Fuel Combustion's Completeness in the GTU Combustion Chamber

A. V. Baklanov and S. P. Neumoin

Will Hydrogen Be Able to Become the Fuel of the Future?

V. A. Kulagin^{a, b, *} and D. A. Grushevenko^{a, b}

^a Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia

^b National Research University Higher School of Economics, Moscow, 101000 Russia

* e-mail: vakulagin@yandex.ru

Received November 5, 2019; revised November 14, 2019; accepted November 20, 2019

Abstract—The results of exploring the prospects of hydrogen economy are presented. The complete production chains are investigated considering various technologies of production, storage, and subsequent utilization of hydrogen in transportation and electric power generation. Comparative analysis of the economic competitiveness of these chains with each other and with solutions based on the use of alternative fuels has been performed. Potential segments for the commercial application of the technologies and the conditions required have been evaluated. The analysis has established the most promising directions in the development of hydrogen economy. They primarily include the use of hydrogen in the defense industry and power supply of critical facilities, where the energy generation costs are not a determining factor. To be competitive in the civil consumption sectors, such as transportation and the power industry, hydrogen technologies have to become significantly less expensive or to receive the corresponding regulatory support. In many countries, the environmental sustainability of hydrogen production will have great significance. The authors conclude that hydrogen can become one of the fuels of the future; to effect this, however, we will have to tread a difficult path of technological progress under stiff competition with continuously developing alternative power-generation methods.

Keywords: hydrogen, hydrogen fuel economy, electrolytic cell, consumption, technologies, economy, competitiveness

Nonlinear Convection in Micropolar Fluid Flow Past a Non-Isothermal Exponentially Permeable Stretching Sheet in Presence of Heat Source/Sink

I. C. Mandal^a and S. Mukhopadhyay^{a,*}

^a*Department of Mathematics, The University of Burdwan, West Bengal, Burdwan, 713104 India*

**e-mail: swati_bumath@yahoo.co.in*

Received March 24, 2019; revised April 22, 2019; accepted June 26, 2019

Abstract— This paper aims to present the consequences of nonlinear convection on boundary layer flow of micropolar fluid over a non-isothermal exponentially stretching sheet. The influences of suction/blowing and heat source/sink are also considered. Using similarity transformations the governing partial differential equations are reduced to ordinary differential equations and these nonlinear equations are then solved numerically by converting the boundary value problem to an initial value problem with the help of shooting technique and Runge-Kutta method. The results are discussed through graphical representations providing physical interpretations as far as practicable. It is found that both fluid velocity and angular velocity increase with the rise in material parameter but the temperature decreases in this case. Fluid velocity increases but the angular velocity and temperature both decrease with the rise in mixed convection parameter and also with the nonlinear convection parameter.

Keywords: micropolar fluid, nonlinear convection, exponential velocity, stretching sheet, suction/blowing, heat source/sink

Assessment of Boiler Units' Technical State Based on Quality Indicators

M. N. Maidanik^{a, *}, A. N. Tugov^a, and V. A. Vereshchetin^a

^a *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

**e-mail: MNMaydanik@vti.ru*

Received May 22, 2019; revised September 25, 2019; accepted September 25, 2019

Abstract—Results from elaborating methodical approaches to assessing the technical state of boiler units based on quality indicators, including assessments based on two groups of indicators—environmental safety and technical and economic efficiency—are presented. The procedure of assessing the technical state based on the considered indicators is given. The main indicators (parameters) of boiler units determining their environmental safety and characterizing their technical effectiveness and economic efficiency are presented. The weighting coefficients of indicators that reflect the extent in relative units to which each individual indicator influences the technical state are given. The basic indicators (basic values of boiler unit parameters) with respect to which the technical state of units is assessed are suggested. Technological standards for specific emissions of harmful substances into the atmosphere are adopted as the basic values of indicators determining environmental safety. For the indicators of technical effectiveness and economic efficiency, it is possible to take the standardized values reflecting the actually achievable technical effectiveness and economic efficiency of the operating equipment or the target values of indicators determining the modern and prospective technically achievable requirements for equipment. Point and indexed assessments of state are considered; reference values of score assessments are pointed out, and functional dependences for carrying out point and indexed assessments of state are given. An interpretation of the assessment system with determining the technical state levels is given, using which it is possible to establish a correspondence between the considered quality indicators and existing standards for harmful emissions and to determine the ability of equipment to perform its prescribed functions. Depending on the values of technical state indices, versions of technical measures taken for the main equipment and aimed at maintaining and improving its effectiveness and economic efficiency are considered. Results from assessing the current technical state of operating boilers, namely, their technical effectiveness and economic efficiency with respect to the standardized and prospective target indicators, are given.

Keywords: boiler unit, boiler, technical state, quality indicators, technical effectiveness, environmental safety, state index

Investigation into Operating Conditions of a Dry Mechanical Draft Cooling Tower at the TETs-12 Cogeneration Power Station of PAO Mosenergo

O. O. Mil'man^{a, c, *}, S. N. Lenev^b, P. V. Golov^b, A. V. Ptakhin^{a, c}, A. V. Kondrat'ev^{a, c}, and V. S. Krylov^a

^aZAO Turbokon Scientific-and-Production Implementation Enterprise, Kaluga, 248010 Russia

^bPAO Mosenergo, Moscow, 119526 Russia

^cTsiolkovski Kaluga State University, Kaluga, 248023 Russia

*e-mail: turbocon@kaluga.ru

Received July 19, 2019; revised October 04, 2019; accepted October 23, 2019

Abstract—The results of the comprehensive investigation into operation of a dry mechanical draft cooling tower (DMDCT) of a PGU-220 power unit at the TETs-12 cogeneration power station of PAO Mosenergo are presented. Thermal performance of the main and auxiliary DMDCTs and their individual sections is examined. To determine the cooling-air flowrate, a rake consisting of 11 velocity transducers and thermocouples was installed at the fan outlet above the fan diffuser of the examined section. The DMDCT heat balances calculated on the basis of water- and cooling-air conditions agree with each other with a maximum error of 8%. The overall thermal performance indices of the main and auxiliary DMDCTs were lower than those specified by the supplier. Performance of DMDCT fans was investigated at different blade angles α . According to our calculations, the effect of better fan performance in terms of an increase in the power of a steam turbine in a combined-cycle unit at $\alpha > 15^\circ$ does not compensate for an increase in the power consumption of fan motors and even reduces the amount of delivered power. Therefore, the range of $\alpha = 10\text{--}15^\circ$ for the fans of the main DMDCT may be considered optimal. As to the auxiliary cooling tower, an increase in the air flow at $\alpha = 17^\circ$ can offer a wider operation range for the fans at high ambient air temperatures, which is important considering limitations on the supply temperature (below 35°C) of the auxiliary equipment cooling water. The investigation of DMDCT operation during the cold season yielded the dependence of the minimum heat load of DMDCT, required for its safe operation, on the ambient air temperature. The study into the performance of the humidification system revealed that its efficiency is inadequate. The best solution to this problem is to replace the normal humidification nozzles with nozzles with smaller diameter holes to improve water dispersion that will prevent the water drops from falling onto the ground and improve the efficiency of the humidification system while decreasing the water flow to the humidification nozzles.

Keywords: dry mechanical draft cooling tower, fan, velocity transducer, thermocouple, diffuser, blade angle, heat load, nozzles, humidification system

Numerical Estimation of the Heat and Mass Transfer Efficiency Considering Nonuniformity in Water and Air Distribution

E. A. Lapteva^{a,*}, E. Yu. Stolyarova^a, and A. G. Laptev^a

^a*Kazan State Power Engineering University, Kazan, 420066 Russia*

**e-mail: tv_t_kgeu@mail.ru*

Received June 24, 2019; revised September 25, 2019; accepted September 25, 2019

Abstract—Using a system of differential equations of heat and mass transfer written in a cylindrical coordinate system with volumetric interphase sources of heat and mass transfer, a mathematical model of heat and mass transfer in film blocks of cooling tower irrigators has been developed. Expressions describing the interphase sources of heat and mass transfer and correlations for calculation of their parameters are presented. The parameters of the sources, i.e., the coefficients of heat and mass transfer, are related with the hydraulic resistance of irrigator blocks and can be calculated with both uniform and nonuniform distribution of air and water. The calculated volumetric coefficients of mass transfer were calculated and compared with the experimental data for regular mesh packing made of polyethylene and sheet-type metal packing. The numerical solution of the system of differential equations yielded the distribution of water, air, and air humidity content along the height of a packing block. The thermal efficiency of water cooling was calculated. It agrees satisfactory with the experimental data for spraying blocks made of polyethylene mesh. The causes of nonuniform distribution of phases among the packing blocks, which decreased the thermal efficiency of the cooling tower, were examined. The numerical investigations revealed that nonuniform air supply has the most significant influence decreasing the thermal efficiency of water cooling by as much as 35% or more compared with uniform phase distribution. The presented mathematical model can be used for estimating the cooling capacity of existing cooling towers at thermal power stations (TPSs) and industrial plants as well as in upgrading or developing high-efficient spraying blocks for film-type apparatuses.

Keywords: cooling tower, film packing, thermal efficiency, mathematical modelling, contact devices, sprayers, heat and mass transfer

The Influence of Fuel–Air Mixture Preparation Quality in the Burner on the Fuel Combustion’s Completeness in the GTU Combustion Chamber

A. V. Baklanov^{a, *} and S. P. Neumoin^a

^a*Kazan Motor-Building Production Association, Kazan, 420036 Tatarstan*

**e-mail: andreybaklanov@bk.ru*

Received September 15, 2018; revised August 1, 2019; accepted September 25, 2019

Abstract—A method for determining the fuel and air mixing quality at the combustion chamber’s (CC) burner outlet in a natural gas fired, power-generating gas turbine unit is developed. Three types of burners differing from one another in the nozzle head design are experimentally investigated. The investigation was carried out on a facility in which carbon dioxide was used to simulate fuel. The field of CO₂ concentrations in different sections was determined during the investigations. An experimental data-processing procedure for determining the mixing quality is developed. Firing tests of three burners in a single-burner compartment simulating the combustion liner were carried out. The experimental setup on which the tests were carried out and the single-burner compartment design are described. The concentrations of final gas mixture components, in particular, the concentrations of CO, O₂, and CH in the combustion products, were determined using a Testo 350 gas analyzer. The obtained concentrations were used as the initial data for calculating the fuel combustion’s completeness. Based on comparison of the obtained experimental data, a dependence characterizing the effect of fuel-mixing quality on the fuel combustion completeness has been derived.

Keywords: combustion chamber, gas turbine unit, fuel–air mixture, mixing quality, experimental investigations