

# Contents

---

---

Vol. 67, No. 5, 2020

---

---

## Steam Turbine, Gas Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Development and Investigation of a New Rotary Valve for Power Steam Turbines

*A. E. Zaryankin, V. A. Zaryankin, A. S. Akatov, and A. S. Zonov*

A Procedure for Experimental and Numerical Investigations  
of Turbine Machinery Labyrinth Shroud Seals

*L. Ya. Lazarev and V. A. Fadeev*

Turbine Generator Rotor Vibrations with Rubbing in the Span and Supports

*V. F. Shatokhin*

---

## Nuclear Power Plants

Economic Assessment of the Possible Desalination Processes for the First Block  
of Bushehr Nuclear Power Plant

*Kh. Sadeghi, S. H. Ghazaie, E. D. Fedorovich, E. A. Sokolova, and A. S. Shirani*

Combined Numerical and Experimental Investigations into the Local Fluid Dynamics  
of Coolant Flow in the Mixed Core of a VVER Reactor

*S. M. Dmitriev, A. V. Gerasimov, A. A. Dobrov, D. V. Doronkov, A. N. Pronin, A. V. Ryazanov,  
D. N. Solntsev, A. E. Khrobostov, A. S. Noskov, Yu. K. Shvetsov, and D. L. Shipov*

---

## Energy Saving, New and Renewable Energy Sources

The Concept of an Energy-Technological Complex for Using Natural Gas in the Production  
of Electric Power, Heat, And Synthetic Liquid Fuel with Partial Sequestering  
of Carbon Dioxide Emissions into the Atmosphere

*V. M. Batenin, V. M. Maslennikov, V. Ya. Shterenberg, and K. A. Gordin*

Comparison of the Efficiency of the Reactors for Low-Temperature Pyrolysis of Biomass

*L. B. Direktor, V. M. Zaichenko, R. L. Is'emin, A. A. Chernyavskii, and A. L. Shevchenko*

---

## Steam Boilers, Power-Plant Fuel, Burner Devices, and Auxiliary Equipment of Boilers

Numerical Analysis of Entropy Production During Hydrogen-air Burner Combustion Process

*Ali Anwar Brohi, Hao-Chun Zhang, and Shahid Karim*

---

## Water Treatment and Water Chemistry

Physicochemical Analysis of Organic Impurities in the Coolant of Combined Heat  
and Power Plants Equipped with Combined-Cycle Power Installations

*A. A. Filimonov, E. K. Arakelyan, A. A. Chichirov, N. D. Chichirova, and A. A. Batalova*

An Analysis of Carbonic Acid Removal in an Atmospheric Deaerator

*A. M. Bravikov, S. V. Alekseev, and A. A. Shatunov*

---

## **Environmental Protection**

Modeling Once-Through Cooling Systems of NPPs and TPPs with Marine-Type Cooling Ponds  
and Environmental Protection

*K. V. Zotov and D. K. Zotov*

---

---

# Development and Investigation of a New Rotary Valve for Power Steam Turbines

A. E. Zaryankin<sup>a, \*</sup>, V. A. Zaryankin<sup>b</sup>, A. S. Akatov<sup>a</sup>, and A. S. Zonov<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

<sup>b</sup>*OOO Yuznyi Poultry Plant, Yuznyi, Malgobeksky raion, Republic of Ingushetia, 386336 Russia*

*\*e-mail: ZariankinAY@mpei.ru*

**Abstract**—Control valves are actuating elements of a steam turbine control system; the quality of their performance directly affects the reliability of the overall steam turbine unit. Accordingly, these valves must meet very stringent requirements. Among the factors and characteristics responsible for the quality of control valves, an important place is occupied by the design simplicity, manufacturability, serviceability, ease of installation, high operating reliability, low hydraulic resistance, low dynamic loads acting on the valve stem, and moderate noise level. At the same time, it should be noted that there is quite a large fleet of old, obsolete steam turbine power units at present in Russia with valves featuring both high hydraulic resistance and poor reliability. In new, linear control valves developed in the last decade, almost all design possibilities for their improvement have been exhausted. Hence, rotary control valves may be of great interest for practice. It is this type of valve that is considered below. This information includes a description of valve design, results from the investigation of flow parameters in the valve flow path, and the flow characteristic obtained by a mathematical simulation technique. This valve meets the above-mentioned requirements to the maximum extent, is fully balanced of axial thrust, has almost zero steam leakage along the drive stem, and is operated with low-power actuators with any bores and any initial steam pressures.

*Keywords:* control valve, rotary valve, balanced valve, diffuser, stem, rotary coupling, gland, velocity field, mathematical simulation, flow characteristics

# A Procedure for Experimental and Numerical Investigations of Turbine Machinery Labyrinth Shroud Seals

L. Ya. Lazarev<sup>a,\*</sup> and V. A. Fadeev<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: llazarev37@gmail.com*

**Abstract**—Labyrinth seals installed in turbine machines serve for decreasing the working fluid leakage through the clearances between the rotating and stationary structural elements in order to increase its flowrate through the flow path. The operational efficiency and reliability of all types of turbine machines (steam, gas, and hydraulic turbines; compressors; fans; pumps; etc.) depend to an essential extent on the type of seals (labyrinth, groove, etc.), which determine the working fluid leakage and intensity of hydrodynamic forces acting on the rotor. Therefore, those who design turbine machines should use a close-to-reality model of the flow pattern in labyrinth seals. Such a model was developed in the 1970s by A.G. Kostyuk with his coworkers at the Moscow Power Engineering Institute and is quite widely used in analyzing the dynamics of turbine machines. However, the procedures for thermal and aerodynamic design analyses of turbine machines, as well as relevant standards and handbooks, do not contain a description of this model nor do they contain recommendations for using it. At present, such a state of things becomes especially dangerous in connection with wide application of numerical methods of 3D design and analysis, when the use of an inadequately selected flow model (in particular, in seals) may give rise to essential errors. The article presents a review and scrutiny of the used numerical and experimental models of shroud seals; their drawbacks are shown, and a model adequately representing a real flow is described.

*Keywords:* turbine machines, shroud seal, numerical and experimental models, relative and absolute motion, leakage, flow structure

# Turbine Generator Rotor Vibrations with Rubbing in the Span and Supports

V. F. Shatokhin<sup>a,\*</sup>

<sup>a</sup>*Kaluga Turbine Works, Kaluga, 248010 Russia*

<sup>\*</sup>*e-mail: shatokhin\_vf@power-m.ru*

**Abstract**—The article presents an algorithm for and results from studying the motion of a rotor involving its simultaneous rubbing against the stator elements in the turbine set span and supports. The aim of the study was to develop the mathematical model describing vibration of the rotor resting in a few supports and to select the main assumptions regarding the contact interaction between the rotor and stator that will make it possible to model a real vibrational process that involves rubbing. An abrupt loss of balancing in the rotor's second span section at the angular rotation speed is taken as the initial disturbance upsetting the turbine set's normal operation. The case of a constant rotor rotation speed with loss of balancing followed by development of contact interaction between the rotor and stator elements is considered. This scenario seems to be the most plausible because the interaction persists for a short period of time during which the safety system still remains silent in producing the command to disconnect the steam supply to the turbine, and the torque on its shaft remains constant. It is shown that with the adopted clearances in the turbine set span and supports, with the loss of balancing corresponding to detachment of the mass of one turbine blade, and with increased damping in the supports, the rotor motion is accompanied by rubbing in the turbine set supports and span. If the damping coefficient in the supports does not exceed the value of this parameter in the plain bearing oil film, asynchronous reverse whirl of the rotor develops, which is characterized by self-excited vibration caused by the effect of contact interaction forces between the rotor and stator. Owing to consideration of the rotor design features, its frequency characteristics, including the change in the frequency characteristics of the rotor–supports system due to additional reactions arising at the moments in which the rotor comes into contact with the stator, it becomes possible to model the vibration development process not only during strong (when whirl is excited) but also during weak (possible excitation of low-frequency vibration) interactions between the rotor and stator and to analyze the influence of detuning from resonances and other factors on the development of self-excitation processes in systems closer to real ones.

*Keywords:* multisupport rotor, stator, casing, bearings, seals, unsteady vibration, rubbing in a few sections, stiffness and damping in rubbing places

# Economic Assessment of the Possible Desalination Processes for the First Block of Bushehr Nuclear Power Plant

Kh. Sadeghi<sup>a,\*</sup>, S. H. Ghazaie<sup>a</sup>, E. D. Fedorovich<sup>a</sup>, E. A. Sokolova<sup>a</sup>, and A. S. Shirani<sup>b</sup>

<sup>a</sup>*Peter the Great St. Petersburg Polytechnic University, Higher School of Nuclear and Heat Power Engineering,  
St. Petersburg, 195251 Russia*

<sup>b</sup>*Shahid Beheshti University, Department of Atomic Engineering, Tehran, 1983969411 Iran*

*\*e-mail: sadegi.h@edu.spbstu.ru*

**Abstract**—The problem of ensuring the continuously growing needs of people for freshwater is becoming more acute in Iran. In order to resolve the serious water crisis in arid regions of the country near the Gulf, several desalination units have been used. However, most of the installed units of seawater desalination are based on fossil fuels consumption, which suffers from several disadvantages. According to the demand for clean energy to provide water and electricity, nuclear technology is gaining higher attention as compared to other energy sources. Bushehr NPP as the first commercial nuclear reactor in the country can be included the establishment of a large-scale desalination plant. In this study, after reviewing pertinent aspects of commercial desalination technologies, the history of seawater desalination in Iran is presented. This paper is focused on economic assessment of coupling the Bushehr NPP with different types of desalination systems, namely, Multiple Effect Desalination (MED), Multi-Stage Desalination (MSF), Reverse Osmosis (RO), and RO + MSF, RO + MED (hybrid methods) by using the Desalination Economic Evaluation Program (DEEP) package. By considering the obtained results and advantages of hybrid methods, RO + MED process with thermal/RO ratio of 0.7 and the total capacity of 150000 m<sup>3</sup>/day is suggested.

**Keywords:** seawater desalination, power plant, Desalination Economic Evaluation Program, Bushehr nuclear power plant, seawater desalination technologies, preheating the reverse osmosis feed water, hybrid methods desalination, energy consumption

# Combined Numerical and Experimental Investigations into the Local Fluid Dynamics of Coolant Flow in the Mixed Core of a VVER Reactor

S. M. Dmitriev<sup>b</sup>, A. V. Gerasimov<sup>b</sup>, A. A. Dobrov<sup>b</sup>, D. V. Doronkov<sup>b,\*</sup>, A. N. Pronin<sup>b</sup>, A. V. Ryazanov<sup>b</sup>,  
D. N. Solntsev<sup>b</sup>, A. E. Khrobostov<sup>b</sup>, A. S. Noskov<sup>a</sup>, Yu. K. Shvetsov<sup>a</sup>, and D. L. Shipov<sup>a</sup>

<sup>a</sup>*AO Afrikantov OKBM, Nizhny Novgorod, 603074 Russia*

<sup>b</sup>*Alekseev Nizhny Novgorod State Technical University, Nizhny Novgorod, 603950 Russia*

*\*e-mail: nevid000@mail.ru*

**Abstract**—The article presents the results from experimental investigations into local coolant flow fluid dynamics that were carried out on the fragmental model of a VVER-type pressurized water reactor's mixed core consisting of two types of fuel assemblies (FAs): TVSA-T (one segment) and TVSA-T.mod.2 (two segments). The coolant flow processes in the fuel rod bundle were simulated on an aerodynamic test bench. The pressure field in the flow was measured using a five-channel pneumometric probe. The obtained pressure field in the flow was recalculated for the coolant velocity vector according to the dependences derived during calibration. For drawing up a detailed flow motion pattern, a characteristic model cross section area was separated, which included the space between the assemblies and four fuel rod rows in each TVSA-type fuel assembly. The spatial distribution of coolant flow velocity projections was analyzed, as a result of which it became possible to reveal the regularities associated with the streamlining of spacer-, mixing-, and combined-spacer grids in TVSA assemblies by coolant; to determine coolant cross flows resulting from streamlining of hydraulically nonidentical grids and determine their localization in the experimental model longitudinal and cross sections; and to reveal the effect of accumulating flow hydrodynamic disturbances in the model longitudinal and cross sections resulting from the staggered arrangement of hydraulically nonidentical grids. The results obtained from investigations of inter-assembly interaction of coolant between the neighboring TVSA-T and TVSA-T.mod.2 assemblies have been adopted for practical use at AO Afrikantov OKBM in estimating the thermal reliability of VVER-type reactor cores and have been included in the database for verification of computation fluid dynamics computer programs (CFD codes) and detailed cell-wise numerical analysis of the core of VVER reactors.

*Keywords:* reactor core, fuel assembly, spacer and combined spacer grids, coolant fluid dynamics, inter-assembly interaction

# The Concept of an Energy-Technological Complex for Using Natural Gas in the Production of Electric Power, Heat, And Synthetic Liquid Fuel with Partial Sequestering of Carbon Dioxide Emissions into the Atmosphere

V. M. Batenin<sup>a</sup>, V. M. Maslennikov<sup>a</sup>, V. Ya. Shterenberg<sup>a,\*</sup>, and K. A. Gordin<sup>a</sup>

<sup>a</sup>*Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

*\* e-mail: vshter@mail.ru*

**Abstract**—The article provides a description and comparative analysis of the original integrated technology for using natural gas with the simultaneous production of energy and synthetic liquid motor fuel and the partial sequestration of carbon dioxide. The installation operates in two main modes: it generates electricity, heat, and methanol during daylight hours. During night hours of the electric load, flue gas is partially extracted from the flue gases using the mastered industrial technology CO<sub>2</sub>, which is converted in a plasmatron with the addition of natural gas and water vapor into synthesis gas, which is significantly richer in hydrogen and carbon monoxide than daytime gas. The resulting additional synthesis gas is sent to a methanol synthesis catalytic reactor, in which, thanks to the use of richer synthesis gas, the methanol synthesis process is accelerated on existing equipment. At the same time, the energy-generating part of the plant's equipment operates in almost the same mode, although the supply of useful electricity in accordance with the requirements of the power system is reduced several times. The use of a single-pass methanol synthesis reactor drastically reduces the size and cost of synthesis unit equipment. At the same time, a significant content of unreacted useful gases (N<sub>2</sub> and CO) at the outlet of the synthesis reactor is not a drawback of the scheme since the exhaust gases are used as fuel for an energy gas turbine plant. A feature of the proposed technology is the beneficial use of CO<sub>2</sub> during the night period, which, in addition to a significant reduction in its emissions into the atmosphere at this time, simultaneously and without additional costs, also solves the problems associated with its disposal since carbon dioxide is used inside the technological scheme as a raw material for obtaining additional amounts of synthesis gas. Compared with existing plants for the separate production of electricity, heat, and methanol, the proposed technological scheme will allow achieving natural gas savings of approximately 20% and reduce atmospheric CO<sub>2</sub> emissions by up to 30%.

*Keywords:* integrated energy technology, CO<sub>2</sub> emissions, CO<sub>2</sub> capture, synthetic liquid fuel, methanol



# Comparison of the Efficiency of the Reactors for Low-Temperature Pyrolysis of Biomass

L. B. Direktor<sup>a</sup>, V. M. Zaichenko<sup>a, \*\*</sup>, R. L. Is'emin<sup>b, \*\*\*</sup>,  
A. A. Chernyavskii<sup>c, \*\*\*\*</sup>, and A. L. Shevchenko<sup>a, \*</sup>

<sup>a</sup>Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

<sup>b</sup>Tambov State Technical University, Tambov, 392000 Russia

<sup>c</sup>Rostovteploelectroproekt Institute, Rostov-on-Don, 344002 Russia

\*e-mail: s1246626@yandex.ru

\*\*e-mail: zaitch@oivtran.ru

\*\*\*e-mail: risemin@gmail.com

\*\*\*\*e-mail: info@rotep.ru

**Abstract**—Results from the comparative analysis of the energy and economic efficiencies of the torrefaction reactors (or low-temperature pyrolysis reactors) with the heat of the heating gas supplied directly to the processed biomass are presented. Upright reactors of two types are considered, viz., reactors with a bed of dense biomass moving by gravity towards the heating gas flow and fluidized-bed reactors. Advantages and drawbacks of the different types of torrefaction reactors are discussed. Criteria for the evaluation of the torrefaction reactors' energy efficiency have been defined based on the data of experimental research conducted on a pilot power-engineering plant at the Joint Institute for High Temperatures, Russian Academy of Sciences, equipped with a moving-bed reactor and the results of numerical modeling of a fluidized-bed reactor. The conditions for creating the thermal effect of the hemicellulose decomposition reaction and the mechanism that restricts the increase in the biomass temperature during the self-heating by the exothermic reaction heat are considered. The analysis performed has shown that a moving-bed reactor with a controlled exothermic biomass destruction reaction has the highest energy efficiency and the best criteria for estimating the financial and commercial efficiency of the investments. Conclusions have been made that moving-bed reactors are preferable for small-scale production for which granulated biomass (biomass pellets) is the optimal feedstock, while fluidized-bed reactors and fine-dispersed feedstock materials are more suitable for large-scale production.

**Keywords:** torrefaction, biomass, energy efficiency, exothermic reaction, moving-bed reactor, fluidized-bed reactor

# Numerical Analysis of Entropy Production during Hydrogen-Air Burner Combustion Process

Ali Anwar Brohi<sup>a, b, \*</sup>, Hao-Chun Zhang<sup>a</sup>, and Shahid Karim<sup>c</sup>

<sup>a</sup>*School of Energy Science and Engineering, Harbin Institute of Technology, Harbin, 150001 China*

<sup>b</sup>*Mehran University of Engineering and Technology, SZAB Campus, Khairpur Mir's, Sindh, Pakistan*

<sup>c</sup>*School of Electronics and Information Engineering, Harbin Institute of Technology, Harbin, 150001 China*

*\*e-mail: alianwar50@gmail.com*

**Abstract**— Entropy production during hydrogen-air diffusion in the combustion chamber (CC) was studied. A two-dimensional axisymmetric combustion chamber is considered in this paper. The numerical simulation of combustion has been done by Fluent software. The entropy production per unit volume for heat conduction and convection, mass diffusion, viscous dissipation, and the chemical reaction was calculated by user-defined function (UDF) post-processing, while the entropy production for heat transfer radiation was determined by post-processing with the help of calculated data of temperature. The results reveal that the radiation entropy production cannot be omitted when second law analysis of thermodynamic is adopted in high-temperature conditions such as boilers, heat exchangers, furnaces, etc; in these devices, thermal radiation is the basic mode of heat transfer. The effects of parameters such as Boltzmann number and Reynolds number on entropy production and entropy production number are analyzed. It is shown that the total entropy production number first decreases with the increase Reynolds and Boltzmann numbers; and then gradually increases. The results provide a theoretical reference for the improvement of thermodynamic efficiency for heat transfer and energy utilization.

**Keywords:** Numerical analysis, entropy production, heat conduction and radiation, Reynolds number, Boltzmann number

# Physicochemical Analysis of Organic Impurities in the Coolant of Combined Heat and Power Plants Equipped with Combined-Cycle Power Installations

A. A. Filimonova<sup>a, \*</sup>, E. K. Arakelyan<sup>b</sup>, A. A. Chichirov<sup>a</sup>, N. D. Chichirova<sup>a</sup>, and A. A. Batalova<sup>a</sup>

<sup>a</sup>*Kazan State Power Engineering University, Kazan, 420066 Russia*

<sup>b</sup>*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: aachichirova@mail.ru*

**Abstract**—In 2018, combined-cycle power installations equipped with heat-recovery steam generators were commissioned at the combined heat and power plant nos. 1, 2, and 3 (CHPP-1, CHPP-2, and CHPP-3) in the city of Kazan. The content of organic substances in the blowdown water of clarifiers, in chemically demineralized water, in evaporating plant condensate, in heat-recovery steam generator feed water and blow-down water, and in turbine condensate was investigated. Organic substances in dry form were separated from water samples using the extraction method. The physicochemical properties and structures of the separated organic impurities were determined using an elemental analysis, infrared spectroscopy, high-efficient liquid chromatography, chromatography-mass spectrometry, and nuclear magnetic resonance methods. It was found that the content of total organic carbon (TOC) was higher than its standardized value in the heat-recovery steam generator feed water, slightly higher than the standardized value in the condensate of evaporators, and in compliance with the existing standard requirements in the turbine condensate and chemically demineralized water. Humic substances that are not removed from water during its pretreatment and enter in the heat-recovery steam generator feed water were identified as the main organic component. It is shown that ion exchange is an efficient technology for removing organic impurities from makeup water for the heat-recovery steam generator.

*Keywords:* heat-recovery steam generator, feed water, humic substances, organic impurities, water chemistry, total organic carbon

# An Analysis of Carbonic Acid Removal in an Atmospheric Deaerator

A. M. Bravikov<sup>a, \*</sup>, S. V. Alekseev<sup>a</sup>, and A. A. Shatunov<sup>a</sup>

<sup>a</sup>AO Sibtechenergo, Novosibirsk, 630032 Russia

\*e-mail: sibte@sibte.ru

**Abstract**—The experience in the operation of atmospheric deaerators demonstrates that decreasing the bicarbonate alkalinity of deaerated water reduces the efficiency of deaerator operation. The available publications on the deaeration do not provide information on the causes of this reduction at a bicarbonate alkalinity of less than 0.2 mg-equiv/dm<sup>3</sup>. There is a problem of carbonic acid removal from the coolant at thermal power plants where steam condensate is used as feed water. AO Sibtechenergo's specialists faced this problem during commissioning of atmospheric deaerators operating at a low bicarbonate alkalinity of the deaerated water. During commissioning of the deaerators, the content of carbonic acid in the deaerated water often changed with no apparent causes. On completion of the commissioning, carbonic acid had a lower content in the deaerated water and was even absent under certain operating conditions. An experimental deaerator where distillate with low bicarbonate alkalinity was used as deaerated water was tested. Carbonic acid was not removed from the deaerated water if its content did not exceed 3.0 mg/dm<sup>3</sup> and the bicarbonate hardness was below 0.06 mg-equiv/dm<sup>3</sup>. Adding tap water to the investigated distillate in an amount of 0.22% decreased the content of carbonic acid in the deaerated water. With an increase in the amount of added tap water to 0.44%, carbonic acid was completely removed from the deaerated water. At thermal power plants with a closed steam-water path (circuit), carbonic acid can be removed from the closed circuit by increasing the steam vent from district water heaters and deaerators above the standard value.

*Keywords:* deaerator, boiler, heater, tray, test, steam vent, water, condensate, steam, oxygen, carbonic acid, bicarbonate alkalinity

# Modeling Once-Through Cooling Systems of NPPs and TPPs with Marine-Type Cooling Ponds and Environmental Protection

K. V. Zotov<sup>a,\*</sup> and D. K. Zotov<sup>a</sup>

<sup>a</sup>*Peter the Great St. Petersburg Polytechnic University, St. Petersburg, 195251 Russia*

*\*e-mail: zotov1205@gmail.com*

**Abstract**—Once-through cooling systems of NPPs and TPPs have well-known advantages compared with reverse systems. Currently in Russia, their design is not allowed according to the Water Code due to environmental concerns. The basis for such a decision for condensing power stations is disputed by the professional community. The question on the abolition of this ban for NPPs and TPPs on the initiative of the Ministry of Energy of the Russian Federation is decided at the legislative level. In a separate class can be distinguished once-through cooling systems with cooling ponds of the marine type. The article discusses the issues of substantiation of their layout and parameters at the predesign stage, taking into account the requirements of environmental protection. A coupling physical and numerical modeling is proposed as a tool of computational justification. Prospects for application of the proposed method for justification of cooling systems as an important element in improving competitiveness and also developing the export potential of Russia's energy complex are considered.

*Keywords:* once-through cooling system, NPP, TPP, physical modeling, numerical modeling, environmental protection