
Contents

Vol. 67, No. 6, 2020

Dear readers!

Energy Saving, New and Renewable Energy Sources

Long-Term Development Prospects of Russia's Wind Energy in the Conditions of Expected Climate Changes

V. V. Klimenko and E. V. Fedotova

Steam-, Gas-Turbine, and Combined-Cycle Power Installations, and Their Auxiliary Equipment

Study into the Separation Ability of the New NRU MPEI Peripheral Sealing

V. G. Gribin, S. S. Dmitriev, B. N. Petrunin, and M. E. A. E. Akhmed

Heat and Mass Transfer and Properties of Working Fluids and Materials

The Flow Boiling Crisis of Saturated Water in Pipes at High Pressures

M. V. Minko, V. V. Yagov, and S. S. Savekin

Calculation Technique of Some Thermodynamic Functions using the Results of Joint Thermal and Acoustic Measurements

K. I. Kuznetsov, A. A. Sukhikh, P. P. Granchenko, and S. V. Skorodumov

Water Treatment and Water-Chemistry

Reagent-Free Water Treatment in the Domestic Power Industry: A Myth or a Reality?

S. L. Gromov

Steam Boilers, Power Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Study into the Combustion Process of Solid Fuel in Furnaces with Rectangular Burners

E. P. Volkov, V. B. Prokhorov, S. L. Chernov, V. S. Kirichkov, and A. A. Kaverin

Cyclone-Bed Furnaces: Experimental Studies and Thermal Design

E. A. Pitsukha, E. K. Buchilko, and Yu. S. Teplitskii

Metals and Strength Analysis

Specific Features of Electron-Beam Welding of ITER Blanket First Wall Components

V. K. Dragunov, A. P. Sliva, A. L. Goncharov, I. E. Zhmurko, E. V. Terent'ev, A. G. Sysoev, and A. Yu. Marchenkov

The Effect of Heat-and-Mass Transfer and Flow Hydrodynamics on the Corrosion-Erosion Wear Rate in Evaporators of Combined-Cycle Unit Heat-Recovery Steam Generators

V. S. Polonskii, D. A. Tarasov, and D. A. Gorr

Nuclear Power Plants

Simulation of Heat and Mass Transfer in Fuel Assemblies with Wire-Wrap Spacers
in the Anisotropic Porous Body Approximation

*A. S. Korsun, I. G. Merinov, V. S. Kharitonov, M. V. Bayaskhalanov,
V. V. Chudanov, A. E. Aksenova, and V. A. Pervichko*

Study into the Distribution of Mass Speed and Enthalpy of Single-Phase and Two-Phase
Flows in the Cross Section of a 19-Rod Beam in a Model of an Electrically Heated
RBMK-1000 Fuel Assembly

*D. A. Afremov, A. V. Basov, E. A. Boltenko, M. V. Davydov, A. I. Emelyanov,
I. V. Kononenko, and A. V. Stolpnik*

Long-Term Development Prospects of Russia's Wind Energy in the Conditions of Expected Climate Changes

V. V. Klimenko^{a,*} and E. V. Fedotova^a

^a*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

^{*}*e-mail: nilgpe@mpei.ru*

Abstract—The climatic effect on the operation of wind power plants in Russia is analyzed. Based on the global experience of wind farms' operation, a quantitative assessment of the sensitivity of electric power generation by modern wind turbines to wind speed variation is carried out. Using the ensemble approach, predictive estimates of changes in the wind fields in Russia are obtained for the 21st century using the results of general atmospheric circulation models participating in the international project CMIP5 (Coupled Multimodel Intercomparison Project Phase 5). The validity of the findings is ensured by the validation procedure, including a comparison of different versions of the multimodel ensemble with data reanalysis. The predictive estimate obtained for the climatic scenario developed at the National Research University Moscow Power Engineering Institute (NRU MPEI) is compared with generally accepted climatic scenarios based on the use of so-called greenhouse gas representative concentration pathways. It is shown that the choice of the scenario has a significant impact on the forecast results. However, the data of the calculations distinguish several features of the wind regime in the 21st century, which are almost independent of the selected scenario or ensemble composition and, apparently, can be considered reliable. In particular, it is found that there is a possibility of some decrease in average wind speeds in a significant part of Russia during the 21st century. However, in Primorskii krai, the expected climate change will lead to the formation of a zone with a steady increase in its speed. Changes in the technical wind potential in the regions of the country where the construction of wind turbines is planned will amount to from -15 to -20% for the subarctic regions and from $+5$ to -10% for Primorskii krai by the end of the 21st century. It follows from the calculations that the currently observed climate warming, in all likelihood, does not pose a serious threat to the development of wind energy in Russia. The modern and planned location of wind farms even makes it possible to expect some growth in their production rate in the first half of the 21st century. At the same time, the prospect of long-term changes in the wind regime should certainly be taken into account when selecting the wind farm location and predesign analysis as part of the measures aimed at adapting to climate changes.

Keywords: wind power, climate change, wind speed, climate scenarios

Study into the Separation Ability of the New NRU MPEI Peripheral Sealing

V. G. Gribin^a, S. S. Dmitriev^{a, *}, B. N. Petrulin^a, and M. E. A. E. Akhmed^{a, b}

^a*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

^b*Banha University, Shupra Department of Engineering, Department of Engineering, Banha, Egypt*

**e-mail: dmitriyevss@mpei.ru*

Abstract—Energy losses caused by steam humidity are one of the main components of losses in the steps of nuclear power plants' wet-steam turbines. The presence of moisture droplets in the flow part of the turbines also poses a serious danger due to erosion wear of their blades. Various separation systems remove part of the erosion-hazardous moisture. However, along with moisture, a certain amount of steam is removed from the flow part of the turbine, which will not take part in performing beneficial work in subsequent stages of this turbine. Other losses are steam leaks through seals, the largest of which occur in seals located above the turbine blades. On the basis of the rectangular-mesh seals developed and studied earlier, the design of a special peripheral seal for NPP turbines was developed at NRU MPEI. The new seal is capable of simultaneously performing two functions: to reduce over-leakage leaks and to ensure the separation of moisture from the flowing part. The results of the studies showed that the presence of special channels in the seal for removing drip moisture hardly worsen the flow characteristics of the new seal. This paper presents the results of experimental studies into the separation ability of new peripheral seals. As a two-phase medium, specially prepared moist air was used. To do this, a plant for the preparation of water and the generation of the droplet phase was designed and manufactured. During the experiments, the ability of the seal structure to remove moisture was investigated. The use of humidified air made it possible to accurately determine the amount of droplet moisture supplied to the seal and separated through it and the separation coefficient of the seal. Studies have shown that the amount of moisture separated through the seal depends on the pressure drop across it, the rotor speed, and the initial degree of humidity of the compressed air supplied to the seal. It is shown that the use of a new seal in the studied range of initial degrees of humidity allows the separation of up to 45% of the moisture passing through the peripheral gap above the working blades. In general, the results of the experiments showed that the use of a rectangular-cell seal from NRU MPEI as a peripheral seal in turbines of nuclear power plants is advisable to remove moisture from the gap above the working blade and to reduce peripheral steam leaks.

Keywords: overbinding seal, moisture, rectangular mesh seal, energy loss, separation, leakage, radial clearance

The Flow Boiling Crisis of Saturated Water in Pipes at High Pressures

M. V. Minko^{a,*}, V. V. Yagov^a, and S. S. Savekin^a

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: mvminko@gmail.com

Abstract—The procedures developed by the authors for calculating the distribution of the liquid over the channel cross section in the dispersed-annular flows open up opportunities for more justified modeling of the conditions for the occurrence of a boiling crisis at positive values of the relative enthalpy of the flow. However, a comparison of the calculated values of the liquid flowrate in the film with the recommended values of critical heat flux (CHF) in water flow boiling in pipes has demonstrated that, in general, there is no obvious correlation between them. An analysis confirms the well-known opinion that a unified model of the flow boiling crisis in pipes cannot be constructed. At the same time, the regularities revealed in calculating the entrainment and deposition of droplets should be considered in developing a crisis model. An increase in CHF with mass flowrate, which was discovered experimentally and accounted for in the reference tables in a wide range of high pressures and mass flowrates, gives us reasons to return to Doroshchuk's hypothesis about the “deposition crisis.” Application of the correlation for the droplet deposition rate in a disperse-annular flow enabled us to quantitatively verify this correlation. The predictions obtained using this correlation agree well with the tabulated data at a steam quality from 0.15 to 0.40 and mass flowrates above 2000 kg/(m² · s). At the same time, it has been demonstrated that the widespread use of extrapolation of the CHF values recommended in the latest edition of these tables makes them, in fact, not only unreliable but also physically unjustified in a certain range of parameters. This paper identifies several such ranges wherein revision of the tables is essential.

Keywords: boiling, heat transfer, crisis, critical heat flux, two-phase flow, dispersed-annular flow, entrainment, deposition, reduced pressure

Calculation Technique of Some Thermodynamic Functions Using the Results of Joint Thermal and Acoustic Measurements

K. I. Kuznetsov^{a,*}, A. A. Sukhikh^{a,**}, P. P. Granchenko^{a,***}, and S. V. Skorodumov^a

^aNational Research University "Moscow Power Engineering Institute", Moscow, 111250 Russia

*e-mail: kikuznlyc@mail.ru

**e-mail: SukhikhAA@mpei.ru

***e-mail: granchenkop@gmail.com

Abstract—An original method of calculating isochoric and isobaric heat capacity based on the fundamental relationships of thermodynamics is presented. The theoretical development of the methodology for calculating isochoric and isobaric heat capacity can be used to obtain high metrological data on the thermophysical properties of new low-boiling working substances of power plants operating on the Rankine organic cycle and to replenish existing databases. The technique allows the use of heterogeneous experimental results of acoustic and thermal measurements to calculate the basic thermodynamic functions without information about the values of ideal gas functions, and also to evaluate the consistency of experimental data. Formulas are derived for calculating isobaric and isochoric heat capacities, which are based on reliable equations describing experimental data on the speed of sound and density depending on state parameters. The method was tested using both the characteristics of the reference substances (H_2O and CO_2), and own new experimental data on the thermal and acoustic properties of octafluorocyclobutane ($c\text{-C}_4\text{F}_8$) in the liquid phase for temperatures of 320 and 340 K and pressures from 4 to 10 MPa. The isochoric heat capacity was calculated from measurements of the density of octafluorocyclobutane and the speed of sound in it. According to the latest series of density measurements in a limited region of the states of the liquid phase of octafluorocyclobutane obtained by the constant volume piezometer method, the isochoric heat capacity was calculated using the equation proposed in this work. The uncertainty of the experimental data used for the test calculation of the density did not exceed 0.25%, and the speed of sound did not exceed 0.05%. The standard deviation in the description of the dependence of thermal quantities was 0.23%, and acoustic — 0.15%.

Keywords: differential relations of thermodynamics, heat capacity, speed of sound, density, octafluorocyclobutane, organic Rankine cycle, standard deviation, constant volume piezometer method

Reagent-Free Water Treatment in the Domestic Power Industry: A Myth or a Reality?

S. L. Gromov*

National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

**e-mail: slgromov@mail.ru*

Abstract—Technologies aimed at reducing the consumption of reagents and the environmental impact resulting from the operation of water-treatment equipment in the domestic power industry are analyzed. Attention is focused on the specifics of the reagents' application in membrane-separation technologies. It is noted that the membrane technologies used for water treatment frequently involve the necessity of applying chemical reagents, the ingress of which into the sewage makes the utilization of the latter more difficult and increases the environmental impacts. A conclusion about the impossibility of completely abandoning reagents for water treatment has been made. A method for the environmentally friendly, reagent-free operation of membrane-separation plants has been devised and its viability has been proven by an example of a pilot nanofiltration water-treatment unit for the heat-supply system operating with a water of the potable quality. Approaches have been outlined that allow a reduction in the water-treatment costs of thermal power plants using integrated membrane technologies and/or their combinations with ion exchange. Despite the fact that there is no possibility of completely abandoning reagents for water treatment in common cases, membrane-separation technologies currently constitute the basis for engineering solutions that allow a reduction in the water-treatment costs and even the implementation of reagent-free techniques in particular cases.

Keywords: water treatment, reagent-free technologies, membrane separation, environmentally friendly nanofiltration and reverse osmosis, integrated membrane technologies and their combination with ion exchange

Study into the Combustion Process of Solid Fuel in Furnaces with Rectangular Burners

E. P. Volkov^a, V. B. Prokhorov^{a, *}, S. L. Chernov^a, V. S. Kirichkov^a, and A. A. Kaverin^a

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: ProkhorovVB@mail.ru

Abstract—The optimization of the boiler furnace's aerodynamics is considered in order to increase the efficiency of burning energy fuel by the example of burning lean Kuznetsk coal in a solid slag removal scheme. Combustion options have been proposed and investigated in schemes with direct injection of coal dust and with an intermediate coal dust bin. The schemes use direct-flow burners with an on-off arrangement and nozzles with a downward inclination, and stepwise combustion of fuel is used. A study of the furnace's aerodynamics on an isothermal bench was carried out. The results of physical modeling were compared with the data of numerical modeling of an isothermal bench. It is noted that combustion schemes differ in the intensity of vortex formation in the active combustion zone. A numerical simulation of fuel combustion in the boiler furnace was performed using the two indicated combustion schemes. The purpose of the simulation was to obtain the distribution of temperatures, gas velocities, concentrations of combustion products, nitrogen oxide emissions, degree of burnout in the furnace volume and other characteristics that affect the efficiency, reliability, and environmental safety of the boiler. The results of model studies showed that the developed schemes provide high efficiency of burning lean Kuznetsk coal with solid slag removal and, at the same time, low emissions of nitrogen oxides. An additional verification of the numerical model was carried out by comparing the gas temperatures by the height of the furnace obtained by its numerical simulation and thermal zoning calculations. A comparison of the temperatures of the gases at the outlet of each zone showed their good agreement (the difference was no more than 30°C).

Keywords: boiler plants, coal-dust furnaces, direct-flow burners and nozzles, step-by-step fuel combustion, physical isothermal modeling, computer simulation

Cyclone-Bed Furnaces: Experimental Studies and Thermal Design

E. A. Pitsukha^{a,*}, E. K. Buchilko^{a,**}, and Yu. S. Teplitskii^{a,***}

^a*Lykov Institute of Heat and Mass Transfer, National Academy of Sciences of Belarus, Minsk, 220072 Belarus*

^{*}*e-mail: pit.ea@mail.ru*

^{**}*e-mail: ebuchilko@gmail.com*

^{***}*e-mail: tep@hmti.ac.by*

Abstract—Furnace processes occurring in laboratory setups, pilot commercial facilities, and small-capacity boilers of various sized equipped with cyclone-bed furnaces containing fixed and fluidized beds burning solid biofuels (wood pellets, straw pellets, sunflower husk pellets, peat pellets, wood waste, wood chips, milled peat, and crushed peat bricks) are investigated. The distribution features of temperature and gas concentrations (CO, CO₂, H₂, O₂, CH₄) in the combustion and secondary combustion chambers have been established in the course of experiments. With this information available, it becomes possible to determine the zones in which fuel actively reacts with the oxidant under the conditions of two-stage vortex combustion. Dependences of the carbon monoxide (CO) and nitrogen oxide (NO_x) concentrations in the flue gases on the excess air ratio, bottom blast share (primary air), furnace power, and the combustion chamber's outlet hole diameter are obtained. The furnace processes in cyclone-bed furnaces are numerically simulated using the standard k – ϵ turbulence model and the Magnussen combustion model, and satisfactory agreement between the calculation and experimental results is shown. A semiempirical method for designing cyclone-bed furnaces has been developed, according to which their main geometrical and operating parameters are determined in two stages: a preliminary thermal design analysis is first carried out, after which the furnace process is numerically simulated. Based on extensive generalization of experimental data on the burning of solid biofuels in cyclone-bed furnaces having different diameters, the parameter $M = 0.52$, which appears in the well-known Gurchich formula for the thermal design of furnace chambers, has been determined. This parameter takes into account the temperature field structure and the heat transfer pattern over the furnace height, thus making it possible to use the standard method in carrying out thermal design computations of furnaces.

Keywords: cyclone-bed furnace, combustion chamber, secondary combustion chamber, fixed bed, fluidized bed, solid biofuel, numerical simulation, thermal design

Specific Features of Electron-Beam Welding of ITER Blanket First Wall Components

V. K. Dragunov^a, A. P. Sliva^a, A. L. Goncharov^a, I. E. Zhmurko^a, E. V. Terent'ev^a,
A. G. Sysoev^a, and A. Yu. Marchenkov^{a, *}

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: art-marchenkov@yandex.ru*

Abstract—Specific features of fabricating welded structures of the international thermonuclear experimental reactor (ITER) blanket components are considered. The results from elaborating the technology for electron-beam welding of cooling system's channel caps in the first wall bearing structure (FWBS) of the ITER blanket shielding module are presented. The design of welded joint samples made of Grade 316L(N) steel and the welding equipment are described. The welding techniques and butt joint design features whose use makes it possible to obtain the required strengthening of weld bead and to avoid metal droplets from appearing in the FWBS inner cavities are considered. A simplified thermal–mechanical model of the cap-welding technological process is described, and the results from experimentally evaluating the structural and mechanical state of the obtained welded structures are presented. A comparison between the modeling and experimental results is given. It is pointed out that the stressed and strain state varies in an active manner at the initial loading stage. Initially, the metal in the heat-affected zone (HAZ) experiences plastic deformation followed by elastic relief at the subsequent stages. It is pointed out that the postweld deformations are on the whole characterized by a low level and remain within the permissible limits. The distribution of mechanical properties in weld joint local zones determined using the indentation method is given. The results from tensile tests and an indenter impressing test show that the weld metal has even better mechanical characteristics than the base metal. Data are presented from metallographic investigations, which testify that there is no growth of grains in the HAZ, which is due to high rates of cooling in the used welding method. Based on the results of elaborating the electron-beam welding technology and using the developed techniques, an FWBS mockup has been fabricated that complies with the class VQC 1A tightness requirements.

Keywords: electron-beam welding, ITER, welded joint, grade 316L(N) steel, heat-affected zone, indentation method, plastic deformation, elastic relief

The Effect of Heat-and-Mass Transfer and Flow Hydrodynamics on the Flow Accelerated Corrosion Rate in Evaporators of Combined-Cycle Unit Heat-Recovery Steam Generators

V. S. Polonsky^a, D. A. Tarasov^a, and D. A. Gorr^{a, *}

^a*OOO Interenergo, Moscow, 112087 Russia*

**e-mail: Gorr_DA@interenergo.info*

Abstract—Flow accelerated corrosion (FAC) is considered one of the major causes of damage to heat-recovery steam generators (HRSG) of combined-cycle units. In the last few decades, a great number of papers devoted to this problem have been published in many countries around the world. The results of investigations were analyzed as a rule, on the basis of the flow-averaged thermochemical parameters of the flow, while the features of the near-wall liquid film determining the FAC rate were not taken into account. The indicators in the near-wall region depends on the heat-and-mass transfer conditions, flow hydrodynamics, and the specific of chemicals used to correct the water chemistry (WC). For ammonia and oxygen water treatment chemistries, an equilibrium model is proposed and its validity for HRSG evaporators is substantiated. The rate of the exchange of gas reagents between steam and water is determined by the distribution coefficient K_d . To simplify calculations, simple approximating correlations of K_d for ammonia and oxygen is recommended. For the water chemistry with solid reagents, a diffusion model has been developed to calculate mass transfer on the basis of data on heat transfer in steam-generating tubes. The concentration of reagents near the wall is determined by both the turbulent transport of the liquid between the flow core and the near-wall layer and the coefficient of reagent distribution between the phases. Simple approximating correlations of distribution coefficients for Na_3PO_4 , NaOH , and 90H Turb helamine are proposed. An approximate correlation between the hydraulic resistance coefficient K_h and the geometric parameter K_c of the FAC process has been established. The hydrodynamic fundamentals of the standard HRSG structural members have been studied in more detail than FAC. To estimate K_c , one can use the known value of K_h and the correlation between them. However, this correlation should be used with care since it has been obtained for certain conditions of unambiguity (i.e., specific construction material, water chemistry, flow history, etc.). Under other conditions, this correlation will change somewhat; therefore, it can only be used for rough estimation.

Keywords: heat-recovery steam generator, evaporator, economizer, geometric factor, water chemistry, pH, reagent, distribution coefficient, flow accelerated corrosion, heat transfer, mass transfer, hydrodynamics, thermochemistry

Simulation of Heat and Mass Transfer in Fuel Assemblies with Wire-Wrap Spacers in the Anisotropic Porous Body Approximation

A. S. Korsun^a, I. G. Merinov^a, V. S. Kharitonov^a, M. V. Bayaskhalanov^{a, *}, V. V. Chudanov^{b, **},
A. E. Aksenova^b, and V. A. Pervichko^b

^a*National Research Nuclear University Moscow Engineering Physics Institute (MEPhI), Moscow, 115409 Russia*

^b*Nuclear Safety Institute, Russian Academy of Sciences (IBRAE), Moscow, 115191 Russia*

**e-mail: MVBayaskhalanov@mephi.ru*

***e-mail: chud@ibrae.ac.ru*

Abstract—Results of the simulation of heat and mass transfer in fuel rod assemblies with wire-wrap spacers in the anisotropic porous body approximation using the developed APMoD software package are presented. The modifications introduced into the porous body's model to make it suitable for fuel assemblies with coiled spacing elements are described. The predictions of thermal and hydraulic characteristics in the liquid-metal cooled experimental and model fuel assemblies according to this updated model are presented. An isothermal sodium flow in a Bundle 2A experimental 19-rod assembly with wire-wrap spacers and uniform or nonuniform heating of the rods was studied. The predictions were compared with the experiments using the pressure difference across the assembly versus the coolant flowrate and the coolant temperature distribution in the assembly's outlet section. The thermal–hydraulic characteristics in the BN-1200 reactor fuel assembly's heated 19-rod fragment with its flow cross-section locally blocked in the central part calculated by the porous body model were compared with the predictions by the CONV-3D DNS code. Before their comparison, the distributions of local velocities, pressure, and temperature in an assembly cross-section calculated by the CONV-3D code were averaged over the averaging cells in the APMoD software package. It is demonstrated that the APMoD software package may be used to calculate parameters, which are averaged over a representative averaging cell, in a liquid-metal coolant flow in fuel assemblies with wire-wrap spacers with an accuracy adequate for engineering applications.

Keywords: fast reactors, liquid-metal coolants, anisotropic porous body model, integral turbulence model, comparison with experimental data, cross verification with DNS computations

Study into the Distribution of Mass Speed and Enthalpy of Single-Phase and Two-Phase Flows in the Cross Section of a 19-Rod Beam in a Model of an Electrically Heated RBMK-1000 Fuel Assembly

D. A. Afremov^a, A. V. Basov^b, E. A. Boltenko^{b, *}, M. V. Davydov^b, A. I. Emelyanov^a,
I. V. Kononenko^b, and A. V. Stolpnik^b

^aAO NIKIET, Moscow, 107140 Russia

^bAO ENIC, Elektrogorsk, Moscow oblast, 142530 Russia

*e-mail: boltenko@erec.ru

Abstract—The results of experimental studies into the distribution of mass velocity and enthalpy of single-phase and two-phase flows over the cross section of a 19-rod beam in an electrically heated model of an RBMK-1000 fuel assembly (FA) are presented. A description is given of the experimental section, which included a 19-rod electrically heated assembly of fuel-element simulators, a system for selecting a medium from cells, and a control system for moving samplers. A bunch of fuel rod simulators consisted of a central unheated rod and 18 electrically heated rods. The heated length of the beam bundle was 3500 mm. The sampling system from characteristic cells included sharp-edge samplers, a system for moving samplers from the starting position to the working position, and a cooling system and measuring sample parameters. Samplers corresponding in shape and geometrical dimensions to five characteristic cells were made of stainless steel. Single and biphasic samples were taken from characteristic assembly cells under the condition of isokineticity. The condition for the isokinetics of the selection was that the parameters of the coolant flow that entered the sampler remained the same as they were before the sampler was introduced into the stream. In the experiments, the achievement of the isokinetic condition was determined on the basis of the measured difference in static pressures in the cells and on the wall of the assembly housing. The results of experiments performed under isothermal and nonisothermal coolant flows in a wide range of mass velocities and enthalpies are presented. It has been shown that the distribution of the reduced mass velocity and steam flow rate over the beam cells depends on the flow regimes of the coolant flow that are formed in the cells.

Keywords: electric heated assembly, fuel cell simulator, isokinetic selection method, characteristic assembly cells, two-phase flow, flow regime, RBMK-1000