

Contents

Vol. 67, No. 7, 2020

Hydropower Deserves More Attention

Steam-Turbine, Gas-Turbine, and Combined-Cycle Plants and Their Auxiliary Equipment

A Method for Parametrically Representing the Aerodynamic Profiles
of Axial Turbine Machinery Blades

*V. G. Gribin, A. A. Tishchenko, R. A. Alekseev, V. A. Tishchenko,
I. Yu. Gavrilov, and V. V. Popov*

Experimental and Calculation Studies into the Possibilities of Improving
the Vibration Isolation of Power Installation Pipelines

A. V. Kirjukhin, O. O. Milman, A. V. Ptakhin, I. S. Serbin, and L. N. Serezhkin

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Assessing the Effectiveness of the Hydrothermal Carbonization Method to Produce Bio-Coal
from Wet Organic Wastes

M. S. Vlaskin and V. Kumar

An Analysis of the Prospects for Coal-Fired Thermal Power Station Reconstruction
on the Basis of Coal Gasification and a Combined-Cycle Unit

*I. A. Sultanguzin, A. V. Fedyukhin, E. A. Zakharenkov, Yu. V. Yavorovsky, E. V. Voloshenko,
S. Yu. Kurzanov, T. A. Stepanova, V. A. Tumanovsky, and V. A. Ippolitov*

Nuclear Power Stations

Physical Simulation of Dynamic Processes in Hydroelastic Systems at Nuclear Power Stations

S. M. Kaplunov, N. A. Makhutov, V. Yu. Fursov, V. A. Panov, and V. I. Solonin

Heat and Mass Transfer, Properties of Fluids and Materials

Study into the Influence of Internal Heat Sources on the Operating Characteristics
of a Thermoelectric Generator

V. S. Volgin and A. F. Ginevsky

Automation and Heat Control in Power Engineering

Assurance of Data Faultlessness in Automated Analysis of the Technical and Economic Indicators
for Power Unit Boiler Installations

E. M. Farhadzadeh, A. Z. Muradaliyev, T. K. Rafiyeva, and A. A. Rustamova

Water Treatment and Water Chemistry

Potentialities of Membrane Water Treatment for Removing Organic Pollutants from Natural Water

E. B. Jurchevsky and A. G. Pervov

Choice of Filter Material for a Mechanical Filter for Purification of Water after Liming

A. A. Panteleev, S. V. Aladushkin, A. S. Kasatokin, M. M. Shilov, and Yu. V. Chudova

ГИДРОЭНЕРГЕТИКА ЗАСЛУЖИВАЕТ БОЛЬШЕГО ВНИМАНИЯ!

DOI: 10.1134/S0040363620070097

Решением редколлегии внесены изменения в содержание и название тематической рубрики “**Энергосбережение, новые и возобновляемые источники энергии**”.

Эти изменения коснулись, прежде всего, гидроэнергетики. Этот вид генерации и ранее присутствовал на страницах журнала. Вопросы развития, эксплуатации установок малой гидроэнергетики (единичной мощностью до 10 МВт) освещались в рубрике о возобновляемых источниках. Значение гидроэнергетики для мирового энергетического баланса и баланса отдельных стран затрагивалось в рубрике “Общие проблемы энергетики”. Однако ни в одном из названий традиционных рубрик журнала термин “гидроэнергетика” не присутствовал. Редакционная коллегия считает такие ограничения несправедливыми по отношению к виду генерации, обеспечивающему 16% мировой выработки электроэнергии.

Другое изменение связано с исключением из названия рубрики термина “энергосбережение”. Энергосбережение оказалось в одной компании с возобновляемыми источниками энергии (ВИЭ) в те давние времена, когда никто не предполагал, что ВИЭ станут серьезным игроком на мировой арене. Они рассматривались как один из способов сократить потребление первичных энергоресурсов и тем самым добиться энергосбережения. За последние 30 лет ситуация принципиально изменилась: ВИЭ решительно расстались с второстепенной ролью помощника в решении проблемы энергосбережения и претендуют на ведущие роли в современной энергетике. Кроме того, понятие “энергосбережение” весьма широкое и его отражение можно легко найти в статьях, которые печатаются в большинстве рубрик журнала: будь то турбины, котлы или теплофикация и т.д. По этим причинам принято решение слово “энергосбережение” из названия рубрики исключить. Это вовсе не означает, что редколлегия теряет интерес к вечной проблеме эффективного производства, передачи и потребления энергоресурсов. Просто материалы по этой проблеме будут включаться в соответствующие рубрики по принадлежности.

Таким образом, теперь название рубрики формулируется как “**Возобновляемые источники энергии, гидроэнергетика**”. По сравнению с нынешним ее содержание расширяется благодаря включению в рассмотрение следующих проблем гидроэнергетики больших мощностей:

- ГЭС – проблемы эксплуатации, экологические аспекты;
- новые технические решения конструкций гидроагрегатов и систем управления;
- надежность, диагностирование, ресурс энергетического оборудования;
- кавитация и эрозионные процессы в гидромашинах;
- комбинированные энергоисточники на основе гидравлической энергии.

Редколлегия приглашает организации, занимающиеся этими проблемами, направлять результаты своих исследований для публикации в обновленной рубрике журнала и рассчитывает на плодотворное сотрудничество.

*Главный редактор,
А. Клименко*

A Method for Parametrically Representing the Aerodynamic Profiles of Axial Turbine Machinery Blades

V. G. Gribin^{a,*}, A. A. Tishchenko^a, R. A. Alekseev^a, V. A. Tishchenko^a, I. Yu. Gavrilov^a, and V. V. Popov^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: GribinVG@mpei.ru*

Abstract—A parametric method for designing the cross sections of axial turbine machinery blade airfoils is described. Analytical Bezier curves are used for representing the profile generatrices and the skeleton line. Their shapes are uniquely determined by a set of 13 parameters that are related to the turbine cascade's aerodynamic and strength characteristics. These parameters determine the main points through which the profile generatrices must pass at the specified tangent line angles. In general terms, the blade shape's design calculation involves the following sequential stages: calculating the geometrical constraints based on 13 parameters, determining the skeleton line shape, and calculating the profile suction and pressure sides. By using the proposed method, it is possible to control the blade shape taking into account the imposed geometrical conditions, including the surface curvature distributions. A distinguishing feature of the proposed method is its adaptability: the degree of Bezier curves is determined during calculation by means of multidimensional minimization. This feature imparts flexibility to the method in terms of the possibility to specify the parameters in wide ranges of their values, thus making the method versatile in nature. An algorithm for iteratively determining the curve shape through calculating the skeleton line is presented. The proposed approach is supplemented by a procedure for automatically parameterizing the profiles specified as unevenly distributed pointwise coordinates of their generatrices. This opens up the possibility to represent the already existing blade shapes in the form of 13 parameters and to optimize them.

Keywords: profiling, parametric designing, power loss, turbine blades, axial turbomachines

Experimental and Calculation Studies into the Possibilities of Improving the Vibration Isolation of Power Installation Pipelines

A. V. Kirjukhin^{a, b, *}, O. O. Milman^{a, b}, A. V. Ptakhin^{a, b}, I. S. Serbin^c, and L. N. Serezhkin^a

^a*Tsiolkovskii Kaluga State University, Kaluga, 248023 Russia*

^b*ZAO Turbocon, Kaluga, 248010 Russia*

^c*OOO Kaluga Turbine Works, Kaluga, 248010 Russia*

**e-mail: turbocon@kaluga.ru*

Abstract—The article presents the results from studying methods and means for reducing the transfer of vibration and pressure pulsations from power installations through elastic vibration isolators of pipelines carrying liquids (cooling water, condensate, or petroleum products) by suppressing the vibration forces and pulsations of the medium by active suppression systems. The results of studies into this subject carried out within the framework of the agreement between the Russian Scientific Foundation and the Tsiolkovskii Kaluga State University are reported. The article discusses the results from calculation and experimental studies aimed at determining the influence of liquid on the vibration-isolating performance of different kinds of pipeline compensators, including those based on bellows, sleeve-type ones made of rubber cord materials, those based on rubber cord shells, and compensators of a new type containing elastic inserts made using thin-layered rubber-metal elements with the minimal interaction between the structure and working medium. The investigations were carried out with the aim to minimize the transfer of vibration through the compensator by improving its design. The results from experimental studies into the effectiveness of joint suppression of the vibration and pressure pulsations by active methods for reducing the transfer of vibration from power installations to the foundation by means of pipeline compensators are presented. It is shown both analytically and experimentally that there is a frequency band in which the vibration forces transferred through the compensator structure are suppressed by the forces from pressure pulsations. The transfer of vibration becomes a factor of ten or more less than it is in the compensator tested without liquid. A physical explanation for this phenomenon is given, and ways of using it in practice are suggested. A two-channel active vibration protection system with a digital control device containing controllers in the form of standard Butterworth, Chebyshev, and band-pass filters, as well as resonance sections in its feedback circuit, is experimentally studied. With the active joint wide-band suppression of vibration forces and pressure pulsations determining the transfer of vibration through the compensators of pipelines with liquid, the effectiveness was found to be up to 32 dB in the frequency band from 10 to 350 Hz.

Keywords: power installation, vibration, pressure pulsations, vibration forces, vibration protection, air noise, pipeline, compensator, active vibration protection system

Assessing the Effectiveness of the Hydrothermal Carbonization Method to Produce Bio-Coal from Wet Organic Wastes

M. S. Vlaskin^{a, *} and V. Kumar^b

^aJoint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

^bDepartment of Chemistry, Uttarakhand University, Dehradun, 248001 India

*e-mail: vlaskin@inbox.ru

Abstract—The study is devoted to the assessment of the thermodynamic efficiency of the hydrothermal carbonization (HTC) method to produce bio-coal from wet organic waste (biomass). The HTC method is a process of thermochemical conversion of biomass into solid biofuel (bio-coal) as a result of its heating up to 150–280°C in the presence of water. The competitive advantages of the HTC method and the properties of bio-coal produced by this method from various organic waste are analyzed. The energy consumption values for implementation of the HTC process and the conventional torrefaction method are compared. It is demonstrated that the energy consumption in the production of bio-coal by the HTC method is several times lower than in the torrefaction process since water heated at a high pressure remains a liquid. This, in turn, offers a high potential for recovery of thermal energy (approximately 87%) in the HTC process. The heating value of the produce bio-coal is as high as 27 MJ/kg, which is comparable with that of commercial power coals. An analysis of the properties of biochar produced in the HTC process suggests that, in principle, it may be burned at coal-fired power stations together with conventional coal (if proper gas treatment equipment is available). The HTC method can be used for pretreatment of water-rich organic wastes and biomass to produce a quality fuel and a water solution that can be used as a base for production of fertilizers.

Keywords: organic wastes, hydrothermal carbonization, torrefaction, thermochemical conversion of biomass, bio-coal, biofuel, thermodynamic effectiveness, heat recovery

An Analysis of the Prospects for Coal-Fired Thermal Power Station Reconstruction on the Basis of Coal Gasification and a Combined-Cycle Unit

I. A. Sultanguzin^{a,*}, A. V. Fedyukhin^a, E. A. Zakharenkov^b, Yu. V. Yavorovsky^a, E. V. Voloshenko^a, S. Yu. Kurzanov^a, T. A. Stepanova^a, V. A. Tumanovsky^a, and V. A. Ippolitov^a

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bThermodflow Company, Jacksonville FL, 32246 United States

*e-mail: SultanguzinIA@mpei.ru

Abstract—Modern trends in technical reequipment of coal-fired thermal power stations (TPS) are analyzed by the example of the Verkhnetagil'skaya District Power Station (GRES), where obsolete coal-fired power units requiring replacement were in operation. This problem is specific for many Russian thermal power stations. Two alternatives of reequipment are considered: replacement of obsolete steam-turbine power units with a natural gas-fired combined cycle unit (CCU) and conversion of coal-fired power units into integrated gasification combined-cycle units (IGCCU) with gas turbines operating on purified synthesis gas. Technical reequipment of the considered TPS was performed by replacing the coal-fired steam-turbine power units of phase I–II with a 420 MW CCU. The CCU core was a 288 MW Siemens SGT5-4000F gas turbine. A CCU on its basis was modelled in the THERMOFLEX code. The calculated results demonstrated high power and environmental effectiveness in replacement of coal-fired power units at TPSs with natural gas-fired CCUs, thereby cutting down coal equivalent consumption by 727 000 t.c.e. (or 25%). For conversion of a TPS to an IGCCU, the fuel saving could be as great as 543 000 t.c.e./year (18%) under comparable conditions. In this case, the atmospheric emissions (of dust and SO₂) could be decreased many times (by 99%) due to implementation of an effective gas treatment process in the gasification system. Due to the huge coal reserves in Russia, the conversion of coal-fired TPSs to modern technologies with coal gasification may be a promising alternative for many TPSs during their reconstruction. In addition, it will contribute to improving the country's energy security. In addition, this will improve the country's energy security.

Keywords: thermal power station, combined-cycle unit, equipment revamping, coal gasification, natural gas, fuel and energy balance

Physical Simulation of Dynamic Processes in Hydroelastic Systems at Nuclear Power Stations

S. M. Kaplunov^{a,*}, N. A. Makhutov^a, V. Yu. Fursov^a, V. A. Panov^{b,**}, and V. I. Solonin^{c,***}

^a*Blagonravov Mechanical Engineering Research Institute, Russian Academy of Sciences, Moscow, 101990 Russia*

^b*Afrikantov OKB Mechanical Engineering, Nizhny Novgorod, 603074 Russia*

^c*Bauman Moscow State Technical University, Moscow, 105005 Russia*

**e-mail: saveliykaplunov@gmail.com*

***e-mail: vapanov@okbm.nnov.ru*

****e-mail: tlu-17@bmstu.ru*

Abstract—Basic approaches are outlined to solving complex engineering problems arising in the design and operation of power units at nuclear power stations (NPS) and based on large-scale physical simulation of dynamic conditions and parameters of dynamics and structural strength of modern power facilities. A procedure for physical simulation of specific dynamic processes in hydroelastic systems has been developed. Taking into account the identified distributions of pressure pulsations and flow rates on the surfaces of the structures of the investigated reactor plants (RU), hydrodynamic loads in various structures and facilities of modern power-machine buildings were determined considering the found distribution of fluctuations in flow pressure and velocity acting on the structure surfaces. The dynamic response parameters of the main structural members, such as dynamic strains and stresses, were obtained and analyzed. The effect of added masses of liquid, damping, and other factors on the dynamic processes in hydroelastic systems and ways for its reduction to increase the durability and service life of structures, first of all the critical elements of the studied power systems for each commissioned reactor, are determined. This approach is based on a comprehensive investigation of the interaction of a turbulent flow with the multicomponent structure of a reactor unit. The results of investigation confirmed the structure serviceability as to the relative error. The fitness for service of a structure during a specified operation time of the power unit was assessed. The implementation of the proposed approach involving large-scale physical simulation and, in many cases, numerical modeling, confirmed its effectiveness and the validity of the results obtained by the authors.

Keywords: physical simulation, reactor, hydrodynamic loads, main structures and components of a reactor unit, pressure, velocity, vibrations, dynamic strains and stresses, vibration frequency, stiffness, damping, durability

Study into the Influence of Internal Heat Sources on the Operating Characteristics of a Thermoelectric Generator

V. S. Volgin^{a,*} and A. F. Ginevsky^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: volginvs@list.ru*

Abstract—The influence of internal heat sources on temperature distribution during the operation of thermoelectric generators (TEG) is investigated. Taking into account various factors affecting the temperature regime, including internal heat sources, a multilevel model of a two-stream TEG has been developed, which allows one to calculate the temperature distribution and the integral characteristics of the generator. The calculations were carried out using the PHOENICS package; as a result, the dependences of the electrical characteristics and the temperature drop on the junctions on the load resistance, speed, and coolant temperature were obtained. A comparison is made with the corresponding indicators in the absence of internal heat sources. It is concluded that the influence of internal heat sources on the temperature drop and electric power increases with decreasing load resistance. Thus, in the maximum power mode, which corresponds to the ratio of the load resistance to the internal resistance of the module $m = 1.15$, the temperature drop decreases by 3.5–4.0%, while that at $m = 0.01$ is by 7.5–8.5%. TEG power in maximum power mode decreases by 7.5–8.0%. Studies have shown that the influence of internal heat sources on the characteristics of the TEG is more substantial when the flow rate in the heat exchangers is lower. The greatest decrease in the values of indicators due to the influence of internal sources was observed at $v = 0.2$ m/s and amounted to 5.5–6.0% for the temperature difference and 12–13% for power. The results obtained indicate that the influence of internal sources on the characteristics of TEGs is very significant, which implies that the most accurate estimates of the thermal and electrical performance of TEGs can be made only by taking into account the effect of internal heat sources on the temperature distribution in TEGs.

Keywords: thermoelectric generator, Seebeck effect, Peltier effect, mathematical modeling, internal heat sources, effective thermal conductivity model

Assurance of Data Faultlessness in Automated Analysis of the Technical and Economic Indicators for Power Unit Boiler Installations

E. M. Farhadzadeh^{a, *}, A. Z. Muradaliyev^a, T. K. Rafiyeva^a, and A. A. Rustamova^a

^a*Azerbaijan Scientific-Research and Design-Prospecting Power Engineering Institute, Baku, Az1012 Azerbaijan*

**e-mail: elmeht@rambler.ru*

Abstract—The performance efficiency of automated intelligent systems (AISs), which provide the managing personnel of electric power systems not only with systematically ordered information about the technical state of equipment and installations but also with recommendations on arranging their operation, maintenance, and repair, depends first of all on the safety and faultlessness of the relevant databases. Continuous monitoring of the indicators characterizing the technical state of equipment and installations involves high costs that are far from always being justified. Therefore, in most frequent cases, these indicators are determined from the results of tests and emergency and scheduled repairs. In fact, this information is discrete in nature and is entered in the database from dedicated logbooks. The urgency of automated settling of matters concerned with arranging maintenance and repair becomes even more important in view of the fact that no less than half of the main equipment and installations operating in electric power systems have worked out their fleet life in many respects. The use of indicators like thermal efficiency margin or permissible number of short circuit fault clearances by a circuit breaker for technical state management purposes leads to a higher risk of making erroneous decisions under these conditions. Therefore, the urgency of the problem of ensuring the safety and faultlessness of AIS databases does not decrease with time but, on the contrary, constantly tends to become more important. As an example of incorrectness of the existing approach to recognition of gross errors, the article considers data on the monthly average values of technical and economic indicators of the boiler installations of gas-and-oil fired 300-MW power units. It is pointed out that the sample of monthly average values of technical and economic indicators is inconsistent with the representative sample from the general totality of data. An interval checking method and a checksum method for recognizing gross errors have been developed and approbated. The first method is based on comparing the realizations of technical and economic indicators with their possible variation interval, and the second method is based on comparing the estimated and real annual average values of the realizations of technical and economic indicators. By using the proposed methods, it is possible to decrease the risks of elaborating erroneous recommendations, making erroneous decisions, and spending excessive costs.

Keywords: safety, faultlessness, technical and economic indicators, sample, general totality, database, boiler installation

Potentialities of Membrane Water Treatment for Removing Organic Pollutants from Natural Water

E. B. Yurchevsky^{a,*} and A. G. Pervov^b

^a*OKB Gidropress, Podolsk, Moscow oblast, 142103 Russia*

^b*National Research Moscow State University of Civil Engineering, Moscow, 129337 Russia*

**e-mail: aquachim@yandex.ru*

Abstract—The potentialities of using ultrafiltration, nanofiltration, and reverse-osmosis membranes for removing organic compounds from water are considered. Experimental results obtained by the authors and the information taken from the literature characterizing the interaction between membranes and organic compounds contained in natural water are presented. Data are obtained concerning the efficiency of different membrane technologies in the removal of organic compounds from natural water. The growth rate of the deposits of organic substances having different molecular weight has been studied. The effect of the membrane's material and the hydrodynamic mode of the membrane's operation on the formation rate of organic deposits has been demonstrated. The influence of these substances' nature, their concentration in natural water, and the molecular weight thereof on the deposition rate on membranes have been revealed. In the experiments, tap water taken from the Moscow water supply and river water were used. The results of the authors' experiments and the results obtained by other Russian and foreign researchers presented in the paper make it possible to consider ultrafiltration as a reliable way to retain organic macromolecules as well as finely dispersed and colloidal impurities. With retaining low-molecular organic compounds that determine the color of water, ultrafiltration is restricted. In the synthesis of nanofiltration membranes, films with different pore size and charge are used. Therefore, for a specific water source and water consumer, an individual choice of nanofiltration membranes is required, a wide range of which is available in the market. Nanofiltration membranes of the NE-90 and NE-70 types for surface waters having a color of 20–100 degrees provide a 85 and 75% decrease in the oxidability level, respectively. According to the results of studies concerning the efficiency of artesian water purification, domestic OPMN-K nanofiltration membranes can also profoundly purify water from natural organic compounds. Among all the membranes used in the water treatment technology, reverse-osmosis membranes have the smallest pore size; their use provides retaining organic compounds with a molecular weight lower than 100 Da. The studies have shown that reverse-osmosis membranes exhibit a 99.5% retention level for the compounds with a molecular weight of 150 Da and a 99.9% retention level for the compounds with a molecular weight higher than 1000 Da. To reveal the nature and concentration of organic compounds deposited on the membranes, water spectrograms have been used.

Keywords: membrane technologies, clarification and desalination of water, organic pollution, interaction between organic pollutants and membranes

Choice of Filter Material for a Mechanical Filter for Purification of Water after Liming

A. A. Panteleev^a, S. V. Aladushkin^{b, *}, A. S. Kasatokin^b, M. M. Shilov^b, and Yu. V. Chudova^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*Research and Production Company Median-Filter, Moscow, 105318 Russia*

**e-mail: Aladushkin@mediana-filter.ru*

Abstract—The possibility of using quartz sand as a filter material for mechanical filters in the schemes of preliminary water treatment in water treatment plants with coagulation and liming at thermal power plants is considered. Comparative experiments on filtering water through quartz sand at the laboratory bench of an operating thermal power plant showed the absence of leaching of silicic acid from sand at pH = 10.0–10.2 and a filtration rate of 7 m/h. The turbidity of the filtrate is close to zero, and the quality of the water obtained after filtering through quartz sand is higher than when filtering through hydroanthracite. Hydroanthracite is characterized by relatively high abrasion and increased cost in comparison with quartz sand. Model experiments were carried out in a wide pH range when filtering water through sand, which showed the absence of a significant release of silicic acid into water. We studied the long-term interaction of water with quartz sand at pH = 12, in which there is no intensive release of silicic acid compounds into water. Studies of the quality of the filtrate of mechanical filters loaded with quartz sand and hydroanthracite at a high pH of the treated water were performed. To prevent silicic acid compounds from entering clarified water, it is recommended that the first portion of the filtrate of the mechanical filters be discharged before being put into operation after a long period of inactivity. Recommendations on the use of quartz sand as a filter material in mechanical filters of the preliminary water treatment scheme at thermal power plants are presented.

Keywords: mechanical impurities, filter material, quartz sand, hydroanthracite, solubility, clarifier, coagulation, liming, mechanical filter