

# Contents

---

---

Vol. 67, No. 8, 2020

---

---

## Nuclear Power Plants

Using Neural Networks in Atomic Energy Thermophysical Problems (Review)

*A. R. Zabiroy, A. A. Smirnova, Yu. M. Feofilaktova, R. A. Shevchenko,  
S. A. Shevchenko, D. A. Yashnikov, and S. L. Soloviev* 5

Verification of a CFD-Class Software Tool as Applied to Modeling the Fuel Assemblies of Liquid Metal Cooled Reactors

*D. A. Afremov, A. A. Dunaitsev, A. G. Zakharov, A. V. Nedaivozov, V. P. Smirnov,  
A. V. Tutukin, and D. V. Fomichev* 20

Preoperational Tests of the PIRATE Program for Identifying and Assessing the Depth of Defects in Heat Exchangers of Nuclear Power Plants' Steam Generators

*A. G. Zhdanov, V. P. Lunin, A. A. Stolyarov, and E. G. Schukis* 29

Optimizing the Design of the Steam-Receiving Perforated Sheet Used in the PGV-1000MKO Steam Generator

*V. Yu. Volkov, L. A. Golibrodo, A. A. Krutikov, O. V. Kudryavtsev,  
A. P. Skibin, and V. V. Sotskov* 37

---

## Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Application of the Parametric Method for Profiling the Interblade Channels in the Nozzle Cascades of Axial-Flow Turbine Machines

*V. G. Gribin, A. A. Tishchenko, R. A. Alekseev, V. A. Tishchenko, I. Yu. Gavrilov, and V. V. Popov* 50

---

## Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Investigation into Factors Causing Damage to Low-Pressure Loop Evaporating Tubes of Large-Capacity Heat-Recovery Steam Generators

*K. A. Pleshanov, R. S. Maslov, V. S. Pankov, K. V. Sterkhov, and D. A. Khokhlov* 58

---

## Heat and Mass Transfer and Properties of Working Fluids and Materials

Investigation of Thermohydraulic Characteristics of Vortex Chambers

*A. V. Vikulin and N. L. Yaroslavtsev* 70

Method for Optimization of Heat-Exchange Units Working in Heat Disposal Systems

*O. E. Prun and A. B. Garyaev* 78

---

## Water Treatment and Water-Chemical Mode

Features of the Water-Chemical Mode of the I Circuit and Problems of Equipment Operation in the Reactor Units of Atomic Icebreakers

*D. S. Urtenov, Yu. B. Vorob'ev, V. E. Karnaukhov, A. L. Malysheva,  
M. E. Panina, and M. L. Lukashenko* 86

---

## **Energy Conservation, New and Renewable Energy Sources**

Application of Fuel-Cell-Based Power Installations at Thermal Power Plants

*R. S. Tsgoev*

93

---

## **Metals and Strength Issues**

Application of Software Tools for Predicting the Corrosion-Erosion Rate to Ensure Integrity of Equipment and Piping of Power Units at Nuclear Power Stations

*G. V. Tomarov and A. A. Shipkov*

101

---

---

# Using Neural Networks in Atomic Energy Thermophysical Problems (Review)

A. R. Zabiroy<sup>a, b, \*</sup>, A. A. Smirnova<sup>a</sup>, Yu. M. Feofilaktova<sup>a</sup>, R. A. Shevchenko<sup>a</sup>,  
S. A. Shevchenko<sup>a</sup>, D. A. Yashnikov<sup>a</sup>, and S. L. Soloviev<sup>c</sup>

<sup>a</sup>*Scientific and Engineering Center for Nuclear and Radiation Safety, Moscow, 107140 Russia*

<sup>b</sup>*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

<sup>c</sup>*All-Russia Research Institute for Nuclear Power Plants' Operation (AO VNIIAES), Moscow, 109507 Russia*

*\*e-mail: zabiroy@secnrs.ru*

**Abstract**—The prospects for the implementation of modern digital technologies based on artificial neural networks (ANN) in the nuclear facility safety analysis are considered and the review of works on this topic is presented. The review includes publications in which neural networks are used in experimental studies and their result processing in such areas as heat transfer and hydrodynamics in single-phase media, in phase transformations, and hydrogen safety. Computational methods of machine learning based on artificial neural networks are successfully used to identify the relationship between the input and output system parameters without building complex mathematical computational models as well as for systems in which processes are characterized by nonlinearity and data uncertainty. However, a unified approach to the substantiation and assessment of the applicability of such methods has not yet been formed. As a result of the analysis, the need is shown for special requirements in order to assess the applicability of these technologies and substantiation (verification and validation) of calculation models based on neural networks.

*Keywords:* machine learning, artificial neural networks, thermal hydraulics, nuclear power plants, verification, validation

# Verification of a CFD-Class Software Tool as Applied to Modeling the Fuel Assemblies of Liquid Metal Cooled Reactors

D. A. Afremov<sup>a,\*</sup>, A. A. Dunaitsev<sup>a</sup>, A. G. Zakharov<sup>a,\*\*</sup>, A. V. Nedaivozov<sup>a</sup>,  
V. P. Smirnov<sup>a</sup>, A. V. Tutukin<sup>a,\*\*\*</sup>, and D. V. Fomichev<sup>a</sup>

<sup>a</sup>AO NIKIET, Moscow, 107140 Russia

\*e-mail: afremov@nikiet.ru

\*\*e-mail: a.zakharov@nikiet.ru

\*\*\*e-mail: a.tutukin@nikiet.ru

**Abstract**—Methodical approaches to verification of a CFD-class code for modeling fluid dynamics and heat transfer processes within the boundaries of a fuel assembly (FA) used in liquid metal cooled reactors are proposed. For verifying the code, experiments that take into account the specific features pertinent to the flow of and heat transfer in liquid metal coolants in the fast reactor FAs with spacer grids were selected. The experiments cover the following regimes: turbulent flow of and heat transfer in liquid metals in the stabilized and nonstabilized sections in simple and complex shaped channels for which the flow structure in the near-wall region is the determining one; turbulent flow in channels containing elements that cause flow separation and redistribution of the flow rate over the cross section, and flow in channels containing abrupt flow constriction/expansion. Proceeding from the need to save computation resources in solving practical problems, the high Reynolds number turbulence model was used, which does not pose the requirement of fulfilling the  $y^+ \approx 1$  criterion for the dimensionless distance from the first computational node to the wall. The computations were carried out with the use of the high Reynolds number Realizable  $k-\varepsilon$  turbulence model with the standard near-wall function. The local Weigand model for the turbulent Prandtl number  $Pr_t$ , applied in a wide range of  $Pr$  number values, including those for liquid metals, was used. The maximum deviations of the calculated values from the experimental data for the practically important parameters are estimated.

**Keywords:** nuclear facilities, fuel assembly, liquid metal coolant, verification of CFD codes, ANSYS Fluent, Realizable  $k-\varepsilon$  turbulence model, turbulent Prandtl number  $Pr_t$ , Weigand model

# Preoperational Tests of the PIRATE Program for Identifying and Assessing the Depth of Defects in Heat Exchangers of Nuclear Power Plants' Steam Generators

A. G. Zhdanov<sup>a,\*</sup>, V. P. Lunin<sup>a,\*\*</sup>, A. A. Stolyarov<sup>a</sup>, and E. G. Schukis<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

*\*e-mail: zhdanov.andrew82@gmail.com*

*\*\*e-mail: LuninVP@mpei.ru*

**Abstract**—The paper presents the results of acceptance and pilot tests developed by the authors of the PIRATE program designed for automatic analysis of eddy current signals during routine monitoring of the metal state of the heat-exchange tubes in steam generators of nuclear power plants with VVER-440 and VVER-1000 reactor plants. As a result of “blind” acceptance tests using certified standard equipment, the detection of realistic defects on specially prepared pipe samples with four gradations of the characteristic size (defect depth) and the reliability of the eddy current control results with a different level of rejection criterion were determined. The obtained values of detectability and depth of defects satisfy the regulatory documents’ requirements. According to the results of acceptance tests, it is possible to use the PIRATE program at nuclear facilities. The purpose of the pilot tests was to compare the results of operational control obtained during scheduled preventive repairs by regular systems along with the conclusions of experienced expert analysts to the results of the analysis of the same signals by the PIRATE program in automatic mode. Pilot tests were carried out using data from operational monitoring of steam generators for nuclear power plants with both VVER-440 reactors and VVER-1000 reactors. Findings of defects with varying depths also meet the requirements of industry guidance documents. Based on analyzing the criteria for coincidence of the control data of the heat-exchange pipes generated by the PIRATE program in automatic mode and a regular system, a conclusion was made about the readiness of the program for industrial operation. In addition, it has been shown that the PIRATE program surpasses the foreign programs used at domestic nuclear power plants in some functional capabilities.

**Keywords:** heat-exchange tubes, multifrequency eddy current control, comparative analysis of signals, pipe defects, detectability, crack depth, PIRATE program, control reliability

# Optimizing the Design of the Steam-Receiving Perforated Sheet Used in the PGV-1000MKO Steam Generator

V. Yu. Volkov<sup>a,\*</sup>, L. A. Golibrodo<sup>a</sup>, A. A. Krutikov<sup>a</sup>, O. V. Kudryavtsev<sup>a</sup>, A. P. Skibin<sup>a</sup>, and V. V. Sotskov<sup>a</sup>

<sup>a</sup>AO OKB Hidropress, Podolsk, Moscow oblast, 142103 Russia

\*e-mail: vasya-volkov@yandex.ru

**Abstract**—The VVER-TOI reactor plant has for the first time been furnished with a new layout of steam generators in the NPP reactor building, according to which the steam produced in the steam generator is removed from it through one steam nozzle. The shift for using one steam-offtake nozzle results in that a nonuniform steam velocity field is produced in the separation volume between the evaporation surface and steam-receiving perforated sheets (SRPSs), which is caused by steam motion along the path with the lowest friction, and this can entail excessive carryover of moisture from the steam generator (SG). To obtain the necessary moisture-separation performance of a horizontal steam generator equipped with one steam nozzle, it is necessary to set up a uniform field of the steam velocity vector's vertical component in the separation volume with limiting the pressure loss in the SG steam path down to the design value. Therefore, it is proposed to arrange nonuniform flow friction along the steam motion path from the evaporation surface to the steam line by using a variable SRPS perforation ratio. In this study, a set of optimization numerical analyses of the SRPS design for the PGV-1000MKO steam generator performed using the CFD methods was carried out for determining the perforation ratio. In carrying out the optimization numerical analyzes, the performance characteristics of the steam-receiving device equipped with one steam nozzle located in the steam generator's upper part and consisting of more than 50 perforated sheets had to be made maximally close to the performance characteristics of the steam-receiving device equipped with ten steam nozzles. By using an elaborated computer model, a set of optimization numerical analyses of the SRPS design was carried out, and an optimized design version of the steam-receiving device with a variable perforation ratio for the PGV-1000MKO steam generator has been obtained.

*Keywords:* CFD-methods, AES-2006, VVER, steam generator, optimization, separation volume, computation fluid dynamics, steam wetness, perforation, mathematical modeling, STAR CCM+

# Application of the Parametric Method for Profiling the Interblade Channels in the Nozzle Cascades of Axial-Flow Turbine Machines

V. G. Gribin<sup>a,\*</sup>, A. A. Tishchenko<sup>a</sup>, R. A. Alekseev<sup>a</sup>, V. A. Tishchenko<sup>a</sup>, I. Yu. Gavrilov<sup>a</sup>, and V. V. Popov<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: GribinVG@mpei.ru*

**Abstract**—Examples of successful application of the technique for parametrically profiling the blades of axial-flow turbine machines are given. The interconnection between the cascade parameters and the profile parameters that are used for representing the blade profile's shape is described. The influence of each of the considered parameters on the flow characteristics downstream of the cascade, in particular, on the kinetic energy losses and working fluid outlet angle, is analyzed. The initial cascade is optimized for enhancing its aerodynamic efficiency by improving the streamlining of the blade suction side and trailing edge. The optimization results were confirmed by calculation and experimental investigations. By using the developed method, the problem of designing the turbine nozzle cascade for its operation under wet steam conditions with high-efficient removal of moisture from the steam turbine flow path has been solved. Based on the elaborated recommendations for controlling droplet flows through modifying the blade profile's shape, the profile and cascade have been designed that make it possible to obtain highly intensive growth of liquid film thickness and flowrate on the interblade channel surfaces in the places from which it can be removed through the interchannel separation slots. The accomplished set of calculation and experimental investigations has confirmed the effectiveness of the selected approach.

*Keywords:* profiling, parametric designing, energy losses, wet steam, liquid film separation, turbine cascade, blade shape, trailing edge

# Investigation into Factors Causing Damage to Low-Pressure Loop Evaporating Tubes of Large-Capacity Heat-Recovery Steam Generators

K. A. Pleshanov<sup>a,\*</sup>, R. S. Maslov<sup>a,\*\*</sup>, V. S. Pankov<sup>b,\*\*\*</sup>, K. V. Sterkhov<sup>a</sup>, and D. A. Khokhlov<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

<sup>b</sup>*Kirishi District Power Plant, Branch of PAO Second Generating Company of the Wholesale Electricity Market, Kirishi, Leningrad oblast, 187110 Russia*

*\*e-mail: PleshanovKA@mpei.ru*

*\*\*e-mail: MaslovRS@mpei.ru*

*\*\*\*e-mail: pankov.vs@mail.ru*

**Abstract**—The article addresses factors causing damage—in particular, flow accelerated corrosion wear (FAC) of tube walls—to the evaporator operating in the low-pressure loop of the Ep-258/310/35-15.0/3.14/0.44-540/535/263 (P-132) heat-recovery steam generator used as part of a 795-MW combined-cycle plant. Factors influencing the FAC, namely, improper water chemistry, availability of gas shunts in the steam generator, and high mixture motion velocity in the tubes in combination with the flow path configuration, are described. The damages inflicted to the tubes and their locations in the heat-recovery steam generator low-pressure loop are described. It is shown that gas shunts in the heat-recovery steam generator result in an increased heat absorption and higher velocity of medium in the boundary tubes of low-pressure evaporator tube banks, which intensifies the tube's wear process. It has been found that the water chemistry used for the Kirishi District Power Plant (DPP) heat-recovery steam generator was not the factor that caused damage to the low-pressure loop tubes. The Kirishi DPP steam generator was compared with other similar large-capacity heat-recovery steam generators. For analyzing the low-pressure evaporator performance indicators, the loop and the processes occurring in it were modeled using the Boiler Designer computer program. An analysis of the results from comparison of the steam generator design and performance characteristics has shown that it is necessary to change the two-phase mixture motion velocity in the Kirishi DPP steam generator low-pressure loop by modifying the design or operating parameters. The wear of the low-pressure evaporator tube walls was mathematically modeled, the results of which confirm that erosion wear is one of the main factors causing damage to the tubes. The erosion is caused by the intense dynamic effect of two-phase, high-velocity flow jets on the tube walls. General recommendations for decreasing the wear of heat-recovery steam generator tubes are given. It has been determined that the increased wear of tubes in the low-pressure loop of the P-132 steam generator at the Kirishi DPP is caused by a combination of a few factors, such as high velocity of steam–water mixture, availability of bends, and unsatisfactory quality of matching the tubes at their welding places.

*Keywords:* heat-recovery steam generator, low-pressure evaporator, circulation loop, flow-accelerated corrosion, water chemistry, gas shunts



# Investigation of Thermohydraulic Characteristics of Vortex Chambers

A. V. Vikulin<sup>a, \*</sup> and N. L. Yaroslavtsev<sup>a</sup>

<sup>a</sup>*Moscow Aviation Institute (National Research University), Moscow, 125993 Russia*

*\*e-mail: vav106@yandex.ru*

**Abstract**—Local flow swirling is used in power facilities and other technical devices. It is an effective means for acting on the air flow structure and can enhance heat transfer. A swirled flow in axisymmetric channels belongs to the group of 3D flows in the field of centrifugal mass forces. It is characterized by the ratio of two (axial and rotational) or, in some cases, three components of the velocity, the presence of transverse and longitudinal pressure gradients, and high turbulent fluctuations that bring about certain difficulties in the investigation of processes occurring in a swirled flow and it complicates detection of their regularities. Therefore, it is proposed to install a vortex chamber (VC) at the leading edge of a blade or vane of a high-temperature gas turbine. Temperature conditions and flow capacity of VC models were studied by a calorimetric method in a liquid-metal thermostat. The regularities of heat transfer rate on the surface of the cooling channels were determined depending on the number and diameter of inlet (supply) and outlet holes for various pressure drops. The VK designs were optimized considering the effect of their geometry on the formation of various swirl flow structures with different levels of heat transfer enhancement. An analysis was performed with account taken of the throughput capacity of the models. The criterial dependences of the Nusselt number vs. Reynolds number  $Re$  were obtained for three VC designs for direct- or reverse-flow direction. The highest heat fluxes were observed on the section of coolant supply via holes, which is explained by a high velocity of the initial flow swirling. Flow swirl breakage and cooling air heating are the cause of a decrease in the relative heat transfer coefficient  $\bar{\alpha}$ . The self-similarity mode is observed at a pressure ratio across the vortex chamber above 1.4. The thermal problem was solved using data of the hydraulic tests of the models with air blowing under isothermal conditions. The results of experimental studies can be included in the data bank of heat and mass transfer software products to reduce the labor intensity and time in the development of a cooling system for blades/vanes of high-temperature gas turbines.

*Keywords:* vortex chambers, geometric characteristics, heat transfer enhancement, thermal and hydraulic characteristics, swirling airflow, method of calorimetric measurements in a liquid metal thermostat, high-temperature gas turbine, heat flux, heat transfer coefficient, Nusselt number

# Method for Optimization of Heat-Exchange Units Working in Heat Disposal Systems

O. E. Prun<sup>a,\*</sup> and A. B. Garyaev<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

<sup>\*</sup>*e-mail: olgaproon@mail.ru*

**Abstract**—The optimization of heat exchangers used in heat-recovery systems of heated media exiting process plants is considered. Such systems are widespread and used in various industries: energy, engineering, ferrous metallurgy, engineering systems of buildings. The authors propose an optimization method that uses target functions that take into account the mass and size characteristics of heat exchangers as well as the difference between the heat returned to the installation and the heat equivalent of electric energy required for pumping heat carriers through heat exchangers. Independent variables are consumable heat capacities of the coolants. Possible limitations are the maximum speeds of the coolants causing a large hydraulic resistance along the path. It is established that the target functions have a pronounced maximum. At certain values of the operating parameters, the target function acquires negative values and the use of heat exchangers becomes impractical. To correctly select the operating parameters of a specific heat-recovery unit, it is proposed to use thermohydraulic characteristics—graphs that reflect the dependence of the target function on the heat-transfer consuming heat capacities. Such dependences are obtained as a result of multiple calibration of thermal and hydraulic calculations for heat exchangers. Thermohydraulic characteristics can be built for each possible temperature mode of operation of the heat exchanger. They can be attached to the technical data sheet of devices and allow you to determine the optimal flow rates of coolants, providing the greatest savings in energy resources. They can also be used to select the desired apparatus from the size range. The heat-hydraulic characteristics calculated for the devices of the most common designs are presented: a plate heat exchanger with water–water heat carriers, a tubular finned gas-liquid heat exchanger, and a plate gas-air heat exchanger. It is shown that the maximum value of the target function when using the same coolants lies near the diagonal of the characteristic, i.e., at approximately equal values of the heat capacity. It is also shown that the use of thermodynamic criteria for optimizing heat exchangers of heat-recovery plants is not always advisable.

*Keywords:* heat exchangers, heat recovery, heat exchanger-utilizer, optimization, operating parameters, thermohydraulic characteristics

# Features of the Water-Chemical Mode of the I Circuit and Problems of Equipment Operation in the Reactor Units of Atomic Icebreakers

D. S. Urtenov<sup>a</sup>, Yu. B. Vorob'ev<sup>a, b, \*</sup>, V. E. Karnaukhov<sup>a</sup>, A. L. Malysheva<sup>b</sup>,  
M. E. Panina<sup>c</sup>, and M. L. Lukashenko<sup>a, \*\*</sup>

<sup>a</sup>National Research Center Kurchatov Institute, Moscow, 123182 Russia

<sup>b</sup>National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>c</sup>AO Baltic Plant, St. Petersburg, 199106 Russia

\*e-mail: yura3510@gmail.com

\*\*e-mail: mllu@yandex.ru

**Abstract**—Analysis of the experience gained in operating atomic icebreakers, the specifics of operating equipment of the first circuit, and the organization of the water-chemical regime shows the relationship between the high content of gases in the coolant and the problems of ensuring reliable equipment operation. Spatial modeling of vapor-gas bubbles' mass transfer in the SG-28 steam generator during damping confirmed the possibility of forming a gas cushion in the stagnant zone of the SG. The abrupt increase in the volumetric content of hydrogen during the transition from the liquid to the gas phase of the water coolant explains the anomalous hydrogenation in the area of weld no. 62 on the tubing of the AO SKBK design steam generators. The multiscale, multiphysical approach to conducting calculations was based on the adaptive use of different calculation codes in accordance with the required degree of analysis detail. Four computational models were developed—a common one based on the Relap5 code and three for the CFD code. An offline scheme of combining codes was used. Within its framework, a consistent decomposition of the general problem into computational domains was carried out; appropriate models for them were used, and organization of information exchange between models was based on the initial and boundary conditions. An analysis of the operating conditions and the nature of the mass transfer of vapor-gas bubbles, taking into account the patterns of their fragmentation, confirms the possibility of their entry into the active zone in transient conditions. The presence of oxygen in vapor-gas bubbles dramatically changes the corrosive environment and can cause the nodular corrosion of zirconium shells. To drastically reduce the content of noncondensable gases in the coolant of the first circuit, it was proposed to study the possibility of using a steam volume compensator instead of a gas compensator in promising projects of transport nuclear power plants (NPPs).

*Keywords:* atomic icebreaker, I circuit, gas content, abnormal hydrogenation, module corrosion, gas compensator, steam compensator

# Application of Fuel-Cell-Based Power Installations at Thermal Power Plants

R. S. Tsgoev\*

*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: TsgoyevRS@mpei.ru*

**Abstract**—The feasibility of using fuel-cell-based power installations (FCBPI) in auxiliary power (AP) systems at thermal gas/oil or gas-fired power stations is discussed. In this case, two options can be implemented at once: replacement of some district water heaters at a thermal power plant (TPS) with heaters using the heat of reaction products in FCBPIs and parallel power generation by TPS with the Rankine cycle and FCBPI. A thermodynamic analysis has demonstrated an increase in the thermal efficiency of TPSs since an FCBPI complex increases power delivery to a power system. Calculations were performed for a 300-MW power unit at a condensing power station (CPS). In particular, the installed capacity of FCBPIs was considered assuming that its thermal output is equal to the thermal output of network water heaters. In this case, additional power generation by the TPS power unit proper amounts to 50 632.8 MW h. Gas is supplied to the CPS power unit and FCBPIs from the same system. It is demonstrated that construction of such a complex is feasible if the FCBPI efficiency is higher than the net efficiency of the CPS power unit. This also yields natural gas saving throughout a year. The payback of the proposal for the use of FCBPIs is based on an increase in the KPS power output due to an increase in the thermal efficiency and the fact the FCBPIs deliver additional power (minus the auxiliary power) to the power system. In addition, turbine steam extraction to network water heaters and the generator power take-off to cover auxiliary power needs are eliminated. Therefore, according to the simplified calculations, the payback period for 25 MW FCBPIs operating on natural gas as a part of a 300-MW gas-fired CPS is approximately 2 years. The maneuverability of the CPS increases considerably within the FCBPI's installed capacity.

*Keywords:* auxiliary power needs, gas-fired thermal power station, fuel cell, complex efficiency, network water heaters, cogeneration unit, hybrid power unit, thermal efficiency

# Application of Software Tools for Predicting the Corrosion-Erosion Rate to Ensure Integrity of Equipment and Piping of Power Units at Nuclear Power Stations

G. V. Tomarov<sup>a,\*</sup> and A. A. Shipkov<sup>a,\*</sup>

<sup>a</sup>*OOO Geoterm-E, Moscow, 111250 Russia*

*\*e-mail: geoatom.m@gmail.com*

**Abstract**—Basic principles are examined of the application of software tools (ST) for predicting the erosion-corrosion (EC) rate to ensure the integrity of equipment and piping of nuclear power station (NPS) power units. Methods for solving the erosion-corrosion problems encountered in NPS power units have been determined. Software tools that are used most widely throughout the world to solve erosion-corrosion problems in the nuclear power industry are reviewed. The specifics in the application abroad and in Russia are highlighted. Attention is given to the successful foreign experience in improving the corrosion-erosion resistance of piping and equipment based on the solution implemented in designing NPS power units. Information is presented on the development of Russian software tools and the results of their application to render the integrity of piping and equipment of NPS power units with a VVER reactor or fast breeder reactor due to numerical prediction and early detection of the maximum allowable erosion-corrosion metal thinning. The feasibility is substantiated of using the software tools in designing new NPS power units with a VVER-1200 reactor, assessing the residual service life, and prolonging the operation of existing NPSs. Examples are given of the ways for reduction in the erosion-corrosion rate of equipment components and piping of nuclear power units, for example, by controlling the intensity of the hydrodynamic component of erosion-corrosion and proper selection of the metal. It is demonstrated that the cost of power units with a VVER-1200 reactor (including export deliveries) can be reduced by a change-over to less erosion-corrosion resistant but relatively inexpensive steels. The prospects are noted on application in practice of STs to assess the carry-over of iron-rich corrosion-erosion products into the working fluid of an NPS with a VVER-reactor. It is pointed out that, when changing over to operation of NPS power units at a super-rated power, this factor should be estimated using STs, and its effect on the wear rate and location of the zones wherein is the highest rate of thinning of the pipeline walls and equipment must be considered.

*Keywords:* nuclear power station power units, piping and equipment, erosion-corrosion, prediction software, operation monitoring, metal thinning