

Contents

Vol. 67, No. 9, 2020

Dear readers! 5

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

A Software Package for Simulating Physicochemical Processes and Properties
of Working Fluids

N. M. Kortsenshtein, G. Ya. Gerasimov, L. V. Petrov, and Yu. B. Shmel'kov 6

Development of Environmentally Friendly Technologies for Pyrolysis
of Organic Compounds

K. A. Lunin, N. A. Zroychikov, and S. A. Fadeev 20

Analysis of the Benefits of TPP's Three-Barrel Smokestacks

N. A. Zroichikov, A. M. Gribkov, M. I. Saparov, and K. M. Mirsalikhov 27

Evaluation of the Influence of Abrasive Wear on the Service Life
of Hydraulic Transport Systems

N. A. Zroichikov, V. Ya. Putilov, I. V. Putilova, S. A. Fadeev, and E. A. Malikova 35

Development of a Fluidized-Bed Reactor for Oxidative Torrefaction of Biowastes

*R. L. Isemin, S. N. Kuzmin, V. V. Konyakhin, O. Y. Milovanov, A. V. Mikhalev,
N. S. Muratova, A. V. Nebyvayev, and V. S. Kokh-Tatarenko* 46

Nuclear Power Plants

The Influence of Cesium Vapor Bulk Condensation on the Transport of Aerosols
in the Reactor Plant's Primary Circuit during a Severe Accident
at a Nuclear Power Plant Equipped with VVER Reactors

L. V. Petrov, Yu. B. Shmel'kov, and N. M. Kortsenshtein 55

Consideration of Uncertainties in Analyzing Nuclear Power Facilities' Fire Hazard

Yu. B. Vorob'ev, D. S. Urtenov, V. E. Karnaukhov, V. N. Podgornyi, and M. L. Lukashenko 61

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Determining Prototypes and Signs for Automated Diagnostics of Steam Turbine Equipment

*K. E. Aronson, B. E. Murmanskii, Yu. M. Brodov, V. B. Novoselov,
A. Yu. Sosonovskiy, and I. B. Murmanskii* 69

Nozzle Steam Distribution with a Remote Mixing Chamber

A. E. Zaryankin, I. P. Lavyrev, and M. A. Cherkasov 79

Renewable Energy Sources, Hydro Power Engineering

The Impact of Operating Parameters on the Performance of a New ORC-VCC Combination for Cogeneration

N. Toujani, N. Bouaziz, M. Chrigui, and L. Kairouani

85

Environmental Protection

Determining the Minimum Allowable Wastewater Purification before Discharging with Allowance for the Harmful Effect Summation

A. K. Sokolov

99

Heating and Heat Networks

Using a Fuzzy Prognostic Model in the Operative-Dispatch Analysis of Heat-Supply Systems' Operation

N. B. Agaev and R. J. Abdullaev

107

A Software Package for Simulating Physicochemical Processes and Properties of Working Fluids

N. M. Kortsenshtein^{a,*}, G. Ya. Gerasimov^b, L. V. Petrov^{a,c,d}, and Yu. B. Shmel'kov^d

^a*Krzhizhanovskii Power Engineering Institute, Moscow, 119071 Russia*

^b*Institute of Mechanics, Moscow State University, Moscow, 119192 Russia*

^c*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^d*National Research Center Kurchatov Institute, Moscow, 123098 Russia*

**e-mail: naumkor@yandex.ru*

Abstract—A software package consisting of the TETRAN-PRO and the COND-KINET-1 proprietary computer codes, as well as computational methods and models they are based on, is described. The TETRAN-PRO code calculates the composition and thermodynamic properties of a multicomponent reacting system under thermodynamic equilibrium conditions, including products of combustion or pyrolysis of organic and composite fuels. The difference of this code from similar ones is the use of the method of prevailing components, which is most effective as to convergence, computation time, and the range of parameters used. The code includes the necessary database of the original thermodynamic properties for 3000 individual substances. The TETRAN-PRO code's capabilities are demonstrated by the results from calculation of mercury vapors' conversion in the combustion products of Kuznetsk and Berezovo coals. The COND-KINET-1 calculates the parameters of a condensing aerosol formed during the volume condensation in a vapor-gas mixture flow. The process is described with a system of moment equations for the droplet size distribution function, which is closed by the equations of motion and energy. A comprehensive approach, thermodynamic and kinetic, has been formulated to the description of the volume condensation in multicomponent reacting systems based on the TETRAN-PRO and COND-KINET-1 codes. The approach's capabilities are demonstrated by the example of numerically simulating the formation of environmentally dangerous submicron particles in burning coals according to the condensation mechanism. Data on the concentration and size distribution of the generated particles are obtained. The predicted data on the fractional composition of particles are compared with the experiment.

Keywords: multicomponent reacting mixtures, fuel combustion products, volume condensation, submicron particles, numerical simulation

Development of Environmentally Friendly Technologies for Pyrolysis of Organic Compounds

K. A. Lunin^{a,*}, N. A. Zroychikov^{a,**}, and S. A. Fadeev^{a,***}

^a*Krzhizhanovsky Power Engineering Institute, Moscow, 119991 Russia*

^{*}*e-mail: lunin@eninnet.ru*

^{**}*e-mail: zroichikov@eninnet.ru*

^{***}*e-mail: fadeev@eninnet.ru*

Abstract—One of the priority scientific areas for many years at the Krzhizhanovsky Power Engineering Institute (ENIN) has been studying the processing of low-grade solid fuels with the production of valuable lighter hydrocarbons in demand in the energy and chemical industries. From 1970–1990 with the direct participation of the institute’s staff, a technology was developed and mastered on an industrial scale for the processing of oil shale using solid coolant. The article shows that ENIN created a serious scientific basis and developed methods for studying the thermal decomposition of low-grade fuels in their various modifications, which allows them to be used for experimental studies into the processing of a wide range of organic materials. Information is provided on the results of studies at the ENIN full-scale experimental stand on the creation of a new technology based on the pyrolysis of organic compounds (low-grade fuels) with the rationale for its use for solving the urgent task of class B and C waste disposal. The circuit diagram is described in detail and the experimental stand’s main components playing a key role in the technological process of environmentally friendly disposal of medical waste (MW) are described. Much attention is paid to the issue of quenching (high-speed cooling) of exhaust gases, which plays a major role in preventing the secondary formation of dioxins. Calculation of the quenching device in the ANSYS Fluent software environment is verified using experimental data. The results of the experiments showed that the measured concentration of dioxins and furanes in the exhaust gases obtained at the ENIN experimental stand during its operation on a typical model mixture of medical waste without the use of special gas purification agents amounted to 0.03 ngI-TEQ/m³ (I-TEQ—dioxin equivalent) under normal conditions at a concentration of O₂ equal to 11%, which is lower than the European standard (0.1 ngI-TEQ/m³)

Keywords: coal, oil shale, waste, pyrolysis, quenching, dioxins, environmental safety

Analysis of the Benefits of TPP's Three-Barrel Smokestacks

N. A. Zroichikov^{a,*}, A. M. Gribkov^{b,**}, M. I. Saparov^{a,***}, and K. M. Mirsalikhov^{b,****}

^a*Krzhizhanovsky Power Engineering Institute, Moscow, 119991 Russia*

^b*Kazan State Power Engineering University, Kazan, 420066 Russia*

**e-mail: zroichikov@eninnet.ru*

***e-mail: gribkovalmi@mail.ru*

****e-mail: saparov@teninnet.ru*

*****e-mail: mirsalihovkm@gmail.com*

Abstract—The structures of three- and four-barrel smokestacks are compared using the method of total discounted costs. It was revealed that three-barrel stacks are more profitable than four-barrel ones in almost the entire range of used smokestack characteristics with modern cost ratios. Formulas are given for calculating the diameter of the smokestack casing with two identical bores and a third, different in size. A technique has been developed for calculating the diameter of the casing of a three-barrel stack with bores of various diameters. In all compared variants, the same distances were laid between adjacent bores and the barrel and casing. For the first time, a methodology has been proposed for choosing the optimal dimensions of a three-barrel smokestack taking into account the individual conditions of gas transport along each barrel, allowing one to find the optimal distribution of gas velocities over bores of a three-barrel stack and to calculate the minimum total discounted costs for smokestacks with bores of different diameters, flow rates, and gas temperatures in them. It is shown that taking into account the hydrodynamic features in the bores with different gas velocities allows us to propose solutions that reduce the total reduced costs by 7–8% compared to traditional solutions. In the event that the optimal solution is to provide different speeds in the bores, then it is necessary to install confusers on each bore with individual and sufficient small angles of narrowing in order to prevent uneven velocity fields at the mouth of the smokestack and possible vortex formation when the flue gas flows from different bores merge when the stack is operating at maximum load.

Keywords: three- and four-barrel smokestacks, perimeters of barrels and reinforced concrete casing, multi-barrel smokestacks with different diameters of barrels, different temperatures of gases in the barrels, optimal speed of flue gases in each barrel

Evaluation of the Influence of Abrasive Wear on the Service Life of Hydraulic Transport Systems

N. A. Zroichikov^{a,*}, **V. Ya. Putilov**^b, I. V. Putilova^{b,**}, S. A. Fadeev^{a,***}, and E. A. Malikova^{b,****}

^a*Krzhizhanovsky Power Engineering Institute, Moscow, 119991 Russia*

^b*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: zroichikov@eninnet.ru*

***e-mail: PutilovaIV@ecopower.ru*

****e-mail: fadeev@eninnet.ru*

*****e-mail: Malikovaea@mail.ru*

Abstract—A review of the work devoted to studying the service life of power equipment's elements shows that important characteristics, such as silicon content, polydispersity, and particle shape of transported materials, are not taken into account in the formulas for calculating the abrasive wear of the hydrotransport pipelines of TPP's ash- and slag-removal systems. There are separate experimental values of the coefficients of relative abrasiveness of ash and slag materials, which differ significantly. Abrasive wear leads to a decrease in the reliability of the hydraulic ash-removal system, forced equipment downtime, environmental degradation in places where slurry pipelines are depressurized, and lower economic efficiency of ash and slag transportation. The causes of increased abrasive wear are considered, which leads to a decrease in the service life of pipelines of ash- and slag-removal systems in thermal power plants. The main factors affecting the abrasive wear of pipelines are identified, and their impact is evaluated. It is shown that one of the key characteristics that affect the wear rate of slurry pipelines is the abrasiveness of the transported material, which, in turn, depends on the content of silicon oxides as well as on the shape and size of the ash particles. The results of calculating the specific abrasive wear of slurry pipelines for various speeds and mass concentration of pulp during its transportation from boilers in which three types of coal of various characteristics are used as fuel are presented. The results can be used in planning the timing of repair and maintenance work in order to increase the over-haul period of hydraulic ash-removal systems.

Keywords: coal, ash abrasiveness, wear rate, specific abrasive wear calculations, slurry pipelines, hydraulic transport, hydraulic ash removal

Development of a Fluidized-Bed Reactor for Oxidative Torrefaction of Biowastes

R. L. Isemin^{a, *}, S. N. Kuzmin^a, V. V. Konyakhin^a, O. Y. Milovanov^a, A. V. Mikhalev^a, N. S. Muratova^a,
A. V. Nebyvayev^a, and V. S. Kokh-Tatarenko^a

^aTambov State Technical University, Tambov, 392000 Russia

*e-mail: penergy@list.ru

Abstract—Torrefaction is considered as a method for producing biofuels with improved characteristics compared to those of the “raw” biomass (higher calorific value, moisture resistance, better grindability). The torrefaction process is an endothermic process that is usually carried out in a gaseous atmosphere in the absence of oxygen. To reduce the required heat input, it is proposed to employ the oxidative torrefaction and conduct the process in a fluidized bed agitated with flue gases containing less than 6% oxygen. Preliminary studies of the oxidative torrefaction of sunflower husks, including thermogravimetric analysis of the treated material, have shown that the heat treatment time for the biomass should be at least 5 min. A fluidized bed is a reactor with ideal mixing of the treated material where uniform treatment of raw material particles cannot generally be attained. To overcome this disadvantage of the fluidization technique and achieve the required residence time for biomass in a fluidized bed during a continuous torrefaction process, it was proposed to equip a torrefaction reactor with a series of vertical baffles spaced at 50 mm. These baffles induce a loop-like flow of the processed biomass from the inlet to the outlet of the reactor. To investigate the residence time for husk particles in the reactor, a tracer, which was colored to husk particles’ color with a water-soluble dye which did not change the weight and size of the particles, was injected into the bed of uncolored particles. Tracer samples were taken every 30 s at the outlet of the reactor and were analyzed using a special procedure to determine the fraction of colored particles in each sample. This enabled us to gauge the time during which the colored particles injected into the fluidized bed reached the point of their discharge from the bed. Studies performed in a “cold” model of the reactor showed that a series of vertical baffles in the bed can provide the required residence time for biomass in a reactor including commercial reactors. Plates can provide the necessary biomass residence time in the reactor.

Keywords: torrefaction, torrefaction reactor, oxidative torrefaction, biomass, fluidized bed, sunflower husk, biomass thermogravimetric, residence time for particles in fluidized bed

The Influence of Cesium Vapor Bulk Condensation on the Transport of Aerosols in the Reactor Plant's Primary Circuit during a Severe Accident at a Nuclear Power Plant Equipped with VVER Reactors

L. V. Petrov^{a, b, c, *}, Yu. B. Shmel'kov^b, and N. M. Kortsenshtein^c

^a*Krzhizhanovsky Power Engineering Institute, Moscow, 119071 Russia*

^b*National Research Center Kurchatov Institute, Moscow, 123182 Russia*

^c*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: petrovlv@list.ru*

Abstract—The article presents the results from numerical modeling of aerosol particles' deposition process during their transportation in the horizontal section of the reactor plant's primary circuit model for the conditions typical for a severe accident at an NPP equipped with VVER reactors. The effect that the bulk condensation of cesium vapors has on the growth and deposition of aerosols during their transportation is analyzed. The influence of the initial size and concentration of aerosol particles on their growth rate and subsequent deposition is considered. Homogeneous condensation occurring in the absence of heterogeneous condensation nuclei (solid aerosol particles) and also heterogeneous condensation under the conditions in which nuclei of the new phase do not emerge according to the homogeneous mechanism are considered as the limit cases. Data on the average size of the produced droplets and aerosol particles along the channel axis in the condensation zone with the varied value of aerosol particles mass fraction in the flow have been obtained, which corresponded to different ratios of the condensate mass fraction in the form of droplets and liquid layer on the surface of solid aerosol particles. It has been established that the general deposition rate decreases if the flow contains droplets generated as a result of homogeneous bulk condensation and having a size smaller than the size of grown aerosol particles. The article describes the analysis scheme of the modeled section whose geometrical shape was specified based on the horizontal section of the experimental installation in the FALCON-ISP1 series of experiments on the deposition and transport of radionuclide aerosols. The cesium vapor homogeneous-heterogeneous condensation process is modeled by numerically solving—using the method of moments—the kinetic equation for the droplet size distribution function with involvement of the authors' COND-KINET-1 computer program. The transport and deposition of aerosol particles in the primary circuit channel were modeled using the MAVR-TA computer code developed at the National Research Center Kurchatov Institute.

Keywords: NPP safety, bulk condensation, cesium, fission products, aerosol particle deposition, severe accident, primary circuit, numerical modeling

Consideration of Uncertainties in Analyzing Nuclear Power Facilities' Fire Hazard

Yu. B. Vorob'ev^{a, b, *}, D. S. Urtenov^b, V. E. Karnaukhov^b, V. N. Podgornyi^a, and M. L. Lukashenko^b

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bNational Research Center Kurchatov Institute, Moscow, 123182 Russia

*e-mail: yura3510@gmail.com

Abstract—Paying increased attention to the safety of nuclear power facilities is a key element for their further development. An approach to analyzing their fire safety with due regard to the uncertainty factors associated with the parameters of applied models and with the fire breakout and development conditions is presented. The two-zone fire modeling code that takes into account the specific features of transportable (floating) nuclear power plants is used, and its basic characteristics are given. An original approach to a dynamic probabilistic safety assessment is applied, which is based on a global optimum search algorithm. This algorithm is used in this study for taking into account the uncertainties associated with combustion models, possible human actions, and change in the equipment's operation modes. The proposed method incorporates a genetic algorithm for searching the global optimum, the main purpose of which is to find the most hazardous fire development scenarios in accordance with adaptive variation of parameters within their uncertainty boundaries. Application of the method is demonstrated for two versions of fire breakout in the process rooms of a transportable power unit equipped with a nuclear power installation. The basic parameters of the two-zone fire model and dynamic probabilistic safety assessment are given. The results of computations for the dynamic probabilistic safety assessment demonstrate the complex nature of interaction among different processes. The data from analyzing the influence of the main parameters are given, a comparison with the standard calculation version and with the use of uncertainty analysis is carried out, and the conditional probability of the worst scenario is estimated. Owing to the consideration of uncertainties and the search for the most dangerous scenarios, it became possible to establish the fire development scenarios that can lead to essentially more severe consequences than those determined in using the standard parameters of two-zone fire models.

Keywords: safety analysis, fires, transportable nuclear power installations, floating power unit, dynamic probabilistic safety assessment, two-zone model

Determining Prototypes and Signs for Automated Diagnostics of Steam Turbine Equipment

K. E. Aronson^{a,*}, B. E. Murmanskii^b, Yu. M. Brodov^a, V. B. Novoselov^a,
A. Yu. Sosonovsky^c, and I. B. Murmanskii^a

^a*Ural Federal University, Yekaterinburg, 620002 Russia*

^b*PAO T Plus, Yekaterinburg, 620075 Russia*

^c*Management Company Teploenergосervis, Yekaterinburg, 620014 Russia*

**e-mail: lta_ugtu@mail.ru*

Abstract—Nowadays, turbine building plants try to equip their turbines with automatic control systems that include, in addition to their basic functions, automated fault-diagnosing procedures. The article presents the authors' experience gained from developing diagnostic systems and evaluating state parameters both for individual components of power equipment and for a power unit and thermal power plant as a whole; in addition, the specific features pertinent to the development of such automated systems are described. Such systems can be used for the purposes of operative and postoperative diagnostics. The first group of applications includes, e.g., vibration diagnostics of turbines, and the second group may include assessing the state of the thermal expansion system components, control system, and turbine plant auxiliary equipment; determining the technical and economic indicators; etc. Development of a prototype is the basis of any diagnostic task. In comparing the equipment's actual state with the state of the prototype, it is necessary to determine the values of the state parameters from which the diagnostic tasks are solved, i.e., the faults are detected. Diagnostic prototypes' development methods are identified: normative, statistical (expert), physical, and digital. These methods can be combined within a single diagnostic algorithm, due to which it becomes possible to achieve more reliable and efficient (less expensive) assessment of equipment malfunctions during its automatic diagnostics. The advantages and drawbacks of each method are described, and examples of implementing diagnostic tasks with different prototypes are given. Matters concerned with revealing a fault, evaluating the state of equipment components and residual life, and predicting the state parameters are solved. It is shown that one of the complex problems that has to be solved in developing a vibration diagnostic system is to substantiate the relationship between the sign and type of equipment malfunction. Using vibration diagnostics as an example, fault symptoms are grouped into boundary, factor, and correlation ones.

Keywords: steam turbine equipment diagnostics, assessment of state, diagnostic prototypes and fault signs

Nozzle Steam Distribution with a Remote Mixing Chamber

A. E. Zaryankin^{a, *}, I. P. Lavirev^{a, **}, and M. A. Cherkasov^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: ZariankinAY@mpei.ru*

***e-mail: lavirev@mail.ru*

Abstract—The experience of operating powerful energy steam turbines has clearly shown that a significant share of losses with reduced steam consumption is accounted for by the steam distribution system, which is characterized by intensive throttling of steam entering the turbine's flow section. Of the two main steam distribution systems—throttle and nozzle—nozzle steam distribution has an obvious advantage, where, unlike throttle, a reduction in steam flow through a turbine is achieved by throttling not only the entire steam stream but only part of it in a series of consecutively opening valves. To implement this method of steam distribution, it was necessary to introduce a special regulating stage into the turbine flow section, separated from the remaining stages by a regulating stage chamber (mixing chamber) designed to equalize uneven velocity fields at the entrance to the first unregulated stage, which are especially distinct with partial turbine loads. A detailed analysis of the advantages and disadvantages of the throttle and nozzle steam distribution is given and it is indicated that, taking into account all the additional consequences associated with the use of nozzle steam distribution, its advantage over the throttle becomes noticeable only when the turbine load is reduced by more than 25%. To eliminate the disadvantages inherent in the nozzle steam distribution, it is proposed to move the mixing chamber (chamber of the control stage) outside the turbine casing, thereby eliminating the control stage and greatly simplifying the supply of steam to the high-pressure cylinder of the steam turbine. In conclusion, a constructive solution for nozzle steam distribution with an external mixing chamber is proposed.

Keywords: steam turbine, nozzle steam distribution, throttle steam distribution, control valves, control stage chamber, partiality, maneuverability, vibration

The Impact of Operating Parameters on the Performance of a New ORC-VCC Combination for Cogeneration

N. Toujani^{a,*}, N. Bouaziz^a, M. Chrighi^b, and L. Kairouani^a

^aUniversité Tunis El Manar, Unité de Recherche Énergétique et Environnement, Ecole Nationale d'ingénieurs de Tunis, BP 37, Le Belvédère, Tunis, 1002 Tunisia

^bTechnische Universität Darmstadt, Department of Mechanical Engineering, (Dept. 16), Darmstadt, Hessen, 64277 Germany

*e-mail: toujeninoureddine@gmail.com

Abstract— This manuscript presents a new combination based on a thermodynamic conversion, the idea is to combine the Organic Rankine Cycle (ORC) with the Vapor Compression Cycle (VCC). The novelty of the system appears essentially in: the development of new ORC-VCC combination architecture, the lowering of the ORC cycle temperature, the possibility of cold production by the ORC cycle upstream of the pumping phase, preheating of ORC cycle using VCC cycle fluid and new configurations based on the integration of heat recovery systems to improve overall system performance. In addition, each installation mode has several configurations depending on the recovery points that will be integrated later, besides its adaptation to any energy source, where we can use biomass, solar and heat rejects of industry at low temperatures (80–160°C). This system can produce a cold with negative and positive temperatures. Although, thanks to its architecture, it is also characterized by many combination of selection fluid for the ORC and VCC cycles it is not necessarily to have the same working fluid as the classic systems. The main purpose of this study is to analyze the performance of a new system which combines Rankine-vapor compression cycle for the cogeneration of electricity and refrigeration. Coefficient of performance (COP) will be compared with other cooling systems and power system, such as the system turbo compressor Rankine. The fluids we used in the work are ammonia for the ORC and R600a for the VCC.

Keywords: Organic Rankine cycle, co-generation, vapor compression cycle, working fluid, fluid combinations, cycle efficiency, regenerative heater, energy efficiency

Determining the Minimum Allowable Wastewater Purification before Discharging with Allowance for the Harmful Effect Summation

A. K. Sokolov*

Ivanovo State Power University, Ivanovo, 153003 Russia

**e-mail: sokolov@bjd.ispu.ru*

Abstract—The procedure and examples of determining the standard (minimum allowable) wastewater purification η , the minimum allowable concentrations of substances in the discharged water c_{st} , and the permissible discharge standards are considered. It is shown in the context of potential effect of several substances, taking into account the harmful effect summation, that it is possible to determine only one unknown (c_{st}). Two analytical methods have been obtained for solving the problem of calculating the standard purification rate η : for all substances (subject to the unknown $\eta_1 = \eta_2 = \eta_3 = \dots$ or the relations between them are equal) and for determining η only for one substance, for example, the first η_1 (subject to the value assignment for other η_2, η_3, \dots). In general, the problem of determining η does not have an unambiguous solution since the choice of one of two types of solutions, as well as substances for which the desired η should be set or calculated, requires an independent technical and economic study. The possibility is established for using the normalized concentration for the summation of substance effects in solving the inverse problems of calculating the wastewater dilution in water bodies. To illustrate the effect of harmful summation on the safety of discharges and methodology testing, a calculation example of the purification degree η of technical wastewater containing two substances, for example fluorine and hydrazine, is given. In addition to fluorine and hydrazine, the water body contained a third substance, formaldehyde, which was absent in wastewater. All the substances have the harmful effect summation. The possible ratios η_1 and η_2 are calculated (for fluorine and hydrazine, respectively), at which the discharge of these substances will be safe for the water body. It is shown that the harmful effect summation significantly affects the standard wastewater purification degree.

Keywords: environmental safety, wastewater, limiting harmful index, hazard class, minimum allowable purification, permissible discharge standards

Using a Fuzzy Prognostic Model in the Operative-Dispatch Analysis of Heat-Supply Systems' Operation

N. B. Agaev^{a,*} and R. J. Abdullaev^{b,**}

^a*Azerbaijan Technical University, Baku, AZ1073 Republic of Azerbaijan*

^b*OAO Azeristiliktejizat (State Heat-Supply Company), Baku, AZ1129 Republic of Azerbaijan*

^{*}*e-mail: Nadir_avia@yahoo.com*

^{**}*e-mail: rashad.abdullayev78@mail.ru*

Abstract—The heating network of a big city is a complex hydrodynamic system consisting of dozens of heating stations with its own local network, and random changes occurring in any of the elements are more noticeable in it. In this case, since each thermal station is autonomous, it can be a normal and efficient source of heat due to the peculiarities of energy control based on its own hydrodynamic properties. At the same time, it is problematic to take into account all influencing factors in specific territories as well as to collect geographically distributed information. In this regard, the development of analysis methods and the prediction of the operation of thermal centers based on the modern theory of analysis and modeling of dynamic processes that are convenient for implementation and adequately describe real physical situations are relevant. In this case, the most important task of the analysis of heat consumption is to determine the patterns of change in the studied phenomenon, which are formed under the influence of a set of reasons that act on it constantly for a long time. These reasons are sometimes completely random, which complicates the study process and can lead to an incorrect conclusion. To get out of this situation, it is necessary to use a fuzzy logic apparatus, which reduces the influence of random in-row changes by introducing linguistic terms. With this in mind, the goal of the article is to build a prognostic model based on the theory of fuzzy logic parameters, which may be key to the development of the energy-management process based on archived data from thermal centers. A method for constructing a forecast model of a fuzzy approach for a time series with in-row multiplicative changes and the possibility of using it for operational dispatch analysis of heat-supply systems are presented. The simulation is based on the calculation of predicted values for the membership function built on the statistical indicators of row-by-row changes. The proposed method is applied to the time series of dynamic parameters in heat-supply systems. Based on the performed experiments and computational experiments, it was found that the average relative error between the predicted and actual indicators was 3.5% for the temperature in the supply and 4.7% in the return pipe of the system.

Keywords: heat-supply systems, weight coefficient, standard deviation, coefficient of variation, fuzzy time series, fuzzy predictive model, membership functions, term