

---

---

# Contents

---

---

Vol. 67, No. 10, 2020

---

---

## Steam-Turbine, Gas-Turbine, and Combined-Cycle Plants and Their Auxiliary Equipment

State of the Art and Trends in the Design and Operation of High- and Low-Pressure Heaters for Steam Turbines at Thermal and Nuclear Power Plants in Russia and Abroad:

Part 1. Heater Types and Designs

*Yu. M. Brodov, K. E. Aronson, A. Yu. Ryabchikov, M. A. Nirenshtein,  
I. B. Murmanskii, and N. V. Zhelonkin*

Analyzing the Results from Numerical and Experimental Determination of Energy Losses in Axial Turbine Profiles' Transonic Gratings

*M. Yu. Leventhal, Yu. R. Mironov, and B. A. Tikhomirov*

---

---

## Renewable Energy Sources, Hydro Power Engineering

Cogeneration Plants with Solar Radiation Concentrators

*P. A. Nesterenkov, A. G. Nesterenkov, and A. N. Temirbekov*

The Effectiveness of Using Air-to-Water Heat Pumps under Russian Climatic Conditions

*I. V. Yakovlev and A. M. Iskhakova*

---

---

## Steam Boilers, Power Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Modelling of the Initial Part of a Smoke Plume from a Four-Flue Stack at a Thermal Power Station

*A. M. Gribkov, N. D. Chichirova, and D. I. Fedorenkov*

---

---

## Environmental Protection

Normative and Legal Regulation for Implementing the Best Available Technologies in Russian Heat-and-Power Engineering

*P. V. Roslyakov, O. E. Kondrat'eva, D. O. Skobelev, T. V. Guseva, and A. Mikaelsson*

Feasibility Study of Using Geothermal Heat-Pump Units for Substituting Small-Capacity Coal-Fired Boiler Houses (Taking the Baikal Natural Area as an Example)

*I. Yu. Ivanova, V. A. Shakirov, M. V. Ermakov, and F. S. Bukher*

Treatment of a TPP's Water from Oil Products with Hydrophobic Carbonate Sludge

*L. A. Nikolaeva*

---

---

## Heat and Mass Transfer and Properties of Working Fluids and Materials

The Specifics of Design and Prediction of Thermohydraulic Characteristics of Thermosiphons

*B. F. Balunov, V. D. Lychakov, A. A. Shcheglov, A. S. Matyash, M. Yu. Egorov,  
V. I. Nikiitin, A. O. Borisov, V. A. Il'in, S. B. Alekseev, and S. V. Svetlov*

---

---

# **Automation and Heat Control in Power Engineering**

Comparative Analysis of the Reliability of Control and Management Systems Using  
the Signature Theory

*I. I. Galiev, V. A. Chepurko, A. N. Chernyaev, and A. A. Shilov*

---

---

# State of the Art and Trends in the Design and Operation of High- and Low-Pressure Heaters for Steam Turbines at Thermal and Nuclear Power Plants in Russia and Abroad: Part 1. Heater Types and Designs

Yu. M. Brodov<sup>a</sup>, K. E. Aronson<sup>a,\*</sup>, A. Yu. Ryabchikov<sup>a</sup>, M. A. Nirenshtein<sup>a</sup>,  
I. B. Murmanskii<sup>a</sup>, and N. V. Zhelonkin<sup>a</sup>

<sup>a</sup>*Ural Federal University, Ural Power Engineering Institute, Yekaterinburg, 620002 Russia*

<sup>\*</sup>*e-mail: lta\_ugtu@mail.ru*

**Abstract**—The modern state in design, calculation, and operation of heaters used in the steam-turbine regeneration systems in Russia and abroad is reviewed and analyzed. The first part of the article gives a list of companies producing steam-turbine feedwater heaters and the market shares occupied by the countries producing these apparatuses. The ranges of operating parameters for the feedwater heaters of Russian and foreign steam turbines are indicated. The article gives the types of heat exchangers included in the regenerative feedwater heating system and serving as high- and low-pressure heaters that are adopted in Russia and abroad, including contact apparatuses and plate-type heaters. Specific examples of arranging such apparatuses at power plants in different countries are given. Advantages and drawbacks associated with the use of contact and plate-type apparatuses as turbine unit feedwater heaters are discussed. Different designs of shell-and-tube high- and low-pressure feedwater heaters adopted in the United States, Europe, and Russia are presented. The designs of particular high- and low-pressure heaters characteristic of different domestic and foreign producers are described. Methods for arrangement and structural makeup of different functional areas of the heater's heat-transfer surface are shown. The advantages and drawbacks of header-and-helical coil-type high-pressure heaters and tubular apparatuses for the similar purpose, including chamber-type apparatuses, are discussed in terms of thermal efficiency, reliability, and repairability. It follows from the presented data that there is no commonly accepted approach to designing the considered apparatuses, and that there is mutual influence of manufacturing experience, design trends, and heater manufacturing traditions in different countries.

**Keywords:** steam turbine, contact-type heaters, plate heaters, shell-and-tube heaters, high-pressure heaters, low-pressure heaters, chamber heaters, header-and-helical coil-type apparatuses

# Analysis of Results of Energy Losses Numerical and Experimental Prediction in Axial Turbine Transonic Cascades

M. Yu. Levental<sup>a,\*</sup>, Yu. R. Mironov<sup>b</sup>, and B. A. Tikhomirov<sup>c</sup>

<sup>a</sup>*JSC Ural Works of Civil Aviation, Yekaterinburg, 620025 Russia*

<sup>b</sup>*JSC Compressor Complex, St. Petersburg, 129029 Russia*

<sup>c</sup>*St. Petersburg State Marine Technical University, St. Petersburg, 190121 Russia*

*\*e-mail: Levental-30@rambler.ru*

**Abstract**—The paper is devoted to the matter of energy losses prediction in axial turbine cascade based on CFD analysis. An intensive development of numerical modelling of flows in turbomachinery and the advent of various turbulence models open up major opportunities for blade row gas-dynamic efficiency estimation. Nowadays statistically significant data on the difference between predicted and experimental losses for flow conditions with Mach number near 1 and above are not available in public domain. Therefore the present paper offers analysis results for several turbine blade cascades of various geometries, that have detailed experimental data. Reynold's stress model in CFD analysis was used. The study has showed that the estimated and experimental data show satisfactory fit for isentropic Mach number along blade profile and significant difference in losses of energy when there is a skew shock waves system. The predicted losses are lower than experimental ones for the most flow conditions.

**Keywords:** axial turbine, blade profile, turbine grid, turbulence model, Mach number, shock wave, profile loss, deviation, velocity distribution, flow structure

# Cogeneration Plants with Solar Radiation Concentrators

P. A. Nesterenkov<sup>a,\*</sup>, A. G. Nesterenkov<sup>b,\*\*</sup>, and A. N. Temirbekov<sup>a,\*\*\*</sup>

<sup>a</sup>*Al-Farabi Kazakh National University, Almaty, 050040, Republic of Kazakhstan*

<sup>b</sup>*Chokin Kazakh Energy Research Institute, Almaty, 050012, Republic of Kazakhstan*

*\*e-mail: stolkner@gmail.com*

*\*\*e-mail: ionotexnica@mail.ru*

*\*\*\*e-mail: almas.temirbekov@kaznu.kz*

**Abstract**—Results from experimental studies of a solar cogeneration system with linear photovoltaic modules of a fundamentally new design are presented. The  $\Lambda$ -shaped frontal walls are installed face-to-face at an angle to each other and mutually shield their own thermal radiation, which decreases the radiation heat losses by 27% compared with linear photovoltaic modules of the known designs. The photocurrent generated by cooled solar cells is directed to a system for charging chemical batteries and the thermal energy released is transmitted to the unconsumed intermediate heat-transfer fluid and then, through the surface of coil pipes of counter-current heat exchangers, to the consumed process water of the outer circulation circuit. The further transportation of thermal energy to the storage system occurs by natural circulation of the consumed process water through the temperature gradient formed by the control system over the height between the heat source, the heat exchanger, and the heat receiver, an insulated container (a heat accumulator). For the first time, efficient controlled transportation of heat has been implemented without using a circulation pump owing to the excess thermal energy released during the conversion of solar energy by the solar cells and a photo-selective film installed in the focal spot of the optical concentrator. Thus, a possibility of increasing the temperature of the heat-transfer fluids at the cogeneration system outlet has been offered. A two-circuit circulation system allows for separation of unconsumed heat-transfer fluids (anti-freezing solutions) and the consumed fluid (the process water) by the pressure in the channels and installation of a linear counter-current heat exchanger that performs the functions of a supporting platform's mechanical axis along the rotational axis of the optical concentrator. The system uses a dual-axis solar tracking concentrating system comprised of flat mirrors installed at an angle to the horizon. The arrangement of the  $\Lambda$ -shaped photovoltaic modules on the supporting framework in series along the heat-transfer-fluid path allows for a reduction in the overall dimensions of the channels, an increase in the total efficiency of the solar cells, and simplification of the encapsulation technology. A method for calculating the output of the cogeneration plant is provided. The method is based on the experimentally measured characteristics of silicon solar cells and heat losses in the channels of the linear photovoltaic modules.

*Keywords:* silicon photovoltaic cells, optical concentrator, linear photovoltaic modules, heat exchanger, circulation system, specific output

# The Effectiveness of Using Air-to-Water Heat Pumps under Russian Climatic Conditions

I. V. Yakovlev<sup>a, \*</sup> and A. M. Iskhakova<sup>a</sup>

<sup>a</sup>*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

<sup>\*</sup>*e-mail: YakovlevIV@mpei.ru*

**Abstract**—The energy efficiency of a combined heat-supply system constructed on the basis of an air-to-water heat pump and an additional heat source (an electric boiler) for its operation under different climatic conditions of Russia is studied using the simulation method. The considered subject is of issue because the answer to the question about the effectiveness of using air-source heat pumps depends on many factors, which may influence the effectiveness in different ways. These factors include, in particular, essentially different climatic conditions in different regions and specific consumption of fuel for supply of electricity and heat and different ratios between the tariffs for heat and electricity. A procedure for estimating the effectiveness of an autonomous space-heating system constructed on the basis of a heat pump as a function of the share of the heat-pump unit's nominal heat output in the design heating load is proposed. The procedure is based on using the relative expenditures of energy carriers (reference fuel) and financial expenditures for them in autonomous heat-supply systems on the basis of a heat pump and district heating. The results from calculations of relative consumption of fuel and energy resources and relative operating costs for certain regions of Russia having different climatic conditions are given. The calculations were carried out using generalized characteristics of heat pumps from different manufacturers, actual climatic data for three heating seasons, and ratios between the specific reference fuel consumptions for generation of electricity and heat and tariffs for energy carriers. It is shown that, in the case of using air-to-water heat pumps, the optimal ratio between the nominal heat output of heat-pump units and the design heating load is in the range from 1.0 to 1.4 depending on the design outdoor air temperature. In this case, the expenditures of fuel and energy resources and the financial expenditures for them are commensurable with the costs for district heating.

**Keywords:** autonomous heat supply, heat-pump-based space-heating system, energy efficiency, air-to-water heat pump, relative energy carrier consumption indicator

# Modelling of the Initial Part of a Smoke Plume from a Four-Flue Stack at a Thermal Power Station

A. M. Gribkov<sup>a, \*</sup>, N. D. Chichirova<sup>a, \*\*</sup>, and D. I. Fedorenkov<sup>a, \*\*\*</sup>

<sup>a</sup>*Kazan State Power Engineering University, Kazan, 420066 Russia*

*\*e-mail: gribkovalmi@mail.ru*

*\*\*e-mail: ndchichirova@mail.ru*

*\*\*\*e-mail: dif-96@mail.ru*

**Abstract**—Multiflue stacks are finding ever increasing application at thermal power stations (TPS) in recent years. Until the present time, the opinion has prevailed that multiflue stacks at the same emission parameters offer lower floating-up height of flue gases than single-flue stacks do. Hence, they must be higher or be provided with devices making a single flume, such as common hoods, or due to a concentric slope of the outlet section of the stack flues. However, the research tools used up until now had poorer capabilities as compared to those implemented in the ANSYS Fluent software package. The process of combining jets outflowing from individual flues of a four-flue stack is studied and analyzed using the ANSYS Fluent package. Much attention is given to the selection of a proper turbulence model and its verification against generally accepted theoretical and experimental data. This revealed the effect of rapprochement of the jets' axis from individual parallel flues similar to the Coanda effect. Comparison of the characteristics of cross sections in a combined plume from a four-flue stack and a plume from a single-flue stack having the same outflow parameters and the distance from the stack mouth, as well as using them as initial data for calculating the trajectory of the smoke plume, showed a good agreement of these trajectories. Selection of a turbulence model and a calculation scheme suitable for the considered conditions is rather complicated, as it is determined not only by physical and geometric parameters but also by the required model accuracy and available computer and time resources. Solutions are presented that are obtained using the ANSYS Fluent package in analyzing jet flows with a scale of approximately 100 m, and a procedure for selecting a turbulence model for a nonisothermal jet is described.

*Keywords:* free nonisothermal jet, turbulence model, smoke plume trajectory, ANSYS Fluent, Coanda effect, ejector effect, boundary layer, outlet section of four-flue stack, smoke plume rising

# Normative and Legal Regulation for Implementing the Best Available Technologies in Russian Heat-and-Power Engineering

P. V. Roslyakov<sup>a, \*</sup>, O. E. Kondrat'eva<sup>a</sup>, D. O. Skobelev<sup>b</sup>, T. V. Guseva<sup>b</sup>, and A. Mikaelsson<sup>c</sup>

<sup>a</sup>National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup>Scientific Research Institute Center for Environmental Industrial Policy, Mytishchi, Moscow oblast, 141006 Russia

<sup>c</sup>Swedish Environmental Protection Agency, Stockholm, SE-106 48 Sweden

\*e-mail: RoslyakovPV@mpei.ru

**Abstract**—New legislation in the field of best available technology (BAT) has provided an incentive for the introduction of resource-efficient and environment-protecting technologies in the Russian thermal power industry. Switching to BAT is based on the principle of a successive achieving of the best economic and environmental efficiency indices of enterprises by means of a gradual displacement of obsolete technological and technical solutions to replace them by modern ones. In the framework of the implementation of the BAT Implementation federal project, the switching to such technologies is considered not only as an improvement of the environmental situation, which is very important in itself, but also as a comprehensive modernization of the entire industrial production linking economic and environmental goals to provide a balanced solution to the problems of sustainable economic growth and environmental improvement. The legal, scientific, technical, and financial problems that arise in the course of real BAT implementation at thermal power facilities with the greatest negative impact on the environment are described. Technological indices of pollutant emissions to the atmospheric air by thermal power plants have been compared with similar standards adopted in the European Union, the United States, and Kazakhstan. It is shown that the proposed technological emission indices do not promote any radical modernization of the industry and any real decrease in the negative impact on the environment. The reasons are considered and the need for the accelerated updating of the information-and-technical reference book ITS 38-2017 is argued. The analysis of the energy equipment of Russian thermal power plants has been carried out, and it has been proven that BAT implementation in order to ensure the technological indices established in ITS 38-2017 is not a technical or financial problem. The risks of the embodiment of the Implementation of BAT federal project are analyzed. It has been noted that continuing education programs in the field of BAT implementation is of importance.

*Keywords:* best available technologies, heat-and-power engineering, information-and-technical reference books, pollutants, emissions, technological indices, objects of negative environmental impact, boiler plants, thermal power plants



# Feasibility Study of Using Geothermal Heat-Pump Units for Substituting Small-Capacity Coal-Fired Boiler Houses (Taking the Baikal Natural Area as an Example)

I. Yu. Ivanova<sup>a, b</sup>, V. A. Shakirov<sup>b, \*</sup>, M. V. Ermakov<sup>b</sup>, and F. S. Bukher<sup>b</sup>

<sup>a</sup>*Irkutsk Scientific Center, Siberian Branch, Russian Academy of Sciences, Irkutsk, 664033 Russia*

<sup>b</sup>*Melentiev Energy Systems Institute, Siberian Branch, Russian Academy of Sciences, Irkutsk, 664033 Russia*

*\*e-mail: mynovember@mail.ru*

**Abstract**—The economic feasibility of substituting small-capacity coal-fired boiler houses with geothermal heat-pump units in the central ecological zone of the Baikal natural area is analyzed. Three versions of a space-heating system equipped with heat-pump units are considered depending on the source of low-grade heat and the method for extracting it: a well, a horizontal ground collector, and a water basin (Lake Baikal). The study is carried out for the raions of the Irkutsk oblast and the Republic of Buryatia located in the most favorable natural and climatic conditions in the southern part of the Baikal natural area's central ecological zone, which have different economic conditions in terms of electricity tariffs and fuel cost. A conditional small-capacity coal-fired boiler house having averaged technical characteristics is taken as the base version for comparing it with heat-pump units. A monovalent mode of heat-pump unit operation is considered taking into account a shift for using a low-temperature space-heating system. The economic feasibility of substituting a coal-fired boiler house is estimated proceeding from the equality between the total discounted costs for implementing a space-heating system equipped with heat-pump units and costs for operation of the coal-fired boiler house for the considered period of time. The dependences of the total discounted costs for the alternatives being compared have been obtained, using which it is possible to determine the level of electricity tariffs and coal prices at which the application of heat-pump units in the studied region becomes economically feasible. The influence of possible deviations of the conditions in a particular locality from the conditions typical for the analyzed regions that were adopted for consideration is taken into account. It can be concluded from the obtained results that, given the current prices for coal and electricity, it is not economically feasible to substitute small-capacity coal-fired boiler houses with heat-pump units under the natural and climatic conditions of the considered regions. The use of heat-pump units may become justified with a coal price equal to 5000–8000 rubles/t and electricity tariffs equal to 2–4 rubles/(kW · h); in this case, the discounted payback period of investments will make approximately 30 years.

*Keywords:* heat-pump units, coefficient of performance, low-grade heat sources, boiler house, economic feasibility, ecology

# Treatment of a TPP's Water from Oil Products with Hydrophobic Carbonate Sludge

L. A. Nikolaeva\*

*Kazan State Energy University, Kazan, 420066 Russia*

*\*e-mail: larisani16@mail.ru*

**Abstract**—A technology for adsorption treatment of a TPP's wastewater from oil films and dissolved oil products by developed powdery and granular sorption materials based on carbonate sludge is proposed. Carbonate sludge is an energy waste generated during the preliminary purification of raw water during liming and coagulation. The technological characteristics and the adsorption capacity of the sludge with respect to dissolved and emulsified oil products are determined. To increase the adsorption capacity and wettability by nonpolar compounds, it is proposed to carry out volumetric hydrophobization of carbonate sludge with Silor silicone fluid. Powdered material was obtained by modifying sludge (humidity 3%, particle size  $d_h = 0.01-0.05$  mm) with 100% Silor liquid with a volume ratio of solid and liquid phase of 5 : 1 followed by heat treatment at 150°C for 60 min until a constant mass was established. The oil capacity of the material of 0.95 g/g, the contact angle of 115°, and the technological characteristics of the sorption material were determined. For TPPs' wastewater treatment from oil products, it is proposed to use the material for collecting floating oil films in the sumps of the technological scheme. A technology has been developed for producing granular sorption material: granules formed from carbonate sludge when mixed in a ratio of 1 : 2 with a binder liquid sodium glass are heat treated at 700°C for 60 min, then 5% are impregnated with Silor water emulsion and dried to constant weight. It is proposed to use granular material in technological schemes for the posttreatment of wastewater from dissolved oil products as a load in adsorption filters.

**Keywords:** wastewater from thermal power plants, petroleum products, hydrophobization, Silor silicone fluid, granules, carbonate sludge, purification flow chart, sorption material

# The Specifics of Design and Prediction of Thermohydraulic Characteristics of Thermosiphons

B. F. Balunov<sup>a, \*</sup>, V. D. Lychakov<sup>a</sup>, A. A. Shcheglov<sup>a</sup>, A. S. Matyash<sup>a</sup>, M. Yu. Egorov<sup>a</sup>,  
V. I. Nikitin<sup>a</sup>, A. O. Borisov<sup>a</sup>, V. A. Il'in<sup>b</sup>, S. B. Alekseev<sup>c</sup>, and S. V. Svetlov<sup>c</sup>

<sup>a</sup>*OAO NPO CKTI, St. Petersburg, 191167 Russia*

<sup>b</sup>*AO Zavod Znamya Truda, St. Petersburg, 195027 Russia*

<sup>c</sup>*AO Atomproekt, St. Petersburg, 197183 Russia*

*\*e-mail: iceo@ckti.ru*

**Abstract**—Recommendations are given on designing thermosiphons (TS) prepared on the basis of the experience that the authors gained in designing more than 4000 TSs for heat-recovery steam generators and the results of long-term investigations and tests carried out to study thermohydraulic and corrosion processes in vertical and inclined TSs filled with steam-water mixture. The results of similar studies performed by other authors are analyzed. References are given to the regulations on the design of heat transfer equipment for thermal and nuclear power stations. The requirements for TS construction materials, the degree of TS filling with water, and the TS vacuum level are outlined. Whether the evacuation of TS may be abandoned was assessed. Measures are proposed to prevent depressurization on water freezing in TSs. Recommendations are given on the calculation of thermohydraulic characteristics and steam-and-gas distribution in vertical or inclined TSs. The conditions of displacement by a steam flow of noncondensable gases, including air, to the top of the condensation zone in a thermosiphon are considered. Various regimes of axial heat transport and heat transfer are described for pure steam condensation (including film condensation, bubble condensation, distribution of different regimes of steam condensation, and condensate cooling along the height of the condensation zone during “flooding”). Heat transfer in the steam condensation from an air-steam mixture (the diffusion component of thermal resistance), maximum power, and the conditions for poorer cooling of the TS heating zone (“flooding”, steam separation at the upper generatrix of the heating zone in an inclined thermosiphon) are examined. Thermosiphons feature a countercurrent flow of steam and its condensate in a single flow with the same mass flowrates. Hence, a special case of “flooding” affecting the maximum power of the thermosiphon, the effect of the incoming steam flow on the heat transfer rate during film condensation, steam-and-gas distribution in a top-plugged channel, corrosion processes in thermosiphons, and hydrogen diffusion through the thermosiphon wall should also be studied.

**Keywords:** vertical and inclined thermosiphons, recommendation on the design of thermosiphons and calculation of their thermohydraulic characteristics, steam-gas distribution, “flooding”

# Comparative Analysis of the Reliability of Control and Management Systems Using the Signature Theory

I. I. Galiev<sup>a,\*</sup>, V. A. Chepurko<sup>a</sup>, A. N. Chernyaev<sup>b</sup>, and A. A. Shilov<sup>b</sup>

<sup>a</sup>*AO Rusanom Automated Control Systems, Moscow, 109507 Russia*

<sup>b</sup>*National Research University Moscow Energy Institute, Moscow, 111250 Russia*

*\*e-mail: galievii@inbox.ru*

**Abstract**—At the present, in the comparative analysis of design decisions from the point of view of system architecture, a qualitative and quantitative analysis of the indicators for each solution is performed followed by a comparison of the results. The classical method of calculating reliability is very laborious due to the need to take into account the properties of all elements of the system. One of the tools to quantify the reliability of systems consisting of components with random times of failure that are independent and equally distributed is signature theory. The signature describes the structure of the system and can be combined with ordinal statistics of the component failure time to form conclusions about the reliability of the system and compare several systems according to this criterion. The article provides a comparative analysis of the safety of control and management systems using the classical method of calculating reliability indicators as well as using signature theory. As an example, the article considers a protection system that includes the initiating and executive parts. The system architecture is presented in several simplified versions. The dependences of the probabilities of failures of the “failure to respond to requirements” and “false responses” type for each of the architecture implementation variants are obtained. It is concluded that, with the exponential distribution of operating time to failure, there is a complete correlation of the results of circuit comparison performed using both the classical method of calculating reliability (based on the failure rates of components) and using signature theory. Moreover, the use of signature theory greatly simplifies comparing the reliability of systems and networks consisting of components of the same type.

*Keywords:* signatures, control and management systems, reliability, industrial control system, comparative reliability analysis