

Contents

Vol. 68, No. 2, 2021

Renewable Energy Sources and Hydropower

Modern State of Hydropower and Construction of Hydro Turbines in Russia and Abroad

V. E. Mikhailov, I. P. Ivanchenko, and A. N. Prokopenko

Steam-Turbine, Gas-Turbine, Combined-Cycle Power Plants and Their Auxiliary Equipment

Experimental Studies into the Effect that the Rotor Rotation and Flow Swirling Upstream of Seals Have on the Leakage Flowrate

S. S. Dmitriev, B. N. Petrunin, and E. A. E. Ahmed Mohamed

Calculating Losses from the Angle of Attack in the Turbine Grille

B. I. Mamaev and A. V. Starodumov

The Upgrading of the Combined-Cycle Cogeneration Plant with Heat-Recovery Steam Generators for Large Cities of the Russian Federation

M. A. Vertkin, S. P. Kolpakov, V. E. Mikhailov, Yu. G. Sukhorukov, and L. A. Khomenok

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

A Review of the Research Results into the Technologies of Solid-Fuel Combustion in a Circulating Fluidized Bed Conducted Abroad and in Russia

G. A. Ryabov

Determining Optimum Productivity of a Ball Drum Mill When Milling Brown Coals

S. D. Ivanov, A. N. Kudryashov, and V. V. Oshchepkov

Nuclear Power Plants

Experimental and Calculated Studies of Condensation-Induced Water Hammer

*G. J. Volkov, I. V. Elkin, A. V. Kapustin, V. I. Melikhov, O. I. Melikhov,
S. M. Nikonov, and O. N. Trubkin*

A Model of the Outlet of Fission Products from the Melt Pool during a Severe Accident in a Liquid-Metallic Cooled Reactor

E. V. Usov, V. I. Chukhno, I. A. Klimonov, V. D. Ozrin, N. A. Mosunova, and V. F. Strizhov

Water Treatment and Water Chemical Mode

Experience of Applying VTIAMIN Brand Reagents for Correction of the Water-Chemical Regime of TPPs' Return Cooling Systems

V. V. Kozlovsky, E. F. Nartya, Yu. V. Ulanovskaya, and A. B. Larin

Determining the Efficiency of Desorption of Corrosive-Active Gases in Columns with Chaotic and Regular Nozzles

E. A. Lapteva and M. I. Farakhov

Modern State of Hydropower and Construction of Hydro Turbines in Russia and Abroad

V. E. Mikhailov^a, I. P. Ivanchenko^a, and A. N. Prokopenko^{a, *}

^a*OAO Polzunov Research and Production Association for Investigation and Design of Power-Generating Equipment, St. Petersburg, 191167 Russia*

**e-mail: ProkopenkoAN@ckti.ru*

Abstract—The role that hydropower plays in the world's energy balance is considered, and a comparative analysis of using hydropower resources in Russia and abroad is presented. It is shown that Russia occupies the world's second place in its hydropower potential after China; however, no more than 20% of the country's hydraulic power resources have presently been harnessed. This is significantly lower than in Germany, France, Sweden and Japan, countries in which 65–90% of their available hydraulic power resources are used. In view of a great variety of natural conditions, turbines of different types are used in the hydraulic power industry. It has been determined that the power performance indicators (efficiency and capacity) of the hydraulic machines that are presently produced in Russia correspond, as in the years of the former Soviet Union, to world-class standards. Trends in the development of hydropower and construction of hydraulic turbines are analyzed. It is shown that, given insignificant scales of constructing new hydroelectric power plants in Russia, replacement of the equipment at the existing hydroelectric power plants that had worked out its standard service life long ago is the industry's main development line for the nearest (10–15 years) future. The need to replace the operating hydraulic machines mainly stems from inefficient utilization of water stream at the existing hydroelectric power plants. It is pointed out that, despite the emerged tendency toward decreasing the reliability of hydraulic power units that have been in operation for a long period of time, its catastrophic drop is not observed at any of the examined hydroelectric power plants even though their machines have been in operation for twice as much as their standard service life (30 years) or even more. Refurbishment of the machines makes it possible and shall mandatorily improve the power performance characteristics of the machines, resulting in an increased power capacity or improved efficiency (of energy generation). An improvement in the power performance characteristics of new hydraulic turbines is achieved almost solely due to the use of more advanced runners while keeping the other flow path elements unchanged.

Keywords: hydropower, hydraulic resources, hydraulic turbine, power performance characteristics, equipment replacement, service life, runner, flow path

Experimental Studies into the Effect that the Rotor Rotation and Flow Swirling Upstream of Seals Have on the Leakage Flowrate

S. S. Dmitriev^{a, *}, B. N. Petrunin^a, and E. A. E. Ahmed Mohamed^{a, b}

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bBenha University, Faculty of Engineering at Shoubra, Mechanical Engineering Department, Benha, Egypt

*e-mail: dmitriyevss@mpei.ru

Abstract—The results from experiments for studying the effect of rotor rotation on the leakage through different types of seals are presented. It is shown from a comparative study of models involving a stalled rotor and rotor rotating with a 50 Hz frequency that the rotor rotation has hardly any effect on the leakage flowrate, so that the rotation may not be taken into account in calculations of leakage flowrate through the steam turbine end and diaphragm seals. The article presents results from experiments for studying the dependence of leakage flowrate on the flow parameters, namely, the change of the velocity vector axial and circumferential components in the annular inlet channel upstream of a single annular throttle orifice. During the experiments, the velocity axial and circumferential components were varied independently and in a very significant range. The accomplished studies have shown that the change of both the axial and circumferential velocity components has hardly any effect on the leakage flowrate. It can be concluded from an analysis of the obtained results that the influence of flow parameters upstream of the seal on the leakage flowrate is so insignificant that its neglect in the previously developed calculation procedures for determining the leakage flowrate in the steam turbine seals, which are still in use at present, is quite substantiated and justified. At present, studies are being carried out that allow the flow structure in different places of turbine machinery flow paths, including the turbine seals, to be analyzed by calculation. It should be noted that it is possible by using the modern calculation methods not only to determine the vortex structure in the seal neighborhood but also to estimate the leakage flowrate, leakage losses, and even the stage efficiency for different configurations of the chamber upstream of the seal. Nonetheless, care should be taken in dealing with practical recommendations on changing the seal configurations that are based solely on the calculation results. The soundness of such recommendations must be confirmed by the relevant experimental investigations.

Keywords: shroud seal, energy losses, leakage flowrate, tip clearance, throttle orifice, flow swirling, rotation frequency, seal pressure ratio, measurement error, discharge coefficient

Calculating Losses from the Angle of Attack in the Turbine Grille

B. I. Mamaev^{a,*} and A. V. Starodumov^a

^a*Lyulki Experimental Design Bureau, Branch of Experimental Design Bureau, Ufa Engine-Building Production Association, Moscow, 129301 Russia*

**e-mail: boris.mamaev35@mail.ru*

Abstract—The flow in turbine cascades with angles of attack is accompanied by a separated flow around the airfoils, which is difficult to calculate with acceptable accuracy. Therefore, in practice, empirical formulas are used to estimate losses from the angle of attack. The analysis of these formulas has made it possible to identify the geometric and operating parameters of the grill that have the greatest influence on the losses: the design angle of entry, thickness of the entrance edge of the profile, thickness of the profile, relative pitch, angle of attack, and flow velocity. It is unrealistic to obtain a reliable analytical expression for losses that takes into account the influence of all these parameters. Therefore, the path consisting in creating a program that uses the data of numerous experiments and finds an equation for calculating the losses in a group of gratings close to the specified one in terms of geometric parameters was chosen. Accordingly, a bank of experimental data on losses in a large number of gratings was formed and tested at different angles of attack and flow rates. According to the test results, an increase in the flow rate out of the cascade leads to a decrease in losses from a positive angle of attack. All grids are clearly divided into three large groups according to the nature of losses. For the gratings of each group, the ranges of variation of the angles of the flow inlet and outlet and the thickness of the profile and its leading edge are determined. The set of these parameters determines the form of the approximating polynomial for each given grill. To reflect the effect of the step and exit speed and find the design equation, gratings with narrow deviations of the parameters from the given value are selected from the group, and the unknown polynomial coefficients are calculated using the least squares method. Calculations according to the developed program give smaller deviations from experiments than the known formulas.

Keywords: angle of attack, defining parameters, loss bank, grill groups, calculation program, profile edge thickness, design angle, profile thickness, relative pitch

ВЕРТКИН и др.

The Upgrading of the Combined-Cycle Cogeneration Plant with Heat-Recovery Steam Generators for Large Cities of the Russian Federation

M. A. Vertkin^{a,*}, S. P. Kolpakov^a, V. E. Mikhailov^a, Yu. G. Sukhorukov^a, and L. A. Khomenok^a

^a*ОАО Polzunov Scientific and Development Association on the Research and Design of Power Equipment,
St. Petersburg, 191167 Russia*

**e-mail: VertkinMA@ckti.ru*

Abstract—In most large cities of Russia, the annual heat consumption exceeds the annual electricity consumption more than twice as a rule. On the contrary, the electric power of the combined-cycle cogeneration heat-power plant (CCCHPP) with heat-recovery steam generators (HRSG) is much higher than the thermal power of the cogeneration extraction of its steam turbine plant. This necessitates equipping combined-cycle gas turbine—combined heat and power plants (CCGT—CHPP) with additional heat sources to cover the heat loads of the heating season, which exceed the heat capacity of the cogeneration extractions of the combined-cycle gas turbines. The article shows that the use of water-heating boilers in this capacity has a number of serious disadvantages. These disadvantages can be eliminated by equipping HRSGs with afterburner units (ABUs), which burn the gas fuel in the residual oxygen of the exhaust gases of the gas turbine engine (GTE) directly in the HRSG. The range of thermal loads can be expanded, and the efficiency of the ABU application can be significantly increased by mounting the ABUs in the HRSG downstream from the high-pressure steam superheater upstream from the high-pressure evaporator. Furthermore, it is necessary to integrate a number of new components into the HRSG configuration, such as a water low-pressure steam superheater (WLPSSH) used instead of the gas LPSSH, a reduction device, and a peak network heater included in the heating plant of the steam turbine unit as the third stage of the network water heater at high (peak) thermal loads. By the example of the PGU-450T CCCHPP, the fundamental possibility of implementing the proposed modernization of its complete HRSG without making any changes to the design of the steam turbine is shown. Since the low-pressure drum of this HRSG is additionally equipped with a deaeration unit, the upgraded HRSG of the PGU-450T plant had also to be equipped with a water condensate heater upstream from the deaerator and additional shut-off and control valves that maintain the pressure in the deaerator and assure the subcooling of the water condensate at the deaerator inlet within the permissible range of all operating modes as well as under changing thermal loads all the year round.

Keywords: gas turbine plant, steam turbine plant, combined-cycle power plant, combined-cycle gas turbine—cogeneration heat and power plant, heat-recovery steam generator, afterburner unit, cogeneration plant, network water heater

РЯБОВ

A Review of the Research Results into the Technologies of Solid-Fuel Combustion in a Circulating Fluidized Bed Conducted Abroad and in Russia

G. A. Ryabov*

OAo All-Russia Thermal Engineering Institute, Moscow, 115280 Russia

**e-mail: GARyabov@vti.ru*

Abstract—The article provides an analysis of the current status and the development of the circulating fluidized bed (CFB) combustion technology. The main distinguishing features of the CFB combustion technology and the stages of its development worldwide are provided. The advantages and disadvantages of the CFB technology compared with traditional flame combustion are outlined. Examples of the largest power-generating units equipped with CFB boilers are provided. The latest studies of the specific features of the CFB boiler designs have been analyzed to increase the steam parameters and assure the highest efficiency of the power units equipped with CFB boilers. The basic trends in the research into the hydrodynamics, separation, composition of the bed, etc. are considered. It is shown that the efficiency of capturing solid particles is the decisive factor in increasing their consumption and retention of fine calcinated particles in the circulating material. The high concentration in the disengaging space of the combustor results in an increase in the heat-transfer coefficient and ensures a uniform temperature distribution in the combustor, the required degree of reaction of limestone particles with SO_2 for the most efficient binding of sulfur, and more complete combustion of the fuel (the highest possible residence time of the fuel particles in the combustor). Studies of Chinese researchers, their practical developments, and the introduction of energy-saving technology with a low volume of particles in the bed are analyzed. The results of the latest studies on the minimization of emissions of both conventional hazardous substances, such as nitrogen and sulfur oxides and other pollutants, including greenhouse gases, are provided. The problems that arise during the combustion of several kinds of fuel, including biomass, are investigated. Results of studying the processes of bed agglomeration, fouling of the heat-transfer surfaces, and corrosion of CFB boiler superheaters are presented.

Keywords: circulating fluidized bed, power-generating units, efficiency of combustion, hazardous emissions, hydrodynamics, separation, bed composition, fuel flexibility, biomass, cocombustion, agglomeration, corrosion

Determining Optimum Productivity of a Ball Drum Mill When Milling Brown Coals

S. D. Ivanov^{a, *}, A. N. Kudryashov^a, and V. V. Oshchepkov^a

^a*Irkutsk National Research Technical University, Irkutsk, 664074 Russia*

**e-mail: ivsd55@yandex.ru*

Abstract—Ball drum mills (BDM) are one of the main types of coal-grinding equipment in Russia. A significant drawback of BDM is high power consumption (a significant part of the TPP's own needs). With a huge scale of production, reducing these costs even by a few percent gives a significant economic effect. The problem of minimizing the specific energy consumption for grinding and transporting Azean coal in an ShK-32 ball drum mill is considered. For moist brown coals, the efficiency of grinding and transport of coal dust is usually achieved in the mode of equality of the grinding and drying capacities of the mill. The implementation of this regime is a necessary but insufficient condition. A system of equations is obtained to describe the processes of grinding and transport of coal dust. The analysis of the equations shows that the specific energy consumption for grinding is inversely proportional to the air consumption, and the specific costs for the transport of the dust and gas flow are proportional to the square of the air consumption. This fact ensures the presence of a minimum specific energy consumption for pulverization. A comparison of the estimated consumption of specific energy for pulverizing in an ShK-32 ball drum mill with experimental results obtained during routine commissioning tests of the dust system of the Irkutsk CHPP-9 is made. The average deviations of the calculation results from the experimental data are in the range of $\pm 10\%$. Comparison of the calculated and experimental data indicates that the mathematical model of the mode of equality of the grinding and drying capacities of the BDM adequately describes the processes occurring during the preparation of fuel for combustion. It is shown that an increase in the efficiency of dust systems with BDM can be achieved only after a detailed study of the transport of coal dust. In the proposed method for determining the optimal performance of the ball mill, the effect of the polydispersity of coal dust on the aerodynamic resistance of the mill is consistently taken into account.

Keywords: ball drum mill, specific energy consumption for pulverization, drying capacity of the mill, particle size distribution of coal dust

Experimental and Calculated Studies of Condensation-Induced Water Hammer

G. J. Volkov^a, I. V. Elkin^b, A. V. Kapustin^c, V. I. Melikhov^{a,*}, O. I. Melikhov^a,
S. M. Nikonov^b, and O. N. Trubkin^b

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bAO Elektrogorsk Research and Engineering Center for Nuclear Power Plants' Safety,
Elektrogorsk, Moscow oblast, 142530 Russia

^cNuclear Safety Institute, Russian Academy of Sciences, Moscow, 115191 Russia

*e-mail: vladimir.melikhov@erec.ru

Abstract—Experience gained from the operation of nuclear power plants shows that emergencies or incorrect actions of the personnel may give rise to water hammer phenomena, which exert additional impacts on the pipelines and equipment. Condensation-induced water hammer (CIWH) is one of the most destructive kinds of water hammer. Experimental studies of CIWH were carried out in a number of scientific organizations around the world. The main features of the experimental facilities used in the world are considered. For studying the CIWH phenomena occurring in a horizontal channel, a special experimental test facility was set up in 2018 at the Elektrogorsk Research and Engineering Center for Nuclear Power Plants' Safety (EREC). The facility's test section and the parameters of experimental regimes are described. Fifty-two experiments were carried out on the facility under different initial and boundary conditions for three values of the water flowrate supplied to the facility (1, 3, and 5 t/h), two values of water temperature (30 and 60°C), and two values of vapor pressure in the test section (0.6 and 1.0 MPa). In all experiments, CIWH phenomena were recorded. As an example, one experimental regime was considered in detail, and the CIWH occurrence mechanism is described proceeding from the readings of pressure and level gages and temperature sensors. The described experimental regime was modeled using the RELAP5 and WAHA thermal-hydraulic codes. The effect that the size of nodalization diagram cells and the integration time step have on the computation results is analyzed. The significant amount of experimental points obtained from the study can be used for setting up a database for validating computer codes.

Keywords: water hammer, condensation-induced water hammer, experimental studies, mathematical modeling, two-phase flows, interphase interaction, RELAP5, WAHA

A Model of the Outlet of Fission Products from the Melt Pool during a Severe Accident in a Liquid-Metallic Cooled Reactor

E. V. Usov^{a,*}, V. I. Chukhno^a, I. A. Klimonov^a, V. D. Ozrin^a, N. A. Mosunova^a, and V. F. Strizhov^a

^a*Institute for Safe Development of Nuclear Power Engineering (IBRAE), Russian Academy of Sciences, Moscow, 115191 Russia*

**e-mail: usovev@gmail.com*

Abstract—Accident scenarios implying the failure of the active and passive reactor protection system are the most severe in their consequences since they are accompanied by the melting of fuel elements, fuel assemblies, and the entire core and, as a consequence, the release of fission products (FP) from the fuel melt and structural materials. The location of reactor facilities near populated areas requires an understanding of the consequences of hypothetical accidents with the destruction of the core. The information on the amount of FP released into the environment is the most important. To assess the possible dose load on personnel and the environment in a hypothetical accident, data on the release of radioactive nuclides from the damaged, including molten, core are required. This work presents approaches that can be used to calculate the amount of fission products released from the fuel melt. The proposed approaches are based on general patterns of behavior and release of impurities from liquid solutions. To simulate this process, a system of differential equations is solved. The proposed approaches were implemented in the form of a software module for calculating the release of FP from the melt. Using the developed module, a test problem for the release of FP from a molten oxide fuel was solved, and an analysis of the results of real experiments carried out at the National Laboratory in Oak Ridge was carried out. Satisfactory convergence of the calculated data on the yield of both nonvolatile (Ce, Sr) and volatile n (Xe, Kr) fission products is shown.

Keywords: fast neutron reactor, severe accident, volatile and nonvolatile fission products, melt, EUCLID/V2, SAFR/V1

Experience of Applying VTIAMIN Brand Reagents for Correction of the Water-Chemical Regime of TPPs' Return Cooling Systems

V. V. Kozlovsky^a, E. F. Nartya^a, Yu. V. Ulanovskaya^b, and A. B. Larin^c. *

^aOOO Water Technologies Engineering, Moscow, 115280 Russia

^bOOO Bashkir Generating Company, Ufa, 450059 Russia

^cIvanovo State Power Engineering University, Ivanovo, 153003 Russia

*e-mail: admin@xte.ispu.ru

Abstract—As part of the implementation of the program for the import substitution of corrosion inhibitors, scale formation and biocides, the branches of OOO Bashkir Generation Company conducted research and pilot testing (RPT) on the use of VTIAMIN reagents when dosing them into the circulating water of recycle cooling systems (RCC) of several CHPPs. The selection of VTIAMIN reagents, manufactured by OOO Water Technologies Engineering, was carried out in accordance with the test objectives, taking into account the composition of the equipment and operating conditions of the RCC, the quality of the make-up water, and the methods of disposal of blow-down water. As a result of studies carried out using a mobile bench installation that simulates the operation of a ventilation cooling tower at a temperature of 45°C and an evaporation coefficient in the range of 1.0–3.5, it was shown that the reagent VTIAMIN TS-5 has a high antiscaling efficiency and can successfully replace the imported Aktifos 640T reagent without changing the dosing scheme and chemical control methods. The use of the VTIAMIN ZS-6 reagent provides sufficient protection against corrosion of copper-containing alloys by inhibiting the local dissolution of copper and creating a protective film on the surface of the equipment under conditions of dosing into circulating water in excess. VTIAMIN B-6 proposed as a domestic biocide at a dosage of 0.2 mg/dm³ is able to suppress biological growth in RCC elements and replace the imported Turbanion M104 reagent. The effectiveness of the reagent is confirmed by the results of controlling the total microbial number on contact slides (biotests Microbiology Environcheck Contact TVC).

Keywords: import substitution in recirculating cooling systems, water regime, scale and corrosion inhibitors, thermal power plants, effectiveness of the VTIAMIN reagent

Determining the Efficiency of Desorption of Corrosive-Active Gases in Columns with Chaotic and Regular Nozzles

E. A. Lapteva^{a,*} and M. I. Farakhov^b

^a*Kazan State Power Engineering University, Kazan, 420066 Russia*

^b*OOO Engineering and Implementation Center Inzhekhim, Kazan, 420032 Russia*

**e-mail: grivka100@mail.ru*

Abstract—The process of removing corrosive gases from water at TPPs in packed columns of calciners and in columns of thermal deaerators with a storage tank in film mode is considered, and a mathematical model is presented for calculating the efficiency of the desorption process. A cell model of the flow structure and an equation for calculating the mass transfer coefficient for a wave flow of a water film over the surface of a packing with artificial roughness are used. The value of the required height of the packing layer is obtained for the given density of irrigation with water and the efficiency of extracting gases dissolved in water. Formulas are given for calculating the parameters of a mathematical model: the coefficient of mass transfer in the wave film, the average velocity of water in the film, the dynamic retention of the liquid in the packing layer and the number of cells for complete mixing of the liquid phase. The possibility of using metal chaotic and regular packings is considered, and the results of calculations of the efficiency of mass transfer and the required height of the packing layer at various operating parameters of the desorption process are presented. The graphs of the required layer height for the given efficiency of mass transfer and the power spent on air supply to the desorber when using various nozzles of domestic and foreign production are presented. The article describes the operation of a thermal deaerator with a storage tank and outdated contact devices in a deaerator column at a TPP. The main mass transfer and hydraulic characteristics of modern nozzles for thermal deaerators are presented. Technical solutions have been developed that can be used when choosing a highly efficient metal chaotic packing with a rough surface, which provides an increase in the mass transfer coefficient in a liquid wave film and, accordingly, the efficiency of mass transfer. A variant for modernization of the deaeration column of the DSA-300 deaerator at the Kazan CHPP-3 by replacing outdated contact devices with a modern chaotic packing is shown. As a result of its application, compliance with the standards of water purification from dissolved oxygen is ensured at various loads on water and steam.

Keywords: thermal power plants, desorption, packing, efficiency, modernization, dissolved gases, mass transfer, cell model, flow structure