

Contents

Vol. 68, No. 3, 2021

General Issues of Power Engineering

Climatic Extremes: a New Challenge for Russian Power Systems

V. V. Klimenko, A. V. Klimenko, A. G. Tereshin, and E. V. Fedotova

Heat and Mass Transfer and Properties of Working Fluids and Materials

The Plasma-Facing Materials of Tokamak Thermonuclear Reactors: Requirements, Thermal Stabilization, and Tests (a Review)

G. Van Oost, A. V. Dedov, and V. P. Budaev

Nuclear Power Plants

Studying the Swirl Flow Hydrodynamics in the Guiding Channel Area Downstream of Mixing Spacer Grids of a PWR Reactor Fuel Assembly

S. M. Dmitriev, A. V. Gerasimov, A. A. Dobrov, D. V. Doronkov, A. P. Zhivoderov, E. V. Rubtsova, A. V. Ryazanov, D. N. Solntsev, A. N. Pronin, and A. E. Khrobostov

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Coal Gasification: At the Crossroads. Technological Factors

S. P. Filippov and A. V. Keiko

Determining the Parameters of the Fluid Layer with a Rigid Mobile Nozzle

N. O. Usmonov, Kh. S. Isakhodzhaev, and M. A. Koroli

Automation and Thermal Control in the Power Industry

From Automated Design to Digital Double of APCS for a TPP

I. M. Sharovin, V. V. Lopatin, V. A. Trofimov, and A. V. Trofimov

District Heating Cogeneration and Heat Networks

An Analysis of Problems and Trends Relating to the Development of Heat-Supply Systems for Russian Cities

E. G. Gasho, V. S. Puzakov, and S. V. Guzhov

Selecting the Forecasting Model of Heat Energy Delivery

A. V. Zatonsky and L. G. Tugashova

Climatic Extremes: a New Challenge for Russian Power Systems

V. V. Klimenko^{a,*}, A. V. Klimenko^b, A. G. Tereshin^a, and E. V. Fedotova^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*National Research Technological University MISIS, Moscow, 119049 Russia*

**e-mail: nilgpe@mpei.ru*

Abstract—Changes in temperature extremes in Russia after 1945 are examined, and their effect on power system performance is analyzed. It is indicated that the United Power System (UPS) of Russia and all integrated power systems (IPS) presently have a considerable amount of installed and available spare capacities. However, a quarter of the regional power systems suffer a power shortage, and three of seven integrated regional power systems of Russia (Northwest, Center, and South) feature a deficit in the power control range, which is covered by power flows from adjacent power systems (Middle Volga, Urals, and Siberia). Based on the meteorological monitoring results and power industry statistic, the observed change in the extremal climatic characteristics over the past 70 years were calculated. Its effect on the power balance and power system modes was assessed. It has been established that climatic changes that occurred in Russia and manifested themselves in an increase in the air temperature in all seasons in all regions of the country reduce the maximum load increase rate in the winter and raise it in the summer in almost all power systems, thereby contributing to an increase in the reliability of electricity supply. For the summer, a continuous increase in the power demand maxima in combination with an enhancement in the nonuniformity of the daily demand, and, as a result, a greater need for the control range mean an increase in the risk of many power supply failures. It has been demonstrated that, against this background, a decrease in the output of generating facilities (such thermal power plants (TPP), hydroelectric power plants (HPP), and nuclear power plants (NPP)) in hot weather and accidents at power facilities lead to the activation of the available spare power and substantiate the fact that many consumers can be disconnected in the power systems of the South and the Center.

Keywords: climatic extremums, power consumption, seasonal maximums, forecast, IPS of the South, daily load curve, integral and extremal characteristics

The Plasma-Facing Materials of Tokamak Thermonuclear Reactors: Requirements, Thermal Stabilization, and Tests (a Review)

G. Van Oost^{a, b}, A. V. Dedov^{a, *}, and V. P. Budaev^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*Ghent University, Ghent, B-9000 Belgium*

**e-mail: dedovav@mpei.ru*

Abstract—The results from experimental investigations of chamber internal parts and plasma-facing materials proposed for use in a thermonuclear reactor are reviewed. The thermonuclear reactor internals will experience various heat loads connected with temperature gradients and local exposure dose with the nuclear reaction neutron energy spectrum. The lifetime of the systems will depend on the resistance of materials to neutron and heat loads. Assurance of heat removal is one of serious problems to be solved in implementing a thermonuclear power plant. The components can be cooled either by gas or liquid, including salt solutions and liquid metals. The parameters of coolants, heat-transfer systems, and cooling systems will take values that are still not attainable as of yet. The variety of available design elaborations suggested in the Russian and foreign projects must be substantiated in terms of heat transfer. The parameters of heat and neutron loads will govern the choice of materials for the thermonuclear reactor systems. The international thermonuclear experimental reactor (ITER), which is under construction, will be built using structures, materials, and technologies that have passed the main tests. The ITER cooling systems will operate with forced single-phase convection of turbulent water flow; the heat transfer will be intensified by using inner finning and flow swirling. The thermal protection lining of the plasma-facing chamber's internal parts in the zones of the highest plasma and heat load will be made of tungsten. In elaborating the design of the next-generation demonstration reactor (DEMO), it will be necessary to additionally develop the blanket construction technologies and solve the problem of converting heat into electricity. The materials for the DEMO reactor must be selected with due regard to the high dose of their irradiation by neutrons with the thermonuclear reaction energy spectrum and critically high heat loads experienced by the plasma-facing chamber's internals. It will be necessary to develop and test new materials for constructing the DEMO thermonuclear reactor and solve matters concerned with their commercial-scale manufacture.

Keywords: thermonuclear reactor, tokamak, materials, thermal tests, heat removal, heat transfer, blanket, divertor, tungsten, lithium, neutron and heat loads

Studying the Swirl Flow Hydrodynamics in the Guiding Channel Area Downstream of Mixing Spacer Grids of a PWR Reactor Fuel Assembly

S. M. Dmitriev^a, A. V. Gerasimov^{a,*}, A. A. Dobrov^a, D. V. Doronkov^a, A. P. Zhivoderov^a,
E. V. Rubtsova^a, A. V. Ryazanov^a, D. N. Solntsev^a, A. N. Pronin^a, and A. E. Khrobostov^a

^a*Alekseev Nizhny Novgorod State Technical University, Nizhny Novgorod, 603155 Russia*

**e-mail: poorvenom@yandex.ru*

Abstract—The results from studying the coolant flow in fuel assemblies downstream of mixing spacer grids of a PWR reactor are presented. The aim of the study is to estimate the effect from using different designs of mixing grids. For this purpose, experimental investigations were carried out on an aerodynamic test facility with scaled models of fuel assembly fragments containing mixing spacer grids of different designs. Two adjacent cells of the guiding channel zone were selected as the representative study area. The specific structural feature of these cells is that the turbulizers installed on the intensifying grids have different spatial orientation. The general flow pattern is represented by the vector fields of tangential velocities and by the distribution of relative velocities in the gaps between the fuel rods and the guiding channel. For estimating the effect from using the grid designs with respect to coolant flow mixing, the intracell vortex formation coefficients and intercell mixing coefficients were analyzed. It has been shown from the performed analysis that, owing to the use of the alternative design with a pair of cell deflectors oriented in a changed direction, the intercell transfer coefficient and the intracell vortex formation coefficient were increased by a factor of 1.13 and 2.2, respectively, in comparison with those in the basic design. Hence, the use of the grid of the alternative design is more preferable for obtaining better mixing of the coolant flow. The accumulated database on coolant flow in the Square FA serves for engineering substantiation of the PWR reactor cores. The results from experimental studies are used for verification of CFD codes developed both in Russia and abroad and of programs for detailed cell-wise analysis of the cores for reducing the conservatism in substantiating their thermal reliability.

Keywords: mixing grids, deflectors, guiding channel, aerodynamic test facility, intracell vortex formation, intercell mixing

Coal Gasification: At the Crossroads. Technological Factors

S. P. Filippov^{a, *} and A. V. Keiko^a

^a*Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia*

^{*}*e-mail: fil_sp@mail.ru*

Abstract—The article presents results from analyzing the state of the art achieved in the coal gasification technologies developed around the world and the demand for them. It is shown that such technologies have presently arrived at a crossroads in their development. Their future will be determined by the development prospects of coal energy as a whole. Coal still continues to play the most important role in the world energy. In recent years, external factors have become extremely negative for the development of coal energy. Among other fuels, coal produces the largest specific emissions of CO₂ during its combustion, in view of which it may become the first victim of the unfolding energy decarbonization policy. Under such conditions, there is a need to diversify the coal utilization fields, primarily through manufacturing a wide range of chemical products with a high added value. This generates the need to develop the appropriate technologies, and, first of all, gasification technologies, the use of which opens the possibility of making almost the entire range of products from coal that are obtained from petroleum and natural gas. It has been determined that gasification technologies have already reached a high level of technical maturity, and a large number of gasifier designs have been proposed. It has been determined that the majority of operating coal gasification plants are presently used for manufacturing various chemical products, first of all, natural gas substitute (which is then forwarded to gas networks) and also methanol and ammonia. It is pointed out that only a few integrated gasification combined cycle plants have been implemented and planned for construction, which means that the private sector shows little interest in this technology. At the same time, such plants have quite a high potential for being used in low-carbon energy, of course, provided that the problem of disposing the captured CO₂ is solved. It is shown that a large number of gasifier equipment manufacturers are available around the world. However, gasifiers are produced in single units or in a small series, which unavoidably leads to the high cost of this equipment. For the further innovative development of the gasification technology, combined efforts should be taken by the private sector and the state.

Keywords: gasification, gasifier, integrated gasification combined cycle plant, synthesis gas, carbon dioxide, coal, thermochemical conversion efficiency, coal energy

Determining the Parameters of the Fluid Layer with a Rigid Mobile Nozzle

N. O. Usmonov^{a,*}, Kh. S. Isakhodzhaev^{a,**}, and M. A. Koroli^{a,***}

^a*Tashkent State Technical University, Tashkent, 100095 Republic of Uzbekistan*

**e-mail: nizomiddin1981@mail.ru*

***e-mail: x.isaxodjayev1965@yandex.ru*

****e-mail: mkoroly@list.ru*

Abstract—Hydrodynamic problems of a three-phase fluidized bed are considered. The main attention is paid to experimental studies into the process of cooling industrial circulating water in a three-phase layer. An experimental setup was developed and assembled, and its brief description and operating principle are given. Adjustment experiments and experiments with a two-phase fluidized bed were carried out, the main task of which was to determine the dependence on the air velocity in the apparatus of the hydraulic resistance of a dry grate without a nozzle. A series of experiments is described that made it possible to establish the optimal cooling mode for circulating water in an apparatus with a three-phase fluidized bed. The experiment was carried out at both constant and variable irrigation density, and the experiments were repeated at different air velocities. The following parameters of the three-phase fluidized bed were recorded: hydraulic resistance, the rate of onset of fluidization, the rate of entrainment, and the height of the dynamic bed. The results of experimental studies into the fluidization rate and entrainment rate at various ball nozzles and the dependence of the dynamic height of a three-phase fluidized bed on the rate and density of irrigation are presented. Experimental data have been obtained on the pressure drop in a three-phase fluidized bed depending on the air velocity, the rate of the beginning of fluidization of the irrigated bed of the packing, and the rate of flooding of the three-phase fluidized bed as a function of the irrigation density. The analysis of hydrodynamic and thermal processes occurring in a three-phase fluidized bed is carried out, and the main technological parameters for the optimal operation of installations with the specified bed are obtained in relation to solving the problem of cooling the circulating water. The dependence of the expansion of a three-phase fluidized bed on air velocity and irrigation density has been investigated. On the basis of the performed experimental studies, empirical formulas for calculations are derived.

Keywords: hydraulic resistance, three-phase fluidized bed, spherical polyethylene packing, irrigation density, dynamic height, cooling of circulating water, critical air velocity, hydrodynamic resistance, onset of fluidization, flooding, entrainment rate

From Automated Design to Digital Double of APCS for a TPP

I. M. Sharovin^a, V. V. Lopatin^b, V. A. Trofimov^b, and A. V. Trofimov^{c,*}

^a*OOO Intertechelectro-Project, Moscow, 107045 Russia*

^b*OOO Energoavtomatika, Moscow, 109316 Russia*

^c*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: trofi56@bk.ru*

Abstract—The concept of a digital twin of an automated process control system (APCS) of a thermal power plants is considered. The principles of its formation and use are proposed on the basis of a design database developed within the framework of a computer-aided design (CAD) system for thermal automation and measurements. Examples of design automation systems aimed at solving similar problems are given and the features of the proposed CAD system are indicated. The typical structure of the APCS and the relationship of its main components—sensors, cables, executive and switchboard devices, signal connection tables, as well as the software and hardware complex (composition and distribution of modules of communication devices with an object)—are described. A description of the project database’s structure is given, which provides comprehensive work with both project documentation and information about the main components of the APCS. The sequence in execution of design procedures and links between the design database and the CAD database during their implementation are shown. Methods for increasing the productivity of designers are considered, such as the use of standard solutions in the organization of measurements and control schemes for actuators of thermal power plants, multiple use of information with a single input, and synthesis of text and graphic design documentation based on the project database. It is proposed to use a digital twin at all stages of the object’s life cycle: during design, installation, commissioning, and operation. The effectiveness of working with information thanks to an intuitive interface for navigating through the project was demonstrated. Examples of objects, in the implementation of which the considered CAD system was used, are given.

Keywords: APCS, TPP, digitalization, digital twin, CAD, databases, design, software and hardware complex, data model, working documentation

An Analysis of Problems and Trends Relating to the Development of Heat-Supply Systems for Russian Cities

E. G. Gasho^a, V. S. Puzakov^b, and S. V. Guzhov^{a,*}

^a*National Research University, Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*OOO Ensys Technologies, Moscow, 108811 Russia*

**e-mail: GuzhovSV@yandex.ru*

Abstract—Problems associated with the development of heat-supply systems for large- and medium-size cities in Russia are analyzed. To this end, the approved heat-supply schemes of almost forty cities are reviewed and briefly analyzed taking into account their key territorial features. The main features of heat-supply systems for cities are analyzed, including the state of heat networks, excess capacities of sources, parameters of combined heat and power plants operating in the forced generation mode, and also the possibilities of using secondary and renewable energy sources for heat generation. The specific indicators characterizing heat consumption are calculated with taking into account, among other factors, the heating season degree days. The dependences of specific fuel consumption and energy generation efficiency on the climatic parameters, population density, and other factors are considered. For estimating the potential efficiency improvement reserves, consolidated data on the total installed capacity and heat-supply modes in cities are given. The aim of the study was to reveal the key problems and main trends associated with the development of heat-supply systems for cities. Large- and medium-size cities of Russia were distributed into a few typological groups, and their analysis has shown similarity of the problems occurring in them along with possible sets of typical measures and methods for solving them. The effectiveness of heat-supply systems as a whole for some cities depending on the population density and number and in different climatic zones is estimated. It is found that the obtained indicators characterizing the resulting efficiency of heat-supply systems are not directly linked with the fraction of industrial load, population density, and climate. In elaborating the heat-supply schemes, it is proposed to use the energy and environmental effectiveness indicators for revealing the key reserves for sustainable development of the most important life-support infrastructures of cities in Russia's different climatic zones.

Keywords: heat-supply scheme of a city, total installed thermal capacity, heat supply, standard wear of heat network pipelines, heat-generation efficiency, climatic zone

Selecting the Forecasting Model of Heat Energy Delivery

A. V. Zatonsky^a and L. G. Tugashova^{b, *}

^a*Bereznikovsky Branch, Perm National Research Polytechnic University, Berezniki, 618404 Russia*

^b*Almetyevsk State Oil Institute, Almetyevsk, 423450 Republic of Tatarstan, Russia*

**e-mail: tugashova@yandex.ru*

Abstract—To solve the problems of saving thermal energy, instead of the currently used cumbersome methods or complex mathematical models, for example, in the form of partial differential equations, it is proposed to use simpler models of time series for the supply and production of thermal energy. The data of a specific heat supply organization on a city scale and the website of the Ministry of Energy of the Russian Federation were used as initial data. The proposed approach is based on a comparison of various mathematical models for predicting the production and supply of heat energy according to the criterion of adequacy (average relative error and coefficient of determination). The results of research carried out using the Matlab software package are presented. A substantiated comparison of the possibility of using different models is carried out. Models have been developed that take into account the seasonal component and higher accuracy. The possibility of using the following time series models is investigated: regression models with a seasonal component, triple exponential smoothing Holt–Winters, multiplicative seasonal autoregression model of the integrated moving average SARIMA (seasonal autoregression integrated moving average), and nonparametric model SSA (singular spectrum analysis). Multiplicative models containing a trend in the form of a linear or autoregression model with the calculation of the seasonality index, as well as additive models with a trend in the form of a linear or autoregression model with a seasonal component in the form of a Fourier series or sum of sines, were compared. In the Holt–Winters model, *fminsearch*, a function of the Matlab software package, was used to determine the tuning parameters. In the multiplicative SARIMA model, the orders of autoregression and moving average were fitted according to the autocorrelation and partial autocorrelation function. The nonparametric SSA model was used for comparison with the listed parametric models. An opportunity has been obtained to make reasonable forecasts of the production and supply of heat energy. It is shown that the best results (average relative error 6.52%) were obtained using the SARIMA multiplicative model.

Keywords: heat supply, autoregression model, one-factor regression model, exponential smoothing, time series, trend, seasonality index, forecasting, multiplicative model, error