
Contents

Vol. 68, No. 4, 2021

Heat and Mass Transfer, Properties of Working Fluids and Materials

Phase Change Materials and Power Engineering

I. S. Grigor'ev, A. V. Dedov, and A. V. Eletskii

Nuclear Power Plants

An Experimental Study into the Hydrodynamics of the Loop Coolant Flows' Mixing
in the Nuclear Reactor Downcomer

*S. M. Dmitriev, A. E. Khrobostov, M. A. Legchanov, A. A. Dobrov, A. V. Ryazanov,
D. V. Doronkov, A. N. Pronin, D. N. Solntsev, A. A. Barinov, and A. V. Gerasimov*

Developing Approaches to Analysis of Melt Motion on the Surface of a Heat-Generating Element

E. V. Usov, P. D. Lobanov, and N. A. Pribaturin

The New Generation of High-Pressure Heaters for Steam Turbine Units of Power Units
at Nuclear Power Plants

V. M. Zorin, A. S. Shamarokov, and S. B. Pustovalov

Steam-Turbine, Gas-Turbine, Combined-Cycle Power Plants and Their Auxiliary Equipment

Experimental Studies of the Discharge Characteristics of Variable-Pitch Multifinned Seals

S. S. Dmitriev, B. N. Petrunin, and E. A. E. Ahmed Mohamed

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Increasing the Efficiency and Increasing the Resource of the Plasma-Ignition System
by Its Modernization at Gusinoozerskaya TPP

*D. V. Sosin, A. V. Shtegman, I. A. Ryzhiy, E. A. Fomenko, S. D. Bor,
Ch. O. Tsyrenov, and A. V. Yakovenko*

District Heating Cogeneration and Heat Network

An Extended Heating Regulation Schedule: Definition and Assessment of Its Efficiency
in Heat-Supply Systems

A. A. Pyatin and D. M. Suvorov

The Effect of Climatic Factors on the Electric Load of Thermal Power Plants (TPP)
in the Southern Federal District by the Example of the Novocherkassk
District Power Plant (GRES)

N. V. Fedorova

Phase Change Materials and Power Engineering

I. S. Grigor'ev^{a, *}, A. V. Dedov^a, and A. V. Eletsii^a

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: vectr2015@yandex.ru*

Abstract—The review contains information on the properties of phase-change materials (PCM) and the possibilities of their use as the basis of thermal energy storage. Special attention is given to PCMs with a phase change temperature ranging between 20 and 80°C since such materials can be effectively used to reduce temperature variations in residential and industrial premises. Thus, the application of PCMs in the construction industry enables one to considerably reduce the power consumption and control the environmental impact of industrial facilities. Thermophysical characteristics of the main types of PCMs are presented. The heat balance for a room with walls made of PCM-added materials is estimated. The predictions demonstrate that such structures can stabilize the temperature in practical applications. The potential of wide application of PCMs as a basis for thermal energy storage is limited due to very low conductivity (less than 1 W/(m · K)) specific for these materials. Hence, the option of increasing the material conductivity by adding some carbon nanotubes whose thermal conductivity is four to five orders of magnitude greater than that of the base material is examined. The numerical predictions of the heat-conduction enhancement in a PCM doped with carbon nanotubes and the preliminary experiments indicate that a PCM with approximately 20% carbon nanotubes can enhance the material heat conductivity by two to four times.

Keywords: phase change materials, thermal energy storage, heat conductivity, carbon nanomaterials, melting heat

An Experimental Study into the Hydrodynamics of the Loop Coolant Flows' Mixing in the Nuclear Reactor Downcomer

S. M. Dmitriev^a, A. E. Khrobostov^a, M. A. Legchanov^a, A. A. Dobrov^a, A. V. Ryazanov^{a,*},
D. V. Doronkov^a, A. N. Pronin^a, D. N. Solntsev^a, A. A. Barinov^a, and A. V. Gerasimov^a

^a*Alekseev State Technical University, Nizhny Novgorod, 603950 Russia*

**e-mail: a_v_ryazanov@rambler.ru*

Abstract—This work is an experimental study into the hydrodynamics of the coolant flow in the in-vessel pressure duct of a pressurized water reactor. In the article, an experimental testbench and a nuclear reactor model under investigation are described, the measurement methods are set forth, and the operating variables at which the study was conducted and the obtained results are provided. In the experiments, the mixing of the loop coolant flows inside the model of the nuclear reactor downcomer was simulated. The study was conducted on the high-pressure aerodynamic testbench of Alekseev State Technical University in Nizhny Novgorod. The scale model of the nuclear reactor had the structural components characteristic of loop-type reactor units, such as the annular downcomer and the bottom pressure vessel. The experiments were conducted at Reynolds numbers within the 20000–50000 range measured in the annular gap of the downcomer of the model. The axial velocity field at the inlet to the reactor core simulator was investigated using a pneumatic probe. The temperature field was recorded in the experiment by the impurity diffusion method, i.e., by introducing of a contrast tracer into one of the loops of the model. The degree of mixing the flows was estimated by the admixture (tracer) concentration at the inlet to the core simulator. Propane was used as the contrast admixture. The study has yielded the spatial distribution of the tracer in the coolant flow in the annular downcomer and in the bottom pressure vessel. The data on the distribution of the contrast admixture are presented in the form of charts. The swirling of the coolant flow in the in-vessel pressure duct has been analyzed. It has been shown that the mixing intensity in the bottom pressure vessel is affected by the central vortex with the central axis. The parameters of mixing the admixture in the model of the in-vessel pressure duct have been estimated.

Keywords: flow hydrodynamics, flow mixing, nuclear reactor, coolant, direct sampling method, tracer

Developing Approaches to Analysis of Melt Motion on the Surface of a Heat-Generating Element

E. V. Usov^{a,*}, P. D. Lobanov^{a,b}, and N. A. Pribaturin^{a,b}

^a*Institute for Safe Development of Nuclear Power Engineering, Russian Academy of Sciences, Moscow, 115191 Russia*

^b*Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

**e-mail: usovev@gmail.com*

Abstract—Based on the analysis of experiments carried out on simulators of fuel elements with a cladding of low-melting metals, models of melting and movement of the melt over the surface of fuel elements are proposed. The presented work is a continuation of experimental and theoretical work carried out jointly at the Institute for Safe Development of Nuclear Power Engineering, Russian Academy of Sciences, and Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, to study the features of the movement of a melt over a cylindrical surface that simulates the surface of a fuel element. It analyzes the factors that determine the thermal destruction of fuel elements. One of the important conclusions drawn from the analysis of experimental data was the conclusion about the prevailing film laminar runoff in the heated part of the fuel element simulator. Using this assumption, an analytical model was built that allows predicting the mass of a fuel element carried out of its limits during melting. As a result of calculations using the proposed model, it was shown that, for an accident with the introduction of positive reactivity, when the power increase can reach ten ratings, a modification of the model is necessary to take into account the turbulent runoff regime. For this purpose, a simplified model of the flow of the melt was built. A comparison is made with known techniques and it is shown that the proposed approach makes it possible to describe the turbulent flow regime with satisfactory accuracy. The modified model made it possible to calculate the features of the movement of a stainless steel melt over the surface of a fuel element of a fast neutron (BN) reactor. Information was obtained on the thickness of the melt, its velocity and Reynolds number, depending on the conditions of drainage, and on the mass carried outside the core.

Keywords: fuel element, melt, mathematical model, shell, motion, severe accident, film, friction, hydrodynamics, heat transfer, melting, nuclear power plant, reactor, fuel assembly

The New Generation of High-Pressure Heaters for Steam Turbine Units of Power Units at Nuclear Power Plants

V. M. Zorin^{a, *}, A. S. Shamarokov^{b, **}, and S. B. Pustovalov^{c, ***}

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bAll-Russia Research and Design Institute of Nuclear Power Machine Building (VNIIAM), Moscow, 115088 Russia

^cNational Research Center (NRC) Kurchatov Institute, Moscow, 123182 Russia

*e-mail: ZorinVM@mpei.ru

**e-mail: rasa7@mail.ru

***e-mail: Pustovalov_SB@nrcki.ru

Abstract—The designs of vertical high-pressure heaters (HPHs) for a regeneration system of steam-turbine units (STUs) at nuclear power plants are compared. The proposed heat exchanger with a header-platen tube system is compared with a conventional counterpart by thermohydraulic and design characteristics, weight and dimensions, and performance indicators. Excellent thermohydraulic performance of the proposed apparatus are brought about by the effective condensation due to a high velocity of the condensing steam flow in the shell's side. The tube bundle consists of standardized platens, the spacing between which can vary in a wide range. The introduction of a cylindrical tube header in place of the tube sheet considerably decreases the wall thickness with a corresponding reduction in the apparatus weight and also prolongs the service life due to elimination of sludge build-up at tube-to-tube header attachment points. Easy maintenance of these heaters is enabled by the access to tubes fixed in the upper and lower vertical cylindrical tube headers through manholes to ergonomically plug faulty tubes. The manufacturing time of the apparatus exchanger and the man-hours for its installation decrease due to the application of standardized tube platens and a shorter length of tube attachment holes. The proposed design has been used as the basis for developing a series of heat exchangers for installation at operating and newly designed power units of NPPs. These apparatuses can accommodate two series-connected, two parallel-connected, or two-series-connected and two parallel-connected HPHs in a single shell, thereby reducing the footprint occupied in a turbine hall. The above-mentioned features of the developed apparatuses are important in the reconstruction (or modernization) of operating NPP power units when the steam capacity of a nuclear steam generating plant is to be increased. The introduction of the proposed apparatuses opens the new way to the optimization of the design, process, and space-and-layout solutions for the regeneration systems of existing and newly designed steam turbine units with a corresponding reduction in operating costs and capital investments in the construction or reconstruction of NPP power units.

Keywords: NPP steam turbine unit, regeneration system, high-pressure heaters, condensation, tube sheet, heat-transfer coefficient, vertical cylindrical header

Experimental Studies of the Discharge Characteristics of Variable-Pitch Multifinned Seals

S. S. Dmitriev^{a,*}, B. N. Petrunin^a, and E. A. E. Ahmed Mohamed^{a,b}

^a*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^b*Benha University, Faculty of Engineering at Shoubra, Mechanical Engineering Department, Benha, Egypt*

**e-mail: dmitriyevss@mpei.ru*

Abstract—Variable-pitch multifinned seals (VPMS) have not hitherto found wide use in the steam turbines produced in Russia, although they are quite often used outside of Russia. In modernizing the existing and designing new steam turbines, rotor blades with an integrally machined shroud are used, which opens the possibility to manufacture multirow peripheral seals. In this connection, the question about selecting the optimal VPMS configuration becomes of important practical significance. The results obtained in this study made it possible to experimentally estimate the extent to which different combination of fin pitches on the rotor and stator influence the VPMS discharge characteristics and to elaborate practical recommendations on using them. The minimal leak flow was recorded for the VPMS models with a 2-mm-wide pitch on the rotor. Comparative experimental investigations of VPMS models with 3- and 4-mm-wide spacers on the rotor and 4- and 5-mm-wide spacers on the stator were carried out as applied to the shroud seals of large-capacity steam turbines. The model pair with the 4- and 5-mm-wide spacers on the rotor and stator, i.e., with the pitches equal to 4.8 and 5.8 mm on the rotor and stator, respectively, can be regarded as the most optimal of those investigated in this work. It has been shown experimentally that, with all other things being equal, the leak in VPMS is by 22–25% smaller than it is in straight-flow seals. By using VPMS, it becomes possible to avoid rubbing of the rotor against the stator under the conditions of relative radial and axial rotor displacements in transient modes of operation. In addition, the aerodynamic forces in VPMS able to excite a low-frequency shaft line self-oscillation are approximately equal to 60% of the similar forces occurring in the conventional radial clearance seals. In view of this circumstance, VPMS can be recommended for use instead of the standard tip shroud seals in the high- and intermediate-pressure cylinders in new and modernized steam turbines.

Keywords: steam turbine, rotor, stator, fin, interfin spacers, variable-pitch multifinned seal, seal pitch, leak, tip clearance, straight-flow seal, shroud

Increasing the Efficiency and Increasing the Resource of the Plasma-Ignition System by Its Modernization at Gusinoozerskaya TPP

D. V. Sosin^{a,*}, A. V. Shtegman^a, I. A. Ryzhiy^a, E. A. Fomenko^a, S. D. Bor^a,
Ch. O. Tsyrenov^b, and A. V. Yakovenko^{b,**}

^aAll-Russia Thermal Engineering Institute, Moscow, 115280 Russia

^bBranch of Gusinoozerskaya TPP AO Inter RAO—Elektrogeneratsiya, Gusinoozersk, Selenginsky District, Republic of Buryatia, 671160 Russia

*e-mail: sosin_work@mail.ru

**e-mail: yakovenko_av@interra.ru

Abstract—The article is devoted to a very urgent problem: reducing the cost of the fuel component in the production of electricity at power plants in Russia, namely, abandoning expensive fuel oil during the kindling of the boiler and the transitioning to the use of coal dust for this purpose. One of the ways to organize such kindling is the use of plasma technology to ignite coal dust. This technology is based on the thermochemical preparation of pulverized coal using an electric arc arising between the electrodes of the plasmatron. A stream of air passes through the arc, forming a plasma, which, meeting with the stream of air mixture, heats it, and promotes the release of volatile substances and the ignition of coal dust. Back in 1994, the first experiments on the implementation of such a system were carried out at the Gusinoozerskaya TPP. It turned out to be effective, but it had a number of significant drawbacks that limited its use. The main one was the low service life of the plasmatron cathode and muffle burner. In 2019, work was organized to modernize the plasma system aimed at increasing the resource of the main units of the plasma-ignition system. To solve a complex of problems, the specialists of OAO VTI proposed technical solutions for the design of a muffle burner, a cleaning system, and the automatic regulation of water and air supply to the plasma torch; a software package was developed to control the operation of the oil-free plasma-ignition system and control its parameters. Installation and testing of the modernized system for one of the pilot burners of the TPE-215 boiler was carried out. The specialists of the Institute of Physics and Mathematics (Siberian Branch, Russian Academy of Sciences) developed the design of the plasmatron and carried out its start-up testing. It is recommended to apply the results of the work to the rest of the boiler ignition burners. This article is devoted to the experience of upgrading the existing oil-free ignition system at the Gusinoozerskaya TPP.

Keywords: boiler, pulverized coal combustion, kindling, resource, efficiency, reliability, plasmatron, muffle burner, reconstruction, technology, combustion, testing, regulation

An Extended Heating Regulation Schedule: Definition and Assessment of Its Efficiency in Heat-Supply Systems

A. A. Pyatin^{a, *} and D. M. Suvorov^b

^a*Kirov Branch of PAO T Plus, Kirov, 610044 Russia*

^b*Vyatka State University, Kirov, 610000 Russia*

**e-mail: piatin@mail.ru*

Abstract—An extended heating regulation schedule with which the heat-transfer agent thermal potential is utilized to the maximum possible extent, the required indoor temperature in the heated rooms is maintained, and the energy expenditures for heat-transfer agent transportation are kept to a minimum is studied. A new equation of relative heating load at which the required indoor air temperature is maintained taking into account heat release and heat expenditures for infiltration is considered. A new heating regime regulation equation is used and verified, which takes into account the heating load, water flowrate supplied to the heating system, the system's nominal capacity margin, the power exponents of the heat-transfer coefficient dependences on the temperature difference and water flowrate through the system, and other factors. With using the extended schedule, the return water temperature is decreased in the heating season's main part down to 30–40°C provided that a sufficient heating system capacity margin is available. As a result, the heat-transfer agent is cooled to a fuller extent, its flowrate is decreased, smaller energy expenditures are required for driving the heat-supply source network pumps, a smaller amount of heat is lost in the network, and more efficient operation of the combined heat and power plant is achieved. For estimating the heat-supply system's performance, it is proposed to use the heat-transfer agent's thermal potential utilization factor. An assessment of the effects resulting from transition of the heating systems to the extended schedule, which was carried out on a model heat-supply system for a heating season, has shown that the heat-transfer agent's thermal potential utilization factor determined taking into account the recurrence of one-degree outdoor air temperature interval increases from 58 to 83% with such a transition, the supply water flowrate decreases from 88 to 38% of its design value, the energy expenditures for driving the network pumps are decreased by a factor of three, and the amount of heat supplied from the heat-supply source is decreased by 12.5%, or by 10.0% with taking hot-water supply into account.

Keywords: heat-supply system, heating load, heating regulation, temperature schedule, extended schedule of regulation

The Effect of Climatic Factors on the Electric Load of Thermal Power Plants (TPP) in the Southern Federal District by the Example of the Novocherkassk District Power Plant (GRES)

N. V. Fedorova*

Platov South-Russian State Polytechnic University (NPI), Novocherkassk, 346428 Russia

**e-mail: fedorovanv61@rambler.ru*

Abstract—A statistical analysis was performed of the electrical load curve according to which the Novocherkassk District Power Plant (NchGRES) operated in the period between 2009 and 2018. The effect of weather and climatic factors, such as daylight time, ambient air temperature, and wind strength, on the electrical load was examined. Climatic components of the NchGRES electric load were estimated, and it has been demonstrated that the lighting load depending on the daylight time in Rostov oblast was as great as 35.4%, the seasonal heating load was up to 11.3%, and the seasonal cooling load was up to 20.2% of the normal baseload. It is shown that the basic heating load in Rostov oblast is carried by centralized and individual heat supply systems, and electric heating appliances are activated when the centralized heat supply systems cannot cover the heating load due to poor maneuverability. The heating component of the electric load depends not only on the ambient air temperature but also on the wind velocity. A formula was derived using the fuzzy logic technique for calculating heat consumption in a heating system depending on ambient air temperature and wind speed. It is noted that high wind speed aggravates the negative temperature factor, bringing about the need to turn on additional heating appliances and, thereby, increasing the electrical load. A fundamental change in the shape of the annual electric load curve within the studied period was revealed: the appearance of the summer maximum load whose amplitude in terms of the indicators approached the winter one and even exceeded it in certain years, which can be attributed to the climate change in the region of the power plant site and the advent of a new type of electrical equipment, i.e., climatic control cooling units. The maximum monthly power consumption of cooling units is 1.8 times the maximum monthly power consumption of heating units and 1.7 times less than the maximum monthly power consumption of lighting facilities. The maximum power consumption for each type of equipment occurs in different months of the year. This change is a stable trend that should be considered, in particular, in scheduling maintenance activities at the power plant.

Keywords: annual electric load curve of TPP, statistical investigation, weather and climatic factors, electrical and head load prediction, fuzzy logic technique, calculating the climatic component of electrical load