
Contents

Vol. 68, No. 5, 2021

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Enhancing the Performance of Blade Rings under Nonuniform Inlet Boundary Conditions

I. V. Afanasev, A. V. Granovskii, V. K. Kostezh, V. G. Krupa, and E. Yu. Marchukov

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Coal Gasification: At the Crossroads. Economic Outlook

S. P. Filippov and A. V. Keiko

Water Treatment and Water Chemistry

Methods of Removing Corrosion Product Deposits from the Primary Circuit
of Light-Water Reactors under Transient Operating Conditions (Review)

S. N. Orlov, A. A. Zmitrodan, and V. V. Krivobokov

Recent State-of-the-Art of Antiscalant-Driven Scale Inhibition Theory (Review)

*M. S. Oshchepkov, G. Ya. Rudakova, S. V. Tkachenko, V. E. Larchenko,
K. I. Popov, M. A. Tusheva*

Analysis of the Water Chemical Regime at an NPP with a VVER-1000
before and after Reconstruction of the Turbine Condenser's Tube System

V. F. Tyapkov

Estimating the Steam Quality in Power-Generating Boilers from Electrical Conductivity
and pH Measurements

A. B. Larin, B. M. Larin, and M. P. Savinov

Renewable Energy Sources and Hydropower

Determining the Void Fraction in the Hydraulic Design of Geothermal
Steam-Water Mixture Piping

A. N. Shulyupin and N. N. Varlamova

Automation and Heat Control in Power Engineering

PID Controllers with a Constant Speed Actuator: Implementation Versions
and Self-Tuning of Pulse Duration

V. F. Kuzhichin, V. S. Drobilko, and A. Ya. Sterlin

Heating and Heating Networks

Applying Modern Information Technologies for Thermal Energy Accounting
in the Operational Search for Humidification of Thermal Insulation

I. G. Akhmetova, K. V. Lapin, T. R. Akhmetov, and E. Yu. Balzamova

Enhancing the Performance of Blade Rings under Nonuniform Inlet Boundary Conditions

I. V. Afanasev^a, A. V. Granovskii^{a,*}, V. K. Kostezh^a, V. G. Krupa^b, and E. Yu. Marchukov^c

^a*Lyul'ka Experimental Design Bureau, Moscow, 129301 Russia*

^b*Baranov Central Institute of Aviation Engines (TsIAM), Moscow, 111116 Russia*

^c*Moscow Aviation Institute, Moscow, 125993 Russia*

**e-mail: andrey.granovskiy@yandex.ru*

Abstract—Blade rings of steam and gas turbines, with the exception of the first nozzle ring, operate at the inlet flow conditions created by the upstream turbine stages. In particular, the conditions of the flow at the inlet of a low-pressure turbine nozzle blades (LPT NBs) depend on the upstream high-pressure turbine (HPT). The first stages of the gas turbines are, as a rule, cooled and transonic stages with high power losses; therefore, the nonuniformity of the radial distribution of the angles of flow, the total pressure, and the total temperature may be extremely substantial at the LPT inlet. This leads to increased levels of profile and, especially, secondary losses in the LPT blade rings. Normally, the LPT nozzle blades have a meridional opening along the inner and outer outlines of the wheelspace that causes the intensification of the secondary flows and, accordingly, an increase in the secondary losses. To minimize adverse effects on the operation of LPT nozzle blades, such as a nonuniform distribution of the flow parameters at the blade inlet, the meridional opening, and the unfavorable elongation, the width of the blade was increased to decrease the meridional angle of the opening and the three-dimensional design of the nozzle blades was applied to reduce the secondary losses. In particular, variants of the LPT nozzle blades of different spatial configurations were investigated, viz., reversely bowed blades, bowed blades, and blades raked in a circumferential direction. The radical change in the nozzle blade shape was restricted by the design of the cooling system of the blades that comprises a deflector in the inner cavity of the blade designed to enhance the efficiency of the cooling. As a result, a compromise between the aerodynamic characteristics and the restrictions imposed by the cooling system was found.

Keywords: nonuniform boundary condition at the nozzle blade inlet, low-pressure turbine nozzle blade, secondary flows and losses, three-dimensional design of the nozzle blade, meridional angle of opening

Coal Gasification: At the Crossroads. Economic Outlook

S. P. Filippov^{a,*} and A. V. Keiko^a

^a*Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia*

**e-mail: fil_sp@mail.ru*

Abstract—Economic aspects of implementing coal gasification technology are considered. Many objective causes hindering the comparison of economic characteristics of the considered coal gasification technologies are outlined. The energy and economic efficiencies of producing synthesis gas (syngas) from coal are estimated. The factors having the most pronounced effect on the efficiency, such as gas generator type, specific oxygen consumption, and initial fuel, are found. According to the calculations, the cost of produced syngas is two to three times higher than the price of natural gas for consumers. Therefore, the use of syngas and hydrogen produced from it for the centralized generation of power and heat will not be economically feasible in the foreseeable future. Integrated gasification combined cycle (IGCC) units are still not competitive with conventional coal-fired power plants, basically due to high specific capital expenditures, which are responsible for more than 2/3 of the price of delivered electricity. The issues of economic competition for hydrogen production from coal using alternative production processes are discussed in detail. It is demonstrated that hydrogen produced from cheap local coals (in Russia, these are coals from large coal deposits in Siberia and the Far East) can win the competition with hydrogen from natural gas. Nevertheless, activities should be continued to improve coal gasification processes and associated technologies, first of all, oxygen production technologies, to cut down capital and operating expenditures. Further development of coal chemical technologies involves high risks associated with the new global climate policy aimed at a drastic decrease in CO₂ emissions and the replacement of fossil fuels in the global fuel and energy balance by renewable energy sources. State support for the development of new coal technologies and for coal chemistry science is necessary to retain the domestic coal industry.

Keywords: coal gasification, gas generator, integrated gasification combined-cycle unit, syngas, hydrogen, energy efficiency, syngas/hydrogen production cost

Methods of Removing Corrosion Product Deposits from the Primary Circuit of Light-Water Reactors under Transient Operating Conditions (Review)

S. N. Orlov^{a,*}, A. A. Zmitrodan^a, and V. V. Krivobokov^a

^a*Aleksandrov Research Institute of Technology, Sosnovy Bor, Leningrad oblast, 188540 Russia*

**e-mail: Orlov.S.N.1989@yandex.ru*

Abstract—In this paper, methods for removing corrosion product deposits from the primary circuit of light-water reactors with pressurized coolant under transient operating conditions are considered. The analysis of these methods, which are successfully used in the main types of light-water reactors, such as PWRs, VVERs, and nuclear marine propulsion reactors, has shown that the promising lines for their development are the selection of chemical reagents that do not violate the water chemistry of the coolant and provide the effective removal (disintegration or dissolution) of corrosion product deposits and experimental validation of their use. To disintegrate the deposits in the VVER-type reactors, hydrazine can be used; hydrazine and ammonia can be used for this purpose in marine nuclear propulsion reactors. The formation on the surface of fuel assemblies of bonaccordite (Ni_2FeBO_5) as a result of coolant boiling is a serious problem that may arise during the purification of the primary circuit from corrosion product deposits under transient conditions in the PWRs. To prevent the formation of this compound, it is proposed to adjust the water chemistry of the primary coolant so that the pH value of the medium is at 7.4 throughout the entire reactor's operational period. The mutual influence of the methods for removing corrosion product deposits under transient operating conditions of nuclear reactors and the technology of injecting zinc into the primary circuit coolant has been analyzed. It has been shown that the technological solutions proposed can complement each other and, despite widespread applications of the zinc-injection technology, the purification methods still remain topical under transient operating conditions of the reactor. The purification methods under investigation have proven their applicability to the basic light-water reactors, such as PWRs and VVERs, as well as nuclear marine propulsion reactors.

Keywords: light-water reactor, primary circuit coolant, corrosion product deposits, decontamination, water chemistry of the coolant, primary coolant purification system

Recent State-of-the-Art of Antiscalant-Driven Scale Inhibition Theory (Review)

M. S. Oshchepkov^{a, b, *}, G. Ya. Rudakova^{a, c}, S. V. Tkachenko^{a, b}, V. E. Larchenko^a,
K. I. Popov^a, and M. A. Tusheva^{a, c}

^aJSC “Fine Chemicals R&D Centre”, Moscow, 107258 Russia

^bMendeleev University of Chemical Technology, Moscow, 125047 Russia

^cOOO NPF “Travers”, Moscow, 107023 Russia

*e-mail: maxim.os@mail.ru

Abstract—Application of antiscalants is a worldwide practice for industrial scale formation mitigation. The range of reagents is constantly expanding, and new scale inhibitors are permanently elaborated, including biodegradable ones. An antiscalant-driven scale inhibition theory has formed in the mid-twentieth century, and is up to date with some minor refinements. However, in recent years, the classical views have been increasingly criticized on the grounds of such modern methods as dynamic light scattering, particle counter technique and fluorescent visualization of antiscalant location in industrial and model system’s deposits. These methods provide a better understanding of scale inhibition mechanisms. In a present review the major mechanisms of scale inhibition are critically examined, and a hypothesis on the dominating role of solid impurities interaction with antiscalant is formulated. According to this hypothesis, the scale crystals nucleation in the bulk aqueous medium is a heterogeneous process, catalyzed by foreign solid nano/microdust particles, serving as crystallization templates (seeds). Thus, an antiscalant competes for these templates with the scale forming ions, blocks the background seeds, and reduces therefore the number of potential crystallization centers. In this way, the scale inhibitor slows down the scale formation due to the foreign seeds isolation, but not via direct interaction with the nuclei of a sparingly soluble salt.

Keywords: thermal engineering, scale formation, scale inhibitors, scale inhibition mechanisms, fluorescence, reverse osmosis

Analysis of the Water Chemical Regime at an NPP with a VVER-1000 before and after Reconstruction of the Turbine Condenser's Tube System

V. F. Tyapkov*

All-Russia Scientific Research Institute for Operation of Nuclear Power Plants (VNIIAES), Moscow, 109507 Russia

**e-mail: vftiapkov@vniiaes.ru*

Abstract—Requirements for improving the reliability, safety, and efficiency of nuclear power plants, as well as increasing the service life of the main NPP equipment up to 60 years, leads to the need to introduce new and improve existing technologies for maintaining water-chemical regimes. One of the directions of such improvement is the decommissioning of equipment and pipelines made of copper-containing alloys. For the operating NPPs with VVER-1000, AO Rosenergoatom Concern developed and implemented a program to replace the turbine condenser's tube system with one made of stainless steels or titanium alloys. Such replacement of the equipment of the secondary circuit made of copper-containing alloys was aimed at ensuring the safe and reliable operation of the steam generator (SG) and extending its residual life. The implementation of the program has significantly increased the reliability of the turbines and equipment of the condensate-feed tract and provided the suction of cooling water at the level of worldwide values. The condenser's tube system of NPP turbines for cooling water with low- or medium salinity is made of stainless steel, while it is made of titanium alloy for cooling water with high salinity. This article analyzes the water chemistry regime at NPPs with a VVER-1000 before and after the reconstruction of the turbine condenser's tube system. The calculations and analysis of the water chemistry management presented in the article were carried out according to the measured concentrations of impurities in the "salt" sections of the SG, since the content of impurities in the feed water and condensate, as a rule, was less than 1 µg and is at the lower limit of sensitivity of the methods and devices used.

Keywords: water chemistry, turbine condensers, cooling water suction cups, water, condensate and steam quality standards, modular demineralization plants

Estimating the Steam Quality in Power-Generating Boilers from Electrical Conductivity and pH Measurements

A. B. Larin^{a, *}, B. M. Larin^a, and M. P. Savinov^a

^a*Ivanovo State Power Engineering University, Ivanovo, 153003 Russia*

**e-mail: yaandy_81@mail.ru*

Abstract—The quality of steam produced by boilers is strictly standardized and must be maintained whatever the quality of makeup water and whatever the composition of the boiler unit's thermal cycle equipment. Under the conditions of constantly improved instruments for chemical monitoring, it becomes possible to develop measurement systems using which the main standardized and diagnostic steam quality indicators can be monitored by measuring the electric conductivity and pH of cooled samples. Unlike boilers operating at a pressure of 13.8 MPa and higher, steam boilers for steam pressures equal to 9.8 and 3.9 MPa—and also industrial heat recovery steam generators—operate with steam that has a higher content of salts and carbon dioxide; in addition, it contains ammonia, which enters into steam from boiler water. Steam quality is often estimated using the two-quadrant nomographic chart of Mostofin, who proposed it more than 50 years ago. In using certain computation algorithms, it is possible to calculate the standardized and diagnostic steam quality indicators, such as concentrations of sodium, chlorides, ammonia, carbon dioxide, and salt content. The article presents an algorithm for estimating the concentrations of the above-mentioned impurities for cooled live steam samples of power-generating boilers operating at pressures below 10.0 MPa, and boilers for superhigh and supercritical pressures, and industrial heat recovery steam generators, including the combined-cycle power plant units. Examples of using the calculation procedure for analyzing the steam quality in industrial boilers are given.

Keywords: steam boilers, steam quality, automatic chemical monitoring, computation algorithm, electrical conductivity, electrical conductivity and pH measurements

Determining the Void Fraction in the Hydraulic Design of Geothermal Steam-Water Mixture Piping

A. N. Shulyupin^{a,*} and N. N. Varlamova^a

^a*Mining Institute, Standalone Division of the Khabarovsk Federal Research Center, Far East Branch, Russian Academy of Sciences, Khabarovsk, 680000 Russia*

**e-mail: ans714@mail.ru*

Abstract—Taking into account new problems arising in the transportation of a steam-water heat carrier to support operation of geothermal power plants (GeoPP), a procedure is outlined for determining the void fraction considering the gravity component of the pressure drop in the hydraulic design calculations of steam-water piping. Unavailability of data on the void fraction under the conditions of geothermal heat carrier transportation is noted. The drift flux model determining the steam velocity averaged over the channel cross-section was used to solve the formulated problem for upward flows. The factors affecting the distribution parameter and the drift velocity are reviewed. It is noted that the drift velocity depends not only on the gravity force but also on the hydrodynamic effect, which can be taken into account using the advanced distribution parameter. A similar approach has been proposed for downward flows according to which the liquid phase velocity averaged over the channel cross-section is calculated using equivalents of the empirical coefficients determined from the condition of equality of the parameters calculated for the upward and downward flows as applicable to the horizontal flow. The empirical values included in the recommended calculation formulas have been established. The proposed recommendations have been used in developing a computer code for the hydraulic design of pipelines. In addition to the gravitational pressure drop, the code also calculates the pressure drop due to friction or local resistance using formulas, which offers good agreement with the experimental data. To verify the model used in the program for the calculation of the gravitational pressure drop, the predictions were compared with the experimental data of the pressure drop across the pipeline from the Geo-1 well to the Verkhne-Mutnovskaya GeoPP (Kamchatka), which is in operation and features the maximum height difference among all existing domestic pipelines carrying steam-water mixture. A good agreement was found between the predictions and the experimental data on pressure drops, which indirectly confirms the adequacy of the recommended procedure for determining the void fraction.

Keywords: geothermal heat carrier, steam-water mixture, pipeline, void fraction, drift flux model, mixture density, distribution parameter, drift velocity

PID Controllers with a Constant Speed Actuator: Implementation Versions and Self-Tuning of Pulse Duration

V. F. Kuzishchin^a, V. S. Drobilko^{a, *}, and A. Ya. Sterlin^{b, **}

^aNational Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^bZhukovsky Central Aerohydrodynamic Institute, Zhukovsky, Moscow oblast, 140180 Russia

*e-mail: dvs@retech.ru

**e-mail: andrey.sterlin@tsagi.ru

Abstract—The article considers three implementation versions of controllers operating with constant speed actuators that are used in automation systems of a technological process: with a relay-pulse control unit (RPCU) with a lagging feedback and topping differentiator (a real differentiating element, RD), with calculating the output according to a PID algorithm and using the actuator model for its implementation, and with calculating the control output speed and using a pulse-width modulator. Formulas for calculating the parameters of the RPCU and RD primary components from the condition of approaching the equivalent PID algorithm are given. The system version with a PID controller with the actuator control proceeding from its model is considered in two options: with individual integrators for the controller's integral component and the actuator model, and with a common integrator for the controller's integral component and the actuator model. In the latter option, the signal from the actuator model is subtracted from the controller's integral component, due to which the possibility of the integrator's output to reach the integral component's limit values is ruled out. The versions are compared by analyzing the automatic control system performance in the pulsed actuator's operation mode based on simulation for the superheated steam temperature control section of a steam boiler equipped with a surface steam desuperheater. The analysis was carried out taking into account both the usual dynamic accuracy indicators and the number of actuators switched into operation during the transient. It is shown that the advantage of the version with the PID algorithm and common integrator for the integral component and the actuator model is that there is no need in this case to calculate the controlled variable second derivative; in addition, this version is free from the problem connected with accumulation of the difference between the signals from the actuator and its model. This version can be considered to be more preferred in implementing a PID algorithm in the software of programmed controllers. Recommendations for self-tuning of pulse duration and the control unit relay element parameters during the control process depending on the algorithm's individual components are given. By using the proposed recommendations, it becomes possible to achieve an essentially lower actuator switching frequency during the control process.

Keywords: automatic controller, PID algorithm, actuator, constant speed, pulse duration, control object, relay element, pulse-width modulator

Applying Modern Information Technologies for Thermal Energy Accounting in the Operational Search for Humidification of Thermal Insulation

I. G. Akhmetova^{a,*}, K. V. Lapin^b, T. R. Akhmetov^c, and E. Yu. Balzamova^{a,**}

^a*Kazan State Power Engineering University, Kazan, 420066 Russia*

^b*AO Tatenergo, Kazan, 420021 Russia*

^c*AO Kazenergo, Kazan, 420021 Russia*

^{*}*e-mail: irina_akhmetova@mail.ru*

^{**}*e-mail: e.balzamova@mail.ru*

Abstract—In modern realities, developing the centralized heat-supply system in Russia is associated with a constant search for reserves for saving heat energy, its rational use, and a constant increase in the reliability and energy efficiency of heat supply to consumers. The solution to the problem of increasing the reliability of the operation of heating networks and maintaining their operability and durability is not limited to the replacement, reconstruction, and modernization of actually worn out, emergency, sections of heating networks that have not passed hydraulic tests. It is equally important during the operation of pipelines to maintain the regulatory conditions that determine their durability. The statistically most significant reason for the failure of heating networks is external corrosion of the metal, which, in turn, is most often caused by the pipe being in a humid environment or simply in water when the channel is flooded. The paper considers the possibility of increasing the reliability of heating networks by timely detection of deviations from the standard of the actual operating conditions of the heating network sections, which are in a humid environment that intensifies the processes of external metal corrosion. The rapid growth in the number of thermal energy meters installed at the facilities of district heating networks and facilities for consumers of thermal energy, together with the use of modern measuring instruments and systems for remote transmission of meter readings, creates the prerequisites for the development of a software product. It is proposed to use a software product that analyzes the operating conditions of heating networks in real time and notifies about their deviation from the standard values. A technique has been developed for the automated calculation of the coolant temperature's standard values.

Keywords: heat supply, digitalization, heat networks, reliability, heat energy losses, software for determining reliability, coolant temperature, calculation of losses, thermal insulation