

---

---

# Contents

---

---

Vol. 68, No. 6, 2021

---

---

*Dear Colleagues!* 5

---

## Steam Boilers, Power Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Overview of Foreign Boiler Designs for Ultra Supercritical (USC) Boilers and Prospects  
for Development of USC Power Units in Russia

*E. V. Somova, A. N. Tugov, and A. G. Tumanovskii* 6

Thermal Calculation of Dust-Preparation Systems in Boiler Plants: A New Approach

*M. N. Maidanik, A. N. Tugov, and V. M. Supranov* 25

Generalization of the Studies of Hydraulic and Thermochemical Operating Conditions  
in the Separation Devices, External Salt Compartments, and Circulation Loops  
of Thermal Power Plant Boilers

*A. I. Fedorov* 33

Heat Recovery Steam Generators of Binary Combined-Cycle Units

*P. A. Berezinets and G. E. Tereshina* 45

Pilot Tests of a Fixed-Bed Coal Gasifier

*I. A. Ryzhiy, A. V. Shtegman, A. N. Tugov, D. A. Sirotin, M. M. Gutnik, E. A. Fomenko,  
D. V. Sosin, K. V. Timashkov, S. V. Alekseenko, A. S. Zavorin, V. E. Gubin, A. S. Matveev,  
D. V. Gvozdiakov, K. B. Larionov, S. A. Yankovsky, and K. V. Slyusarsky* 55

---

## Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants, and Their Auxiliary Equipment

Development of Low-Emission Combustors for Power GTUs

*A. G. Tumanovskii, L. A. Bulysova, V. D. Vasil'ev, M. N. Gutnik, M. M. Gutnik* 68

Improving the Flexibility and Reliability of Steam Power Units at Thermal Power Plants

*Yu. A. Radin* 77

The Most Powerful Energy GTU (Review)

*G. G. Olkhovsky* 87

---

## Automation and Heat Control in Power Engineering

The Participation of Thermal Power Plants in Controlling Frequency and Power

*N. V. Zorchenko, A. G. Chaplin, M. F. Pavlova, and M. E. Parshutin* 94

---

## Metals and Strength Analysis

Thermal and Mechanical Equipment Safety and Operational Reliability

*E. A. Grin', A. V. Pchelintsev, K. K. Kreitser, V. I. Bochkarev, and R. N. Kalugin* 103

---

## **Environmental Protection**

Development of SNCR Technology and Prospects of Its Application

*S. N. Anichkov, A. M. Zykov, A. G. Tumanovsky, O. N. Kulish, and K. I. Zaporozhsky*

---

---

110

# Overview of Foreign Boiler Designs for Ultra Supercritical (USC) Boilers and Prospects for Development of USC Power Units in Russia

E. V. Somova<sup>a, \*</sup>, A. N. Tugov<sup>a</sup>, and A. G. Tumanovskii<sup>a</sup>

<sup>a</sup>All-Russia Thermal Engineering Institute (VTI), Moscow, 115280 Russia

\*e-mail: evsomova@vti.ru

**Abstract**—In the coming years, global electricity generation will largely be carried out using coal as fuel (coal generation). Certain European countries, the United States, Canada, and Japan are trying to cut down the number of coal-fired power units with their complete disposal by 2030. At the same time, the countries of the Asia-Pacific region, mainly China and India, are extensively developing a technology for the coal generation of steam at ultra supercritical (USC) conditions, which improves the efficiency of electricity generation and reduces harmful atmospheric emissions. The world power industry presently uses steam conditions of approximately 30 MPa and 610/620°C. The efficiency is as high as 47%. An overview is presented of the designs of USC coal-fired power boilers from the largest foreign manufacturers of boiler equipment in Europe (Alstom), Japan (Mitsubishi Hitachi Power Systems and Ishikawajima-Harima Heavy Industries), and China (Harbin Boiler Co., Ltd., Dongfang Boiler Co., Ltd., and Shanghai Boiler Works, Ltd.). Russia ranks tenth in the world as to the total coal-fired power generation. The percentage of coal-fired generation in Russia was approximately 13.5% in 2016. The development of engineering solutions for the USC power unit was undertaken in Russia at the beginning of the 21st century. Boiler equipment manufacturers worked out projects of boilers designed to operate on various coal types for a 660-MW power unit. The construction of the USC power unit prototype requires joint efforts of the government, power engineers, metallurgists, research organizations, and equipment manufacturers.

**Keywords:** coal generation, pulverized coal-fired power unit, ultrasupercritical steam conditions, boiler, burner unit, steam reheat, water-wall cooling, harmful emissions

# Thermal Calculation of Dust-Preparation Systems in Boiler Plants: A New Approach

M. N. Maidanik<sup>a,\*</sup>, A. N. Tugov<sup>a</sup>, and V. M. Supranov<sup>b</sup>

<sup>a</sup>All-Russia Thermal Engineering Institute, Moscow, 115280 Russia

<sup>b</sup>National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

\*e-mail: MNMaidanik@vti.ru

**Abstract**—A new approach to thermal calculation of dust-preparation systems, at which the dust system is considered and calculated as part of the boiler plant operating in a single technological cycle with the boiler and having a common dust-gas-air duct with it. This approach provides for the possibility of conducting a joint thermal calculation of the boiler and dust systems. The thermal balance of the dust system is considered with determining the parameters of the drying agent according to the actual composition of the flue gas and air flows directed to the dust system, calculated from the general material balance of the gas-air duct of the boiler plant with the boiler, and the calculation of the enthalpy of gases and air in accordance with the norms of thermal calculation of boilers for the full elemental composition of burned fuels and their mixtures. Basic formulas for calculating the components of the heat balance of a dust system and methods for determining the output parameters of the drying agent are given. The proposed method of thermal calculation makes it possible to take into account the actual heat supplied with the drying agent when burning not only one type of fuel but also a mixture of solid fuels as well as solid fuels together with gaseous and/or liquid fuels. According to the developed algorithm for thermal calculation, along with the thermal calculation of the dust system, the general material balances of the gas-air path of the boiler plant and the dust-gas-air path of the boiler furnace and burner are compiled, the parameters of the drying agent along its path are calculated, taking into account the actual places of entry of the flows of the recirculating drying agent, air suction, and air to the seal of the mills. The algorithm for thermal calculation of dust systems is implemented in a computer program that has been tested in the calculations of several boiler installations, including thermal calculations joint with the boiler.

*Keywords:* boiler plant, boiler, dust-preparation system, heat calculation, dust and gas air path, material balance, drying agent, heat balance

# Generalization of the Studies of Hydraulic and Thermochemical Operating Conditions in the Separation Devices, External Salt Compartments, and Circulation Loops of Thermal Power Plant Boilers

A. I. Fedorov\*

*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: a.fedorov.vti@mail.ru*

**Abstract**—The results of studying hydraulic and thermochemical operating conditions of thermal power plant drum boiler's internals are presented. Data on the boiler water's salt content are given for the salt compartment comprising two pairs of external cyclones per boiler side, which are connected to one waterwall. It is shown that the salt content in the distant (along the water flow) cyclone is a factor of three higher than it is in the nearby cyclone. It is found from studying the hydraulic and thermochemical operating conditions in the drums that, in order to exclude salt imbalances in the drum, the circulation loop feeding place and the steam–water mixture inlet should be spaced apart by no less than two to three longitudinal pitches between the down-comer tube rows. A procedure for calculating staged evaporation schemes with double-sided salt compartments is developed and experimentally verified. It is shown that the existing procedure does not reflect the real distribution of salt concentration in the evaporation stages. Results from studies of salt ratio lines are given, which made it possible to refine their calculation procedure and optimize the place of their connection to the boiler circulation loops. Based on the results from studies and mathematical modeling of physicochemical processes in the drum using the ANSYS Fluent software system, an efficient scheme of boiler internals without the use of bubble-cap steam washers is developed for the high-pressure drums of the PK-85 heat recovery steam generator, which made it possible to obtain high-quality steam in using feed water with a sodium content (Na) four times higher than its standardized value and with two times higher than normal content of silicon oxide ( $\text{SiO}_2$ ) in boiler water during operation with a continuous blowdown rate up to 0.5–1.0%.

*Keywords:* drum boilers, hydraulic and thermochemical operating conditions, separation and bubble-cap steam washers, external salt compartments, circulation loops, turbulent diffusion, staged evaporation, calculation procedures, mixing, process models, pulsating circulation characteristics, salt ratio lines

# Heat Recovery Steam Generators of Binary Combined-Cycle Units

P. A. Berezinets<sup>a,\*</sup> and G. E. Tereshina<sup>a</sup>

<sup>a</sup>All-Russia Thermal Engineering Institute, Moscow, 115280 Russia

\*e-mail: vti-berezinets@mail.ru

**Abstract**—Heat recovery steam generators (HRSGs) are compared. HRSGs of gas turbines are designed for deep cooling of the exhaust gases while maximizing generation of steam at conditions corresponding to the working process of the steam turbine. To achieve this goal, the elements of the HRSG heating surface of the waste heat boiler are arranged so that the heated fluid (steam or water) is in the counterflow with exhaust gases from the gas turbine and heat transfer occurs in them at minimum temperature differences. Heat-exchange elements can be installed in both vertical and horizontal gas ducts. Accordingly, they are made from coils with horizontal pipes and inlet and outlet headers or from panels with vertical tubes, each with lower and upper headers. Panels in an element are connected with cross-over pipes to arrange a counterflow of the heated fluid (water or steam) and the gas turbine exhaust gases. This means that each bend of the coil of a vertical boiler is replaced with two headers connected with cross-over pipes in a horizontal boiler. The vertical arrangement of heat-transfer tubes in a horizontal gas requires the tubes of each panel to be properly drained using a branched drain system with shut-off valves and drain expansion tanks installed below the grade (el. 0). Heat-exchange elements made of horizontal tubes in the form of coils and located in a vertical gas duct are drained only through two headers, and the drainage expansion tank is installed at the grade (el. 0). The evaporating elements of a vertical HRSG are units with a parallel-flow pattern offering a uniform distribution of the steam generated in the evaporating coils, while the evaporative elements of a horizontal HRSG are cross-flow units featuring nonuniform distribution of the steam generated in the evaporating panels. An additional advantage of the vertical HRSG is provided by the stack effect increasing the power of the gas turbine. Despite the obvious heat-engineering advantages of vertical HRSGs, horizontal HRSGs are predominantly being built in Russia, although the global competition is observed between vertical and horizontal HRSGs, in which the customer's opinion is decisive.

*Keywords:* combined-cycle units, gas-turbine units, vertical and horizontal heat-recovery steam generators, evaporating panels and coils, parallel flow and counter-flow of heat carriers, drain system

## Pilot Tests of a Fixed-Bed Coal Gasifier

I. A. Ryzhiy<sup>a,\*</sup>, A. V. Shtegman<sup>a</sup>, A. N. Tugov<sup>a</sup>, D. A. Sirotin<sup>a</sup>, M. M. Gutnik<sup>a</sup>, E. A. Fomenko<sup>a</sup>,  
D. V. Sosin<sup>a</sup>, K. V. Timashkov<sup>a</sup>, S. V. Alekseenko<sup>b,c</sup>, A. S. Zavorin<sup>b</sup>, V. E. Gubin<sup>b</sup>, A. S. Matveev<sup>b</sup>,  
D. V. Gvozdiakov<sup>b</sup>, K. B. Larionov<sup>b</sup>, S. A. Yankovsky<sup>b</sup>, and K. V. Slyusarsky<sup>b</sup>

<sup>a</sup>All-Russia Thermal Engineering Research Institute, Moscow, 115280 Russia

<sup>b</sup>Tomsk National Research Polytechnic University, Tomsk, 634050 Russia

<sup>c</sup>Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia

\*e-mail: ryzhy1987@mail.ru

**Abstract**—Gasification is one of the promising technologies for the use of solid fuels in power generation, chemical industries, and a number of related areas. Despite a significant amount of theoretical and experimental work performed in Russia, one of the key factors that limits the widespread commercialization of gasification technologies is the lack of practical experience of operation under industrial conditions or those close to them. To gain experience in managing the fixed-bed coal gasification technology, in autumn 2019, specialists of Tomsk Polytechnic University, based on the Ekoenergetika 4.0 (Ecoenergy Generation) research center in Tomsk, tested Russia's first pilot fixed-bed gasifier with a capacity of 4 t of fuel per hour, which was developed at the All-Russia Thermal Engineering Research Institute. The tests were conducted using coals of four grades of the Kuznetsk and Kansk-Achinsk basins, viz., anthracite, long-flame and lean coals, and lignite. As a result of the tests, the technical feasibility of both individual components and the gasification plant as a whole was proven. In the course of the tests, high-quality synthesis gas was obtained with a calorific value in the range 6.0–8.3 MJ/m<sup>3</sup>, which makes its use as a fuel in combined-cycle plants with the reliable and stable ash removal possible. The possibility of using the gas produced in the tests of the fixed-bed gasifier for the synthesis of liquid hydrocarbons by the Fischer–Tropsch process has been experimentally established. Further, the possibility of producing coke and semicoke in the gasifier has been proven. The assessment of the reliability of the gasification plant performed using the ANSYS software based on the test data has shown a satisfactory lifetime of the plant with the expected service life of the most stressed gasifier components of 68 000 h.

**Keywords:** gasification, coal, coke, semicoke, synthesis gas, pilot tests, synthesis of liquid hydrocarbons, Fischer–Tropsch process, production of coke and semicoke

# Development of Low-Emission Combustors for Power GTUs

A. G. Tumanovskii<sup>a</sup>, L. A. Bulysova<sup>a, \*</sup>, V. D. Vasil'ev<sup>a, \*\*</sup>, M. N. Gutnik<sup>a, \*\*\*</sup>, and M. M. Gutnik<sup>a</sup>

<sup>a</sup>All-Russia Thermal Engineering Institute (VTI), Moscow, 115280 Russia

\*e-mail: bulysov@mail.ru

\*\*e-mail: basbas@mail.ru

\*\*\*e-mail: kc-vti@bk.ru

**Abstract**—The main results of VTI's investigations into low-emission combustors for gas-turbine units (GTU) are presented. In recent years, the combustion of a premixed fuel-air mixture (FAM) in a swirling flow in a limited space has been under development for this purpose to attain more complete combustion, stable fluctuation-free operation of a combustor in a wide range of parameters, and compliance with environmental protection requirements. To solve the problems encountered in this field, a procedure has been developed for assessing the effect of temperature in the combustion zone, flow velocity, combustor pressure, and other factors on the combustion stability. A review is presented of a comprehensive approach employed by VTI's specialists to study the processes in combustors using numerical and experimental methods enabling them to cut down the cost and time of activities on development of low-emission combustors. For example, a relationship is presented between the numerically estimated quality of the produced fuel-air mixture and the experimental nitrogen oxide concentrations. A design parameter relating the process conditions in a flame tube with the vibration combustion amplitude is proposed. The experiments demonstrated a good correlation of the proposed parameter with measured pressure fluctuation amplitude. Of real interest are the presented examples of changes in the velocity and temperature fields with an increase in the working pressure, which should be considered in designing and bench testing the combustor. The low-emission combustors (LEC) developed for large- and medium-power GTUs are presented. The potential for scaling the combustors for other GTUs is examined.

**Keywords:** low-emission combustor, gas-turbine unit, fuel-air mixture, nitrogen oxides, stable combustion, pressure fluctuations, experimental studies, control algorithms



# Improving the Flexibility and Reliability of Steam Power Units at Thermal Power Plants

Yu. A. Radin\*

*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: vti-unit@yandex.ru*

**Abstract**—Information about the research activities conducted at the All-Russia Thermal Engineering Institute (VTI) in the field of flexibility of steam power units at thermal power plants (TPPs) is given. Many of these activities were conducted jointly with specialists of Firm ORGRES, TsKTI, power machinery building works, and power plants. As a result of these activities, thermal cycle and starting process circuits, standardized technologies, and instructions on starting TPP power units for capacities of 200–800 MW and power units of combined heat and power plants (CHPPs) equipped with 100–250-MW turbines have been developed. An important line of activities on substantiating the power equipment's flexibility characteristics was concerned with ensuring the thermal and cyclic strength of highly stressed parts of power-generating boilers and steam turbines, which led to the development of mathematical models of drums and boiler steam superheater outlet headers, steam lines, cylinders, and turbine rotors and the casings of high- and intermediate-pressure valves. Regulatory documents, technical requirements for power unit flexibility, starting fuel loss values, minimum loads and their variation rate within the adjustment range, keeping the power unit in the idle mode and in the mode of supplying power to in-house loads after full load rejection and generator disconnection from the grid, fast turbine valving, and the number of these operations were developed. Efforts aimed at improving the flexibility generated the need to automate the control and develop the appropriate process algorithms, the implementation of which has led to widespread introduction of microprocessor-based automated process control systems. Among the persons who made a great contribution in the arrangement and implementation of these activities were the leading specialists of VTI and the power industry V.B. Rubin, G.I. Moseev, E.R. Plotkin, B.I. Shmukler, A.L. Shvarts, N.I. Davydov, N.F. Komarov, E.N. Sergievskaya, V.F. Rezinikh, A.Sh. Leizerovich, and others. The fundamental solutions adopted for steam power units were used in the last 20 years in elaborating the technology for starting combined cycle plants equipped with heat recovery steam generators. Among the totality of problems, the article addresses improvement of steam power unit flexibility, one of the basic lines the relevance of which is doubtless also at present.

*Keywords:* power unit, supercritical pressure, boiler, steam turbine, drum, header, thermal and cyclic strength, automated process control system, thermal power plant, combined heat and power plant

# The Most Powerful Energy GTU (Review)

G. G. Olkhovsky\*

*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: vti@vti.ru*

**Abstract**—The history of the creation of gas-turbine units (GTU) is briefly stated. The first power gas turbine was built by the Swiss company Brown Boveri in 1939. The efficiency of this gas turbine was 17.5%. The modern technical level of gas turbines is analyzed by the example of the most powerful of them (550–600 MW), produced by the four world power engineering firms: General Electric (United States), Siemens (Germany), Mitsubishi (Japan), and Ansaldo (Italy, Brown Boveri successor). The efficiency of such gas-turbine units has reached 44%, and combined-cycle gas turbines based on them have reached 63–64%. Their high efficiency is the result of the consistent development of science and technology: aerodynamics of turbomachines, high-temperature materials and designs of parts made of them with advanced cooling systems and new coatings, methods of forming such parts, and devices for low-emission combustion of fuels and control systems. The prospects for the development of gas-turbine engineering in the world are considered. The dependence of the unit cost of various types of gas turbines on their capacity is given. It is concluded that the use of the most powerful and economical gas turbines in the domestic electric power industry will allow for the reduction in fuel consumption for electricity generation by more than a third. The creation of the most advanced gas-turbine units in the country using the experience of domestic aviation gas turbine construction is necessary for the technical reequipment of the Russian electric power industry.

*Keywords:* gas-turbine unit, combined-cycle plant, aircraft engines, power, thermodynamic cycle, fuel consumption, gas turbine generations, efficiency, electric power industry, unit cost of gas turbine

# The Participation of Thermal Power Plants in Controlling Frequency and Power

N. V. Zorchenko<sup>a,\*</sup>, A. G. Chaplin<sup>a</sup>, M. F. Pavlova<sup>a</sup>, and M. E. Parshutin<sup>a</sup>

<sup>a</sup>All-Russia Thermal Engineering Research Institute, Moscow, 115280 Russia

\*e-mail: zorchenko@mail.ru

**Abstract**—The article describes the experience in the development and research of automatic power-control systems and operating modes for various equipment of the thermal power plants gained at the All-Russia Thermal Engineering Research Institute over the past 20 years. Further, it presents a unique file of the results of dynamic and certification tests of thermal power plants' equipment of various types. The transient processes of the main control actions are described, and technological characteristics of the most representative experiments aimed at checking the conformance of the equipment with the requirements of the rated primary frequency control (RPFC) when simulating step deviations of the frequency for gas-and-oil-burning power-generating plants with a condensing turbine and a drum boiler and for a combined-cycle plant are provided. Stages and results of the research on this subject that had a significant influence on the development of the control systems in Russia are reviewed. For example, the research project on exploring the possibility and feasibility of engaging the cross-connection thermal power plants in the RPFC initiated by the System Operator of the Unified Energy System (SO UES) is described and the results of experimental implementation of the RPFC requirements at a cross-connection thermal power plant exemplified by the Priufimskaya TPP are presented. A long and important phase of the work conducted at the institute to engage the thermal power plants in solving tasks in energy systems was a study into the influence of the control modes on the operation of the equipment supported by the SO UES and conducted in 2009–2013. In the course of the research, approaches to the determination of the probable reduction in the cost-efficiency and reliability of the thermal power plants were developed. The introduction of the power reserves was analyzed. The results of the study facilitated the effective development of the energy service market in Russia. All researches on the automatic control conducted at the institute are based not only on experimental results and calculations but also on model-based investigations. As an example, the article provides results of studying the efficiency of equipping thermal power plants with automatic power-control systems. The tasks of the current research aimed at ensuring reliable and correct interaction between the automatic power-control systems and the emergency control automatics are formulated.

*Keywords:* automatic power-control system, primary control, power, droop, electrical frequency, transient

# Thermal and Mechanical Equipment Safety and Operational Reliability

E. A. Grin<sup>a,\*</sup>, A. V. Pchelintsev<sup>a</sup>, K. K. Kreitser<sup>a</sup>, V. I. Bochkarev<sup>a,\*\*</sup>, and R. N. Kalugin<sup>a</sup>

<sup>a</sup>All-Russia Thermal Engineering Institute, Moscow, 115280 Russia

\*e-mail: EAGrin@vti.ru

\*\*e-mail: VIBochkarev@vti.ru

**Abstract**—The development of new, heat-resistant high-chromium martensitic steels and mastering their production and use at the end of the last century made it possible to construct thermal power equipment for a steam temperature of 600–620°C. The manufacture of equipment made of these steels is supported by the necessary regulatory documents, and there is a positive experience of its long-term operation. An analysis and generalization of the results obtained from tests of steel grades P91 and Di82 for long-term strength have shown that the obtained values are in compliance with the requirements of Russian and European standards for using them at elevated steam parameters. However, the heat resistance properties of these steels at temperatures below 550°C are somewhat lower than the level stipulated by the European standard. As a result of a regression analysis of an experimental data array, an approximation in the form of a fifth-degree polynomial is proposed, which establishes the material service life dependence on temperature and stress for P91 and Di82 steels. In the course of investigations carried out at the All-Russia Thermal Engineering Institute (VTI), the main regularities pertinent to the development of the deformation and destruction processes in these steels under creep conditions were established. Specific correlations between the accumulated creep deformation and the metal microdamage degree with linking them to the worked-out service life fraction were established. These results formed the basis of the developed scale for classifying the chromium steel microdamage during long-term operation. The practical application of this scale opens the possibility to assess the service life exhaustion stage based on the scheduled diagnostics results, thereby contributing to achieving better operational reliability of equipment made of martensitic chromium steels. In Russia and in other industrially developed countries, a scientific and technical base has been created for manufacturing advanced equipment made of new chromium steels that allow this equipment to operate at temperatures up to 640°C. It is necessary to continue studies of the service characteristics of these new steels for their further improvement and subsequent introduction into production.

**Keywords:** thermal power engineering, equipment, metal, reliability, safety, creep, service life, diagnostics, strength, chromium steel, microdamage

## Development of SNCR Technology and Prospects of Its Application

S. N. Anichkov<sup>a,\*</sup>, A. M. Zykov<sup>a</sup>, A. G. Tumanovsky<sup>a</sup>, O. N. Kulish<sup>b,\*\*</sup>, and K. I. Zaporozhsky<sup>b</sup>

<sup>a</sup>All-Russia Thermal Engineering Institute, Moscow, 115280 Russia

<sup>b</sup>Gubkin National University of Oil and Gas, Moscow, 119991 Russia

\*e-mail: [SNAnichkov@vti.ru](mailto:SNAnichkov@vti.ru)

\*\*e-mail: [com@gubkin.ru](mailto:com@gubkin.ru)

**Abstract**—The state of and development prospects for the technology of selective noncatalytic reduction (SNCR) of nitrogen oxides in the combustion products of organic fuels are considered. Its advantages and disadvantages and factors influencing the efficiency of its application for gas purification of technological furnaces for natural gas conversion at power and waste incineration boilers are analyzed. The results of experimental studies into the process of reducing nitrogen oxides by products of thermal decomposition of carbamide are presented, depending on the temperature, flow rate, and the method of introducing the reagent into the flue gases. The results of pilot tests and industrial implementation of the technology are shown. The possibility of increasing the technical and economic indicators of SNCR plants by organizing a multizone injection of the reducing mixture into the gases to be cleaned with a flow rate less than the stoichiometric one is substantiated, which makes it possible to achieve high technology efficiency with a minimum ammonia slip. Relatively low capital costs for the construction of SNCR plants and the manufacture of main equipment at domestic enterprises and the small area required for equipment placement can significantly reduce emissions of nitrogen oxides into the atmosphere, even at operating boilers in a short time. It is advisable to widely introduce SNCR technologies at pulverized coal TPPs and enterprises for thermal waste disposal as one of the best available technologies.

**Keywords:** thermal power plant, pulverized coal boiler, incineration plant, nitrogen oxides, urea, noncatalytic reduction, ammonia, ammonia slip, multizone injection of reductant, cleaning efficiency