

Contents

Vol. 68, No. 7, 2021

ZAO Scientific Production and Innovation Enterprise Turbocon Turns 30

Turbocon Research, Production and Development Company: From the Past to the Future

Prospects for Using Liquefied Natural Gas as Backup and Emergency Fuel at Power Plants Owned by the Gazprom Energoholding Group

O. O. Mil'man, V. B. Perov, M. V. Fedorov, S. N. Lenev, and E. A. Popov

Turbogenerating Units for Cogeneration and Distributed Power Plants

I. S. Serbin, Yu. G. Savinchenko, O. O. Mil'man, and V. M. Tolkachev

Turbogenerator Options for a Heat-Recovery Thermal Power Complex on the Basis of a Low-Boiling Working Fluid

B. A. Shifrin, V. B. Perov, and V. M. Tolkachev

Spatial Active Damping of Vibrations, Vibration Forces, and Pressure Fluctuations Transferred via Expansion Joints in Liquid-Filled Pipelines

A. V. Kiryukhin, O. O. Mil'man, A. V. Ptakhin, A. A. Kiryukhin, and L. N. Serezhkin

Heat and Mass Transfer and Properties of Working Fluids and Materials

Investigation of the Effect of Fin Configuration and Fin Angle on Thermal Performance of Finned-tube Heat Exchanger. Experimental Study

K. Goudarzi

Energy Saving, New and Renewable Energy Sources

A Hybrid Solar–Geothermal Heat- and Hot-Water Supply System

A. B. Alkhasov, D. A. Alkhasova, and M. G. Dibirov

Water Treatment and Water Chemistry

Modeling the Dissolved Oxygen Desorption when Superheated Water Enters the Rarefaction Zone

G. V. Ledukhovsky, V. P. Zhukov, Yu. E. Barochkin, and E. V. Barochkin

Resource-Saving Solutions for Membrane-Demineralization Plants

E. B. Yurchevskii and V. V. Solodyannikov

District Heating Cogeneration and Heat-Supply Networks

The Use of the Heat-Accumulation Properties of Heat-Supply Networks and Buildings for the Extension of the Electric Power Output Control Range at Combined Heat and Power Plants

R. Z. Aminov, E. Yu. Burdenkova, and A. B. Moskalenko

Prospects for Using Liquefied Natural Gas as Backup and Emergency Fuel at Power Plants Owned by the Gazprom Energoholding Group

O. O. Mil'man^{a, b}, V. B. Perov^{c, d, *}, M. V. Fedorov^e, S. N. Lenev^f, and E. A. Popov^g

^a*Tsiolkovsky Kaluga State University, Kaluga, 248023 Russia*

^b*ZAO Scientific Production and Innovation Enterprise (NPVP) Turbocon, Kaluga, 248010 Russia*

^c*OOO Termokon, Moscow, 143026 Russia*

^d*OOO Kriokon, Kaluga, 248010 Russia*

^e*OOO Gazprom Energoholding, St. Petersburg, 197198 Russia*

^f*PAO Mosenergo, Moscow, 119526 Russia*

^g*PAO Gazprom, Moscow, 117997 Russia*

*e-mail: turbocon@kaluga.ru

Abstract—The results from studying prospective energy-technology complexes for producing liquefied natural gas (LNG) and using it at electric power facilities as backup fuel are outlined. The article also gives a description and the main parameters of the original process flow diagram of the LNG complex for combined heat and power plants of PAO Mosenergo, which operates solely on the plant's secondary energy resources: the pipeline gas excess pressure and the heat of the closed-circuit cooling system. The complex includes means for pipeline gas liquefaction, long-term storage of the standard backup fuel stock, and LNG gasification using the heat removed from the steam turbine condensers when the power plant is shifted for using backup fuel. Based on an analysis of the experience gained around the world from development of similar complexes and the design parameters of the natural gas liquefaction process flow diagram proposed by the authors, a procedure for calculating the economic efficiency indicators of the projects of LNG-based energy technology complexes is developed. Based on the actual data on the consumption of main and backup fuel at PAO Mosenergo, calculations of the technical and economic parameters of LNG complexes were carried out, the results of which have demonstrated the economic efficiency of fuel oil replacement by liquefied natural gas for the options of its production at power plants solely as commercial product or construction of energy technology complexes instead of planned fuel oil facilities. It is shown that, in view of a low net cost of self-produced LNG and taking into account the rapidly developing market of gas engine fuel, the sales of LNG produced in excess of the standard stock amounts may become a significant item of additional income for a power company. In addition, the construction of additional low-tonnage production facilities equipped with large-capacity LNG storage systems will make it possible to enhance the fuel supply reliability of prospective fueling networks.

Keywords: liquefied natural gas, backup fuel, regasifier, economic efficiency, pipeline gas, fuel supply, standard stock, fueling networks, cost, investments, recouplement

Turbogenerating Units for Cogeneration and Distributed Power Plants

I. S. Serbin^a, Yu. G. Savinchenko^a, O. O. Mil'man^{b, c}, and V. M. Tolkachev^{b, *}

^aOAO Kaluga Turbine Works (KTW), Kaluga, 248010 Russia

^bZAO Scientific Production and Innovation Enterprise (NPVP) Turbokon, Kaluga, 248010 Russia

^cTsiolkovsky Kaluga State University, Kaluga, 248023 Russia

*e-mail: turbocon@kaluga.ru

Abstract—A description of the energy-saving technology for the generation of electrical energy is presented in the superstructure of steam boiler houses with turbine-generator units (TGU) with backpressure turbines operating in parallel with reduction cooling units. The characteristics and description of a TGU for distributed energy, developed at OAO KTW, with backpressure turbines and condensing turbines with and without steam extraction, surface and air condensers, and mini-CHP with built-in boilers for heating network water are given. TGUs are described for geothermal energy with turbine exhaust to the atmosphere or to a heat-supply station with condensing turbines with air condensers. The technical characteristics of TGUs of various types, the number of units produced, and the place of their operation are given. The design features of TGUs manufactured at OAO KTW are noted: block layout, 100% factory readiness, high degree of automation, and reliability during operation. Prospects for further developing the direction of turbine-generator sets for distributed energy are shown: development and delivery of condensing and backpressure turbine-generating sets with a capacity increased to 8 MW; expanding the range of a “connected-in” TGU operating on steam from the extraction or exhaust of the main turbines, which make it possible to compensate for seasonal or technological fluctuations in heat energy consumption and ensure more efficient operation of the main turbines; and development of binary plants using low-grade heat and operating on low-boiling organic heat carriers. High efficiency of distributed power generation in combination with cogeneration is noted.

Keywords: turbine, generator, distributed energy, layout, backpressure, power, binary cycle, condenser, heat supply, heat energy consumption, organic heat carriers

Turbogenerator Options for a Heat Recovery Thermal Power Complex on the Basis of a Low-Boiling Working Fluid

B. A. Shifrin^a, *, V. B. Perov^b, and V. M. Tolkachev^a

^aZAO Scientific Production and Innovation Enterprise (NPVP) Turbocon, Kaluga, 248010 Russia

^bOOO Termokon, Moscow, 143026 Russia

*e-mail: turbocon@kaluga.ru

Abstract—Optional lists of turbogenerator equipment for a 1-MW heat-recovery thermal power complex operating on isopentane are examined. It has been found that, with the selected initial conditions, the axial turbine used as a direct drive of the generator with a standard speed of 3000 min⁻¹ should have five or six stages with the first stage having a partial admission of the working fluid. An alternative 6500 min⁻¹ high-speed five-stage turbine for driving a generator with subsequent conversion of the current frequency has approximately halved the diametrical overall dimensions and the increased internal efficiency due to the elimination of the partial admission of isopentane vapor and reduction of the losses caused by clearance leakages and disc friction, yielding a total of at least than 3%. Should an 8400 min⁻¹ high-speed turbine be used, the number of stages may be reduced to three. High-speed turbines are less labor intensive to manufacture. The turbine generator can be made suitable for using heat sources different in power and temperature potential by modifying the basic design of the turbine through adding or removing the first or the last stages. A prototype of a heat-recovery power complex can be created using commercial equipment, conventional technologies, and standards adopted for the manufacture of high-pressure cylinders (HPC) of steam turbines. At the same time, a turbine generator with commercial prospects should be a high-speed unit integrated into a closed loop featuring minimal manufacturing and operating costs using equipment specially designed for this service.

Keywords: organic Rankine cycle, heat-recovery unit, turbine generator, sealed circuit, direct drive, low-boiling working fluid, basic option, modification, turbine stage

Spatial Active Damping of Vibrations, Vibration Forces, and Pressure Fluctuations Transferred via Expansion Joints in Liquid-Filled Pipelines

A. V. Kiryukhin^{a, b, *}, O. O. Mil'man^{a, b}, A. V. Ptakhin^{a, b}, A. A. Kiryukhin^c, and L. N. Serezhkin^a

^a*Tsiolkovsky State University, Kaluga, 248023 Russia*

^b*ZAO Scientific Production and Innovation Enterprise (NPVP) Turbocon, Kaluga, 248010 Russia*

^c*Rubin Central Design Bureau for Marine Engineering, St. Petersburg, 191119 Russia*

*e-mail: turbocon@kaluga.ru

Abstract—An analysis from the results of investigation into spatial active damping of pressure fluctuations, vibrations, and vibration forces transferred from power facilities via expansion joints in their piping is presented. Vibration transfer from power facilities via piping can be several orders of magnitude greater than along the support structures. This fact should be kept in mind in designing vibration isolation of power equipment from the foundation and the environment through pipelines in the power and transport engineering, shipbuilding, and in oil and gas pipelines in pumping stations. To reduce the transfer of vibrations via a pipeline by means of vibration-isolating expansion joints, it is necessary to decrease their structural stiffness and the forces induced by fluctuations of the working fluid pressure in an expansion joint in a wide frequency band using structural or active methods. A review of the available publications has not revealed, except for the studies performed within the scope of this investigation, any analysis of the interaction between the fluid fluctuations and vibration in the expansion joints or information on reducing the transfer of vibrations and pressure fluctuations via expansion joints in liquid-carrying pipelines. The effectiveness of various multichannel spatial active vibration protection systems whose feedback circuit includes regulators in the form of standard band-pass filters has been studied experimentally. The effect that the interaction of active vibration force damping channels has on the damping efficiency, which may be caused by the cross sensitivity of three-component vibration force sensors during damping of the vibration forces, has been revealed. The active spatial vibration damping of a pipeline downstream of the expansion joint has also demonstrated the interaction of active vibration damping channels resulting in a noticeable change in the damping effectiveness. The effectiveness of the investigated options varied from 10 to 32 dB (reducing fluctuations, transfer of vibration, and forces transmission by 3–30 times) both at individual frequencies and in frequency bands in the range between 10 and 500 Hz.

Keywords: power facility, vibration, pressure fluctuations, vibration forces, vibration isolation, pipeline, expansion joint, active vibration protection system

Investigation of the Effect of Fin Configuration and Fin Angle on Thermal Performance of Finned-tube Heat Exchanger. Experimental Study

K. Goudarzi*

Department of Mechanical Engineering, Yasouj University, Yasouj, 75918-74831 Iran

**e-mail: kgoudarzi@yu.ac.ir*

Abstract—The influence of the configuration of flat fins on the thermal characteristics of a finned-tube heat exchanger is experimentally investigated. The configurations fins of four shapes are studied: plain (P), nozzle (N), diffuser (D), and nozzle-diffuser (ND). The bend angles of the N-fins were 10 and 20°, and the D-fins were 10, 20, 30, and 40°. It has been established that the configuration of the finning and the angle of bending of the fins play an important role in increasing the thermal characteristics of the finned-tube heat exchanger. The main advantage of the proposed finning method in comparison with those used earlier is an increase in heat transfer practically without an increase in the coefficient of friction inside the heat exchanger tube. The scheme of the experimental setup and its main characteristics are described. The obtained experimental data on heat transfer are graphically presented. It is shown that small bending angles of the nozzle and diffuser fins significantly increase heat transfer, while angles of more than 40° lead to its deterioration. A formula for calculating the Nusselt number is presented, which generalizes the experimental data for all investigated finning configurations with an error of $\pm 14\%$.

Keywords: finned-tube heat exchanger, fin configuration, bending angle, transfer enhancement, the friction factor, pitch of fins

A Hybrid Solar–Geothermal Heat- and Hot-Water Supply System

A. B. Alkhasov^{a,*}, D. A. Alkhasova^a, and M. G. Dibirov^a

^a Institute for Problems of Geothermal Research and Renewable Energy of the Joint Institute for High Temperatures, Russian Academy of Sciences, Makhachkala, 367030 Dagestan, Russia

*e-mail: alibek_alkhasov@mail.ru

Abstract—The cooling of rock formations when extracting heat by a borehole heat exchanger and the restoration of the thermal field in the rock during the idle time of the well have been investigated. The heat in the rock during the summer downtime of the well is partially restored due to the influx of heat from the outside formation. The radius of the rock cooling front around the borehole in the heating period can reach 6–8 m. The temperature on the borehole wall is restored by approximately 50% in one month and by 80–85% in summer. Hybrid technology is proposed for the extraction and accumulation of thermal energy from the upper layers of the earth’s crust comprised of a shallow borehole heat exchanger, a heat pump, and solar collectors. The technology provides for both the extraction of heat from the rock during the heating period and transmission of this heat to the heating system with a heat pump and the restoration of the temperature field around the well during the interheating period by accumulating in the rock formation the heat fed to the borehole heat exchanger with hot water from the storage tank. This system was implemented in Makhachkala at the test site of the Joint Institute for High Temperatures, Russian Academy of Sciences, for supplying heat and hot water to cottage-type houses. The main components of the system are solar collectors with a total area of 20 m², a heat-insulated hot water storage tank with a built-in heat exchanger, a 15-kW heat pump, and a 100-m deep borehole heat exchanger. The test results have demonstrated high efficiency of the system for supplying heat to low-power consumers not covered by central heating.

Keywords: low-temperature heat, heat transfer, heat pump, solar thermal collector, well, heat exchanger, intermediate heat-transfer medium, rock, renewable energy sources

Modeling the Dissolved Oxygen Desorption when Superheated Water Enters the Rarefaction Zone

G. V. Ledukhovsky^{a, *}, V. P. Zhukov^a, Yu. E. Barochkin^a, and E. V. Barochkin^a

^aIvanovo State Power Engineering University, Ivanovo, 153003 Russia

**e-mail: lgv83@yandex.ru*

Abstract—A mathematical model describing the desorption of dissolved oxygen from superheated water when it enters the rarefaction zone is proposed. The initial model was obtained proceeding from a thermodynamic approach as a result of solving the material balance equations for the components of the considered “water–water vapor–gas” system taking into account the phase transition in the liquid. Further development of the model for taking into account the nonequilibrium nature of the processes occurring in the system was carried out using the methods of the heat and mass transfer processes similarity theory and regression analysis involving experimental data on various types of deaeration devices. Based on the results from a statistical analysis of alternative models, including the well-known model describing the deaeration of water when it enters into vacuum jet-bubbling deaerators, the choice of the final mathematical model is substantiated. Using this makes it possible to calculate the deaeration effect under the considered conditions depending on the initial water superheating with respect to the saturation temperature in the rarefaction zone, the deaeration element hydraulic load, and static pressure in it. It has been found that the obtained mathematical description is able to generalize, with acceptable accuracy, the experimental information on structurally different deaeration elements operating when superheated water is injected into them: droplet, centrifugal-vortex, cavitation-jet, and vacuum-cavitation ones. The obtained model can be used in designing new and improving the performance efficiency of existing deaeration plants at thermal power plants and industrial enterprises. As part of the study, the model was tested in solving problems concerned with operational adjustment of a cavitation-jet deaerator and for substantiating the technical solutions on upgrading the jet deaerator by topping it with a deaeration device operating under superheated water conditions.

Keywords: deaeration, heat and mass transfer, dissolved oxygen desorption, mathematical modeling, superheated water deaerator, phase transition in liquid, saturation temperature

Resource-Saving Solutions for Membrane-Demineralization Plants

E. B. Yurchevskii^a, * and V. V. Solodyannikov^b, **

^aAO OKB Gidropress, Podolsk, Moscow oblast, 142103 Russia

^bOOO SVT Engineering, Samara, 443080 Russia

*e-mail: aquachim@yandex.ru

**e-mail: vvssvt@yandex.ru

Abstract—Technologies for recycling effluent waters from pretreatment, reverse-osmosis plant concentrate, and demineralized water from a polishing plant that have been apporobated under field conditions are proposed. It is shown that the application of these technologies is efficient in solving resource-saving problems. For the topping ultrafiltration plant, the use of the considered technical solution makes it possible to return 82–88% of the effluent water volume to the permeate. Reverse-osmosis plant concentrate is suggested to be forwarded to an H-cation exchange filter charged with a weak-acid cation exchange resin. The filter is incorporated into a closed loop for multiple use of regeneration solutions that contains a crystallizer in which calcium sulfate is extracted from a supersaturated regeneration solution. The permeate from the H-cation exchange filter is divided into two flows. One of these flows is mixed with the ultrafiltration plant permeate, and the other is removed from the demineralization plant process circuit and is used as makeup water for cooling systems or water supply and heat-supply systems or is removed into the environment. For estimating the efficiency of the proposed technical solutions, specially developed mathematical models of individual processes were used. It is shown that it is possible by applying the proposed scheme for recycling the effluent water from a membrane demineralization plant to achieve 91.8–99.0% efficiency of using natural water relating to the hydrocarbonate class and sulfate group, which encompasses the overwhelming majority of surface fresh water sources. By applying the regeneration solution multiple usage loop for recycling the reverse-osmosis plant concentrate, it is possible to return a significant part of the concentrate into the main cycle and to extract commercial-grade calcium sulfate from the concentrate. It was also shown from the accomplished calculations that the application of the proposed concentrate recycling technology is inexpedient for source water belonging to the hydrocarbonate class and magnesium group. The schemes for recycling effluent water according to the proposed technology can be practically implemented by using standard equipment and technical solutions apporobated under field conditions.

Keywords: membrane water-treatment technologies, reverse-osmosis water demineralization, concentrate, resource saving in water treatment, effluent recycling, heat network makeup water, drinking water

The Use of the Heat-Accumulation Properties of Heat-Supply Networks and Buildings for the Extension of the Electric Power Output Control Range at Combined Heat and Power Plants

R. Z. Aminov^{a,*}, E. Yu. Burdenkova^{a,**}, and A. B. Moskalenko^{a,***}

^a Saratov Scientific Center, Russian Academy of Sciences, Saratov, 410054 Russia

*e-mail: oepran@inbox.ru

**e-mail: lena.burdenkova@yandex.ru

***e-mail: Aleksandr.moskalenko1@gmail.com

Abstract—As a result of the lack of flexible capacities and an increase in the fraction of nuclear power plants in European Russia, the combined heat and power (CHP) plants currently need offloading during the off-peak hours of electric power demand. The adjustment of electric power demand necessitates additionally increasing the electric power of the power-generating units in the on-peak hours and decreasing it at nighttime. The existing methods for increasing the power of combined heat and power plants suffer from a number of serious drawbacks. The reduction in the electric power in the heating period is restricted, as a rule, by high heat demand. In this work, we show the possibility of extending the control range of the electric power output at CHP plants through the use of the heat-accumulation properties of the heat-supply networks and buildings and, accordingly, through the changeover of the operating modes of the cogeneration plant. Several operating-mode variants of the cogeneration plant are considered. The calculations conducted show that the consideration of the heat-accumulation properties of the heat-supply networks and buildings allows, having reduced the electric output of the CHP plant at nighttime, for an increase in the thermal output to increase the electric output in the day reducing the thermal output. An important requirement for the heat supply to buildings is the maintenance of comfortable indoor conditions. The optimal permissible temperature range for living space in the cold period of the year is 20–22°C. The possibility of ensuring the comfortable conditions indoors is confirmed by the calculations of the indoor air temperature by the method previously proposed by the authors that considers the heat-accumulation properties of the heat-supply networks and buildings. The indoor air temperature decreases by the end of the discharge period, i.e., the time when the accumulated heat has been consumed, to approximately 19°C; consequently, it does not go down below the permissible range. It should be noted that this is predominantly due to the heat-accumulation properties of the buildings. The material of the main heating system pipelines has a low accumulation capacity, i.e., the pipe walls transfer heat rapidly to the water that enters the pipeline at a temperature lower than that of the pipes. However, due to the considerable length of the heat system's pipelines, the temperature of the heating-system water that arrives at the consumer remains constant at the time moment after the temperature perturbation on the heat source.

Keywords: heat accumulation, cogeneration plant, peak hot-water boiler, supply heating-system water, control range, heat-supply system layout