

Contents

Vol. 68, No. 8, 2021

Renewable Energy Sources, Hydro Power Engineering

Reducing Costs for Integration of Renewable Energy Sources: A Way to Making Renewable Energy More Accessible

S. A. Nekrasov

Numerical Simulation of the Gas Expansion Process in a Turboexpander Unit by the Finite Volume Method

A. A. Sidorov and A. K. Yastrebov

Developing Models of Turbine Thermal Processes in Low-Steam and Motor Modes

G. A. Pikina, E. K. Arakelyan, F. F. Pashchenko, and G. A. Filippov

Heat and Mass Transfer and Properties of Working Fluids and Materials

Verification of New-Generation Generalizing Correlations and the Results from Predictions and Theoretical Studies on Heat Transfer of Supercritical-Pressure Coolants

V. A. Kurganov, Yu. A. Zeigarnik, G. G. Yankov, and I. V. Maslakova

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Experience Gained from Shifting the 225 MW Power Units at the Cherepet State-Owned District Power Plant Equipped with TPE-223 Drum Boilers for Operation in the Sliding Pressure Mode

*E. A. Fomenko, I. A. Ryzhii, A. V. Shtegman, D. V. Sosin,
D. V. Stepanishin, and D. G. Tochilin*

Metals and Strength Analysis

Studying the Metal from Drums at Thermal Power Plants after Long-Term Operation Using Subsize Charpy Specimens

A. G. Rudenko, V. N. Voyevodin, S. V. Gozhenko, and P. A. Mischenko

Automation and Thermal Control in Power Industry

Methodology for Determining the Actual Values of Statism and the “Deadband” for Primary Regulation of TPP Equipment

A. A. Nikiforov, A. G. Chaplin, and N. V. Zorchenko

Heating and Heating Networks

Analysis of Thermal Loads and Specific Consumption of Thermal Energy
in Apartment Buildings

A. S. Gorshkov, M. S. Kabanov, and Yu. V. Yuferev

Reducing Costs for Integration of Renewable Energy Sources: A Way to Making Renewable Energy More Accessible

S. A. Nekrasov*

Central Economics and Mathematics Institute, Russian Academy of Sciences, Moscow, 117418 Russia

**e-mail: san693@mail.ru*

Abstract—The prices for electricity from renewable energy sources (RES) tend to decrease around the world and have already become lower than 1.5 rubles/(kW h) in the most advantageous projects. However, this indicator in Russia has essentially higher values both at present and in the forecast for 2035, which is caused by the system effect of RES integration in the power system. In fact, renewable energy and conventional energy are antipodes in Russia and are in contradiction with respect to each other. The article substantiates the possibility of harmonizing them with each other from the viewpoint of the universal organizational science called tectology and gives examples of technological solutions for implementing this: changing the operation modes of electrical loads in the compositions of consumer electrical systems and development of distributed cogeneration in accordance with the schedule of electrical rather than heat loads as a result of separating the heat-recovery and consumption processes in time by using thermal energy-storage devices. In fact, this refers to achieving better structural stability of the energy sector based on an alternative concept of its development and transition to optimizing the operation of the inseparable process chain “production—consumption of fuel and energy resources,” which also includes new, renewable sources. Apart from decreasing the costs for integrating RES into the power system and making the prices for electricity from RES in Russia commensurable with those around the world, this will also result in a more efficient power supply as a consequence of more uniform loading of thermal and nuclear power plants, the use of the nonutilized potential of decreasing the specific fuel consumption for electricity production in the cogeneration mode, and decreased losses in distribution networks.

Keywords: tectology, structural stability of a system, renewable energy sources, alternative energy sector development concept, electricity demand management, distributed cogeneration, specific reference fuel consumption, reduction of electric energy losses, reactive power compensation, electric vehicles

Numerical Simulation of the Gas Expansion Process in a Turboexpander Unit by the Finite Volume Method

A. A. Sidorov^{a,*} and A. K. Yastrebov^a

^a *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: AlexSid-MPEI@yandex.ru*

Abstract—Finite volume methods were used to study the process of gas expansion in the stage of a turboexpander unit (TEU) in a three-dimensional, nonstationary setting. The main objectives of the work are to verify the calculation methodology based on a real experiment, to obtain a qualitative and quantitative agreement of data for further studies of the processes occurring in the flow path of the stage of a turboexpander unit, namely, phase transitions during condensation of impurities in the bulk. Due to the fact that the experiment is only preliminary tests, there is no reliable data on the intermediate values of the macroparameters; therefore, the verification of the proposed method was carried out only in terms of the temperature at the outlet from the diffuser and the isentropic efficiency. The calculation technique used in this work, thanks to the use of sliding interfaces, made it possible to study the turboexpander unit not in parts but with the help of a unified calculation model, taking into account the leaks and overflows of the working fluid (helium). In the course of calculations, the fields of velocity, pressure, and temperature were obtained in the longitudinal and cross sections of the turboexpander unit as well as on its walls. A simplified h, s -process diagram, and the values of isentropic efficiency are determined for several points. The proposed calculation method, applied for a specific model of a turboexpander unit, can be extrapolated to other variants of the flow paths of microturbine expander units for boundary conditions and operating modes close to the original variant. To prepare an extended calculation method, it is necessary to carry out additional studies as well as to establish the limits of applicability of the finite volume method on a larger data set.

Keywords: turboexpander, cryogenic technology, expansion process, CFD modeling, numerical solution, finite volume method

Developing Models of Turbine Thermal Processes in Low-Steam and Motor Modes

G. A. Pikina^{a, b, *}, E. K. Arakelyan^{a, **}, F. F. Pashchenko^b, and G. A. Filippov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b Trapeznikov Institute for Management Problems, Russian Academy of Sciences, Moscow, 117997 Russia

*e-mail: PikinaGA@mail.ru

**e-mail: arakelianek@mpei.ru

Abstract—The main purpose of the motor mode is to keep the turbine in hot standby (with the boiler off) without generating electricity to the grid. To do this, the generator is switched to the engine mode, which rotates the turbine rotor, and the cooling of the flow path is performed by supplying one or two intermediate steam extractions from the extractions of the neighboring turbine. The first stages of the high-pressure cylinder run on steam from the front seals. The noted specificity of the purpose and operating conditions of the turbine in low-steam modes imposes additional requirements on the mathematical model. When developing models of a turbine stage in a motor mode, the physical media included in the object were taken into account: the steam of the flow path passing through the nozzle and working discs, participating in the conversion of its thermodynamic and kinetic energy into mechanical energy of the rotor rotation; vapor leakage into the space between the discs; steam leakage through the rotor-guide vane seal; metal of rotating devices (working disks and turbine rotor); and metal of the stator and exhaust pipes. Multipoint models are obtained with lumped parameters distributed along the length of the flow channel with values that vary depending on the ordinal number of the stage. The main part of the step models are eight ordinary differential equations or partial differential equations of physical media. The developed models are necessary for computer modeling and investigating the temperature distribution of the turbine flow path. Based on the research results, it is proposed to create a real automatic control system that ensures the implementation of restrictions on metal heating and the generation of added power.

Keywords: turbine, low steam and motor modes, thermal processes, multipoint models, distributed parameter model, partial differential equations, lumped parameter model, ordinary differential equations

Verification of New-Generation Generalizing Correlations and the Results from Predictions and Theoretical Studies on Heat Transfer of Supercritical-Pressure Coolants

V. A. Kurganov^a, Yu. A. Zeigarnik^{a,*}, G. G. Yankov^b, and I. V. Maslakova^a

^a *Joint Institute for High Temperatures of the Russian Academy of Sciences (JIHT), Moscow, 125412 Russia*

^b *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: zeigar@oivtran.ru*

Abstract—Heat transfer of supercritical-pressure (SCP) coolants continues to attract the attention of both researchers and engineers. Works on developing phenomenological models of the process, elaboration of universal computer codes, and search for reliable semiempirical generalizing correlations, primarily for deteriorated heat-transfer conditions, are continued. To ensure sufficiently accurate and reliable results obtained using these correlations and codes, they should be verified using the same array of experimental data (benchmark). This data array should be carefully selected, analyzed, and checked on the basis of many studies and practical engineering applications. The choice of data for verification should not be selective in nature; the more so, it should not be based solely on the experimental data of the authors of the proposed correlations. The article presents a tabulated summary of experimental studies on heat transfer and fluid dynamics of supercritical pressure water and carbon dioxide in round tubes. These studies cover normal and deteriorated heat-transfer conditions (with sorting into groups depending on the extent of influence caused by buoyancy and thermal acceleration effects) and data on pressure drop, velocity profiles, and tangential stresses. At the same time, these richest and practically tested data should be used in a very competent and accurate manner. Preference should primarily be given to the use of primary data reported in these studies, and it is not recommended to verify the new calculated data by applying the generalizing correlations from these studies obtained using the old standards on thermophysical properties. It is emphasized that the results from new calculations of heat transfer become essentially more valuable if they are accompanied by simultaneously obtained data on the flow hydraulic characteristics.

Keywords: coolant, supercritical pressure, hydrostatic resistance, normal heat transfer, deteriorated heat transfer, generalizing correlations, computer codes, verification

Experience Gained from Shifting the 225 MW Power Units at the Cherepet State-Owned District Power Plant Equipped with TPE-223 Drum Boilers for Operation in the Sliding Pressure Mode

E. A. Fomenko^{a,*}, I. A. Ryzhii^a, A. V. Shtegman^a, D. V. Sosin^a, D. V. Stepanishin^a, and D. G. Tochilin^b

^a *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

^b *Zhimerin Cherepet State-Owned District Power Plant, Suvorov, Tula oblast, 301430 Russia*

**e-mail: fkbosch@mail.ru*

Abstract—The operation of a steam boiler in a sliding pressure mode is characterized by certain advantages in comparison with the usual mode of equipment operation: it becomes possible to reduce the power unit's minimum allowable load, reduce the electric energy expenditures for driving the feed pump, and reduce the specific reference fuel consumption. Increasing the equipment energy efficiency is a priority task for all power plants. Shifting a power unit for operation in a sliding pressure mode is a universal way to solve this problem irrespectively of the boiler type (drum or once-through) and the kind of combusted fuel (coal, natural gas, or fuel oil). Up to date, practical implementation of boiler operation in a sliding pressure mode has not received wide application in Russia. The existing examples of a power unit's operation at sliding pressure are mainly associated with the transient conditions of equipment operation and are only related to once-through boilers. In drum boilers, practical studies of their operation at sliding pressure were not carried out in view of certain difficulties connected with the change of heat transfer conditions in the waterwall heating surfaces. The article presents the results of activities aimed at shifting the Cherepet state-owned district power plant (SDPP) 225-MW power units equipped with Ep-630-13.8-565/570KT (the TPE-223 model) drum boilers for operation at sliding pressure. These boilers use grade D coal from the Kuznetsk field as the main fuel. The operation of the power units was modeled using the Boiler Designer computer program, and a procedure for estimating the economic feasibility of shifting the power units to operate at sliding pressure was elaborated. Based on the results of preliminary studies, operational and adjustment tests of the power units were carried out, which confirmed the possibility and economic feasibility of shifting them to operation in the sliding pressure mode. The study results are presented, and the possibility of extending such practices to a significant part of the operating boiler and turbine equipment at the power plants of Russia is evaluated.

Keywords: steam boiler, sliding pressure, power unit, power unit load, reduction of specific reference fuel consumption, improvement of energy efficiency, modeling, tests

Studying the Metal from Drums at Thermal Power Plants after Long-Term Operation Using Subsize Charpy Specimens

A. G. Rudenko^{a, *}, V. N. Voyevodin^a, S. V. Gozhenko^a, and P. A. Mischenko^a

^a *Institute of Solid State Physics, Materials Science, and Technologies NSC KIPT,
Kharkiv, 61108 Ukraine*

**e-mail: rudenko@kipt.kharkov.ua*

Abstract—Mechanical properties of the metal from drums of boilers at the Starobeshevskaya and the Lugansk thermal power plants (TPPs) were investigated. According to the results of the standard technical diagnostics and a strength analysis, both drums comply with the applicable regulatory requirements. At the Starobeshevskaya TPP, the drum was ruptured during a hydraulic test. It was found that this was caused by the low impact strength of the metal at room temperature. The objects of the investigation were fragments of the ruptured drum and a “plug” cut out of the shell during a scheduled inspection. An attempt is made in this paper to assess the state of equipment metal based on the results of tests on subsize Charpy specimens. It has been demonstrated that when standard Charpy specimens (10 × 10 × 55 mm) cannot be made but impact bend tests have to be performed, the brittle-to-ductile transition temperatures for standard Charpy specimens may be obtained in testing 2 × 8 × 55 mm specimens. The correlation developed to relate the test results from subsize specimens to standard Charpy specimen enables us to assess in the first approximation the fitness for service of the metal to prolong the equipment’s service life. The rupture surface of subsize Charpy specimens has almost the same appearance as that of standard specimens. The temperature dependence of ductile component of subsize specimens agrees well with the corresponding dependence for standard Charpy specimens. To integrate the test data into a single database, it is desirable to derive a correlation to relate the critical brittleness temperature from a subsize specimen test to the critical brittle temperature from standard Charpy specimens.

Keywords: boiler drum, Charpy specimens, subsize specimens, metal impact strength, equipment service life, thermal power plants

Methodology for Determining the Actual Values of Statism and the “Deadband” for Primary Regulation of TPP Equipment

A. A. Nikiforov^{a, *}, A. G. Chaplin^a, and N. V. Zorchenko^a

^a OAO All-Russia Heat Engineering Institute, Moscow, 115280 Russia

*e-mail: unnicked123@yandex.ru

Abstract—Currently, more than 60 units of generating equipment for power plants are involved in standardized primary rated frequency control (PFRC). The active power of such power units or turbines should vary in proportion to the deviations of the network frequency (turbine rotation speed) with certain dynamic characteristics. For the objectivity of assessing the quality of power plants’ participation in the PFRC, nine criteria were formulated, for which mathematical algorithms were developed. One of the important criteria that is used for automatic control of the participation of power plants in the PFRC is the assessment of the actual values of the “deadband” and statism of the primary regulation. In practice, when using the existing algorithm to determine the values of the deadband and statism of the primary regulation, an incorrect result is often obtained. Incorrect calculation results lead to economic losses of power plants participating in the PFRC and inadequate assessment of the technical state of turbine control systems. The article discusses the existing methodology for assessing the actual values of statism and deadband of the primary regulation of generating equipment when operating in normalized primary frequency regulation. The assumptions used in its development and leading to an additional error of the method are analyzed, for example, that the actual static characteristic is symmetrical relative to zero. Examples of incorrect calculations obtained using the existing methodology are given. An alternative method for evaluating these parameters of primary regulation, which allows them to be more accurately and objectively evaluated, is proposed and it is compared with the existing methodology. A description of the calculation algorithm using an alternative method is given, its features and advantages are considered, including the absence of restrictions on the amount of initial data. Comparative graphs and data of estimates of the actual values of the deadband and statism of primary regulation, obtained using the considered algorithms, for various equipment involved in the normalized primary regulation of frequency are presented. It is shown that the values obtained using the proposed algorithm more adequately characterize the actual dependence of the generating equipment’s active power on changes in the network frequency, which makes it possible to obtain more representative and adequate data in comparison with the results of calculations using the existing methodology and, accordingly, to give an objective assessment of the generating equipment’s operation.

Keywords: regulation, frequency of electric current, power, statism, deadband of primary regulation, mathematical expectation, regression model

Analysis of Thermal Loads and Specific Consumption of Thermal Energy in Apartment Buildings

A. S. Gorshkov^{a,*}, M. S. Kabanov^b, and Yu. V. Yuferev^a

^a AO Gazprom promgaz, St. Petersburg, 191124 Russia

^b Fuel and Energy Complex of St. Petersburg, St. Petersburg, 197342 Russia

*e-mail: a.gorshkov@spb.promgaz.gazprom.ru

Abstract—An analysis of the contractual loads of heat-consumption objects connected to one of the boiler houses of the Fuel and Energy Complex of St. Petersburg is presented. The analysis was carried out on the basis of the results of processing the readings of heat-metering devices installed at the subscriber inputs of apartment buildings located on the territory of St. Petersburg. The analysis was carried out of the consumption of heat energy for heating during the heating period of 2018/2019, and a comparison was made of the calculated and contractual loads of heat-consumption objects located in the area of operation of the considered source of heat energy. Change in the specific indicators of thermal energy in apartment buildings for heating depending on the series/types of buildings, their number of stories (taking into account the number of entrances), construction periods, and their heated area is shown. Examples of determining the calculated heat load for heating- and hot-water supply of heat-consumption objects according to the data array of general house heat meters, including within the schedule for regulating the supply of heat at the source. The coefficients showing the ratio of the calculated heat load of heat consumption subscribers to the contractual load were obtained. The reserve of thermal power for existing consumers of thermal energy and the source to which these consumers are connected has been identified. The average value of the coefficient, which is the ratio of the calculated heat load for heating to the contractual one, is 0.66, the averaged value of the coefficient, which is the ratio of the calculated heat load for hot-water supply to the contractual one, is 0.82.

Keywords: apartment building, heating, ventilation, hot-water supply, heat supply, heating season, heat energy, heat load