

---

---

# Contents

---

---

**Vol. 68, No. 9, 2021**

---

---

## **Nuclear Power Plants**

Current State and Prospects of Hydrogen Production At NPPs

*R. Z. Aminov and A. N. Bayramov*

The Digital Acoustic Model of a Pressurized Water Reactor

*K. N. Proskuryakov*

---

## **Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment**

Perfecting the Operative Management in the Performance Efficiency of Electric Power System's Unique Facilities

*E. M. Farhadzadeh, A. Z. Muradaliyev, T. K. Rafiyeva, and U. K. Ashurova*

Preliminary Assessment of the Possibility to Shift Thermal Power Plant Boilers for Burning Alternative Coal

*M. N. Maidanik, E. Kh. Verbovetskii, and A. N. Tugov*

Application of the Aspen Plus Software Package for Simulation of the Synthesis-Gas Composition in Oxygen-Free Steam Gasification of Biomass

*S. A. Shevyrev*

---

## **Heat and Mass Transfer and Properties of Working Fluids and Materials**

An Engineering Model of Steam Condensation from a Flowing Steam-Gas Mixture on a Bundle Made of Horizontal Tubes

*K. B. Minko, G. G. Yan'kov, V. I. Artemov, V. S. Krylov, and A. A. Klemen'ev*

Determining Temperature of Adiabatic Surfaces in Rooms with Radiant Heating

*A. O. Shatskov*

---

## **Water Treatment and Water Chemistry**

New Method for Measuring Colloidal Index

*A. A. Pantelev, A. A. Smirnov, V. B. Smirnov, and V. P. Kovalenko*

---

## **Metals and Strength Issues**

Risk Monitoring Based on Early Diagnosis of Potential Damage to Power Equipment

*A. A. Dubov*

---

---

# Current State and Prospects of Hydrogen Production at NPPs

R. Z. Aminov<sup>a</sup> and A. N. Bayramov<sup>a, \*, \*\*</sup>

<sup>a</sup> *Saratov Scientific Center, Russian Academy of Sciences, Saratov, 410054 Russia*

*\*e-mail: oepran@inbox.ru*

*\*\*e-mail: art2198@yandex.ru*

**Abstract**—According to the strategy of Rosenergoatom State Corporation, hydrogen energy is included in the list of priority areas for the development of nuclear energy in Russia. To ensure the base load of nuclear power plants (NPP), the technology of hydrogen production by the method of electrolysis of water at hydrogen complexes in combination with NPP power units becomes relevant. Traditionally, it was assumed to use pumped storage power plants (PSPP) for this purpose. However, their construction is limited by natural conditions and it is impossible near the NPP, which implies their charging from the power system at a rate three to four times higher than the cost of electricity produced at the NPP. A specific feature of the hydrogen complex is the possibility of its underground location at a small distance from the NPP using the electricity generated at the NPP for charging at cost. The advantage of underground placement is to reduce by one to two orders of magnitude the total risk from explosions and fires of a mixture of hydrogen with an oxidizer in the event of an accident. A block diagram of the use of hydrogen and oxygen when combining a hydrogen complex with a nuclear power plant is presented. The scale of consumption of hydrogen and its purity by industry for the period up to 2100 are given. The world prospects for the development of water electrolysis technology and the possibilities of hydrogen production in Russia are analyzed. Comparison of the efficiency of hydrogen production by water electrolysis and steam reforming of natural gas is carried out. Forecasted prices for nuclear fuel and natural gas are accepted for the future until 2035. In the production of hydrogen on the basis of “disrupted” night off-peak electricity, it is possible to operate a nuclear power plant without unloading power units, which ensures a reduction in the cost of hydrogen production and its competitiveness by the method of steam reforming of natural gas.

*Keywords:* nuclear power plant, hydrogen, hydrogen energy complex, “failed” electricity, water electrolysis, steam reforming of natural gas, hydrogen purity

# The Digital Acoustic Model of a Pressurized Water Reactor

K. N. Proskuryakov\*

*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: ProskuriakovKN@mpei.ru*

**Abstract**—The digital acoustic model of a nuclear reactor (NRDAM) is represented as a self-oscillatory system belonging to a special class of nonlinear dissipative systems that can generate sustained oscillations whose parameters do not depend on the initial conditions and are only governed by the properties of the system itself. It has been found that a pressurized water reactor with coolant flowing in a turbulent mode is an open system of high complexity with a large number of components with links between them being probabilistic rather than predetermined in nature. The coolant loop components featuring negative dissipation (negative friction) are revealed. It is shown that chaotic turbulent pulsations and vortices are self-organized in these components into ordered wave oscillations, the frequency of which is determined according to the Thomson (Kelvin) formula. An electronic generator of self-oscillations with a transformer feedback used in radio engineering circuits has similar properties. A nozzle is an acoustic analog of a transformer. A negative resistance contained in nonlinear dynamic systems like a nozzle or a natural circulation loop results in that chaotic turbulent disturbances become self-organized, and self-oscillations are generated in the form of acoustic standing waves (ASW). Based on theoretical and experimental data, the certainty of the ability of a reactor together with the pipelines connected to it to simultaneously generate several ASWs—a property that has not been known previously—is confirmed. By using the NRDAM in designing and operation of nuclear power plants (NPPs), it becomes possible to reveal the sources of ASWs arising in the coolant, their occurrence conditions, and frequency. The use of the NRDAM is also necessary for determining the effect that the coolant circuit equipment geometrical parameters and layout have on the interaction of neutronic, thermal-hydraulic, and vibroacoustic processes. By applying the NRDAM, it becomes possible to optimize the engineering and design solutions in developing new-generation NPPs by eliminating the conditions causing the occurrence of undesirable self-oscillations of coolant and vibroacoustic resonances resulting from the coincidence of the ASW frequencies with the vibration frequencies of nuclear fuel and equipment in normal and emergency operation modes and also under the conditions of shock impacts and seismic loads.

*Keywords:* self-oscillations, electroacoustic analogs, reactor, vibroacoustic resonance, safety, equipment layout optimization, neutronic, thermal-hydraulic, and acoustic processes

# Perfecting the Operative Management in the Performance Efficiency of Electric Power System's Unique Facilities

E. M. Farhadzadeh<sup>a,\*</sup>, A. Z. Muradaliyev<sup>a</sup>, T. K. Rafiyeva<sup>a</sup>, and U. K. Ashurova<sup>a</sup>

<sup>a</sup> *Azerbaijan Scientific-Research and Design-Prospecting Power Engineering Institute, Baku, Az1012 Azerbaijan*

*\*e-mail: elmeht@rambler.ru*

**Abstract**—Maintaining efficient operation of facilities that have been in operation in excess of their standard service life is among the most significant and complex problems faced in modern electric power systems. The urgency of this problem stems from the systematically growing fraction of such facilities, which has reached as high as 60% by now. The difficulties of solving it are caused by the necessity to develop methods and algorithms for quantitatively evaluating the operative performance efficiency (OPE). A method and an algorithm are proposed for quantitatively estimating the integral OPE indicator for unique facilities, i.e., facilities that do not have analogs for the specified combination of attribute varieties. By using the proposed approach, it becomes possible to obtain not only error-free estimates of technical and economic indicators (TEIs) but also, what is most important, a physical interpretation of the integral indicator. The multidimensional nature of the monthly average values of TEIs and nonrandom nature of samples from the totality of TEIs are factors that pose serious limitations to the application of the classic hypothesis tests. A new criterion that successfully overcomes these obstacles is developed. The critical values of integral indicators appearing in this criterion are determined by simulating possible realizations of the integral indicators. A smaller risk of obtaining an erroneous solution on the maintenance of unique facilities is achieved, due to which reliable methodical support for the enterprise management staff is ensured. The sequence of calculations carried out for a gas- and oil-fired 2400-MW condensing thermal power plant (CTPP) is illustrated. To make the data transformation manipulations more compact with concurrently retaining the possibility to compare them with the results from a quantitative estimation of the OPEs for facilities of the same type, the calculations are carried out only for certain leveled monthly average TEI values of the CTPP power unit boiler plants. By using the monthly average values of unique old power facilities, so-called oldtechs (UPOTs), it becomes possible to perform operative monitoring of their variation with time, and the changeover from actual to normalized values makes it possible to estimate the change in the UPOT technical state from the average wear and the degree of its maladjustment.

*Keywords:* operative management, performance efficiency, unique facility, integral indicator, method, algorithm, benchmarking, randomness, “oldtech,” ranking, economic efficiency, reliability, hazard

# Preliminary Assessment of the Possibility to Shift Thermal Power Plant Boilers for Burning Alternative Coal

M. N. Maidanik<sup>a,\*</sup>, E. Kh. Verbovetskii<sup>a</sup>, and A. N. Tugov<sup>a</sup>

<sup>a</sup> *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: MNMaydanik@vti.ru*

**Abstract**—The article presents methods and a system of assessments for estimating the technical feasibility of shifting the boilers of thermal power plants (TPPs) operating on solid fuel for burning alternative coal. A basic arrangement of carrying out works at the preliminary stage is proposed, which includes an analysis of experience gained from combustion of alternative coal at other TPPs and the characteristics (properties) of the design and alternative coals burned at a TPP. Based on field experience, the correspondence of coal grades to each other in regard to combustion stability is determined. In the course of a comparative analysis into the characteristics of the design coal burned at a TPP and alternative coal, the thermal performance indicators of the fuels, their characteristics influencing the harmful emissions and ash and slag removal, slagging and fouling properties, fuel and ash abrasive properties, explosion hazard properties, indicators characterizing the proneness to oxidation and self-ignition, and fuel flowability and congelation are estimated. The specific features of carrying out assessments in burning mixtures of solid fuels are considered. The conditions determining the technical feasibility of using alternative fuel without performing its mandatory experimental combustion are presented. Programs of organizational and technical measures for preparing and performing experimental combustion of alternative coal are given. Based on the results of works carried out at the preliminary stage, the conditions for obtaining substantiated assessments of technical feasibility and advisability of using alternative coal are determined more exactly, including the need to perform experimental combustion of alternative coal and the required scope of equipment's modifications.

*Keywords:* thermal power plant, solid fuel, boiler, alternative coal, fuel physicochemical characteristics, fuel properties, comparative assessment of fuels, experimental combustion

# Application of the Aspen Plus Software Package for Simulation of the Synthesis-Gas Composition in Oxygen-Free Steam Gasification of Biomass

S. A. Shevyrev\*

*Gorbachev Kuzbass State Technical University, Kemerovo, 650000 Russia*

*\*e-mail: ssa.pmahp@kuzstu.ru*

**Abstract**—The gasification process is among the hydrogen production methods finding ever increasing application in the world practice. In its industrial implementation, a steam-oxygen mixture is employed most often as a gasifying agent. However, superheated steam is more promising for this purpose, since water is a hydrogen donor. It is essential to have an oxygen-free gasifying agent. This not only saves fuel eliminating its oxidation in the gasification process but also reduces the cost of synthesis gas (syngas) due to the fact that energy-consuming air separation units for oxygen production are not needed. Superheated steam for the gasification process can be generated at thermal power plants of various thermal and electrical power. This will enable the superheated steam to be generated at conditions in a wide range of temperatures and pressures and with high flowrates as required for gas generators with high specific thermal power. This process was modeled in the Aspen Plus software package widely used for simulation of chemical process and power systems in many countries of the world. The gasification process is generally modeled using the RYield or RGibbs reactor. The effect of superheated steam temperature (750–965°C) and pressure (0.1 to 3.0 MPa) of the syngas composition is demonstrated. Depending on the superheated steam pressure and temperature, the generated syngas can be used as a fuel for power units (in power industry) or as a feedstock for the production of various chemicals, such as hydrogen and synthetic liquid fuel. Comparison of the simulation results with the published data revealed that their difference does not exceed 15%.

**Keywords:** biomass, oxygen-free steam gasification, syngas, polygeneration, thermal power plant, hydrogen energy, Aspen Plus, synthetic liquid fuel

# An Engineering Model of Steam Condensation from a Flowing Steam-Gas Mixture on a Bundle Made of Horizontal Tubes

K. B. Minko<sup>a, b, \*</sup>, G. G. Yan'kov<sup>a, b</sup>, V. I. Artemov<sup>b</sup>, V. S. Krylov<sup>a, c</sup>, and A. A. Klemen'ev<sup>b</sup>

<sup>a</sup> Tsiolkovski Kaluga State University, Kaluga, 248023 Russia

<sup>b</sup> National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

<sup>c</sup> Research and Production Innovative Company Turbokon, Kaluga, 248010 Russia

\*e-mail: minkokb@gmail.com

**Abstract**—Based on an analysis of modern approaches to the calculation of heat-and-mass transfer processes in water-cooled condensers, an engineering model of steam condensation from a flowing steam-gas mixture (SGM) on a bundle made of smooth horizontal tubes is proposed. This model was verified against available experimental data and predictions by the detailed CFD-model described in our previous publications. The engineering model adequately describes the experimental data. Local characteristics of heat-and-mass transfer processes were studied in small-scale condenser tube bundles with a constant or variable cross-section fed with SGM having a volume fraction of air from 0 to 15%. For the case with an air volume fraction of 10% at the condenser inlet, the distributions of heat-transfer coefficient, heat flux, and total removed power removed along the SGM flow, as well as the distribution of heat flux density among the tubes of the first, fifth, and ninth rows are presented. A comparative analysis revealed that, despite almost the same average characteristics, the distribution of local heat-transfer coefficients is more uniform in a tube bundle with a decreasing cross-section along the SGM flow. The distributions of local heat-and-mass transfer characteristics calculated by the engineering model agree quite well with the predictions by the detailed CFD-model. Some qualitative disagreement can be explained by the fact that the engineering model uses characteristics averaged over the cross section of a row, and the detailed CFD model takes into account the nonuniformity in the velocity field and composition of the SGM flowing over the tube bundle.

**Keywords:** condensation, steam-gas mixture, forced flow, horizontal tube bundle, condenser arrangement, mathematical simulation, overall heat-transfer coefficients, local characteristics, model verification

# Determining Temperature of Adiabatic Surfaces in Rooms with Radiant Heating

A. O. Shatskov\*, \*\*

*Donbass National Academy of Civil Engineering and Architecture, Makeevka, Donetsk oblast, 86123 Ukraine*

*\*e-mail: Reggie.88@mail.ru*

*\*\*e-mail: aoshatskov@donnasa.ru*

**Abstract**—One of the most important problems today is to solve heat-supply problems and simultaneously decide the problem of energy saving. Systems of low-temperature electric infrared heaters show high efficiency. Radiant heating systems have several advantages over traditional heating systems, like the possibility of heating both the entire room and separate zones, lack of massive pipelines and air ducts and the expenditure for heat-transfer agent transportation, and lack of dust and pollutant circulation in the heated room. Using radiant heating systems can also reduce air temperature in the heated room by 1–3°C due to features of heat-transfer processes when radiant heating is used and it is allowed by building standards. Thermal comfort in rooms with radiant heating devices is created by increase in the radiation temperature of the enclosing structures' internal surfaces with a simultaneous decrease in the internal air temperature. In this case, it is necessary to achieve compliance with the first thermal comfort conditions. In order to determine whether these requirements are met and whether they comply with the current building standards, it is necessary to develop a method for calculating heat transfer in rooms with radiant heating. It is necessary to develop a methodology that will take into account all the variety of heating device configurations. The most important parameters are the dimensions of the devices, the surface temperature, and their number and location in the serviced rooms. It is also necessary to take into account the geometric parameters of premises and the material and emittance of the inner surface of enclosing structures. Heating devices for residential and public buildings are considered in the article. Due to the low height of such premises, devices with surface temperatures up to 100°C are accepted for meeting the second thermal comfort condition. The developed method has a number of assumptions that gives an error not exceeding five percent.

*Keywords:* surface temperature, radiant heat transfer, heat flux, emittance



# New Method for Measuring Colloidal Index

A. A. Pantelev<sup>a, b</sup>, A. A. Smirnov<sup>b, \*</sup>, V. B. Smirnov<sup>b</sup>, and V. P. Kovalenko<sup>b, \*\*</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> Research and Production Company Mediana-Filter, Moscow, 105318 Russia

\*e-mail: Smirnov\_A@mediana-filter.ru

\*\*e-mail: Kovalenko@mediana-filter.ru

**Abstract**—The colloidal index (CI) (Silt Density Index—SDI) is an important integral indicator of the quality of water prepared for reverse osmosis plants (ROP). To date, this is the only indicator that allows us to assess the likelihood of the membrane unit's contamination with colloids and suspended solids contained in the source water. It is shown that the new method for measuring the colloidal index, in contrast to the standard one, makes it possible to eliminate the contribution of nonlinearities to the description of water quality and it has a smaller error in a wide range of concentrations of suspended particles, which provides a more accurate prediction of potential contamination of reverse osmosis plants. Based on the differential form of the CI, a generalization of the standard technique for measuring the colloidal index in the linear region of decreasing the water flow rate using more accurate measurement and automation methods is presented. For waters with a low content of suspended and colloidal particles, the water flow through the microfilter changes slowly; therefore, to notice a drop in its performance, a considerable observation time is required (approximately 15 min). Attempts to measure CI on water with a high content of colloidal particles and suspended solids show their practical impossibility. The data of experimental studies are presented, confirming the correctness and advantages of the methodology for measuring the colloidal index demonstrated in the article. Comparison of methods for calculating the generalized colloidal index presented in the article and the modified fouling index (MFI) is performed. It is shown that the colloidal index is proportional to the concentration of suspended particles, and the MFI additionally contains a normalization factor inversely proportional to the filtrate velocity. In practice, the results presented in the article are likely to make it possible to calculate the load on reverse osmosis plants and to reveal the correlation of the frequency of chemical purification. In the course of the experiments, the phenomenon of an initial sharp drop in the flow rate of the filtrate through the filter was discovered, which is still awaiting its explanation.

*Keywords:* colloidal particles, water quality indicators, colloidal index, reverse osmosis unit, membrane filter, microfilter performance

# Risk Monitoring Based on Early Diagnosis of Potential Damage to Power Equipment

A. A. Dubov\*

*OOO Energodiagnostika, Reutov, Moscow oblast, 143965 Russia*

*\*e-mail: mail@energodiagnostika.ru*

**Abstract**—Currently, in order to ensure the safety of industrial facilities, diagnostics and monitoring of the condition of potentially dangerous equipment and the risks of its operation are being actively developed. At the same time, the risk assessment during the operation of various technical devices (TD) is carried out on the basis of the available damage statistics, which has accumulated over the past period of the TD operation, i.e., a probabilistic approach is used. This approach is imperfect and insufficiently objective since the risk assessment is done for the future period of time when the state of technical conditions can change significantly and fatigue damage to individual equipment units can occur in those zones that, as a rule, do not coincide with the calculated ones. The article proposes to carry out a risk assessment based on early diagnosis of the most damaged elements of TPP equipment. To implement this task, it is necessary to use more extensive methods of nondestructive testing of the actual stress-strain state in order to identify stress concentration zones (SCZ): the main sources of damage and modern methods of early diagnostics—acoustic emission, metal magnetic memory (MMM), and thermal control. An example of early diagnostics of developing damage from the practice of using the MMM method when monitoring the bend of a steam line is considered. It is shown that the difference in economic damage in risk assessment for TPPs with cross-links can be significant in case of damage to the steam line and damage to the boiler pipe.

*Keywords:* stress concentration zone, damage, early diagnosis, risks, technical devices, metal magnetic memory, nondestructive testing, economic damage