

---

---

# Contents

---

---

**Vol. 68, No. 11, 2021**

---

---

## **Renewable Energy Sources and Hydropower**

Modern Development Trends in Photovoltaics (Review)

*O. S. Popel' and A. B. Tarasenko*

---

## **Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment**

Aeroderivative GTUs for Power Generation (Overview)

*G. G. Ol'khovskii*

---

## **Nuclear Power Plants**

Verification of a Reactor's Digital Acoustic Model in the Startup and Nominal Operation Modes of NPPs Equipped with VVER Reactors

*K. N. Proskuryakov, A. V. Anikeev, and I. Afshar*

Verification of the EUCLID/V2 Integrated Code Thermal-Hydraulic Module Based on Experiments That Take into Account the Parameter Distribution over the Fuel Assembly's Cross Section

*A. A. Butov, I. A. Kliminov, I. G. Kudashov, V. I. Chukhno, T. V. Sycheva,  
E. V. Usov, N. A. Mosunova, and V. F. Strizhov*

Research of Slag Accumulation Recovered by Hydrogen in Circulation Circuits with Lead-Containing Heat Carriers

*V. V. Ulyanov, M. M. Koshelev, and Yu. A. Teplyakov*

---

## **Steam Boilers, Power-Plant Fuel, Burner Devices, and Auxiliary Equipment of Boilers**

Analytical Capabilities of FGM and EDM Combustion Models in Partially Premixed Burners for HVAC Applications

*N. Jaggu, S. R. Alluru, A. Balakrishna, and V. Kamasetty*

Introduction of Burners with In-Furnace Flue Gas Recirculation at a Power Boiler

*N. A. Zroychikov, D. R. Grigoriev, M. Gamburg, and A. V. Pay*

---

## **Water Treatment and Water-Chemical Regime**

Influence of Water-Chemical Regime on Electrization of Steam Flow, Reliability and Efficiency of a Turbo Unit

*A. A. Tarelin and A. V. Nechaev*

---

---

# Modern Development Trends in Photovoltaics (Review)

O. S. Popel<sup>a, \*</sup> and A. B. Tarasenko<sup>a</sup>

<sup>a</sup> *Joint Institute of High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

*\*e-mail: O\_Popel@mail.ru*

**Abstract**—Photovoltaics is developing around the world at the fastest rate in comparison with all other renewable energy sectors and demonstrates, owing to the improvement of relevant technologies and growing amounts of equipment manufacture, a significant decrease in both specific capital outlays per unit installed capacity of power installations and in the reduced cost of electricity generated by them with a simultaneous increase in the capacity utilization factor (CUF). The article briefly reviews the developments aimed at improving the characteristics of photovoltaic converters and development trends in the silicon photovoltaics technologies that have been seen in recent years. The article discusses the specific features, advantages, and shortcomings of the technologies for manufacturing silicon photovoltaic converters using passivated emitter and rear contact (PERC) technology, heterojunction modules that use HJT technology (a heterojunction on the basis of monocrystalline and amorphous silicon with intrinsic thin insulating layer), that with the  $p-n$ -junction brought to the wafer's rear side known as IBC technology (interdigitated back contacts), fragmented modules, and multijunction nonsilicon photovoltaic converters. It is pointed out that, in view of the fact that the achieved efficiency of silicon photovoltaic converters is approaching its theoretical limit, various methods for increasing the amount of solar radiation falling on the module surface, such as concentration of solar radiation, use of solar tracking systems, and use of bifacial modules, are becoming of special importance. The growing production of bifacial modules, silicon-based heterojunction modules, and, in the future, tandem structures with the use of perovskite-like materials generates the need to modify the methods used to predict the power output generated by photovoltaic modules with taking into account their spectral sensitivity. The state of photovoltaics development in Russia is briefly reviewed. Problems connected with the integration of photovoltaic stations into the grid are discussed, including matters concerned with using electric energy storage devices and flexible tariff regulation, and, as far as the private sector is concerned, promoting consumption of the energy inside the household in which it was produced. These problems will become increasingly more topical with a growth in the share of solar generation in the grid. It is pointed out that prices for photovoltaic modules can reach a competitive level in the world's market primarily owing to increasing the amounts of their manufacture up to 1 GW per annum or more.

*Keywords:* photovoltaic converter, production technologies, passivated emitter and rear contact (PERC), heterojunction with intrinsic thin layer (HJT), interdigitated back contacts (IBC), bifacial module, photovoltaic stations, photovoltaics in Russia, stimulation measures

# Aeroderivative GTUs for Power Generation (Overview)

G. G. Ol'khovskii\*

*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: vti@vti.ru*

**Abstract**—Aircraft gas turbine engine technology has made more rapid advancement than land-based gas turbine unit (GTU) technology has. The application of aviation achievements in the development of power gas turbines requires much time. However, assemblies from aircraft engines or their complete gas generators can be used directly in power plants with redesigning only the inlet stages of the compressors and adding a power turbine where after-expansion of the jet gases occurs. Therefore, this enables us to develop a mobile power unit with an output as high as 60 MW and an efficiency above 40%. Thousands of such GTUs with an individual power ranging from 6 to 45 MW have already been constructed and are successfully operating throughout the world. The article discusses the design features and main performance indicators of aeroderivative gas turbines developed by the world's leading manufacturers, such as General Electric (United States), Pratt & Whitney (United States), and Rolls-Royce (United Kingdom), namely, the GE LM6000 GTU (and its modifications), GE LM9000 GTU, industrial (Rolls-Royce) Trent GTU, and FT4000 GTU from Pratt & Whitney.

*Keywords:* gas-turbine unit, aeroderivative GTU, combined-cycle unit, combustion chamber, package, compressor, power turbine, rotational speed, efficiency, starting time, harmful emissions

# Verification of a Reactor's Digital Acoustic Model in the Startup and Nominal Operation Modes of NPPs Equipped with VVER Reactors

K. N. Proskuryakov<sup>a,\*</sup>, A. V. Anikeev<sup>a</sup>, and I. Afshar<sup>a</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

\*e-mail: ProskuriakovKN@mpei.ru

**Abstract**—At present, the regulatory technical documents developed in the late 21st century that stipulate design solutions and operating regulations for nuclear power plants do not include provisions for predicting and preventing the occurrence of vibroacoustic resonances of structures involving acoustic standing waves (ASWs) in operational and emergency modes and also under the effect of seismic waves. This results in that the existing feedbacks between neutronic and thermophysical processes under the conditions of coolant density fluctuations caused by ASWs have not been given proper attention. A nuclear reactor digital acoustic model (NRDAC), using which it is possible to identify the sources of self-exciting ASWs and to predict their frequency, has been developed at the NRU MPEI Department of Nuclear Power Plants. The article presents a new method for identifying the ASW frequencies in the acoustic system comprising a pressurized water reactor (in its Russian version known as a VVER, meaning a water-cooled, water moderated power-generating reactor) with the cold and hot leg pipelines connected to it. The models and analysis methods have passed verification in the Novovoronezh NPP unit 3 equipped with a VVER-440 reactor. For measuring the auto-spectral power densities (ASPD) of pressure pulsations, the main equipment vibration monitoring system SÜS developed by Siemens was used. The predicted values of ASW frequencies are consistent with the signals measured by pressure pulsation sensors. It is shown that the ASW frequencies depend on the operation conditions and may coincide with the pressure fluctuation frequencies caused by the operation of reactor coolant pumps (RCPs) with vibration of fuel assemblies (FAs) and equipment of the NPP reactor coolant system. It is shown that, whatever the number of coolant circulation loops, the nuclear reactor acoustic properties are similar to the properties of a group of simultaneously used Helmholtz resonators. By using the verified procedure, it is possible to optimize the design and layout solutions by constructing equipment able to minimize undesirable cyclic loads. This possibility is the most important one from the viewpoint of ensuring long-term operation of small modular reactors in maneuverable modes. Small NPPs should be highly maneuverable to complement renewable energy sources. The majority of small modular reactors are designed for little-attended operation with long periods of time between refueling outages (2–10 years vs. 12–24 months in large power units) or with the fuel loaded for the entire life cycle. The requirements of ensuring long-term operation in maneuverable modes can be fulfilled subject to minimizing the dynamic loads applied to the reactor plant structures by preventing the occurrence of hydrodynamic instability and resonances of structural vibration with acoustic fluctuations of coolant.

*Keywords:* vibration, fuel assemblies, Helmholtz resonator, cyclic loads, dynamic loads, coolant, optimization of structures and layouts, verification of analysis methods

# Verification of the EUCLID/V2 Integrated Code Thermal-Hydraulic Module Based on Experiments That Take into Account the Parameter Distribution over the Fuel Assembly's Cross Section

A. A. Butov<sup>a</sup>, I. A. Kliminov<sup>a</sup>, I. G. Kudashov<sup>a</sup>, V. I. Chukhno<sup>a</sup>, T. V. Sycheva<sup>a</sup>, E. V. Usov<sup>a,\*</sup>,  
N. A. Mosunova<sup>b</sup>, and V. F. Strizhov<sup>b</sup>

<sup>a</sup> Nuclear Safety Institute, Novosibirsk Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia

<sup>b</sup> Nuclear Safety Institute, Russian Academy of Sciences, Moscow, 115191 Russia

\*e-mail: usovev@gmail.com

**Abstract**—The second version of the EUCLID/V integrated code, denoted by EUCLID/V2, has been developed for analyzing the processes occurring in the course of severe accidents in sodium-cooled reactor plants with uranium dioxide fuel. Within the verification of this version that uses a 3D thermal-hydraulic module, modeling was carried out, and the prediction results were compared with the experimental data obtained on experimental setups in Germany and France on simulating accidents involving partial and complete blockage of the flow section (the first type) and also with loss of coolant flowrate (the second type). The experiments on simulating an accident involving partial blockage of the flow pass section in a 169-pin assembly (KNS 169) and on simulating an accident involving complete blockage of the flow pass section in a 37-pin assembly (SCARABEE-N BE+3) correspond to accidents of the first type, and experiments on simulating an ULOF type accident in a 37-pin assembly (KNS 37) correspond to accidents of the second type. Based on calculations carried out taking into account the available experimental data, the correctness of modeling performed using the EUCLID/V2 integrated code 3D thermal-hydraulic module is estimated, and the error of the coolant and fuel pin cladding temperatures predicted using the presented code is determined.

*Keywords:* fast reactor, core, liquid metal, EUCLID/V2, modeling, verification, spatial effects, sodium, boiling, input data uncertainty

# Research of Slag Accumulation Recovered by Hydrogen in Circulation Circuits with Lead-Containing Heat Carriers

V. V. Ulyanov<sup>a,\*</sup>, M. M. Koshelev<sup>a</sup>, and Yu. A. Teplyakov<sup>a</sup>

<sup>a</sup> *Leipunsky Physics and Power Engineering Institute, Obninsk, Kaluga oblast, 249033 Russia*

*\*e-mail: zroichikov@eninnet.ru*

**Abstract**—A thermodynamic analysis into the processes of slag accumulation during interaction of lead and lead-bismuth coolants with gaseous oxidants was carried out. It is shown that the oxidation of lead-containing coolants will lead to the formation of lead oxide, while the formation of bismuth oxide is unlikely. The possibility of selective oxidation of iron, chromium, and nickel to their oxides without the formation of slag from solid lead oxide with a dosed supply of a gaseous oxidizer to lead-containing coolants has been determined by calculation. It was revealed that the formation of solid lead oxide is unlikely when water vapor acts on lead-containing coolants. The calculation showed that it is necessary to extract the formed hydrogen from water vapor to a ratio of 1 : 20000 or less in order to create conditions for the formation of solid lead oxide. The regularities of the formation of lead oxide during depressurization of a circuit with a lead-containing coolant and their interaction with atmospheric oxygen have been investigated. According to the results of the experiment, the largest amount of solid PbO is formed upon contact with oxygen in a circuit not filled with a coolant and cooled to ambient temperature. Short-term depressurization of the loop in the hot state led to the formation of a smaller mass of PbO, and the presence or absence of a coolant in the loop had an insignificant effect on the mass of the PbO formed. The possibility for the formation of solid PbO during a microleak of a steam generator in the TT-2M stand with a Pb–Bi coolant has been investigated. Under the experimental conditions, it was not possible to obtain solid lead oxide, and the achieved limiting content of dissolved lead oxide turned out to be 550 times less than the saturation concentration.

*Keywords:* reactor plant, circulation contour, lead coolant, lead-bismuth coolant, hydrogen-reduced slags, steam generator microleaks, hydrogen purification

# Analytical Capabilities of FGM and EDM Combustion Models in Partially Premixed Burners for HVAC Applications

N. Jaggu<sup>a, \*</sup>, S. R. Alluru<sup>a, \*\*</sup>, A. Balakrishna<sup>a, \*\*\*</sup>, and V. Kamasetty<sup>a, \*\*\*\*</sup>

<sup>a</sup> *Trane Technologies Engineering and Technology Centre, Bangalore, India*

*\*e-mail: NJaggu@tranetechnologies.com*

*\*\*e-mail: Sreedhar.ReddyAlluru@tranetechnologies.com*

*\*\*\*e-mail: abalakrishna@tranetechnologies.com*

*\*\*\*\*e-mail: Venugopal.Kamasetty@tranetechnologies.com*

**Abstract**—Natural gas furnaces are the major source of heat for Heating, Ventilation, and Air Conditioning (HVAC) applications. The usage of partially premixed type burners in gas furnaces are significant from past few years. The use of Computational Fluid Dynamics (CFD) on solving and understanding flame and heat transfer characteristics in these devices are limited. The accurate modelling of turbulence chemistry interactions in any combustion device has always been a great challenge to the CFD engineers. Especially, gas heat furnaces uses a lot of components with turbulent flow making the modelling more challenging. Since CFD must be able to predict the combustion flame behaviour such as flame structure, flame length, flame temperature etc. over a region of fast chemical reactions zone, it is important to understand the different combustion modelling methods. In this paper an attempt has been made to compare two different modelling techniques, one using a simple global reaction mechanism Eddy Dissipation Method (EDM) and a detailed chemistry model Flamelet Generated Manifold (FGM). Most industries have been using these modelling methods based on the required application. The effect of air to fuel ratios on flame temperatures, conjugate heat transfer, mass fractions of CO<sub>2</sub> and the furnace efficiency has been analysed for both models. The study shows a better correlation of results with test using the FGM model as compared with EDM, in terms of air rise temperature, flue gas temperature and thermal efficiency.

**Keywords:** modelling, FGM, EDM, gas furnace, air-fuel mixture, combustion processes, CFD, heat transfer, flue gas temperature

# Introduction of Burners with In-Furnace Flue Gas Recirculation at a Power Boiler

N. A. Zroychikov<sup>a, \*</sup>, D. R. Grigoriev<sup>b, \*\*</sup>, M. Gamburg<sup>c, \*\*\*</sup>, and A. V. Pay<sup>a, \*\*\*\*</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> OOO Ecogor, Moscow, 115280 Russia

<sup>c</sup> Zeeco Inc., Oklahoma, 74014 United States

\*e-mail: zroychikovna@mpei.ru

\*\*e-mail: grigoryev@ecogor.ru

\*\*\*e-mail: Michael\_Gamburg@zeeco.com

\*\*\*\*e-mail: PaiAV@mpei.ru

**Abstract**—The results of the reconstruction of an E-500-13.8-560 KDT (TPE-430) boiler performed to reduce nitrogen oxide (NO<sub>x</sub>) emissions are discussed. In this case, a NO<sub>x</sub> concentration of 119 mg/m<sup>3</sup> has been reached only by using new burner devices. It has been demonstrated that the applicable environmental legislation contains a set of measures having a considerable effect on the current and planned business activities of the thermal power industry and power machine building enterprises. A brief description of the boiler is presented. Challenging issues of its operation are considered, and the operating and investment expenditures are analyzed. The thermal design of the boiler is assessed. The available burner devices with ultralow emissions are considered, and their best option has been selected. It has been demonstrated that successful implementation of the project requires special engineering activities to be performed before replacing the burners in the boilers to optimize the design and parameters of the air path. To construct a model of the air path, on-site studies of the air ducts of the TPE-430 boiler were carried out. On the basis of the obtained data, a physical model of the air path was made of plexiglass air. It was blown with cold air whose flow was visualized using helium soap microbubbles. The results of the physical simulation were used to arrange the annular ducts from the manifold to the new burners and to determine location and size of structural members to be installed in air ducts and burner boxes to achieve the required uniformity of the air flow.

*Keywords:* boiler, combustion chamber, burners, fuel, flue gases, ecology, standard emissions, nitrogen oxides, thermal design calculations, physical model, reconstruction, production localization



# Influence of Water-Chemical Regime on Electrization of Steam Flow, Reliability and Efficiency of a Turbo Unit

A. A. Tarelin<sup>a,\*</sup> and A. V. Nechaev<sup>a</sup>

<sup>a</sup> Podgorny Institute of Mechanical Engineering Problems, National Academy of Sciences of Ukraine, Kharkiv, 61046 Ukraine

\*e-mail: tarelin@ipmach.kharkov.ua

**Abstract**—The influence of the pH of the working medium on the processes of electrification of the wet steam flow and the indicators of the reliability and efficiency of the turbine plant are considered. The assessment of the formation of charges in the flow, depending on the water-chemical regime (WCR), was carried out on a laboratory bench created for this purpose and directly on the turbine. The laboratory bench was equipped with an air-droplet flow supply system, which, passing through a special device, electrified, and the current was recorded at the exit depending on the pH of the medium. Full-scale tests were carried out on an 800 MW turbine unit at the Navajo TPP (Arizona, United States). On the basis of these studies, it was found that the intensity of the formation of charges and their polarity depend on pH during the electrification of wet steam in a turbine. In an alkaline medium, the sign of the charges at certain boundary pH changes from negative to positive. The study of the influence of the pH of the feed water on the efficiency of the steam expansion process in the flow path of the turbine was carried out on a thermodynamic bench using a supersonic nozzle and in natural conditions on a turbine with a capacity of 800 MW. It was found that significant changes in both the thermodynamic process in the supersonic nozzle at the test bench and the turbine power do not occur at pH 7.0–9.6. A well-reasoned explanation and justification of these experimental results is presented. The influence of an aggressive charged working medium on the surface strength of rotor blades is considered, and studies in this direction were based on the fact that the degradation of the blade surfaces, especially the last stage of the turbine, largely depends on the intensity of the formation of charges and their polarity. The indicators of the working environment that most significantly (by 1.5–2.0 times) intensify electrocorrosive processes are determined. It is proposed, due to the rational choice of pH in the preparation of feed water, to control the process of formation of flow charges and control it, which will make it possible to increase the wear resistance of the surfaces of the blades and extend their service life.

*Keywords:* wet steam turbines, water chemistry, efficiency, reliability, charge formation, polarity, turbine blades, supersonic nozzle