

---

---

# Contents

---

---

Vol. 68, No. 12, 2021

---

---

## General Issues of Power Engineering

- Long-Term Energy Demand Forecasting Based on a Systems Analysis  
*S. P. Filippov, V. A. Malakhov, and F. V. Veselov* 5
- Energy-Economic Assessment of the Strategies for Energy Efficiency Improvements at Thermal Power Plants in Russia  
*F. V. Veselov, I. V. Erokhina, A. S. Makarova, A. I. Solyanik, and L. V. Urvantseva* 20
- 

## Renewable Energy Sources and Hydropower

- Methods for Simplification of the Mathematical Model for the Calculation of Flows in the Flow Path of Hydraulic Turbines  
*S. Fialová, F. Pochylý, A. V. Volkov, A. V. Ryzhenkov, and A. A. Druzhinin* 33
- Exergoeconomic Optimization of Low Temperature Solar Driven Organic Rankine Cycle  
*S. Upadhyaya and V. Gumtapure* 45
- 

## Nuclear Power Stations

- Thermo-Hydraulic Investigations of a Typical Small Modular PWR Using Computational Fluid Dynamics Modelling  
*S. F. Mirian and N. Ayoobian* 52
- 

## Steam-Turbine, Gas-Turbine, Combined-Cycle Power Plants and Their Auxiliary Equipment

- Optimizing Parameters of a High-Efficiency Steam Condenser from a Steam-Gas Mixture with a Large Content of Noncondensing Gases  
*O. O. Milman, A. Yu. Kartuesova, V. S. Krylov, K. B. Minko, and A. V. Ptakhin* 62
- Thermohydraulic Test of a Model of a High-Pressure Mixing Heater  
*Yu. G. Sukhorukov, B. F. Balunov, V. V. Lemekhov, V. A. Kogut, A. V. Proukhin, A. A. Shcheglov, F. A. Svyatkin, A. Yu. Yurchenko, A. S. Matysh, A. O. Borisov, N. A. Shorin, and K. A. Grigor'ev* 68
- Film Cooling of a Concave Surface with Two-Row Coolant Supply in Trenches  
*A. A. Khalatov and T. V. Donik* 76
- 

## Heat and Mass Transfer, Properties of Working Bodies and Materials

- Thermal Properties of Arv-U Graphite in the Interval of Temperatures of 293–1673 K  
*A. Sh. Agazhanov, D. A. Samoshkin, Yu. M. Kozlovsky, and S. V. Stankus* 87
- 
-

# Long-Term Energy Demand Forecasting Based on a Systems Analysis

S. P. Filippov<sup>a, \*</sup>, V. A. Malakhov<sup>a</sup>, and F. V. Veselov<sup>a</sup>

<sup>a</sup> Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia

\*e-mail: fil@eriras.ru

**Abstract**—Energy demand forecasting plays a key role in solving the majority of problems connected with determining the economic and energy development prospects. In view of high inertia and capital intensity of energy generation facilities, the changes in the energy consumption structure and rates should be considered for a sufficiently long-term future of no less than 15 years. This adds much difficulty to the development of such forecasts, because it is necessary to take into account the possible results of technological progress in different sectors of the economy and changes in its structure. The suggested approach to energy demand forecasting is based on the systems analysis methods. Energy consumers are disaggregated by economic sectors, country regions, energy carriers, and their utilization areas. As a result, it becomes possible to take into account the possible future technological and structural changes in the economy, its differences in different regions, mutual replacements of energy carriers, and energy saving. The most important feature of the approach is that it involves the separation of economic and energy variables. Economic variables determine the development scales of economic sectors, and energy variables determine the energy consumption intensities in them. The separation of variables helps obtain essentially more accurate forecasts owing to the possibility of taking into account the differences in the variation trends of these variables in the forecast period. For forecasting the economic variables, a nonlinear conditionally dynamic model of interrelations between the economy and energy is used. The energy variables are forecasted on the basis of their links with economic factors, e.g., with cumulative investments in the fixed capital of the considered economic sectors. The discussed approach was implemented as the totality of adaptive simulation models united into the EDFS computing system. The approach was repeatedly and quite successfully used to forecast the energy demand for an up to 10–20-year horizon in solving various problems. The gained experience has demonstrated the correctness of applying the approach for solving long-horizon forecast problems. To illustrate the capacities of the approach, the electric energy demand forecast for the period of up to 2040 for the basic version of the social and economic development of Russia's economy prepared on the basis of this approach is presented.

*Keywords:* energy, energy carrier, economy, demand, forecasting, methodology, systems analysis, efficiency, specific energy consumption, energy intensity, long horizon

# Energy-Economic Assessment of the Strategies for Energy Efficiency Improvements at Thermal Power Plants in Russia

F. V. Veselov<sup>a, \*</sup>, I. V. Erokhina<sup>a</sup>, A. S. Makarova<sup>a</sup>, A. I. Solyanik<sup>a</sup>, and L. V. Urvantseva<sup>a</sup>

<sup>a</sup> Energy Research Institute, Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia

\*e-mail: info@eriras.ru

**Abstract**—The current problems of strategic goal-setting for the development of thermal power plants (TPPs) as the main sector of the electric power industry in Russia are considered. The article presents the results from studies of the possible scale and conditions of the technological transformation of Russia's thermal power industry that will make it possible to achieve the target indicators of the Energy Strategy to reduce the average TPP heat rate through improving the utilization of the capacity of existing power plants and implementing investment decisions on replacing the existing TPPs and constructing new ones based on state-of-the-art technologies. For this purpose, alternative cases of power plant development in the Unified Power System (UPS) of Russia, which differ from one another in the amounts and technological structure of the required capacity additions at TPPs and take into account the current plans for the development of nonfossil types of power plants, have been prepared. In each case, the dynamics of changes in the generating capacity structure and electricity production mix in the UPS of Russia, the demand for different kinds of fuel, and the amount of required capital investments are determined. The incremental characteristics of the TPP energy efficiency improvement are estimated according to the necessary volumes of capacity renewal and the corresponding capital requirements. Interrelations between the scales of technological renewal of the thermal power sector, the volumes of the required revenue gained by TPPs, and the electricity generation sector as a whole are studied with the use of financial and economic models. The price consequences from implementation of various TPP heat rate decreasing programs differing from one another in intensity are determined. It is shown that the implementation of an intense investment program for technologically restructuring the thermal power sector to achieve the target indicators of the Energy Strategy will not lead to a sharp and constant increase in the price burden provided that the policy for restraining the growth of gas prices to an extent not higher than the inflation rate is retained, and provided that measures are taken to rapidly decrease, within the nearest 5–7 years, the cost of new equipment for TPPs serially produced in Russia, primarily that based on high- and medium capacity gas turbines.

**Keywords:** Energy Strategy, electric power industry, thermal power plants, energy efficiency, technical renewal, heat rate, Unified Power System, capital investments, fuel cost

# Methods for Simplification of the Mathematical Model for the Calculation of Flows in the Flow Path of Hydraulic Turbines

S. Fialová<sup>a, \*</sup>, F. Pochylý<sup>a</sup>, A. V. Volkov<sup>b</sup>, A. V. Ryzhenkov<sup>b</sup>, and A. A. Druzhinin<sup>b, \*\*</sup>

<sup>a</sup> *Brno University of Technology, Brno, 61669 Czech Republic*

<sup>b</sup> *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: Fialova@fme.vutbr.cz*

*\*\*e-mail: Alexey2959@mail.ru*

**Abstract**—The main concern of this paper is fundamental research into an acute problem arising in the operation of hydraulic turbines, namely, the formation of a vortex rope downstream of the impeller. It is noted that, at present, the operating range of these machines has to be extended due to the change in power network loads in daily and seasonal cycles, thereby increasing the time of hydraulic turbines' operation under off-design or undesirable conditions, including those involving the risk of formation of a vortex of varying intensity. To describe this complex fluid flow, a mathematical model of the vortex rope flow downstream of the hydraulic turbine's impeller was developed. This paper focuses on the fundamental issues encountered in developing the mathematical model. The methods are presented for simplifying the formulation of equations describing the structure of vortex rope formed in the flowpath. In this case, the equations of mathematical physics containing a dependent variable and taking the form of the Navier–Stokes equations when applied fluids flows were employed. They describe the time changes of the selected parameters in a controlled volume induced by the flow through the volume boundaries. The boundary conditions have been demonstrated to considerably affect the unsteady vortex structures. A special case is formulated for a potential force field using the stress tensor that governs the equilibrium. This makes it possible to describe complex motion in liquids without using an intricate form of the Navier–Stokes equations for vortex structures.

*Keywords:* unsteady flow, vortex structure, incompressible liquid, Navier–Stokes equations, unsteady term, divergence theorem, finite-volume method

# Exergoeconomic Optimization of Low Temperature Solar Driven Organic Rankine Cycle

S. Upadhyaya<sup>a</sup>, \* and V. Gumtapure<sup>a</sup>

<sup>a</sup> *Department of Mechanical Engineering, National Institute of Technology Karnataka, Surathkal, Mangalore, 575025 India*

*\*e-mail: suhas.upa@gmail.com*

**Abstract**— One of the most promising technologies in the field of distributed energy is the use of installations operating on the so-called organic Rankine cycle (ORC). The ORC technology is applicable for the utilization of low-potential thermal energy of natural or man-made origin. At the same time, in each specific case of using ORC systems, it is important to carry out technical and economic optimization of the project. In this paper, it is proposed to estimate the cost of electricity production by a ORC power block using an exergoeconomic model. To optimize the system parameters in order to minimize the electricity cost rate, the method of a genetic algorithm is used. The paper presents the results of optimization of the parameters of the ORC system, which includes a solar collector in combination with a ORC power block. R245fa is used as the working fluid in this analysis. With the help of a mathematical model, the electricity cost is calculated by comparing the costs for each of the components of the ORC system. For a given operating range of parameters of a ORC power block with an electric capacity of 1.03 kW, a minimum cost rate of 0.056 \$/(kW h) is determined. The optimal parameters of the working fluid in the ORC power block, at which the minimum electricity cost can be obtained, are also determined.

**Keywords:** Organic Rankine Cycle, working fluid, coolant, genetic algorithm, exergoeconomic, optimization, electricity cost rate, energy cost

# Thermo-Hydraulic Investigations of a Typical Small Modular PWR Using Computational Fluid Dynamics Modelling

S. F. Mirian<sup>a</sup> and N. Ayoobian<sup>a, \*</sup>

<sup>a</sup> Department of Nuclear Engineering, University of Isfahan, 81746-73441 Isfahan, Iran

\*e-mail: N. Ayoobian@ast.ui.ac.ir

**Abstract**—Computational Fluid Dynamics (CFD) is widely used in different industrial applications. In this research, the application of CFD in the thermo-hydraulic evaluation for a typical small modular Pressurized Water Reactor (PWR) was studied using ANSYS Fluent software. First, reactor core with different (pitch – fuel rod diameter) was simulated using MCNP code. Subsequently, axial neutron heat flux was calculated in the hottest rod. In the following, different fuel channels were simulated using ANSYS workbench and corresponding mass flow rate according to the fluid outlet temperature was computed using Fluent. Then, thermo-hydraulic parameters including pumping power, convective heat transfer coefficient and turbulent intensity were calculated. Artificial neural network (ANN) coupled with genetic algorithm (GA) was used for optimization; and pair pitch – fuel rod diameter (0.012 m, 0.0072 m) was selected as the optimum value. Also, Critical Heat Flux (CHF) was computed with CFD-simulation, and compared with Tong CHF correlation and Groeneveld look-up table. A good agreement was observed between results, but CHF obtained from CFD simulation was more conservative. According to the results, Minimum Departure from Nucleate Boiling Ratio (MDNBR) was obtained as 2.12, which was compatible with its typical value. Accordingly, it could be concluded that the optimum reactor core was in the safe mode in the steady state conditions.

**Keywords:** small modular reactor (SMR), Computational Fluid Dynamics (CFD), ANSYS Fluent, MCNP code, minimum departure from nucleate boiling ratio (MDNBR), artificial neural network (ANN), genetic algorithm (GA), optimal pair pitch – fuel rod diameter

# Optimizing Parameters of a High-Efficiency Steam Condenser from a Steam-Gas Mixture with a Large Content of Noncondensing Gases

O. O. Milman<sup>a, b, \*</sup>, A. Yu. Kartuesova<sup>a, b</sup>, V. S. Krylov<sup>a, b</sup>, K. B. Minko<sup>b, c</sup>, and A. V. Ptakhin<sup>a, b</sup>

<sup>a</sup> ZAO NPVP Turbokon, Kaluga, 248010 Russia

<sup>b</sup> Kaluga State University, Kaluga, 248023 Russia

<sup>c</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

\*e-mail: turbocon@kaluga.ru

**Abstract**—A method and a program for calculating a steam condenser from a steam-gas mixture (SGM) while maintaining its velocity along the depth of the pipe bundle have been developed. At a constant velocity of the SGM, as the steam condenses, a high intensity of heat and mass transfer remains due to the dynamic effect of the flow, but there is a loss of pressure at the same time, as a result of which the saturation temperature of steam in the SGM decreases. The program was used to calculate the optimal steam velocity in a condenser with a high content of noncondensable gases. The optimization took into account the ratio between intensification heat and mass transfer with an increase in the SGM rate and decrease in temperature saturation steam in the mixture due to an increase in pressure loss. The target function was the minimum heat-transfer surface area for a given degree of vapor condensation in the tube bundle. Calculations have been carried out at a pressure of 5–30 kPa at the inlet to the tube bundle, the temperature of cooling water at the inlet to the condenser 12–30°C, water velocity in the pipes 1–4 m/s, length of pipes 4–12 m, and concentration of noncondensable gases (NCG) at the inlet 1–20% at an SGM flow rate of 1 kg/s. An assessment of the influence of deposits on the surface of pipes on the intensity of heat transfer during operation, as well as the influence of the accuracy of calculating the heat-transfer coefficient on the results of calculating the optimal speed, has been carried out. The dependences of the surface area of the heat-exchange surface on the velocity of the SGM and the dependence of the optimal velocity of the SGM on the temperature and speed of the cooling water, the condensation pressure, and other parameters have been obtained. The optimal value of the SGM velocity lies in the region of more than 40 m/s, which must be taken into account when designing capacitors.

**Keywords:** condensation, intensification, vapor-gas mixture, saturation temperature, pressure loss, noncondensable gases, optimal velocity, concentration, tube bundle, heat-exchange surface

## Thermohydraulic Test of a Model of a High-Pressure Mixing Heater

Yu. G. Sukhorukov<sup>a,\*</sup>, B. F. Balunov<sup>a</sup>, V. V. Lemekhov<sup>b</sup>, V. A. Kogut<sup>b</sup>, A. V. Proukhin<sup>b</sup>, A. A. Shcheglov<sup>a</sup>,  
F. A. Svyatkin<sup>a</sup>, A. Yu. Yurchenko<sup>a</sup>, A. S. Matysh<sup>a</sup>, A. O. Borisov<sup>a</sup>, N. A. Shorin<sup>a</sup>, and K. A. Grigor'ev<sup>a</sup>

<sup>a</sup> Polzunov Scientific and Development Association on the Research and Design of Power Equipment (NPO CKTI),  
St. Petersburg, 191167 Russia

<sup>b</sup> Dolezhal' Research and Development Institute for Power Engineering, Moscow, 107140 Russia

\*e-mail: iceo@ckti.ru

**Abstract**—The thermal cycle of the secondary circuit at an NPP with a BREST-OD-300 reactor includes a mixing feed water heater (MFWH) to heat the feedwater at the steam generator's inlet to a minimum of 340°C (to keep the lead coolant temperature above the lead pour point in the shell side of the steam generator) under all operating conditions. To substantiate the design solutions and finalize the procedure for thermohydraulic design of the MFWH at an operating pressure as high as 15 MPa, NPO CKTI conducted bench tests on an MFWH model in versions with one or two heating stages with water distribution by gravity. The experiments have confirmed that the feedwater can be heated as required in a full-scale heater. Generalization of the experimental data has demonstrated the advantage of the droplet model in describing the thermohydraulic processes in the MFWH over the jet model used to calculate the low-pressure mixing heaters (LPMH). The dependences for calculating the average diameter of water droplets and their fall velocity in a steam environment have been updated. It has been established that, at a pressure of 5–15 MPa, the time to heat droplets depends mainly on their size and the thermal conductivity of water in them. The minimum height of the heating section (the zone of free fall of water droplets in a steam environment) in the MFWH should be 0.7 m, which will provide the subcooling of water to the steam saturation temperature of less than 1°C in a heater with two heating stages.

*Keywords:* mixing feedwater heater, gravity water distribution, heat-transfer rate, subcooling, droplet model, thermal engineering experiment



# Film Cooling of a Concave Surface with Two-Row Coolant Supply in Trenches

A. A. Khalatov<sup>a, b</sup> and T. V. Donik<sup>a, b, \*</sup>

<sup>a</sup> Institute of Engineering Thermophysics, National Academy of Sciences of Ukraine, Kyiv, 03057 Ukraine

<sup>b</sup> National Technical University of Ukraine Igor Sikorsky Kyiv Polytechnic Institute, Kyiv, 03057 Ukraine

\*e-mail: doniktv@ukr.net

**Abstract**—The results of computer simulation of the film cooling efficiency on a concave surface with coolant supply through inclined round holes in shallow trenches are presented. The calculations were carried out in a range of blowing ratio  $m$  from 0.56 to 1.97 using the commercial computer package ANSYS CFX and the SST turbulence model. In the region between the trenches, the average (within an individual strip) cooling efficiency hardly changes at all in the transverse direction for all blowing ratios. Downstream of the second trench, the average cooling efficiency is nonuniform across the width of the surface and increases with the blowing ratio. The local (“point”) cooling efficiency is nonuniform across the plate and becomes more uniform with an increase in the blowing ratio. For low blowing ratios, the number of local maximums in the cooling efficiency behind the first trench is equal to the number of film cooling holes. For  $m \geq 1.12$ , the cooling efficiency is almost uniform and close to unity immediately behind the first trench, while it reduces on the side strips behind the second trench. The efficiency of film cooling on a concave surface with two trenches has been demonstrated to be 5–11% lower than that on a flat surface under the same conditions.

*Keywords:* gas turbine, two-row system, film cooling efficiency, computer simulation, blowing ratio, degree of nonuniformity

# Thermal Properties of Arv-U Graphite in the Interval of Temperatures of 293–1673 K

A. Sh. Agazhanov<sup>a, \*</sup>, D. A. Samoshkin<sup>a</sup>, Yu. M. Kozlovsky<sup>a</sup>, and S. V. Stankus<sup>a</sup>

<sup>a</sup> Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia

\*e-mail: scousekz@gmail.com

**Abstract**—The demand for the production of various grades of reactor graphite is growing every year. This is due to their active use in nuclear power. To carry out engineering calculations of temperature fields in the core and simulate the operation of the reactor in the normal mode, as well as to predict the consequences of possible extreme situations, highly reliable data on the thermophysical properties of structural carbon materials in a wide temperature range are required. However, such data, which were obtained in limited temperature ranges and with an unknown error, are fragmentary in the literature. In this work, the thermal diffusivity  $a$ , isobaric heat capacity  $c_p$ , and thermal coefficient of linear expansion (TCLE)  $\beta$  of ARV-U graphite at temperatures from room temperature to 1673 K are determined by the methods of laser flash, differential scanning calorimetry, and dilatometry. This graphite is considered as a cladding for fuel elements for neutron moderation. Thermal conductivity  $\lambda$  was calculated from the measurement results. Estimated error of the received data for  $a$ ,  $\lambda$ ,  $c_p$ , and  $\beta$  was 2–4, 3–5, 2–4, and 3%, respectively. By approximating the experimental results, expressions are constructed that describe the dependence of the studied properties on temperature and allow one to determine the thermophysical properties of ARV-U graphite with high accuracy, and they can be considered as reference values. Based on the obtained results, it was concluded that the properties of ARV-U graphite in the entire investigated temperature range change monotonically, without jumps or breaks, and are well reproduced in heating–cooling cycles. This indicates that the structure of the carbon composite remains unchanged. The comparison of the data of this work with the properties of graphite of other grades is carried out. It was confirmed that the heat capacity of graphite in the investigated temperature range is practically independent of its grade. A relationship has been established between the heat transfer coefficients ( $a$ ,  $\lambda$ ) of graphite and its macroscopic density (or porosity). The maximum difference in the density of the studied samples of 1.7% led to a difference of 13–17% in thermal diffusivity and 12–15% in thermal conductivity. A method has been developed for predicting the thermal conductivity of ARV-U graphite based on the density value at room temperature.

**Keywords:** ARV-U graphite, structural carbon material, thermal conductivity, thermal diffusivity, specific heat capacity, thermal expansion, density, error