

---

---

# Contents

---

---

**Vol. 69, No. 1, 2022**

---

---

## **Renewable Energy Sources and Hydropower**

Geothermal Energy of Russia: Resources, Electric Power Generation, and Heat Supply (a Review)

*V. A. Butuzov, G. V. Tomarov, A. B. Alkhasov, R. M. Aliev, and G. B. Badavov*

Prospects for Decreasing the Amount of Water Use by Thermal Power Plants in Russia through Application of Heat Pumps

*M. A. Treshcheva, I. D. Anikina, and D. A. Treshchev*

---

## **Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment**

Chemical Looping Combustion and Gasification of Fuels. A Review of Studies and New Process Solutions

*G. A. Ryabov*

---

## **Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment**

Experimental Studies of Airfoil Cascades with High Velocity Vector Circulation around the Airfoil

*N. G. Rodionov*

The Effect of Turbine Cascade Pitch on the Incidence Losses

*B. I. Mamaev, S. A. Poluboyarinova, and A. V. Starodumov*

---

## **Environment Protection**

Arrangements for Ensuring Reliable Continuous Instrument-Assisted Monitoring of Atmospheric Emissions of Marker Polluting Substances from Thermal Power Plants

*P. V. Roslyakov, O. E. Kondrat'eva, I. L. Ionkin, and L. E. Egorova*

---

## **Heat and Mass Transfer, Properties of Working Bodies and Materials**

Steam Explosion: Experimental Observations

*S. N. Vavilov, N. V. Vasiliev, and Yu. A. Zeigarnik*

---

## **Water Treatment and Water Chemical Mode**

Estimating the Possibility of Deferrization of Return Production Condensate of a TPP with Granulated Carbonate Sludge

*L. A. Nikolaeva*

---

---

# Geothermal Energy of Russia: Resources, Electric Power Generation, and Heat Supply (a Review)

V. A. Butuzov<sup>a, \*</sup>, G. V. Tomarov<sup>b</sup>, A. B. Alkhasov<sup>c</sup>, R. M. Aliev<sup>d, e</sup>, and G. B. Badavov<sup>c</sup>

<sup>a</sup> *Trubilin Kuban State Agrarian University, Krasnodar, 350044 Russia*

<sup>b</sup> *OOO Geoterm-EM, Moscow, 111250 Russia*

<sup>c</sup> *Institute for Geothermy and Renewable Energy, Branch of the Joint Institute for High Temperatures, Russian Academy of Sciences, Makhachkala, Republic of Dagestan, 367030 Russia*

<sup>d</sup> *Dagestan State Technical University, Makhachkala, Republic of Dagestan, 367030 Russia*

<sup>e</sup> *OOO Geokoprom, Makhachkala, Republic of Dagestan, 367030 Russia*

\**e-mail: ets@nextmail.ru*

**Abstract**—The geothermal resources of Russia have been studied since 1956. Three versions of the country's geothermal maps and estimation of geothermal field reserves with a total design yield of 218 m<sup>3</sup>/s have been developed. The largest reserves are available in Kamchatka krai, the Kuril Islands, the Republic of Dagestan, Krasnodar krai, Stavropol krai, and the Republic of Adygea. Steam-hydrothermal fields are located mainly in Kamchatka and the Kunashir Island (the Kuril Islands). In Russia, a total of 26 geothermal fields were in operation in 2019, including 11 fields in Kamchatka, four in Dagestan, and 11 in Krasnodar krai, Stavropol krai, and the Republic of Adygea. In 2019, 743500 t of geothermal steam (without the Mutnovsky and Verkhne-Mutnovsky fields) and 20.2 million m<sup>3</sup> of geothermal water were produced, including 13.9 million m<sup>3</sup> in Kamchatka, 4.3 million m<sup>3</sup>, in Dagestan, and 2.0 million m<sup>3</sup> in Krasnodar krai, Stavropol krai, and the Republic of Adygea. In 2019, 161 geothermal wells were in operation in Russia, including 84 wells in Kamchatka, 42 in Dagestan, and 35 in Krasnodar krai, Stavropol krai, and the Republic of Adygea. The Russian geothermal electric power facilities with a total capacity equal to 83.9 MW, which produced 428 million kW h of electric energy in 2019, are reviewed. The main technical characteristics and basic thermal cycle circuits of the Pauzhetka and Mutnovsky geothermal power plants (GeoPPs) are considered, and the problems connected with their operation and the prospects for their future development are pointed out. In 2019, 23 heat distribution stations (HDS) and central heat-supply stations (CHSS) with the total thermal power capacity equal to 82.5 MW and the thermal energy output equal to 282000 (MW h)/year supplied geothermal heat for regions in Russia. The total length of geothermal heat networks in the two-pipe equivalent was equal to 172 km. The specific features relating to the operation of HDSs and CHSSs are pointed out, and prospects for the future development of geothermal heat supply are determined.

**Keywords:** geothermal waters, steam-hydrothermal fields, geothermal power plant, geothermal heat-supply system, well, reinjection, heat distribution station, geological stratum

# Prospects for Decreasing the Amount of Water Use by Thermal Power Plants in Russia through Application of Heat Pumps

M. A. Treshcheva<sup>a, \*</sup>, I. D. Anikina<sup>a</sup>, and D. A. Treshchev<sup>a</sup>

<sup>a</sup> *Peter the Great St. Petersburg Polytechnic University, St. Petersburg, 195251 Russia*

*\*e-mail: milana.treshcheva@gmail.com*

**Abstract**—The article considers the main factors influencing the annual economic gain from decreasing the payment for the water use by a thermal power plant (TPP) in the case of applying heat pumps in the steam turbine condenser cooling system. For the conditions of Russia, an expected variation range of tax rates for withdrawal of water resources from a source is established depending on the TPP service cooling water system's location and type, and the potential decrease in the amounts of water use by a TPP is determined. With reference to combined cycle technologies, the maximal power capacity of the heat pump that can be installed at a combined cycle TPP is estimated subject to the condition of plant lossless operation in the Russian wholesale market of electricity and power. A tentative variation range of the heat pump unit's operation time in using thermal energy both in the TPP production processes and for heating purposes is estimated. For the conditions of Russia, the territorial distribution of the maximal expected economic gain from decreased amounts of water use owing to heat pump application in the TPP condenser cooling system is estimated. The effect the economic gain obtained from decreasing the amounts of water use has on the key indicators of an investment project on introducing a heat power unit with a thermal capacity of 50 MW at a TPP under the conditions of St. Petersburg is analyzed for different service cooling water-supply systems. The integral economic gain obtained from decreasing the amounts of water use in implementing such a project for the entire service life of the heat pump used as part of the TPP equipment is expected to be 182.7 million rubles with a once-through water-supply system, 2.6 million rubles with a circulation water system with a cooling tower, and 2.0 million rubles with a circulation water system with a pond.

*Keywords:* thermal power plants, combined cycle plants, heat supply, heat pumps, rational water use, service cooling water-supply system, steam turbine condenser, integral economic gain

# Chemical Looping Combustion and Gasification of Fuels. A Review of Studies and New Process Solutions

G. A. Ryabov\*

*All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

*\*e-mail: GARyabov@vti.ru*

**Abstract**—The current status and research and development on CO<sub>2</sub> in chemical looping combustion and gasification of fuels is analyzed. The major results presented in foreign publications are analyzed. At present, this technology is being studied in laboratory and pilot units with a maximum output of 1 MW. It has been demonstrated that the high-temperature chemical looping combustion and gasification technology with metal oxides, which are used as oxygen carriers, can be effective with respect to CAPEX and OPEX. In this type of combustion system, a metal oxide, rather than air, is used to bring oxygen to the fuel. The metal oxide, upon interaction with fuel in a fuel reactor, is reduced to a metal (or a lower oxide) with the formation of CO<sub>2</sub> and water vapor. After that, the metal is oxidized in a special reactor, and the produced oxide is returned to the cycle. The gases coming from the fuel reactor after condensation of water vapor consist of more or less pure CO<sub>2</sub>, which can be used or recycled. Data on the application of various metal oxides are reviewed and analyzed with special attention given to the investigations into the use of natural ores as oxygen carriers. It has been demonstrated that ilmenite is most suitable for this application in terms of its properties (oxygen capacity, abrasion resistance) and cost. The design and operation features of various experimental setups are examined. The main approaches to the design calculation of chemical looping combustion plants are presented. It is shown that, in addition to the properties of oxides themselves, the efficient conversion of fuels requires a sufficient residence time of particles in the reactors and their specific gravity, which are largely determined by the hydrodynamics of interconnected reactors with a fluidized bed and a circulating fluidized bed. In the process, a high circulation rate of particles between the reactors, effective capture of particles, and their stable movement in downcomers and pneumatic loop seals should be maintained. Results are presented of the investigation into the hydrodynamics of interconnected reactors and binary mixtures of particles of different density.

*Keywords:* CO<sub>2</sub> capture, chemical looping, combustion and gasification of fuels, metal oxides—oxygen carriers, fluidized bed, interconnected reactors, hydrodynamics, calculation methods, capital and operating expenditures

# Experimental Studies of Airfoil Cascades with High Velocity Vector Circulation around the Airfoil

N. G. Rodionov\*

*Kaluga Branch, Bauman Moscow State Technical University (National Research University), Kaluga, 248000 Russia*

*\*e-mail: ngr-energo@yandex.ru*

**Abstract**—The results from experimental studies of flat turbine airfoil cascades carried out at a steam setup are presented. Cascades having the same airfoil featuring an increased velocity vector circulation rate around the airfoil and also ones with modified initial airfoil versions were considered. The steam flow inlet and outlet angles for the airfoil cascades are approximately  $50^\circ/14^\circ$ ; the blade length is 100 mm, and the airfoil chord is 40.64 mm. The cascade blowing experiments were carried out at  $Re > 4 \times 10^5$ . The cascades of S-13GM airfoils were studied in a wide airfoil relative pitch variation range of 0.55–0.98 and Mach number variation range  $M \approx 0.5$ –1.1. The initial blade airfoil had a configuration close to the well-known S-5515A airfoil developed at the Moscow Power Engineering Institute (MPEI). The optimal values of the airfoil relative pitch in the cascade versus the Mach number have been determined. It has been found that there are two energy loss minimums depending on the relative pitch of such airfoils in the cascade. Some technical solutions are suggested for reducing the total energy losses in the cascade of airfoils through adjusting the steam flow by design measures. The effect of incidence angles on the energy losses in the cascade of airfoils with and without a vortex chamber on the airfoil is studied. The effect the change in some geometrical and flowrate parameters in airfoil cascades has on the steam energy losses during the flow in the interblade channel is shown. A profiled slot at blade tips and also a two-row cascade increase the energy losses. A vortex chamber made on the airfoil convex part decreases the total energy losses in the cascade by approximately 0.5–1.0% with  $M = 0.8$ –0.9 and by 3% with  $M = 1.0$ ; the decrease of total energy losses in the cascade with short blades may reach approximately 4%. Based on the geometrical similarity to the dolphin body outlines and profile smoothing methods, turbine blade airfoils have been fabricated and tested, which have shown high gas dynamic properties. The cascades assembled of airfoils of such type such show efficient performance, especially in operating on wet steam.

*Keywords:* turbine, cascades of airfoils, energy losses, experimental studies, flow alteration, turbine blades, interblade channel, vortex chamber

# The Effect of Turbine Cascade Pitch on the Incidence Losses

B. I. Mamaev<sup>a, \*</sup>, S. A. Poluboyarinova<sup>a, \*\*</sup>, and A. V. Starodumov<sup>a, \*\*\*</sup>

<sup>a</sup> Lyulka Design Bureau, Branch of PAO ODK-UMPO, Moscow, 129301 Russia

\*e-mail: boris.mamaev35@mail.ru

\*\*e-mail: poluboyarinova\_sa@okb.umpo.ru

\*\*\*e-mail: andrey.starodumov@okb.umpo.ru

**Abstract**—The results from studies of flat subsonic and transonic cascades with the convergence ratio  $C_r = 1.2–3.1$  are considered. Series with three to four cascades in each with the same airfoil profile and different relative pitches were studied: nine series with a constant blade setting angle and eleven series with a constant effective outlet angle  $\beta_{2\text{eff}}$ . The pitch variation range in the series was approximately 25% with values larger and smaller than the optimal one. The cascades were mainly tested with the incidence angle  $\Delta\beta_1$  from  $-20^\circ$  to  $20^\circ$  and flow outlet velocity  $\lambda_2 \approx 0.6–0.9$ . The experiments have shown that, for cascades with a large convergence ratio  $C_r \geq 2.9$ , the energy loss coefficient in the cascade  $\Delta\zeta = 0$  and remains unchanged in varying the pitch and with all of the studied values of  $\Delta\beta_1$  and  $\lambda_2$ . In cascades with a smaller convergence ratio, with negative  $\Delta\beta_1$  and positive  $\Delta\beta_1 \leq 5^\circ$ , it can be taken that the value of  $\Delta\zeta$  does not depend on the pitch. With  $\Delta\beta_1 > 5^\circ$ , increasing the pitch results in a growth of  $\Delta\zeta$  with decreasing the cascade convergence ratio and flow outlet velocity. The growth of losses is attributed to poorer streamlining of the airfoil profile suction side inlet section, in which the velocity peak increases. An analysis of losses has shown that the dependences  $\Delta\zeta(\bar{\tau})$  in the series can be taken to be linear. This made it possible to obtain a generalized dependence for the relative change of losses in varying the pitch as a function of  $C_r$ ,  $\Delta\beta_1$ , and  $\lambda_2$ . A study in which two cascade series with different pitches and the same airfoil profile and with airfoil profiles specially constructed for each pitch were compared using viscous flow numerical analyses for different specified flow conditions has shown that the influence of pitch on the incidence losses that has been revealed in the course of experiments can also be used in optimizing the cascades.

*Keywords:* turbine cascade, cascade airfoil profile, convergence ratio, relative pitch, incidence angle, streamlining, losses, energy loss coefficient, wind tunnel test, channel convergence ratio

# Arrangements for Ensuring Reliable Continuous Instrument-Assisted Monitoring of Atmospheric Emissions of Marker Polluting Substances from Thermal Power Plants

P. V. Roslyakov<sup>a, \*</sup>, O. E. Kondrat'eva<sup>a</sup>, I. L. Ionkin<sup>a</sup>, and L. E. Egorova<sup>a</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

\*e-mail: RoslyakovPV@mpei.ru

**Abstract**—In accordance with the Russian environmental legislation, all coal-fired thermal power plants (TPPs) producing a significant adverse effect on the environment shall be equipped with means for automatically measuring and accounting the atmospheric emissions of polluting substances and for transmitting the information on them to the state fund of state environment monitoring data. Automatic emission monitoring and accounting systems (AEM&AS) can be installed either in the gas conduits of each boiler unit and in the smoke stack. The rules of and requirements for constructing AEM&AS have been stipulated by the relevant regulation and legal acts. Nonetheless, there are still certain problems concerned with arranging continuous monitoring of polluting emissions in the operating equipment. The article discusses matters concerned with ensuring reliable instrument-assisted measurements of the content of marker substances in the flue gases from TPPs. Nonuniformity of the concentration and temperature fields of gas flow in the boiler gas conduit is a factor that introduces the largest contribution in the error of measuring the concentration of any gas mixture component. It is shown that compliance with the requirements of the Russian Federation national standard GOST R EN 15259–2015 does not seem to be possible under the actual conditions in which automatic gas conduit monitoring systems are introduced at operating power installations. Smoke stacks are an exception from this statement but subject to fulfilling a number of requirements. Single-point probes for taking gas samples in the gas conduit control section must be installed at special representative control points determined from the section calibration results. It is shown that, even though the gas conduit measurement section has preliminarily been calibrated, it is not always possible to obtain a representative point that would characterize the average integral (over the section) concentration of marker substances in the entire operating range of loads and use it for automatic monitoring of emissions. To ensure the required reliability of continuous measurements in the control section, it is recommended to install multipoint sampling probes. A procedure for calculating the geometrical characteristics of a multipoint probe that yields an averaged gas sample over its operating length is presented.

*Keywords:* thermal power plants, marker substances, atmospheric emissions, continuous instrument-assisted monitoring, reliability of instrument-assisted measurements, sampling probe

## Steam Explosion: Experimental Observations

S. N. Vavilov<sup>a, \*</sup>, N. V. Vasiliev<sup>a, b</sup>, and Yu. A. Zeigarnik<sup>a</sup>

<sup>a</sup> *Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

<sup>b</sup> *Bauman Moscow State Technical University, Moscow, 105005 Russia*

*\*e-mail: sergeynv@mail.ru*

**Abstract**—In this work, we studied the explosive fragmentation of a molten drop of sodium chloride NaCl in distilled water subcooled to saturation temperature and in water saturated with carbon dioxide in the absence of external triggering (process initiation). Explosive fission of a droplet into fragments occurred in all experiments performed with water with a temperature of 20 to 70°C, which was not saturated with gas. This phenomenon was not observed upon contact with water droplets of molten metals (lead, Rose and Wood alloys, etc.) when the explosive fragmentation was of a random (spontaneous) nature. This fact can be explained by the lower viscosity of the salt melt in comparison with the viscosity of liquid metals as well as by its solubility in water. The saturation of water with carbon dioxide prevented the occurrence of a steam explosion even when the NaCl melt droplets were in contact with water at a temperature of 15–20°C. It is assumed that the presence of a large amount of dissolved carbon dioxide in water leads to its intense release upon contact of water with the surface of an NaCl droplet, shields it from water, and prevents the development of fragmentation according to any of the most probable process models (thermoacoustic, liquid capture, destruction of the solidified crust under the action of thermoelastic forces). Based on the analysis of high-speed video filming of the process, a preliminary conclusion was made about the actual merging of the stages of triggering, fine fragmentation, and the actual vapor explosion upon contact of a molten NaCl drop with water at a temperature of 20–70°C and about the absence of a vapor explosion on drops of NaCl melt at a water temperature above 80°C.

**Keywords:** steam explosion, subcooled water, molten salt, metal melts, fragmentation, dissolved gas, triggering, high-speed video

# Estimating the Possibility of Deferrization of Return Production Condensate of a TPP with Granulated Carbonate Sludge

L. A. Nikolaeva\*

*Kazan State Power Engineering University, Kazan, 420066 Russia*

*\*e-mail: lartisanik16@mail.ru*

**Abstract**—The technology of deferrization of industrial condensate of thermal power plants and its purification from petroleum products by granular sorption materials made on the basis of carbonate sludge is proposed. Carbonate sludge is waste from the power industry formed at the stage of preliminary purification of raw water during liming and coagulation. Granular sorption material for deferrization was obtained using the following technology: sludge with particles ranging in size from 0.01 to 0.09 mm is mixed with liquid sodium glass at a mass and volume ratio of 2 : 1. Heat treatment is carried out at a temperature of 250°C for 60 min. The technological characteristics, as well as the static and dynamic exchange capacities of the granular sorption material in relation to iron cations from model solutions, have been determined. The time and coefficient of protective action of the layer of the developed material were calculated using the Shilov equation. It is shown that the hydrogen index (pH) of the filtrate corresponds to a neutral medium, and the sorption material does not introduce secondary pollution into the production condensate and meets the standard quality indicators. It is envisaged to regenerate the spent sorbent with a dilute solution of sulfuric acid with an increasing concentration from 0.5 to 2.5%, flowing countercurrent to the production condensate. A typical scheme for cleaning return industrial condensate with loading sorption material into mechanical and ion-exchange filters for deferrization is presented. The standard equipment was selected for the production of filter material at the place of condensate purification. The cost of making material and cleaning 1 m<sup>3</sup> condensate was calculated. The prevented environmental damage to the environment and the economic effect from the modernization of the technological scheme for the purification of returnable industrial condensate at the Kazan CHPP-1 have been determined.

*Keywords:* returnable industrial condensate of TPP, deferrization, granules, carbonate sludge, sorption material, purification process flow chart, regeneration