

# Contents

---

---

Vol. 69, No. 2, 2022

---

---

## Nuclear Power Plants

Modeling of Thermohydraulic Processes in a Steam Generator with Several Plugged Heat-Transfer Tubes

*V. Yu. Volkov, L. A. Goliborodo, A. A. Krutikov, and O. V. Kudryavtsev*

Simulation of Aerosol Removal from the Atmosphere of an NPP Containment using a Sprinkler System

*C. C. Savekin and Yu. B. Shmelkov*

---

## Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Oxidative Torrefaction of Some Biomass Kinds in a Fluidized Bed

*V. S. Kokh-Tatarenko, S. N. Kuz'min, A. V. Nebyvaev, R. L. Is'emin,  
A. V. Mikhalev, and O. Yu. Milovanov*

New Possibilities for Joint Calculation of a Boiler and Its Dust Systems

*V. M. Supranov, G. I. Doverman, I. G. Petrov, and K. A. Pleshanov*

Studying the Slagging Properties of Mechanically Activated Coals

*M. Yu. Chernetskii and E. B. Butakov*

---

## Energy Conservation, New and Renewable Energy Sources

The Influence of Heat Accumulators on the Performance Indicators Characterizing Joint Operation of a Boiler House and Windmill in the European North Coastal Regions

*V. A. Minin*

---

## Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants, and Their Auxiliary Equipment

Results of Rig Test and Numerical Modeling of Rotor Oscillation with Rubbing in Water-Lubricated Bearings

*V. F. Shatokhin, G. V. Golobokov, and O. V. Orlov*

---

## Heat and Mass Transfer, Properties of Working Bodies and Materials

Exhaustion of a Steam Liquid Flow through a Channel with a Monodispersed Grain Layer

*D. P. Khramtsov, B. G. Pokusaev, D. A. Nekrasov, and A. V. Vyazmin*

---

## **Water Treatment and Water Chemistry**

The New Generation of CHP Plants: Water Chemistry and Its Support Systems

*A. B. Larin, B. M. Larin, A. V. Kirillina, S. Yu. Suslov, E. F. Nartya, and V. V. Kozlovskii*

---

About Presentation of the *Teploenergetika* Journal and Its Translated Version *Thermal Engineering*  
in Leading Abstract Databases

---

---

# Modeling of Thermohydraulic Processes in a Steam Generator with Several Plugged Heat-Transfer Tubes

V. Yu. Volkov<sup>a, \*</sup>, L. A. Goliborodo<sup>a</sup>, A. A. Krutikov<sup>a</sup>, and O. V. Kudryavtsev<sup>a</sup>

<sup>a</sup> OKB Hidropress, Podolsk, 142103 Russia

\*e-mail: volkov\_yu@grpress.podolsk.ru

**Abstract**—Experience with the operation of nuclear power plant (NPP) steam generators (SGs) has shown that the main factor determining the technical condition and actual service life of a steam generator (SG) is the condition of the heat-transfer tubes, which belong to the parts of a steam generator that cannot be replaced or restored. Corrosion defects in heat-transfer tubes initiate and grow during operation of power units. This can lead to depressurization of the primary circuit of the nuclear power plant and primary-to-secondary leakage during on-load operation of the reactor unit. When this leakage in the steam generator exceeds a certain standard value, the power unit is shut down for unscheduled inspection of heat-transfer tubes for integrity. To ensure safe operation of the power unit and to avoid unscheduled shutdown of the reactor unit, the heat-transfer tubes are subjected to nondestructive examination, the results of which are used to plug faulty tubes. This paper presents the results of the development and validation of the thermohydraulic CFD model of the NPP primary circuit in the PGV-1000M steam generator, taking into account the three-dimensional effects in the steam generator headers. To simulate the thermohydraulic processes in heat-transfer tubes of a steam generator heat-transfer tubes in the STAR-CCM+ code, a one-dimensional flow and heat-transfer model describing changes in the thermohydraulic parameters of the coolant only along the length of the tubes is implemented in the STAR-CCM+ code. Thermohydraulic calculations of a steam generator with several plugged heat-transfer tubes and the analysis of the effect of their location on the thermohydraulic characteristics of the steam generator under rated operating conditions of the reactor unit have been performed. The results of optional calculations were obtained using the CFD model of the primary SG circuit when varying the number of plugged heat-transfer tubes and their location. The effect of the number of plugged tubes and their location on hydrodynamics and heat transfer in the considered SG has been analyzed.

*Keywords:* steam generator, nuclear power plant (NPP), CFD, mathematical modeling, heat-transfer tube plugging, hydrodynamics, heat transfer

# Simulation of Aerosol Removal from the Atmosphere of an NPP Containment using a Sprinkler System

C. C. Savekin<sup>a,\*</sup> and Yu. B. Shmelkov<sup>a</sup>

<sup>a</sup> National Research Center Kurchatov Institute, Moscow, 123182 Russia

\*e-mail: starsavrus@gmail.com

**Abstract**—In the course of accidents at a nuclear power plant (NPP) beyond the design basis, radioactive fission products enter the atmosphere of the containment shell and then are released into the environment through leaks and the ventilation system. The release of radioactive substances is one of the key factors that determine the radiation consequences of an accident and, as a consequence, the safety of a nuclear power plant. Within the framework of the concept of managing beyond design basis accidents at NPPs with a pressurized water reactor (VVER), a sprinkler system is one of the safety systems used, among other things, to mitigate the consequences of beyond design basis accidents when radioactive fission products (FP) are released. The main functions of the sprinkler system are to reduce the pressure of the environment in the accident localization zone and remove heat from it and to reduce the concentration of radioactive substances (iodine in molecular and organic forms and aerosol particles) in the premises of the accident localization zone. Thus, the description of the process of removing radioactive fission products from the atmosphere of the containment shell of a nuclear power plant becomes an important task in the numerical modeling of beyond design basis accidents. This paper presents models of the main mechanisms for removing aerosol particles from the atmosphere of the containment by water droplets of a sprinkler system as well as the results of validation of these models in the TOSQAN and CSE experiments using the IRKA and MAVR-TA codes developed at the Kurchatov Institute.

**Keywords:** fission products, aerosols, beyond design basis accidents, sprinkler system, emergency, accident management, NPP safety systems, containment

## **Oxidative Torrefaction of Some Biomass Kinds in a Fluidized Bed**

**V. S. Kokh-Tatarenko<sup>a,\*</sup>, S. N. Kuz'min<sup>a</sup>, A. V. Nebyvaev<sup>a</sup>, R. L. Is'emin<sup>b</sup>,  
A. V. Mikhalev<sup>b</sup>, and O. Yu. Milovanov<sup>b</sup>**

<sup>a</sup> *Tambov State Technical University, Tambov, 392000 Russia*

<sup>b</sup> *OOO Chistaya Energiya, Tambov, 392032 Russia*

*\*e-mail: penergy@list.ru*

Abstract—Recent years have seen increasingly growing attention to decarbonizing the energy sector and decreasing, owing to this policy, the consumption of fossil fuels. Since recycling of waste is among the urgent problems at present, then, seeing that biomass accounts for a significant fraction of waste, efforts taken to more efficiently use it as fuel are becoming of issue. Torrefaction is one of the most acceptable technologies for obtaining high-quality fuel from biomass, the application of which makes it possible to increase the heating value of biofuel, decrease its hydrophilicity, and improve its grindability, all with relatively moderate energy expenditures. The torrefaction process can be further improved by performing it in a gaseous medium with some content of oxygen. This will make it possible to decrease both the energy expenditures for conducting the process and the time taken to perform it. The article presents the results from studying the oxidative torrefaction of three kinds of finely dispersed biomass: ground sunflower husk, chicken litter, and wood sawdust. The process is performed in a fluidized bed with biomass fluidization by subjecting it to smoke gases at a temperature of 250°C and with the oxygen content equal to 2–3 vol %. The study results have shown that, given the polydispersed composition and complex shape of biomass particles, their stable fluidization is possible in a rather narrow range of gas velocities. The oxidative torrefaction process itself takes from 5 to 15 min for its completion, depending on the biomass kind. Such a wide interval of time is due to the presence or almost complete absence of exothermal reactions developing in the process depending on the kind of raw material used. The maximal and minimal exothermal effects take place in performing oxidative torrefaction of sunflower husk and chicken litter, respectively.

*Keywords:* biomass, oxidative torrefaction, fluidized bed, exothermal effect, torrefaction process duration, efficiency improvement, energy expenditures, fluidized state

# New Possibilities for Joint Calculation of a Boiler and Its Dust Systems

V. M. Supranov<sup>a, \*</sup>, G. I. Doverman<sup>b, \*\*</sup>, I. G. Petrov<sup>b</sup>, and K. A. Pleshano<sup>a</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> OOO OPTSIM-K, Moscow, 117534 Russia

\*e-mail: svm-mpei@mail.ru

\*\*e-mail: doverman@optsim-k.com

**Abstract**—Modern pulverized coal boilers and individual pulverization systems serving them are distinguished by high complexity, high metal consumption, and a wide range of physical and chemical processes occurring in them. The components of the drying agent or transport medium are formed from the heating media used in the boiler. The withdrawal of a part of the heat carriers from the boiler ducts into the pulverization systems affects the course of heat exchange processes and, ultimately, the boiler efficiency and fuel consumption. As a result, dust systems have a significant impact on the thermal operation of the boiler, while the boiler itself impacts the operation of the dust systems. If the thermal calculation of the boiler is carried out without taking this circumstance into account, the error in the flue gas temperature can reach 25–30°C and 1.5–2.0% in terms of efficiency. Therefore, when designing new or when studying the operation of existing boiler plants, the urgent task is to carry out a joint thermal calculation of a pulverized coal boiler and its dust systems, which is practically impossible without the use of computer programs. Until now, two programs were used in Russia for this: one for the thermal calculations of the boiler and the other for calculating the dust systems, while the communication between them was carried out by the user. But such a technology for conducting a joint calculation has many disadvantages; they are indicated in the article. An analysis of these shortcomings shows that most of them can be eliminated if the joint calculation of the boiler and dust systems is performed in one program. Software package Boiler Designer, widely used both in Russia and abroad, is built on an object-oriented principle, which allows its expansion through the creation of new elements. The Vacuum System element was developed and a new version of the program was released, allowing this joint calculation to be carried out. Large-scale testing of the program was successful and showed that it became easier, more convenient, and faster to carry out the calculation than using the old technology using two programs. At the same time, labor intensity is reduced by at least two times.

*Keywords:* pulverized coal boiler, pulverizing systems, coal, heat calculation, joint calculation, calculation programs, Boiler Designer

# Studying the Slagging Properties of Mechanically Activated Coals

M. Yu. Chernetskii<sup>a, \*</sup> and E. B. Butakov<sup>a</sup>

<sup>a</sup> *Institute of Thermal Physics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

<sup>\*</sup>*e-mail: micch@yandex.ru*

**Abstract**—Intense mechanical pretreatment of coal is among promising technologies in thermal engineering owing to its ability to achieve essentially higher coal reactivity. In being subjected to such treatment, the coal's mineral part becomes significantly transformed, and a change occurs in the gas and ash flows during combustion, which may result in either lower or higher fouling of the boiler's heating surface. Till now, there have been no activities in the world practices on studying the effect that the “mechanical activation” of coals has on the deposit formation intensity. For coals characterized by different degrees of metamorphism, specifically, brown coal from the Kansk–Achinsk basin and black coal from the Ekibastuz basin, regularities pertinent to the change in the slagging onset temperature after pulverization in mills having different degrees of energy intensity are established. Results from studying the slagging intensity in burning the dust of brown coals after their having been pulverized in a disintegrating mill are given. The numerical analyses were carried out by applying the universal SigmaFlow CFD software package. The mathematical model used in carrying out the studies comprised the submodels of a reacting turbulent gas flow and models of motion, heat transfer, coal particle combustion, and slag deposit formation. For taking into account the specific features pertinent to the combustion of “mechanically activated” coals, the model was supplemented with the reaction properties, volatile release rates, and coal residue burning rates. The numerical analyses of slagging intensity in burning pulverized brown coals have shown that the slagging onset temperature becomes by 40–60°C higher after having been pulverized in a disintegrator.

**Keywords:** pulverized coal fuel, slagging, disintegrator, “mechanical activation”, numerical modeling, slagging index, slagging onset temperature, incident flow

# The Influence of Heat Accumulators on the Performance Indicators Characterizing Joint Operation of a Boiler House and Windmill in the European North Coastal Regions

V. A. Minin\*

*Center for Power Engineering Physical and Technical Problems of the North, Kola Scientific Center,  
Russian Academy of Sciences, Apatity, Murmansk oblast, 184209 Russia*

*\*e-mail: v.minin@ksc.ru*

**Abstract**—An assessment of the wind potential in the western sector of Russia's arctic zone is given, which testifies that there is high wind intensity in the Barents Sea and White Sea coastal regions. According to the meteorological stations data, the annual average wind velocities in this zone are in the range from 5 to 8 m/s at a height of around 10 m, which is an obvious prerequisite for using windmills in the power and heat-supply systems of remotely located consumers in the north. Another important prerequisite is that there is a winter maximum of wind intensity, which coincides with the winter maximum of energy demand for space heating needs. This helps incorporate the wind energy into the space heating load schedule, decrease the heating boiler house operation time, and achieve essential fuel saving. Based on the results from synchronous observations of the outdoor air temperature and wind velocity in the Kola Peninsula's northern coast, which determine the heat consumption amounts, the annual heating load schedule of coastal consumers is considered, and the possible participation of a boiler house and windmills in covering this schedule is shown. Based on the study results, it has been evaluated whether it is feasible to supplement the heat-supply scheme with heat accumulators that can store energy surpluses in the strong wind periods and then produce them, in the periods of low wind power, for covering the heating load schedule, as necessary. The incorporation of heat accumulators makes it possible to utilize the wind energy to a fuller extent, to minimize its idle rejections, decrease the boiler house operation time, and achieve lower fuel consumption and operation costs.

*Keywords:* European north of Russia, wind energy, heat supply, boiler house, windmill, heat accumulator



# Results of Rig Test and Numerical Modeling of Rotor Oscillation with Rubbing in Water-Lubricated Bearings

V. F. Shatokhin<sup>a,\*</sup>, G. V. Golobokov<sup>a</sup>, and O. V. Orlov<sup>a</sup>

<sup>a</sup> PAO Kaluga Turbine Works, Kaluga, 248010 Russia

\*e-mail: shatokhin\_vf@paoktz.ru

**Abstract**—The design of water-lubricated journal bearings and the results of bench tests of a turbine generator rotor that ended in bearing damage are described. A program module has been developed for mathematical modeling of rotor oscillation with rubbing against the bearing. This process was modeled for different values of the flexibility and damping in the supports and of the sliding friction coefficient at rubbing points. Considerable attention was given to the potential risk of an accident developing into a catastrophic failure, determined by the development of asynchronous rolling of rotor over the stator elements (stator). The risk of rotor rubbing against the stator is the development of the forces of contact interaction of the rotor with the stator causing the self-excited vibrations of the rotor—supports system. The nature of these forces is related to the appearance of sliding friction at the rotating rotor-to-stator contact point. The contact interaction forces caused by the rotor-stator rubbing are governing ones as compared to other vibration excitation forces. A short time interval for development of the asynchronous rolling determines its explosive nature. It has been demonstrated that an increase in flexibility and damping of the supports does not facilitate the development of a pattern of the rotor contact interaction with a bearing— asynchronous rolling, which is dangerous to the construction integrity. With flexible supports and energy losses in the dampers, the vibrations with rubbing give rise to synchronous rolling generation with pressure forces acting on the bearings, which will not be dangerous to the construction until the machinery protection system operates in response to excessive peak-to-peak vibrations. ADP-2400 shock absorbers, whose dynamic impact properties had been determined in a shock-testing machine, were selected as dampers for the supports. With more rigid bearings and no damping, the rubbing induces the asynchronous rotor rolling over the bearing with pressure forces acting on the bearings that are dangerous for their integrity.

**Keywords:** rotor, stator, bearings, seals, casing, dampers, friction pair, antifriction coating, synchronous and asynchronous rolling, rolling excitation forces

# Exhaustion of a Steam Liquid Flow through a Channel with a Monodispersed Grain Layer

D. P. Khramtsov<sup>a, b, \*</sup>, B. G. Pokusaev<sup>a</sup>, D. A. Nekrasov<sup>a</sup>, and A. V. Vyazmin<sup>b</sup>

<sup>a</sup> *Moscow Polytechnic University, Moscow, 107023 Russia*

<sup>b</sup> *MIREA - Russian Technological University, Moscow, 119454 Russia*

*\*e-mail: dp@khramtsov.net*

**Abstract**—The authors performed 3D numerical simulation of the unsteady outflow of a two-phase liquid-vapor flow from a tube with spherical monodisperse filling. The numerical model was developed by the smoothed particle method, and its verification was carried out using experimental data on the motion of a bubble flow in a tube. The minimum size of smoothed particles and their required number to build a correct computational model have been determined. Structural and hydraulic characteristics of the flow in the presence of phase transitions have been obtained. The calculated data on the three-dimensional spatial distribution of the vapor phase and pressure losses both over the cross section of the unit cell formed by the dispersed backfill and along the entire length of the channel are given. The analysis of the dynamics of changes in pressure losses along the length of the tube has been carried out; two characteristic sections with different dynamics of the growth of pressure losses have been found. Data were obtained on the distribution of the volumetric steam content in the tube at its various positions: horizontal, vertical, and with an inclination of 45°. The influence of the angle of inclination of the tube on the character of the distribution of steam over its cross section is shown. In this case, the greatest difference in the structure is observed between the vertical and horizontal positions. It has also been demonstrated that its structure tends to be homogeneous as the flow moves. The calculation model used made it possible to determine pressure loss in the working section from the inlet of the vapor-liquid flow into the tube to the outlet under conditions corresponding to the onset of the critical flow regime. Comparison of the results of numerical calculations, including the critical mass flow rates at the outflow of a vapor-liquid flow from the tube, with the available experimental data and previously obtained results of analytical studies, noted their good match.

**Keywords:** critical flows, granular bed, computational fluid dynamics, two-phase flows, phase transitions, monodisperse backfill, volumetric vapor content

## The New Generation of CHP Plants: Water Chemistry and Its Support Systems

A. B. Larin<sup>a, \*</sup>, B. M. Larin<sup>a</sup>, A. V. Kirillina<sup>b</sup>, S. Yu. Suslov<sup>b</sup>, E. F. Nartya<sup>b</sup>, and V. V. Kozlovskii<sup>b</sup>

<sup>a</sup> *Ivanovo State Power Engineering University, Ivanovo, 153003 Russia*

<sup>b</sup> *OOO Vodnye Tekhnologii Inzhiniring, Moscow, 115280 Russia*

*\*e-mail: yaandy\_81@mail.ru*

**Abstract**—The quality of the coolant at combined heat and power plants (CHPPs) can be improved by upgrading the water chemistry and its support systems. In the context of this problem, we should analyze the experience gained in operating the equipment, determine the advantages and disadvantages of the employed technologies and apparatuses, and propose promising solutions with the maximum use of reliable and environmentally friendly materials and process developments. A new water chemistry based on amine-containing reagents has been mastered at Russian CHPPs. The paper presents examples of the use of domestic complex reagents under the VTIAMIN brand, which differ from imported equivalents in composition and have been tested in actual applications at CHPPs, in implementing the proper water chemistry in the main and auxiliary coolant circuits. Membrane-based water treatment plants (WTPs) are used at CHPPs together with conventional WTPs. The results of the inspection of several WTPs at CHPPs are presented, and schemes combining ion-exchange and membrane processes are proposed to decrease the consumption of reagents and reduce the amount of effluents with a high process reliability of the equipment. Promising information technologies are widely applied at CHPPs. The potential is demonstrated for developing digital systems for chemical-process monitoring of the water chemistry based on the new generation of Russian-made analyzers.

**Keywords:** CHPP modernization, amine-based water chemistry, promising water treatment, chemical monitoring of water heat carrier, monitoring system of a new generation

---

---

## О ПРЕДСТАВЛЕНИИ ЖУРНАЛА “ТЕПЛОЭНЕРГЕТИКА” И ЕГО ПЕРЕВОДНОЙ ВЕРСИИ THERMAL ENGINEERING В ВЕДУЩИХ РЕФЕРАТИВНЫХ БАЗАХ

DOI: 10.1134/S0040363622020084

По итогам публикационной активности изданий, представленных в базе “Российский индекс научного цитирования” (РИНЦ) за 2020 г., теоретический и научно-практический журнал “Теплоэнергетика” добился прогресса по большинству показателей, характеризующих авторитет и состоятельность периодических изданий ([https://www.elibrary.ru/title\\_profile.asp?id=8246](https://www.elibrary.ru/title_profile.asp?id=8246)).

Особенно стоит отметить существенный рост показателя Science Index, по которому строятся рейтинги в РИНЦ: он увеличился с 1.704 в 2019 г. до 2.623 в 2020 г., подняв журнал на 136-ю позицию общего рейтинга. Число цитирований статей “Теплоэнергетики” за год в 2020 г. стало самым большим с 2008 г., когда впервые был сформирован рейтинг отечественных журналов в РИНЦ, и составило 1659.

Кроме того, журнал “Теплоэнергетика” уже шестой год подряд уверенно занимает первое место в этом рейтинге по тематике “Энергетика”.

По итогам 2020 г., подведенным в международной библиографической базе Scopus, англоязычная версия журнала Thermal Engineering также заметно улучшила свои наукометрические показатели. Так, показатель SCImago Journal Rank (SJR), который используется для построения рейтингов научных изданий, за год возрос с 0.397 до 0.602.

Журнал укрепил свои позиции во втором квартале Q2 по обоим тематическим направлениям Energy Engineering and Power Technology и Nuclear Energy and Engineering. По этим направлениям Thermal Engineering занимает первое место среди журналов, выходящих в странах Восточной Европы, включая Россию.

Среди 534 отечественных журналов, представленных в базе Scopus, Thermal Engineering располагается на 16-м месте.

В 2021 г. высокий качественный уровень журнала отмечен включением Thermal Engineering в ведущую мировую библиографическую базу Web of Science.

**С сентября 2021 г. изменился порядок подачи статей в журнал “Теплоэнергетика”/Thermal Engineering**

Уважаемые авторы!

Сообщаем вам об изменениях в порядке подачи рукописей в журнал. С **сентября 2021 г.** статьи в журнал “Теплоэнергетика”/Thermal Engineering принимаются только через портал Издательства “Pleiades Publishing”: <https://publish.sciencejournals.ru/login>

Перед подачей статьи необходимо пройти процедуру регистрации на портале. Для упрощения данной процедуры можно воспользоваться *Инструкцией по регистрации авторов на портале Pleiades Publishing*, размещенной на сайте журнала в разделе “Авторам”: <http://tepen.ru/avtoram/>. Там же размещена *Инструкция по подаче статьи в журнал “Теплоэнергетика”*, регламентирующая процесс подачи рукописей и сопроводительных материалов к ним.

В случае возникновения трудностей с регистрацией на портале и/или подачей статьи рекомендуется обращаться в редакцию журнала по адресу: [teploen@mpei.ru](mailto:teploen@mpei.ru)