

# Contents

---

---

**Vol. 69, No. 3, 2022**

---

---

## General Subjects

Will the Energy Transition Be Able to Stop Global Warming and why Are Climatic Forecasts so Erroneous?

*V. V. Klimenko, A. V. Klimenko, A. G. Tereshin, and O. V. Mikushina*

---

## Automation and Heat Control in Power Engineering

Improving the Large Steam Power Unit's Automatic Control System Structures to Comply with Unit Load Control and Primary Frequency Control Requirements

*V. A. Bilenko, I. V. Tuzov, and D. Yu. Nikol'skii*

---

## Nuclear Power Plants

Development of the Water Radiolysis Model in the AERMOD Module

*D. S. Sinitsyn, D. A. Nazarov, O. V. Tarasov, N. A. Mosunova, and A. A. Sorokin*

---

## Renewable Energy Sources, Hydropower

Solar Biogas Plant Using Heat Accumulators and the Calculation Technique for the Main Units' Parameters

*A. B. Alkhasov, Ya. A. Dibirov, and K. Ya. Dibirov*

---

## Heat and Mass Transfer and Properties of Working Fluids and Materials

Numerical and Experimental Study of Loop Heat Pipe Steady-State Performance

*A. E. Belov, A. A. Velikanov, D. N. Il'mov, O. A. Nagornova, V. V. Sobolev, and N. I. Filatov*

An Analysis of Heat Transfer in Assemblies of Finned Heat-Exchange Elements

*V. D. Lychakov, M. Yu. Egorov, A. A. Scheglov, A. S. Sivovolov, A. S. Matyash, and B. F. Balunov*

---

## Environmental Protection

TPP Ashes As a Sorbent for Waste Water Purification from Ammonium Ions

*T. T. Gorbacheva and D. V. Mayorov*

---

## Water Treatment and Water Chemical Mode

Calculated Evaluation of Mass Transfer of Corrosive Hydrogen in a Steam Generator of a Sodium Water Type During Chemical Washing and in Operation

*K. G. Legkikh, V. B. Smykov, and V. F. Tyapkov*

Research into Bacterial Contamination of the Coolant of the Chemical Desalination Scheme at Kazan CHPP-1

*S. M. Vlasov, A. Yu. Vlasova, N. D. Chichirova, and O. E. Babikov*

---

## **Metals and Strength Analysis**

Morphology and Phase Composition of Oxide Films and Corrosion Product Deposits  
in the Steam Generator of a BN-800 Reactor Unit

*B. A. Gusev, A. A. Efimov, A. M. Aleshin, V. G. Semenov, V. V. Pnachuk,  
V. V. Martynov, and A. N. Maksimova*

---

The 3rd Baumann Wet Steam Conference

---

---

# Will the Energy Transition Be Able to Stop Global Warming and why Are Climatic Forecasts so Erroneous?

V. V. Klimenko<sup>a, c, \*</sup>, A. V. Klimenko<sup>b</sup>, A. G. Tereshin<sup>a, c</sup>, and O. V. Mikushina<sup>a, c</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> National University of Science and Technology MISIS, Moscow, 119049 Russia

<sup>c</sup> Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia

\*e-mail: nilgpe@mpei.ru

**Abstract**—The current state of studies aimed at forecasting the development of world energy and its influence on the planet’s atmosphere and climate is analyzed. Advantages of applying a historical-extrapolation approach to forecasting the development of world energy and other anthropogenic sources affecting the planet’s atmosphere and climate, and also comprehensive consideration of natural climatic factors and natural variability features of the global climate are demonstrated. It is shown that a pattern adequately reflecting the change in the world’s energy consumption and its carbon intensity was presented as a result of a genetic (based on the historical development regularities) world energy development forecast elaborated at the Moscow Power Engineering Institute (MPEI) more than 30 years ago. The cumulative carbon dioxide emission estimates for the period of 1990–2020 obtained using this approach are fully in line with the actual data following from the world energy statistics. By using this approach, it became possible to predict an essential transformation of the world energy balance (energy transition) at the beginning of the current century, which manifested itself in the growing role of carbon-free energy sources, primarily renewable ones. The predictions carried out in the 1990s using the MPEI’s combined climatic model, which combines the principles of dynamic and statistical modeling of the global climatic system and takes into account the effect of natural climatic factors and the climatic system’s internal features with using a genetic forecast of world energy consumption and carbon dioxide emission for the period of 1990–2020, showed an encouraging consistency with the data of observed global temperature variation dynamics. The prediction results show that the majority of the most radical energy consumption and corresponding carbon dioxide emission scenarios are in reality unfeasible, and the model predictions of global climatic changes performed according to these scenarios are also extremely unlikely. At the same time, it is stated that, to achieve the goals of preventing the average global temperature increase by more than 2°C in comparison with the preindustrial period, it is necessary, along with decreasing the consumption of fossil fuel, to develop, on significant scales, carbon dioxide absorption technologies, both biological (forest recreation, protection from forest fires, etc.) and geological (direct disposal).

**Keywords:** world energy, global climatic system, energy consumption amounts and structure, carbon dioxide emission and absorption, sulfur emissions, natural climatic factors, forecasts, scenarios, models

# Improving the Large Steam Power Unit's Automatic Control System Structures to Comply with Unit Load Control and Primary Frequency Control Requirements

V. A. Bilenko<sup>a, \*, \*\*</sup>, I. V. Tuzov<sup>a</sup>, and D. Yu. Nikol'skii<sup>a</sup>

<sup>a</sup> ZAO Interavtomatika, Moscow, 115280 Russia

\*e-mail: bilenko@ia.ru

\*\*e-mail: bilenko@intermatic.energy

**Abstract**—The first decade of the new century, from 2000 to 2010, was marked by widescale use in the Russian power industry of modern microprocessor equipment and a fundamentally new level of power unit automation implemented on the basis of this equipment, with which it becomes possible to comply with the modern power grid requirements relating to unit load control (LC) and primary frequency control (PFC). The new control systems are used in two types of power units: classic steam power units (SPUs) and combined cycle power units (CCPUs), which are new ones for the Russian power industry. The discussion in this article is limited to SPUs only. A list of 29 accomplished projects is given, the LC and PFC requirements posed to different equipment types are presented, and the technical solutions developed by ZAO Interavtomatika for improving the dynamic characteristics of once-through boiler units for fulfilling the LC and PFC requirements are considered in detail. Unlike the conventional solutions involving separate consideration of the power unit's main automatic control loops, a unified general structure of the automatic frequency and power control system (AFPCS) is proposed, which includes five main process groups: automatic frequency and power control proper, control of water and fuel flowrates, maintaining of the boiler temperature operation mode, the automatic control system (ACS) of coal-pulverization systems for coal-fired power units or fuel controllers for gas-and-oil-fired power units, and the boiler gas—air path ACS. The suggested version of presenting information for online indication of the automated power unit's current operation mode is recommended.

**Keywords:** AFPCS, LC, PFC, SPU, coal-fired power units, gas-and-oil-fired power units, process groups of power unit controllers, forcing, automatic closed loop control systems, process parameters

## Development of the Water Radiolysis Model in the AERMOD Module

D. S. Sinitsyn<sup>a, \*</sup>, D. A. Nazarov<sup>a</sup>, O. V. Tarasov<sup>a</sup>, N. A. Mosunova<sup>a</sup>, and A. A. Sorokin<sup>a, b, \*\*</sup>

<sup>a</sup> Nuclear Safety Institute, Russian Academy of Sciences (IBRAE RAN), Moscow, 115191 Russia

<sup>b</sup> Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

\*e-mail: [sinitcyn.dmitriy@mail.ru](mailto:sinitcyn.dmitriy@mail.ru)

\*\*e-mail: [sorokin@ibrae.ac.ru](mailto:sorokin@ibrae.ac.ru)

**Abstract**—In the case of accidents involving loss of fuel pin tightness in pressurized water reactors (specifically, their Russian version known under the brand name VVER), it is necessary to take into account their potential interaction with the radiolysis products accumulated in the coolant for correctly modeling the fission products' behavior. Since such interaction can entail generation of a significant quantity of volatile compounds, which may pose a threat in the case of release into the environment, a relevant block in the integrated code was developed, using which this phenomenon can be modeled. The article describes the water radiolysis model used in the AERMOD, which was developed for numerically analyzing radiation-chemical transformations in water occurring under the influence of ionizing radiation. By using the model, it is possible to trace changes in the concentrations of individual radiolysis products for different values of initial concentration of impurities in water and absorbed dose rate. The model is also supplemented with an interphase transfer mechanism for determining the release of volatile radiolysis products (e.g., hydrogen) into the gas volume. A method for numerically solving the obtained equation systems is presented, and the model is compared with the existing domestically developed analogs. The results obtained from validation of the model describing water radiolysis and hydrogen release into the gas gap against experimental data are given.

**Keywords:** modeling, water radiolysis, analysis model, validation, VVER, loss of tightness, fuel pins, radiation dose, interphase mass transfer, calculation error

# Solar Biogas Plant Using Heat Accumulators and the Calculation Technique for the Main Units' Parameters

A. B. Alkhasov<sup>a</sup>, Ya. A. Dibirov<sup>a, \*</sup>, and K. Ya. Dibirov<sup>a</sup>

<sup>a</sup> *Institute of Geothermal and Renewable Energy Problems, Branch of the Joint Institute for High Temperatures, Russian Academy of Sciences, Makhachkala, 367030 Russia*

*\*e-mail: jakhya@yandex.ru*

**Abstract**—The energy efficiency of existing biogas plants (BGP) can be improved using solar energy. At present, more than half of the thermal energy generated by solar collectors in solar biogas plants remains unclaimed for directly covering the technological needs of biogas plants. A schematic diagram of a bioreactor plant with two bioreactors has been developed, which allows, regardless of the seasonal and daily irregularities in the supply of solar energy, to maximize the full potential of the thermal energy generated by solar collectors to ensure all the energy consumption of the technological scheme of fermentation of the feedstock. One bioreactor is fully operational all year round and the second during a period when the amount of thermal energy generated by solar collectors exceeds the total level of thermal energy required to compensate for all energy costs for biogas production in the first bioreactor. The connection (or disconnection) of the second bioreactor is carried out by a thermocontroller with servo drives installed on the pipelines for the circulation of the coolant, the supply of a daily dose of the raw material substrate to the bioreactor, and the discharge hatch into the liquid fertilizer tank. The round-the-clock maintenance of the optimal thermal mode of biomass fermentation in each bioreactor during periods of absence of solar energy is ensured by supplying the thermal energy of the discharge of a phase-transition heat accumulator installed in a reservoir with a liquid around each bioreactor. Using the example of raw materials—cattle manure (cattle) with a thermophilic mode of fermentation—the method of calculating the optimal values of the parameters of each bioreactor of a bioreactor, the area of solar collectors, and the amount of heat storage material is considered. Implementation of the proposed biogas plant makes it possible to reduce the area of solar collectors by more than two times and by 25% the total cost of the main biogas units.

**Keywords:** biogas plants, solar collector, thermocontroller, heat accumulator, dose volume of the initial substrate, thermal energy

# Numerical and Experimental Study of Loop Heat Pipe Steady-State Performance

A. E. Belov<sup>a</sup>, A. A. Velikanov<sup>a</sup>, D. N. Il'mov<sup>a, \*</sup>, O. A. Nagornova<sup>a</sup>, V. V. Sobolev<sup>a</sup>, and N. I. Filatov<sup>a</sup>

<sup>a</sup> State Scientific Center Keldysh Center, Moscow, 125438 Russia

\*e-mail: [ilmovdn@mail.ru](mailto:ilmovdn@mail.ru)

**Abstract**—Loop heat pipes (LHPs) have all the advantages of conventional heat pipes, are less susceptible to gravity effects, and offer better heat-transfer performance. They can readily be used in confined areas. As to temperature maintenance, they are self-regulating devices thereby preventing a considerable decrease in the temperature of the mounting seat of heat-releasing equipment on a heat load reduction. Miniature LHPs can replace conventional heat pipes in promising spacecrafts, while substantially increasing the ability to remove heat and reducing their weight. To develop effective methods for the design of LHPs, physical and mathematical models of conjugated heat and mass transfer in the device are required. This paper presents a procedure for the calculation of the steady-state performance of an LHP. This procedure is to be used to calculate the hydraulic resistance to the motion of liquid and vapor in LHP elements. The heat-transfer ability is determined by the ability of the capillary structure to transport the coolant against the hydraulic resistance. In the second part of the problem, the thermal condition of all elements is calculated using an approach based on the balance of heat fluxes. The model considers the potential vapor superheating in a vapor pipeline. Thermophysical properties of the coolant is calculated in each transport section as a function of the local temperature. The predictions describe the LHP performance quite accurately and agree with the results of testing an experimental loop heat pipe under various conditions at an evaporator temperature from  $-35$  to  $+25^{\circ}\text{C}$ . The tests were carried out at room temperature or in a climatic chamber, when the temperature of the radiator was almost equal to the temperature of the environment. The maximum deviation of the predicted evaporator temperature from the measured one was less than  $5^{\circ}\text{C}$  with the average deviation being below  $3^{\circ}\text{C}$ .

**Keywords:** capillary effect, capillary pump, heat pipe, loop heat pipe, spacecrafts, thermal regime maintenance system

# An Analysis of Heat Transfer in Assemblies of Finned Heat-Exchange Elements

V. D. Lychakov<sup>a</sup>, M. Yu. Egorov<sup>b, c, d, \*</sup>, A. A. Scheglov<sup>a</sup>, A. S. Sivovolov<sup>a</sup>,  
A. S. Matyash<sup>a</sup>, and B. F. Balunov<sup>a</sup>

<sup>a</sup> Polzunov Scientific and Development Association on the Research and Design of Power Equipment (NPO CKTI),  
St. Petersburg, 191167 Russia

<sup>b</sup> Peter the Great St. Petersburg Polytechnic University, St. Petersburg, 195251 Russia

<sup>c</sup> St. Petersburg State University of Aerospace Instrumentation, St. Petersburg, 190000 Russia

<sup>d</sup> St. Petersburg State Forest Technical University, Saint-Petersburg, 194021 Russia

\*e-mail: mikhail.yu.egorov@gmail.com

**Abstract**—Together with the widely used heat exchangers with an extended heat transfer surface, uniquely designed heat-exchange assemblies are also available. This paper presents the results of thermohydraulic tests of finned tube assemblies brazed from KP 20 elements of four sizes. The elements are a 0.4 mm thick plate coated with 0.025 mm thick copper film. One or two 17 mm long tapered necks are drawn in the plates. A set of cones inserted into one another forms a brazed finned tube with a toothed inner surface. To check the resistance of the brazed joint to water temperature gradients, 301 cycles of experiments were carried out to determine the temperature of the water supplied to the assembly. Each cycle differed by the water temperature at the outlet from the upper and lower tubes of the assembly and the temperature of the water and the fin metal. After the experiments, the assemblies retained their shape, dimensions, and tightness. It has been found out that the experimental results agree with the predictions by the regulatory recommended practice if a correction for the small number of rows in the tube bundle is used. The tested assemblies demonstrated high strength characteristics. High fin thickness-averaged heat conductivity at a level of 75 W/(m K) was confirmed. It has been demonstrated that the heat transfer rate increases by a factor of 2.15 as compared to the predictions for smooth tubes with a moderate increase in the hydraulic resistance caused by process protrusions on the tube inner surface. The expressions for thermohydraulic design calculations of heat exchangers consisting of similar tubes were corrected. The calculations were made using expressions from the regulations RD 24.035.05-89 “Thermal and Hydraulic Design Calculation of Heat-Exchange Equipment for Nuclear Power Plants” with amendments taking into account the high degree of finning of the tested tubes and the asymmetry of the edges of the fins relative to the axis of the pressure bearing tubes as well as the small number rows in the tube bundles.

**Keywords:** surface heat exchanger, thermohydraulic tests, brazed finned tubes, heat transfer enhancement, water/metal temperature



# TPP Ashes As a Sorbent for Waste Water Purification from Ammonium Ions

T. T. Gorbacheva<sup>a</sup> and D. V. Mayorov<sup>b, \*</sup>

<sup>a</sup> *Institute for Problems of Industrial Ecology of the North, separate subdivision of the Federal Research Center Kola Scientific Center, Russian Academy of Sciences, Apatity, Murmansk oblast, 184209 Russia*

<sup>b</sup> *Tananaev Institute of Chemistry and Technology of Rare Elements and Mineral Raw Materials, separate subdivision of the Federal Research Center Kola Science Center, Russian Academy of Sciences, Apatity, Murmansk oblast, 184209 Russia*

*\*e-mail: dvmayorov@mail.ru*

**Abstract**—A review of the use of waste from thermal power plants as secondary resources in industry and agriculture has been carried out. The results of a study of the structural-surface and physicochemical properties of ash and slag from a thermal power plant operating in an industrially developed region of the far north (the city of Apatity, Murmansk oblast) are presented. According to the data of chemical analysis, silicon and aluminum oxides predominate in their composition, the content of calcium oxide does not exceed 2.1%. It was established by the BET and BJH methods that the material has a predominantly mesoporous structure and a specific surface area of 17.8 m<sup>2</sup>/r that corresponds to the maximum observed in European medium-sized TPP plants. The phase composition of ash and slag was identified using the International Diffraction Database JCPDC-ICDD 2002; the dominance of quartz and calcium ferrite is noted in the mineral composition, but a significant part of the material is present in the X-ray amorphous state. It was found that, in terms of the main indicators, ash and slag correspond to the F-type of the international classification ASTM C 618, which makes it possible to recommend them for use as a sorbent in the treatment of domestic wastewater. The predominant extraction of the multicomponent composition of cationic forms from solutions was predicted from the pH value of the isoionic point equal to 7.63. Experimental data were obtained on model solutions in the range of concentrations of ammonium ions typical for municipal wastewaters of the city geographically adjacent to the TPP. Processing of the results obtained using the Langmuir sorption equations was carried out. The sorption capacity of ash and slag is 20.43 mg NH<sub>4</sub><sup>+</sup>/g. According to the results of experiments on the study of the kinetics of sorption on model solutions, the degree of extraction of ammonium ions when using ash and slag reaches 90% of the equilibrium concentration within 1 h, the sorption process is limited by external diffusion. An assumption is made about the expediency of using the spent sorbent, which is proposed as an ameliorant with a prolonged fertilizing effect, for the formation of bulk soils during the restoration of anthropogenically disturbed territories.

**Keywords:** ash and slag from TPP, bulk analysis, structural and surface properties, particle size distribution, X-ray phase analysis, acid-base properties, sorption capacity, ammonium ion, water treatment, domestic wastewater, Langmuir equation, sorption kinetics, bulk soil

# Calculated Evaluation of Mass Transfer of Corrosive Hydrogen in a Steam Generator of a Sodium Water Type During Chemical Washing and in Operation

K. G. Legkikh<sup>a</sup>, V. B. Smykov<sup>a, \*</sup>, and V. F. Tyapkov<sup>b</sup>

<sup>a</sup> *Leipunsky Physics and Power Engineering Institute, Obninsk, Kaluga oblast, 249033 Russia*

<sup>b</sup> *All-Russia Scientific Research Institute for Operation of Nuclear Power Plants, Moscow, 109507 Russia*

*\*e-mail: smykov@ippe.ru*

**Abstract**—For timely and prompt detection of depressurization of the “sodium–water” type steam generator in the second circuit, the hydrogen content as a product of the interaction of sodium with water is continuously monitored. During the operation of the steam generator, corrosion products accumulate on the surface of the structural material. Removal of deposits is carried out using operational chemical flushing (OCF). However, during the OCF, the corrosion rate increases significantly, which leads to an increase in the concentration of hydrogen in water and sodium. Diffusion of hydrogen from the water circuit to the sodium circuit through the walls of the steam generator tubes can affect the material (steel) of the steam generator by hydrogenation of the steel. If the established limits for hydrogen content in steel are exceeded, it becomes embrittled, which can lead to a leak in the steam generator. This problem raises concerns due to the regular OCF (one steam generator is washed every year). However, rejection of OCF is unacceptable. In order to answer the question of whether the contribution of OCF to the hydrogenation of steel is critical, it is necessary to assess the contribution of the mass transfer of corrosive hydrogen to the operating mode of the steam generator. The article presents the results of the analysis of the operational data of the BN-600 reactor plant on the hydrogen content in the washing solution and sodium in the secondary circuit during chemical washing, passivation, and start-up of the power unit. A computational and analytical assessment of the behavior of corrosive hydrogen and its mass transfer to the steam generator during chemical washes has been carried out. Estimating the hydrogenation of the pipes’ metal in the steam generator is carried out.

**Keywords:** sodium–water steam generator, operational chemical washing, electrochemical corrosion, hydrogen diffusion, hydrogen mass transfer, steel hydrogenation

## Research into Bacterial Contamination of the Coolant of the Chemical Desalination Scheme at Kazan CHPP-1

S. M. Vlasov<sup>a, \*</sup>, A. Yu. Vlasova<sup>a</sup>, N. D. Chichirova<sup>a</sup>, and O. E. Babikov<sup>a</sup>

<sup>a</sup> Kazan State Power Engineering University, Kazan, 420066 Russia

\*e-mail: vlasovsm@list.ru

**Abstract**—Thermal power plants are the largest consumer of natural water and the main sources of polluted wastewater discharge. Water serves as an irreplaceable resource in the organization of production cycles in the petrochemical industry. Water is used as a cooling agent for the final product, as a cooler for technological units and equipment, as a solvent for preparing reagent solutions, and as a source of steam and condensate. The production of chemically demineralized water at TPPs is a complex process, which involves several water-treatment plants. During operation, colonies of microorganisms can form in the water-treatment equipment of TPPs. Typically, the total bacterial count ranges between 1 and 100 million CFU/cm<sup>3</sup>. The composition and number of bacteria depend on the source of water supply, seasonality, and water-chemical regime. A list of bacteria that affect the operation of water-treatment equipment and the main methods for analyzing biological pollution at TPPs are given. A technological scheme with an operating water-treatment plant, on which industrial research on biological pollution has been carried out, is considered. The aim of the research is to determine the number of bacteria in water samples at chemical desalination units at CHPPs. The effect of bacterial contamination of ion-exchange resins, which reduces the performance of water-treatment equipment, is described. Determining the number of bacterial colonies in water samples at water-treatment plants was carried out using BART tests. As a result of the research, the values of the total microbial number determined in water samples at chemical desalination plants were obtained. The results were processed using the BARTsoft V6 software and hardware complex and various types of risks were calculated. Additional methods for water treatment are proposed on the example of Kazan CHP-1.

**Keywords:** thermal power plants, water-treatment plants, chemical desalination, ion exchange technologies, biological pollution, mixed filter, industrial research

# Morphology and Phase Composition of Oxide Films and Corrosion Product Deposits in the Steam Generator of a BN-800 Reactor Unit

B. A. Gusev<sup>a, \*</sup>, A. A. Efimov<sup>a</sup>, A. M. Aleshin<sup>a</sup>, V. G. Semenov<sup>b</sup>, V. V. Pnachuk<sup>b</sup>,  
V. V. Martynov<sup>a</sup>, and A. N. Maksimova<sup>a</sup>

<sup>a</sup> *Alexandrov Research Institute of Technology, Sosnovy Bor, 188540 Russia*

<sup>b</sup> *Institute of Chemistry, St. Petersburg State University, St. Petersburg, 198504 Russia*

*\*e-mail: gusev@niti.ru*

**Abstract**—The results of the investigation into the morphology and phase and chemical composition of protective films and corrosion products deposits that form spontaneously on the steel surface during operation of the heat-exchange equipment with the oxidizing water chemistry in the tertiary coolant circuit of a BN-800 reactor unit are reported. A comparison is made of the phase composition of protective oxide films on the working surfaces in the tertiary coolant circuit of steam generators at BN-600 and BN-800 reactor units operating with different water chemistries. It has been demonstrated that, unlike type PGV horizontal steam generators employed at power units with pressurized water power reactors, where oxide films and deposits of corrosion products in the secondary circuit are determined only by magnetite ( $\text{Fe}_3\text{O}_4$ ), films and deposits in the N-272 steam generator contain three phases: magnetite ( $\text{Fe}_3\text{O}_4$ ), hematite ( $\alpha\text{-Fe}_2\text{O}_3$ ), and lepidocrocite ( $\gamma\text{-FeOOH}$ ). A protective oxide film of magnetite (100%) is formed directly on the metal. On the film surface are formed a layer of deposits tightly bound to it and consisting of 70% of magnetite, 25–30% of hematite, 1–5% of lepidocrocite, and loose surface corrosion products deposits of corrosion products. The phase compositions of the dense layer (hematite) and loose corrosion products' deposits (hematite + lepidocrocite) on the working surfaces of the heat-transfer tubes in the N-272 steam generator correspond to the weakly alkaline oxidizing water chemistry for the tertiary circuit of the BN-800 reactor unit. It has been established that, irrespective of the type of water chemistry (oxidizing for the BN-800 reactor or reducing for the BN-600 reactor), an oxide layer of magnetite with protective properties is formed spontaneously on the surface of pearlitic steel during operation.

**Keywords:** vertical steam generator, tertiary circuit, pearlitic steels, oxidizing water chemistry, protective oxide films, corrosion products' deposits, morphology, phase composition