

# Contents

---

---

Vol. 69, No. 5, 2022

---

---

## Heat and Mass Transfer and Properties of Working Fluids and Materials

Boiling in Forced Convection of Subcooled Liquid as a Method for Removing High Heat Fluxes (Review): Part 2. Critical Heat Fluxes and Heat-Transfer Enhancement

*N. V. Vasil'ev, Yu. A. Zeigarnik, and K. A. Khodakov*

Application of a Pair of Conical Narrowing Devices for Defining the Flow Rate of Horizontal Two-Phase Water–Gas Flows in a Separationless Flowmeter

*A. Yu. Filippov and Yu. P. Filippov*

---

## Nuclear Power Stations

Study on Heat Transfer Behaviour in a Scaled Down Core Catcher using Simulant Corium Having Indirect Cooling and (Quasi) Volumetric Heat Source

*S. S. Munot, A. K. Nayak, and J. B. Joshi*

Performance Optimization for the Regenerative Feedwater Heating System of Turbine Units at Nuclear Power Plants with Type VVER Reactors

*E. N. Kulakov, V. A. Dub, Yu. V. Smolkin, and A. N. Kovalenko*

---

## Renewable Energy Sources and Hydropower

Multistage Organic Rankine Cycles: Utilization of Medium Temperature (120°C) Geothermal Fluid

*G. V. Tomarov and A. A. Shipkov*

---

## Steam Boilers, Power Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

An Experiment with Flame Combustion of a Mixture of Brown Coals at the Zheleznogorsk Combined Heat and Power Plant (CHPP)

*A. V. Zhuikov, A. I. Karlovskii, A. I. Matyushenko, P. Yu. Greben'kov, S. G. Kozlov, M. N. Vykhristyuk, and D. A. Loginov*

---

## District Heating Cogeneration and Heat Networks

Intellectualization of Heat-Supply Systems: Current State, Trends and Tasks (a Review)

*N. N. Novitskii, Z. I. Shalaginova, A. V. Alekseev, O. A. Grebneva, V. V. Tokarev, A. V. Lutsenko, and O. V. Vanteeva*

Calculation of Operating Modes of Centralized Heat-Supply Systems in Nonproject Conditions

*V. A. Petrushchenkov*

---

---

# Boiling in Forced Convection of Subcooled Liquid as a Method for Removing High Heat Fluxes (Review): Part 2. Critical Heat Fluxes and Heat-Transfer Enhancement

N. V. Vasil'ev<sup>a, b, \*</sup>, Yu. A. Zeigarnik<sup>a</sup>, and K. A. Khodakov<sup>a</sup>

<sup>a</sup> Joint Institute for High Temperatures (JIHT), Russian Academy of Sciences (RAS), Moscow, 125412 Russia

<sup>b</sup> Bauman Moscow State Technical University, Moscow, 105005 Russia

\*e-mail: nikvikvas@mail.ru

**Abstract**—The article is the second part of the review devoted to the boiling of a liquid subcooled to the saturation temperature, the process which enables the removal of heat fluxes of extremely high density. The first part presents the specific features of the process mechanism, together with its phenomenological model, and analyzes data on heat transfer and hydraulic resistance. This article is devoted to the heat-transfer crisis during subcooled boiling and the issues of heat-transfer enhancement. The heat-transfer crisis has been demonstrated to be caused by a sharp change in the flow structure involving the corresponding transformation of the heat-transfer mechanism, when the ensemble of individual bubbles is replaced with the regime of merged bubbles and vapor agglomerates, thereby causing the conditions facilitating the rupture of near-wall liquid films and the formation of dry spots increasing in size. The simplest and sufficiently effective relationship for calculating the critical heat flux ( $q_{cr}$ ) at high subcooling values is the modified empirical formula proposed by Tong. It has been concluded that it would be impractical to describe  $q_{cr}$  by a single formula in the entire range of studied subcoolings. Several processes for modifying the heating surface to enhance heat transfer and increase  $q_{cr}$  are briefly examined. Engineering problems arising in implementing these processes are discussed. The advisability of continuing comprehensive studies into the subcooled liquid boiling, primarily for understanding the physical features of the phenomenon, has been demonstrated.

*Keywords:* boiling, subcooled liquid, critical heat flux, heat-transfer enhancement, heating surface modification

# Application of a Pair of Conical Narrowing Devices for Defining the Flow Rate of Horizontal Two-Phase Water–Gas Flows in a Separationless Flowmeter

A. Yu. Filippov<sup>a, \*</sup> and Yu. P. Filippov<sup>b, \*\*</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> Joint Institute for Nuclear Research, Dubna, 141980 Russia

\*e-mail: forsc2231@gmail.com

\*\*email: fyp@dubna.ru

**Abstract**—Two methods are offered for defining the mass flow rates of two-phase flows of water–compressed gas, which are a particular case in the operation of a three-phase oil–water–gas flow meter based on a dual-isotope gamma densitometer and a conical narrowing device (ND). In the first method, when calculating the flow rates, pressure losses due to friction and the crisis of hydraulic resistance in the ND are taken into account. This method is based on a model in which the true void fraction  $\phi$  is determined using the proposed approach to find the values of the slip ratio phase slip in the ND. A feature of another method is the reasonable possibility of using a quasi-homogeneous model. In this case, the relationship between flow rates, pressure drops through the ND, thermophysical properties of the components, volumetric flow gas content  $\beta$ , and friction factor are taken into account. On the basis of experimental data and calculation methods, the effect of a geometric parameter for a pair of conical ND with diameters of 98/70 mm and 70/50 mm was analyzed. For a real flowmeter with a nominal diameter of DN 100, it is recommended to use a 70/50 mm ND; for this ND, the relationship between  $\phi$  and  $\beta$  is  $\phi = C\beta$ ,  $C < 1$ . Experimental data were obtained on the State Standard of Multiphase Flows GET195-2011 in Kazan for volumetric water flow rates from 24 to 56 m<sup>3</sup>/h and volumetric flow gas content from 0 to 70% at a temperature of approximately 20°C. The second method is preferable and allows defining the flow rates of two-phase flows with maximum relative deviations of approximately  $\pm 2\%$ . This is quite optimistic for the conditions under consideration. The possibility of the existence or absence of a hydraulic resistance crisis in both NDs is discussed.

**Keywords:** flow rate, multiphase flow, narrowing device, water-gas, gamma densitometer, friction factor, hydraulic resistance crisis, quasi-homogeneous model

# Study on Heat Transfer Behaviour in a Scaled Down Core Catcher using Simulant Corium Having Indirect Cooling and (Quasi) Volumetric Heat Source

S. S. Munot<sup>a, b, \*</sup>, A. K. Nayak<sup>a, b, \*\*</sup>, and J. B. Joshi<sup>a, c</sup>

<sup>a</sup> Homi Bhabha National Institute, Anushakti Nagar, Maharashtra, Mumbai 400094 India

<sup>b</sup> Reactor Engineering Division, Reactor Design and Development Group, Bhabha Atomic Research Centre, Maharashtra, Mumbai 400085 India

<sup>c</sup> Department of Chemical Engineering, Institute of Chemical Technology, Maharashtra, Mumbai, 400019 India

\*e-mail: samykm@barc.gov.in

\*\*e-mail: arunths@barc.gov.in

**Abstract**—To mitigate the consequence of severe accident involving core meltdown, many advanced reactors employ ex-vessel core catchers which stabilize and cool the corium for prolonged period by strategically flooding it. The cooling system for the core catcher is one of the key components in designing the core catcher. To understand the coolability of melt pool including the effects of decay heat, a simulated experiment was performed in a scaled down ex-vessel core catcher model (CCM) employing electrical heaters to simulate decay heat of 1 MW/m<sup>3</sup>. The experiment was carried out by melting about 25 litres of sodium borosilicate glass, as a mixture of corium and sacrificial material simulant, using cold crucible induction furnace at about 1200°C. The electrical heaters were turned on as the molten corium was poured in the CCM test vessel. K-type thermocouples were used to monitor melt pool temperature as well as the bulk water temperature at different locations with time. The results show that in presence of water outside of the CCM test vessel for the present geometry, coolability of melt pool including removal of decay heat is achievable with outside vessel temperatures not exceeding 100°C. A stable crust was observed at the top surface of the melt pool, which prevented water ingress into the molten corium.

**Keywords:** nuclear power plant, severe accident, melt coolability, core catcher, melt, imitator, melt cooling, heat transfer, stable crust, sacrificial material

# Performance Optimization for the Regenerative Feedwater Heating System of Turbine Units at Nuclear Power Plants with Type VVER Reactors

E. N. Kulakov<sup>a, \*</sup>, V. A. Dub<sup>b</sup>, Yu. V. Smolkin<sup>a</sup>, and A. N. Kovalenko<sup>a</sup>

<sup>a</sup> OAO Polzunov Scientific and Development Association on Research and Design of Power Equipment (NPO CKTI), St. Petersburg, 191167 Russia

<sup>b</sup> AO Atomenergoproekt, Moscow, 105120 Russia

\*e-mail: KulakovEN@ckti.ru

**Abstract**—The cost of electricity generated at a nuclear power plant (NPP) considerably depends on the NPS thermal effectiveness. An important reserve for increasing the thermal effectiveness of nuclear power plants with water-moderated water-cooled power reactors (VVER) lies in the performance optimization of the system for regenerative heating of feed water and main condensate. In this paper, this problem is formulated as applied to a promising low-speed turbine unit at NPPs with VVER reactors. According to the regulations adopted abroad and in Russia, the criterion of technical and economic efficiency, on the basis of which a decision can be made on the choice of one or another equipment configuration, is the reduced cost of electricity for the entire period of operation. It is advisable to use it when all performance indicators of power units are available and the economic conditions for the development, construction, operation, and decommissioning of the power unit, as well as the conditions for its operation in the power system during various time periods, are known. At the stages of making decisions on the thermal scheme and equipment designs, criteria are used in Russia and abroad to reduce the cost of electricity relative to a basic case. In doing so, only the cost components, which is affected in optimizing the technical solutions for the power unit, are considered. An optimization of performance indicators of the regenerative feedwater heating system is carried out in this work for a low-speed turbine unit at an NPP with type VVER reactor based on the criterion of annual economic effect. The specific of the used procedure is the determination of optimal values of the regenerative system parameters on a change in the conditions at the electricity and equipment market, operating conditions, and economic policy. Based on the calculated results, it is proposed to increase the feedwater temperature at the steam generator inlet. It has been established that it is necessary in order to improve the efficiency of a turbine plant to design low-pressure heaters with the minimum (within the process and layout limitations) subcooling to the saturation temperature due to their high thermodynamic contribution to the cycle efficiency and a relatively low cost. For the subcoolings in high-pressure heaters, technical and economic optimums have been determined. The presented procedure for technical and economic optimization may be used to determine the optimal values of the parameters of thermal power systems. The results obtained may be used by developers in designing turbine units for NPPs with type VVER reactors.

*Keywords:* VVER, turbine unit, cost of electricity, regeneration system, high- and low-pressure heaters, thermal effectiveness, parameter optimization

# Multistage Organic Rankine Cycles: Utilization of Medium Temperature (120°C) Geothermal Fluid

G. V. Tomarov<sup>a, \*</sup> and A. A. Shipkov<sup>a, \*</sup>

<sup>a</sup> *OOO Geoterm-M, Moscow, 111250 Russia*

<sup>\*</sup>*e-mail: geoatom.m@gmail.com*

**Abstract**—With a growth in the scales on which binary cycle (ORC) power units are constructed, new technical solutions aimed at improving the efficiency of binary technologies are searched for. To this end, the possibility of using multistage ORCs based on the principle of incremental (staged) conversion of geothermal fluid energy is also studied. In view of the fact that low-temperature geothermal resources dominate around the world (the fluid outlet temperature is lower than 130°C in up to 60% of all geothermal fields), the optimization calculated studies of two- and three-stage ORCs were carried out for a source geothermal fluid with a temperature of 120°C. The article presents the results of studying the effect that the choice of low-boiling organic substances and the geothermal fluid temperature in the stages have on achieving the cycle maximal power output and minimal fluid mass flowrate. The technical characteristics of two- and three-stage ORCs are compared with those of a conventional single-loop ORC power unit in the case of using various nontoxic and fire- and explosion-safe organic substances. It is shown that, by applying a three-stage process circuit with R-600 working fluid in all loops and using geothermal fluid with a temperature of 120°C, it is possible to increase the amount of heat transferred to the binary cycle by 36.5% in comparison with the single-stage process circuit. In accordance with the previously performed calculations, the growth of heat transferred to the binary cycle in the case of using geothermal fluid with a temperature of 180°C amounted to 15.0%. It has been found that the minimal (net and gross) mass flowrates of geothermal fluid with a temperature of 120°C in the three-stage process circuit are achieved in the case of using R-600 substance as working fluid in the first, second, and third stages and make 44.6 and 42.7 (kg/s)/MW, respectively. The obtained results can be used in the development and designing of multistage ORCs with the geothermal fluid temperature equal to 120°C.

*Keywords:* low-temperature geothermal fluid, binary (ORC) power units, organic working fluid, multistage ORCs, mass flowrate, power

# An Experiment with Flame Combustion of a Mixture of Brown Coals at the Zheleznogorsk Combined Heat and Power Plant (CHPP)

A. V. Zhuikov<sup>a, \*</sup>, A. I. Karlovskii<sup>b</sup>, A. I. Matyushenko<sup>a</sup>, P. Yu. Greben'kov<sup>c</sup>, S. G. Kozlov<sup>c, \*\*</sup>,  
M. N. Vykhrystyuk<sup>c</sup>, and D. A. Loginov<sup>d</sup>

<sup>a</sup> Siberian Federal University, Krasnoyarsk, 660041 Russia

<sup>b</sup> Krasnoyarsk Regional Power Company (AO KrasECO), Krasnoyarsk, 660049 Russia

<sup>c</sup> OOO SibVTI, Krasnoyarsk, 660041 Russia

<sup>d</sup> OOO Sibniugleobogashchenie, Krasnoyarsk, 660060 Russia

\*e-mail: azhuikov@sfu-kras.ru

\*\*e-mail: kozlovsg@sibvti.org

**Abstract**—The purpose of the study presented in this paper is to assess the engineering and environmental performance during the long-term operation of four BKZ-160-1.4-5 boilers on off-design fuel, consisting of 50% of Grade 2BR brown Borodino coal (with a lower heating value of  $Q^r = 11.3\text{--}16.3$  MJ/kg) and 50% of Grade 3BR brown Bol'shesyrsk coal ( $Q^r = 19.3\text{--}20.1$  MJ/kg) from the Kansk-Achinsk basin. The fuel-handling system operated normally with this mixture. The application of water washing eliminated any problems with slagging of the furnace water walls. Increasing the heating values of the coal mixture and the gross efficiency of the boilers reduced the total fuel consumption at the CHPPs. As a result of a decrease in heat losses with flue gases, the efficiency of boilers when operating on the mixture, according to the reported data on the CHPP performance, increased by 0.4%. These data also demonstrate that decreasing the heat losses with the flue gases increased the boiler efficiency by 0.4% when firing the above-mentioned mixture. The gross emission of nitrogen oxides remained at the same level, while the emission of sulfur dioxide increased by 40.6 t/month (14.4%) due to the elevated sulfur content in the fuel mixture. A lower ash content in the fuel mixture decreased the gross atmospheric emissions of solid particles by 15.1 t/month (25.2%), while the amount ash and slag wastes reduced by 1166 t/month (25.3%).

**Keywords:** boiler, brown coal, fuel mixture, heating value, flame combustion, gross efficiency, ash, harmful emissions, heating surface slagging

# Intellectualization of Heat-Supply Systems: Current State, Trends and Tasks (a Review)

N. N. Novitskii<sup>a</sup>, Z. I. Shalaginova<sup>a, \*</sup>, A. V. Alekseev<sup>a</sup>, O. A. Grebneva<sup>a</sup>,  
V. V. Tokarev<sup>a</sup>, A. V. Lutsenko<sup>a</sup>, and O. V. Vanteeva<sup>a</sup>

<sup>a</sup> *Melentiev Energy Systems Institute, Siberian Branch, Russian Academy of Sciences (ESI SB RAS), Irkutsk, 664033 Russia*

*\*e-mail: shalaginova@isem.irk.ru*

**Abstract**—The article addresses matters concerned with digitalization and intellectualization of district heating systems (DHS) and is of a reviewing and problem-stating nature. Intellectualization of DHSs is viewed as a process of transition for a fundamentally new platform, within which it becomes possible to efficiently coordinate the interests, requirements, and capacities of all stakeholders participating in the heat-supply processes, and the consumer is given the role of an active full-fledged participant. The main lines, aims, and features of this process are briefly characterized. Both domestic and foreign experience gained from setting up centralized (district) heat-supply systems, including the most advanced development trends of these systems in EU member states. Special attention is paid to matters concerned with intellectualization of Russian DHSs. It is shown that the transition for a new paradigm will generate the need to cardinaly revise the existing practices of DHS design, operation, and supervisory (dispatch) control. The key lines and tasks connected with transition to the new concept of managing the operation of DHSs as cyberphysical objects are formulated. The transition to this concept implies a wide use of mathematical and computer modeling methods for automating the DHS state monitoring processes, its analysis, prediction, and optimization. A significant part of the article is devoted to an analytical review of the current state of scientific-methodical developments in this field in four basic lines: mathematical modeling of DHS operation modes (hydraulic, temperature and thermal-hydraulic, stationary and dynamic, deterministic and probabilistic), identification of the DHS's actual state (equipment characteristics, operating parameters, etc.) based on measurement data, optimization of DHS operation modes (for estimating the effectiveness of new heat-supply technologies, efficient DHS operation, and optimal control of DHS operation modes), and software for computer modeling of DHSs. Informative statements of DHS mathematical and computer modeling tasks are described along with the background developments for solving them available at ESI SB (Russian Academy of Sciences) are described.

**Keywords:** intellectualization, digitalization, heat-supply systems, modeling, operation mode optimization, parameter identification, information and computation technologies



# Calculation of Operating Modes of Centralized Heat-Supply Systems in Nonproject Conditions

V. A. Petrushchenkov\*

*Peter the Great St. Petersburg State Polytechnic University, St. Petersburg, 195251 Russia*

*\*e-mail: pva38@mail.ru*

**Abstract**—A rational explanation of the reasons for the widespread practice of significant noncompliance with the design values of the temperature of mains water and coolant in heating devices in cold periods of the year is given. The process of forming the design load of heating systems is analyzed. It is shown that the term in the heating load, due to the heating of the supply air, should take into account different modes of operation of the premises during the day. Failure to take this fact into account leads to an overestimation of the design load of heating and all parts of the heat-supply system by up to 30%. The modes of operation of heat-supply systems with dependent connection of heating systems with elevator mixing and with their independent connection through heat exchangers at low temperatures of direct mains' water are considered. It is shown that it is possible under these conditions, with proper consideration of the standard average daily air exchange of premises for existing heat-supply systems, to switch to a reduced temperature schedule. For an overestimated estimated capacity of heat losses of buildings by 30% while maintaining high-quality regulation, examples of switching to a temperature schedule of 114–58°C for a heating system with both elevator mixing and with its independent connection to the heating network are given.

*Keywords:* typical profile of indoor air exchange, temperature schedule, regulation quality, operating characteristics