

Contents

Vol. 69, No. 7, 2022

Heat and Mass Transfer and Properties of Working Fluids and Materials

The Structure of Disperse-Annular Two-Phase Flows in a Wide Range of Reduced Pressures

V. V. Yagov and M. V. Minko 3

Spontaneous Triggering of Vapor Explosion: Results of Experimental Studies

S. N. Vavilov, N. V. Vasil'ev, Yu. A. Zeigarnik, A. V. Klimenko, and D. A. Skibin 15

Numerical Investigation into the Effectiveness of Internal Finning of a Flow-Type Metal-Hydride Reactor for Purifying Hydrogen of Impurities

M. D. Nashchekin and K. B. Minko 23

Nuclear Power Plants

Description of Models of Sodium Combustion on Premises of an NPP with a Fast Reactor Unit using the EUCLID/V2 Integrated Code and the Results of Their Validation

O. V. Tarasov, D. A. Nazarov, D. S. Sinitsyn, N. A. Mosunova, and A. A. Sorokin 38

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Myths about Lack of Competitiveness of Combined Electricity and Heat Production by Combined Heat and Power Plant Steam Turbine Units in Comparison with the Best Available Technology of Their Separate Production

S. S. Beloborodov and A. A. Dudolin 50

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Features of Primary Fragmentation of Wood Biomass During Fast Heating and Devolatilization

D. S. Litun, G. A. Ryabov, and E. A. Shorina 61

Renewable Energy Sources and Hydropower

Evaluating the Possibility of Increasing the Capacity Utilization Factor of Grid-Connected Photovoltaic Power Plants

S. E. Frid and N. V. Lisitsksaya 74

Metals and Strength Analysis

Investigation into the Influence of Jet Cavitation Impact on Changes in Characteristics of the Surface of Structural Steel 30L and 20GL

A. B. Tkhabisimov, O. S. Zilova, K. D. Skobelev, and O. V. Kalakutskaya 85

The Structure of Disperse-Annular Two-Phase Flows in a Wide Range of Reduced Pressures

V. V. Yagov^a, * and M. V. Minko^a, **

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: yagovvv@gmail.com

**e-mail: mvminko@gmail.com

Abstract—An analysis of two-phase disperse-annular flows requires verifying the intensity of droplet entrainment and deposition. Unlike conventional empirical equations, including those derived by processing large arrays of experimental data, we propose approximate physical models of entrainment and deposition of droplets. They are used to obtain semiempirical equations for calculating the liquid distribution over a channel cross-section with an accuracy to numerical coefficients whose values were found from the generalization of experimental data. The turbulent diffusion model applied in our previous works has been demonstrated to be valid for the prediction of the droplet deposition rate only in the range of high reduced pressures (above 0.45), for which fine droplets are characteristic. At moderate and low reduced pressures, the liquid deposition from the flow core onto the film is basically controlled by large droplets transported by energy-carrying turbulent vortices. The model based on this hypothesis yielded a single correlation for the fraction of liquid in the flow core at pressures below 10 MPa. This equation provides good fitting of the available experimental data on the structure of gas-liquid and single-component vapor-liquid two-phase flows and, together with the previously proposed formula for high reduced pressures, enables us to calculate the distribution of liquid in the channel section at pressures from 0.1 to 20 MPa.

Keywords: two-phase flow, disperse-annular flow, liquid film, entrainment and deposition of droplets, turbulent diffusion, energy-carrying vortices

Spontaneous Triggering of Vapor Explosion: Results of Experimental Studies

S. N. Vavilov^a, N. V. Vasil'ev^{a, b, *}, Yu. A. Zeigarnik^a, A. V. Klimenko^c, and D. A. Skibin^d

^aJoint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

^bBauman Moscow State Technical University, Moscow, 105005 Russia

^cNational University of Science and Technology (MISiS), Moscow, 119049 Russia

^dOOO S7 Space Transport Systems, Moscow, 107031 Russia

*e-mail: nikvikvas@mail.ru

Abstract—In the paper, the results of experimentally studying of spontaneous vapor explosion triggering are presented. They were obtained under model conditions when heated solid hemispherical samples were used and under laboratory conditions during the interaction of molten NaCl droplets with a distilled water pool at 15–70°C. It is shown that the development of violent, disordered 3-D perturbations (oscillations) of the vapor film surface precedes spontaneous vapor explosion triggering. Such oscillations are accompanied by vapor destruction film and the creation of local short-term contacts of hot and cold fractions and intense, explosion-like formation of a vapor phase of the volatile fraction. The experiments also showed that, under laboratory conditions, spontaneous vapor explosion at the molten droplets of usual metals and alloys (lead, tin, POS-61 solder, Wood's and Rose's alloys, etc.) occurred very seldom and researchers are forced to apply an external triggering to provide a vapor explosion. At the same time, during the interaction of NaCl melt with water spontaneous vapor explosion, triggering was practically attained with a probability of 100%. It was also shown that, during the simultaneous interaction of several NaCl melt droplets with water, the spontaneous vapor explosion triggering that has been originated at one of the droplets after a time lag of some tens of microseconds provokes explosion-like water evaporation at the other droplets also. Spontaneous triggering is accompanied by a typical sharp pressure pulse in the working medium and luminescent flashes at the molten droplet surfaces. The thesis was postulated that there is no common mechanism of fine hot fraction fragmentation, which is true for any situations and regime conditions.

Keywords: vapor explosion, subcooled water, molten salt, spontaneous triggering, high-speed video filming

Numerical Investigation into the Effectiveness of Internal Finning of a Flow-Type Metal-Hydride Reactor for Purifying Hydrogen of Impurities

M. D. Nashchekin^a and K. B. Minko^{a, *}

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: minkokb@gmail.com

Abstract—Among the directions of alternative energy development is the use of hydrogen as an energy carrier. At present, the worldwide production of relatively pure hydrogen by water electrolysis does not exceed 5%. Other methods of hydrogen production are accompanied by its contamination with impurities. At the same time, fuel cells and turbine- and engine-cooling systems require high-purity hydrogen. One of the promising and safe methods of hydrogen purification is based on its selective absorption during filtration through a layer of metal hydride. This article presents the results of a numerical study of heat- and mass-transfer processes in a flow-through metal hydride reactor for hydrogen purification with internal finning in the “active” volume (the volume of the sorption layer). To enhance heat transfer from the sorption material to the cooled or heated reactor walls, radial fins made of various metals are provided. Internal finning options and the effect of external cooling conditions on heat- and mass-transfer processes in the reactor are analyzed. The sensitivity of the calculation results to the accuracy of determining the parameters of the mathematical model is checked. It has been demonstrated that internal finning and proper selection of the external cooling conditions can considerably improve the performance of the metal-hydride system for storage and purification of hydrogen. A conclusion has been made that the density of the fins (the number of fins) and the thermal conductivity of the fin material have a noticeable effect on the efficiency of a flow reactor only when certain values of the heat-transfer coefficient to the coolant are attained on the reactor’s outside.

Keywords: flow-type metal-hydride reactor, hydrogen purification, numerical simulation, heat and mass transfer, finning efficiency, heat-transfer coefficient, permeability, heat conduction

Description of Models of Sodium Combustion on Premises of an NPP with a Fast Reactor Unit using the EUCLID/V2 Integrated Code and the Results of Their Validation

O. V. Tarasov^{a, *}, D. A. Nazarov^a, D. S. Sinitsyn^a, N. A. Mosunova^a, and A. A. Sorokin^{a, b, **}

^a Nuclear Safety Institute, Russian Academy of Sciences (IBRAE RAN), Moscow, 115191 Russia

^b Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

*e-mail: olegtarasov79@gmail.com

**e-mail: sorokin@ibrae.ac.ru

Abstract—Results are presented on the validation of the second version (V2) of the EUCLID integrated code with extended capabilities in comparison with its first version. The additional models incorporated in the code include, in particular, combustion of sodium and formation and transport of sodium combustion aerosols and fission products in the premises of a nuclear power plant during severe accidents in a fast neutron reactor. This paper describes the results of the code validation to substantiate its applicability in calculating accidents with depressurization of a coolant loop in a sodium cooled fast neutron reactor, including sodium combustion and the transport of aerosols formed from the sodium combustion products. Information is given on the models introduced in the code and the experimental data employed for the code validation. It has been demonstrated that the available experimental data are sufficient to validate the code as applicable to the above-listed phenomena. The results are outlined of the model validation against the experiments carried out in the SOLFA and CSTF experimental facilities with the combustion of a sodium puddle under different conditions: with an excess of oxygen or oxygen starvation, without or with sodium supply from a free-falling jet, without a steam source (simulation of evaporation from concrete) and with a steam source, and in a closed or ventilated room. The procedure for the analysis of uncertainty and sensitivity developed at IBRAE (Nuclear Safety Institute of the Russian Academy of Sciences) was used to substantiate the main calculated parameters, such as the temperature of sodium puddle, the rate of its combustion, and the concentration of combustion aerosols. It has been demonstrated that the deviation of these values from the experiments can be explained by the uncertainty in the input data. The applicability of the EUCLID/V2 code for modeling sodium combustion and further aerosol phenomena occurring with the sodium combustion products in the rooms of a nuclear power plant with a fast reactor has been substantiated.

Keywords: validation, fast reactor, sodium coolant, EUCLID/V2, HYDRA-IBRAE/LM, AEROSOL/LM, simulation, integrated code, aerosol

Myths about Lack of Competitiveness of Combined Electricity and Heat Production by Combined Heat and Power Plant Steam Turbine Units in Comparison with the Best Available Technology of Their Separate Production

S. S. Beloborodov^a, * and A. A. Dudolin^b, **

^a NP Energy Efficient City, Moscow, 195094 Russia

^b National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

**e-mail: enefgorod@gmail.com*

***e-mail: DudolinAA@mpei.ru*

Abstract—Factors causing degraded efficiency of existing combined heat and power plants (CHPPs) in the electricity and heat (capacity) markets, and ways of solving this problem are considered. The competitiveness of combined production at CHPPs is compared proceeding from a comprehensive analysis of economic, process, and environmental parameters for real electrical and thermal loading modes of equipment, the same amount of rendered services, and equal reliability and survivability levels of power systems, i.e., their ability to withstand emergency disturbances and prevent cascading progression of accidents with mass-scale loss of power supply to consumers. It is shown that the existing steam turbine CHPPs can compete with the best available technologies (BAT) for separate electricity and heat production. The analysis results are presented in convenient graphic form in applying a methodical approach to determining the competitiveness of combined electricity and heat production with the most up-to-date technologies for their separate production. It is proposed to introduce amendments into the existing rules of the wholesale and retail electricity and capacity markets that will make it possible to eliminate factors causing the artificial unprofitability of existing CHPPs, including termination of subsidizing the construction of new generating capacities within the framework of the CSA, RES CSA, HPP/NPP CSA, and Mod CSA programs at the expense of existing thermal generation sources. The operation of CHPP cogeneration equipment in the condensing mode should be considered as forced. The fuel consumption during CHPP operation in the condensing mode should be fully assigned to electricity production instead of allocating it to both electricity and heat. The CHPP price bids for the condensing tails should be applied proceeding from the actual fuel rates and shall not participate in the formation of marginal prices in the day-ahead market (DAM). In making strategic decisions on power system development, it is advisable to do away with using the ORGRES method (the separate production method) and the physical and thermal methods of allocating the fuel consumption between the electricity and heat supply because they yield incorrect information.

Keywords: CHPP, wholesale electricity and capacity market, fuel rate, competitiveness, cogeneration, best available technologies

Features of Primary Fragmentation of Wood Biomass during Fast Heating and Devolatilization

D. S. Litun^a, *, G. A. Ryabov^a, and E. A. Shorina^a

^a *OAO All-Russia Thermal Engineering Institute (VTI), Moscow, 115280 Russia*

*e-mail: litoun@gmail.com

Abstract—Results are presented from experimental studies into primary fragmentation of wood particles during their fast heating and devolatilization. The experimental equipment and the study procedure are described. It has been demonstrated that the probability and intensity of primary fragmentation of wood particles increases with an increase in their initial size, process temperature, and the ratio of their longitudinal and transverse dimensions. The results of experimental studies suggest that the stresses arising from the pressure of volatiles and wood shrinkage control the primary fragmentation of wood particles. Based on the study into the microstructure of coke fragments formed during primary fragmentation, assumptions were made about the mechanism of cracking and its dependence on the structure and shape of wood particles. As applied to wood biomass, it is proposed to use the ratio of the volatile yield to the specific volume of wood as a criterion of devolatilization resistance. Processing of experimental data has revealed that smaller specific volumes and, accordingly, higher devolatilization resistances facilitate primary fragmentation. An analysis of the obtained data enabled the authors to determine the main lines of further studies into the primary fragmentation of wood particles during combustion and gasification in fluidized and dense beds.

Keywords: biomass, fluidized bed, wood particles, primary fragmentation, coke residue, microstructure, gasification, pyrolysis, heat release, fluidization, volatile yield

Evaluating the Possibility of Increasing the Capacity Utilization Factor of Grid-Connected Photovoltaic Power Plants

S. E. Frid^{a,*} and N. V. Lisitsksaya^a

^aJoint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

*e-mail: s_frid@oivtran.ru

Abstract—The influence of two methods for increasing the amount of solar radiation incident on the solar power plant (SPP) photovoltaic array surface—the use of Sun tracking systems (trackers) and bifacial photovoltaic modules—on the capacity utilization factor (CUF) value is estimated for the entire territory of Russia. The CUF values are estimated for a few types of photovoltaic modules under the climatic conditions of Russia by means of dynamic simulation in the TRNSYS software system. The actinometric and climatic data from the NASA POWER long-term satellite observations database with the $1^\circ \times 1^\circ$ latitude-longitude spatial resolution were used. The photovoltaic modules were described by a five-parametric model, the parameters of which were determined from the module nameplate data provided by the manufacturers. The electricity outputs and CUF values were compared for SPPs equipped with vertical axis and tilted-axis trackers and SPPSs equipped with fixed south-oriented photovoltaic modules with different tilt angles. It has been determined that the maximal effect from the use of trackers can be achieved in the transpolar zone of Russia, where the amount of electricity generated by an SPP can be increased by 70–80%. In certain southern regions of the country, the amount of electricity generated in the case of using trackers can be increased by as much as 55%. It is shown that the best effect is obtained in the case of using fixed bifacial modules equipped with tilt-axis trackers (the increase of CUF is up to 4% abs.). By using vertically oriented bifacial modules, the CUF value can be increased to some extent in high latitudes. In moving toward lower latitudes, the gain in the CUF from using the module rear side decreases until it becomes fully compensated by the loss resulting from their non-optimal orientation.

Keywords: photovoltaic solar power plant, capacity utilization factor, Sun tracking system, tracker, bifacial photovoltaic module

Investigation into the Influence of Jet Cavitation Impact on Changes in Characteristics of the Surface of Structural Steel 30L and 20GL

A. B. Tkhabisimov^a, *, O. S. Zilova^a, K. D. Skobelev^a, and O. V. Kalakutskaya^a

^a MIREA – Russian Technological University, Moscow, 119454 Russia

*e-mail: thabisimov@mirea.ru

Abstract—The work is devoted to the study of the dynamics of changes in the surface roughness of structural steels 30L and 20GL under the cavitation effect of a liquid jet during tests according to the ASTM G134-17 standard. The research method was based on the study of the parameters of the relief and the dynamics of destruction of the near-surface layer of steel samples using metallographic analysis and the construction of 3D maps of worn surfaces. The kinetic curves of wear are presented, the change in fractograms and surface topography with increasing testing time is analyzed. Based on the change in the surface profile and the evaluation of the roughness parameters, the wear kinetics of the studied steels is revealed. It is shown that, in the period of time characterized by the maximum wear rate, there is a sharp increase in roughness after the end of the incubation period and a slowdown in growth upon reaching fluctuating, almost constant values of its parameters at a steady wear rate. The obtained range of roughness parameters in the region of the cavitation cavity of 15–20 μm for steel 30L and 20–25 μm for steel 20GL during the period with a steady wear rate can be due to the removal of a layer of constant thickness, depending on the microstructure of the materials under study. The results of the work can be used to predict the cavitation destruction of elements of hydraulic turbines and centrifugal pumps made of cast steels, based on fixing changes in the roughness parameters of their functional surfaces during operation.

Keywords: hydropower, jet cavitation, cavitation destruction, structural steels, surface roughness, profilometry, microscopy