
Contents

Vol. 69, No. 8, 2022

Nuclear Power Plants

Application of Multifunctional Systems with Latent Heat Thermal Energy Storages:
A Way to Improve NPP Safety and Efficiency

R. Z. Aminov

5

Determining the Reasons for the Appearance of Resonant Vibrations in Fresh Steam Pipelines
of Power Unit No. 1, Novovoronezh NPP-2

*R. P. Anurkin, G. V. Arkadov, V. A. Belyshko, I. O. Budko, I. N. Gusev, A. V. Kuzmin,
Yu. F. Kutdyusov, and M. T. Slepov*

14

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Studying the Casing Design Influence on the Losses in Unshrouded Turbine Blades

I. V. Afanas'ev, A. V. Granovskii, and I. A. Manaev

21

Experience in Application of Fire-Resistant Liquids in Automatic Control Systems
of Steam Turbines at TPPs

A. V. Okhlopov, D. V. Shuvarin, and K. A. Orlov

31

Heat and Mass Transfer and Properties of Working Fluids and Materials

Solution to the Problem of Convective Heat Transfer in a Toroidal Channel Using
a Curvilinear Coordinate System

N. G. Razuvanov, E. A. Belavina, O. N. Polyanskaya, and I. A. Belayev

39

Experimental Investigation into the Effect of Elastic Deformation of Plates on
the Friction Resistance of Plate Heat Exchangers

A. S. Matyash, V. D. Lychakov, and E. S. Zakira

50

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Calculation and Selection of Apparatus' Parameters for Steam Blowing the Heating Surfaces
of Steam Boilers

M. N. Maidanik and A. N. Tugov

56

Experimental Substantiation of the Sulfur Oxide Concentration Reduction Mechanism
in Coal and Biomass Particle Mixture Pyrolysis Products

S. A. Yankovskii, G. V. Kuznetsov, and A. A. Galaktionova

64

Environmental Protection

Processing of Ash and Slag Waste from Coal Fuel Combustion at the CHPP of the Arctic Zone of Russia with Obtaining Porous Geopolymer Materials

E. A. Yatsenko, B. M. Goltsman, S. V. Trofimov, and G. I. Lazorenko

72

Water Treatment and Water Chemistry

The Influence of Steel Alloying on the Flow-Accelerated Corrosion of Steels in the Loops of NPPs with VVERs

V. G. Kritskii, A. V. Gavrilov, N. A. Prokhorov, and E. A. Motkova

82

Metals and Strength Issues

Analysis of the Thermal Stress Concentration Coefficients in Tee Joints

E. R. Plotkin and T. S. Kontorovich

91

Application of Multifunctional Systems with Latent Heat Thermal Energy Storages: A Way to Improve NPP Safety and Efficiency

R. Z. Aminov*

Gagarin Saratov State Technical University, Saratov, 410054 Russia

**e-mail: oepran@inbox.ru*

Abstract—Growth in the number of nuclear reactors in power systems and their involvement in controlling the electricity consumption schedule call for the need to impose more stringent requirements for their safety. It is shown that the safety of NPPs can be enhanced, and their participation in variable power-consumption schedules can be implemented by combining them with latent heat thermal energy storages (LHTES) and an additional small-capacity steam turbine. A scheme is proposed for combining a two-loop nuclear power plant with a multifunctional thermal energy storage system (TESS) on the basis of an LHTES, with means for heating feedwater above the nominal temperature in the LHTES discharging period. With such a solution, it becomes possible to increase the live steam flowrate without changing the reactor plant output power. The proposed scheme features high thermodynamic efficiency. In addition, doing away with the steam generation system in the LHTES results in that its design becomes significantly simpler and cheaper. Thus, due to increasing the feedwater temperature in a power unit with a VVER-1000 reactor from 215 to 260°C, the additional turbine can produce up to 140 MW of electric power. A distinguishing feature of the proposed scheme is that it allows uninterrupted power supply for the NPP auxiliaries to be provided in an emergency involving loss of power supply by using the steam generated due to the decay heat produced by the shutdown reactor. This makes it possible to enhance the NPP safety level in compliance with the growing requirements set forth by the International Atomic Energy Agency (IAEA) and ensure the possibility of power unit participation in controlling the electric load schedule without changing the reactor plant's power output. Assessments of accrued net present value (ANPV) carried out with taking into account the multifunctional properties of the system being developed have shown that it has a positive value in the entire adopted range of the difference between the day and night electricity tariffs.

Keywords: nuclear power plant, safety, emergency, thermal energy storing, latent heat thermal energy storage, efficiency, additional power, plant auxiliaries

Determining the Reasons for the Appearance of Resonant Vibrations in Fresh Steam Pipelines of Power Unit No. 1, Novovoronezh NPP-2

R. P. Anurkin^{a,*}, G. V. Arkadov^b, V. A. Belyshko^a, I. O. Budko^a, I. N. Gusev^c,
A. V. Kuzmin^a, Yu. F. Kutdyusov^a, and M. T. Slepov^c

^a Energy Technologies Research Center Centrenergo, Moscow, 109507 Russia

^b Scientific and Technical Center, Obninsk, Kaluga oblast, 249031 Russia

^c Branch of Rosenergoatom Concern AO Novovoronezh NPP,
Yuzhnaya Industrial Zone, Novovoronezh, Voronezh oblast, 396072 Russia

*e-mail: info@ce91.ru

Abstract—The problem of the occurrence of increased levels of operational vibrations in the main steam pipelines of the VVER-1200 power unit and ways to reduce them are considered using the example of power unit no. 1 of the Novovoronezh NPP-2. For the first time, this problem was identified during the commissioning of power unit no. 1 of the Zaporizhzhya NPP (VVER-1000) at the stage of commissioning and power development and remained relevant for all power units with VVER-1000 series reactors. Increased vibrations of the steam pipelines of the live steam system led to various damages—the appearance of fistulas, breakage of auxiliary pipelines for fittings, etc.—and also caused a multiple decrease in the cyclic strength of the main steam pipelines and an increase in the likelihood of their cyclic destruction. In order to study the resonant vibration frequencies of the live steam pipelines of the 10LBA system and pipelines of the high-pressure bypass pipes of the 10MAA system of NVNPP-2 power unit no. 1, their mathematical model was developed. Comparison of the data obtained by measuring the natural frequencies in the course of the experimental modal analysis of the identified resonant frequencies during the vibration survey with the calculated natural frequencies of the pipelines of these systems using the developed model of the ANSYS program showed their satisfactory convergence, which made it possible to verify this ANSYS model. As a result of the modal analysis (analysis of natural forms and natural frequencies of vibrations) of the 10LBA and 10MAA systems, all natural frequencies of the systems in the range of 0–100 Hz were determined. A method is proposed to reduce the vibration of live steam pipelines of the 10LBA system and pipelines of high-pressure bypass pipes 10MAA, based on the shift of the identified natural frequencies to the high-frequency region by selecting and installing additional dampers on the pipelines of the systems at the places of maximum displacement obtained in the course of calculations on the model.

Keywords: VVER-1200, reactor plant, pipelines, vibration, resonance, vibration examination, tracing, modeling, modal analysis, natural frequency, driving force frequency, damping device

Studying the Casing Design Influence on the Losses in Unshrouded Turbine Blades

I. V. Afanas'ev^a, A. V. Granovskii^{a, *}, and I. A. Manaev^a

^a Lyulka Experimental Design Bureau, Moscow, 129301 Russia

*e-mail: andrey.granovskiy@yandex.ru

Abstract—At present, the majority of power-generating gas turbines produced by the world's leading companies have unshrouded rotor blades of all stages except the last one and a number of turbines also have the last-stage rotor blades unshrouded. This became possible owing to the advent of tip clearance monitoring and control systems, the use of which makes it possible, depending on the plant operation mode, to secure highly efficient and reliable gas turbine operation. Since almost all stages of modern gas turbines operate at high working fluid temperatures, it is necessary to take into account significant temperature stresses arising in the turbine casing components and rotor blades; these stresses give rise to deformations, which are difficult to predict in advance. In some cases, the mutual displacements of cooled nozzle vane platforms upstream and downstream of the rotor blade, and also of the casing treatment inserts give rise to ledges at the periphery of rotor blades with an open tip clearance, the streamlining of which entails the occurrence of vortex zones. These vortex zones generate additional losses at the rotor blade periphery and affect the pattern of working fluid leakage through the tip clearance. Based on the example cases modeling possible casing designs at the wheel space periphery near the rotor blades, the flow structure and the level of losses are numerically analyzed as functions of tip clearance.

Keywords: gas turbine, rotor blades, open tip clearance, temperature stresses, deformation, vortex structure, tip clearance losses

Experience in Application of Fire-Resistant Liquids in Automatic Control Systems of Steam Turbines at TPPs

A. V. Okhlopkov^{a, *}, D. V. Shuvarin^a, and K. A. Orlov^a

^a National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

*e-mail: OkhlopkovAV@mpei.ru

Abstract—Currently, in order to ensure fire safety, fire-resistant fluids are used in the electro-hydraulic control systems of high-capacity steam turbines in thermal power plants. In the Soviet Union and some other countries, fire-resistant OMTI oil, which consists of a mixture of trixylenyl phosphates, was used and similar oils have been used since the beginning of the 1990s. The accumulated experience in the use of fire-resistant liquids allows us to conclude that their quality has a significant impact on the reliability of turbine units. Improving the reliability of the oil systems of steam turbines and other thermal mechanical equipment, as well as increasing the service life of turbine oils, is of wide scientific and industrial interest. The results of long-term studies into the quality of fire-resistant liquids during their operation in automatic control systems of steam turbines of power units of combined-cycle plants located in the central and southern parts of Russia are presented. The objectives of this study were to determine the reasons for the decrease in the resource of fire-resistant liquids and the formation of proposals for updating regulatory documents for their use and quality control. The issues of ensuring the regulatory requirements for fire-resistant liquids are considered, the volumes and methods of conducting chemical analyzes of their quality are analyzed, proposals are made to adjust the instructions for operating equipment and the scope of tests, the causes of aging of fire-resistant liquids are determined, and ways to extend their service life are proposed. Based on the production experience of using imported and domestic fire-resistant liquids, conclusions were drawn about the impact of the quality of the original product and the operating mode on the quality of the oil during its operation as well as the importance of informing the responsible services of the operating organization about the compliance of the production process with the requirements of current regulatory documents.

Keywords: fire-resistant liquids, acid number, content of water-soluble acids, industrial purity class, deaeration time, varnish formation potential

Solution to the Problem of Convective Heat Transfer in a Toroidal Channel Using a Curvilinear Coordinate System

N. G. Razuvanov^a, E. A. Belavina^a, O. N. Polyanskaya^{a, *}, and I. A. Belayev^a

^a Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

*e-mail: treize@bk.ru

Abstract—A procedure is proposed for solving problems of hydrodynamics and heat transfer in coiled tubes, such as loops with smooth pipe turns and helically coiled tubes. Application of a curvilinear (toroidal) coordinate system simplifies the solution to these problems. The differential equations of mass, momentum, and energy conservation were derived for a liquid metal using the tensor analysis provisions in a generalized coordinate system. The equations with additional terms added written in a cylindrical coordinate system are taken as a basis. These terms are necessary for changing over to a new (toroidal) coordinate system. The toroidal system also has an orthogonal basis where the coordinates are also expressed by the same triple of values. The difference from the cylindrical coordinate system is that the length of the third basis vector depends on the other two space coordinates and the radius of the curvature. The method of numerical simulation in the toroidal coordinate system considerably simplifies the geometric description of the problem, construction of the computational grid, formulation of the boundary conditions, and presentation of the results. The proposed approach enables us to model problems with different curvature radii within a single generalized form. The proposed procedure yielded velocity, pressure, and temperature fields for a liquid metal turbulent flow in a toroidal (coiled) tube. The parameter of the tube curvature radius was varied in the calculations. The parametric studies performed demonstrate the principal limits of the effect of the tube curvature on the liquid metal flow hydrodynamics and heat transfer.

Keywords: toroidal coordinate system, differential conservation equations, hydrodynamics, heat transfer, liquid metals, heat-transfer coefficient, tube curvature radius

Experimental Investigation into the Effect of Elastic Deformation of Plates on the Friction Resistance of Plate Heat Exchangers

A. S. Matyash^{a, *}, V. D. Lychakov^{a, **}, and E. S. Zakira^{b, ***}

^a *Polzunov Scientific and Development Association for Research and Design of Power Equipment (NPO CKTI), St. Petersburg, 191167 Russia*

^b *OOO Zavod Elektrosevkavmontazhindustriya, Krasnodar, 350080 Russia*

**e-mail: matyash-93@yandex.ru*

***e-mail: vitalyl@yandex.ru*

****email: e.zakira@zeskmi.ru*

Abstract—To experimentally determine the coefficient of friction resistance on a large-scale bench, tests of collapsible plate heat exchangers (HE) of two benchard sizes with plate packs of three types (five configurations in total) were carried out, differing in the angle of inclination of the chevron surface of the plates. Water was used as the heat carrier during the tests. The dependence of the friction drag coefficient on the Reynolds number and the value of the critical Reynolds number corresponding to the transition from laminar to turbulent flow are obtained. A difference of up to several times in the experimental values of the friction drag coefficient for the same tested HE model at close Reynolds numbers was found. The obtained data were divided into two groups, which included similar values of the coefficient of friction resistance. It is concluded that a significant scatter of the experimental data is due to the elastic deformation of the plates caused by the pressure drop between the heat-exchanger circuits. Due to the introduction of the deformation coefficient, the dependence of the friction resistance coefficient on the Reynolds number was refined, which showed good convergence of the results obtained, combined into one group. The refined algorithm for processing experimental data made it possible to determine the coefficients and exponents included in the criterion formulas for calculating the friction resistance in the transitional and turbulent flow regimes. For each HE configuration, the values of the critical Reynolds number have been refined. The dependence of elastic deformation on the size and type of corrugation of the chevron surface has not been established. The alleged cause of the deformation, identified after disassembling the tested models, is the different depths of stamping of the chevron surface and the mechanical deformation limiter.

Keywords: heat exchangers, collapsible plate heat exchangers, coefficient of frictional resistance, hydraulic losses, elastic deformation

Calculation and Selection of Apparatus' Parameters for Steam Blowing the Heating Surfaces of Steam Boilers

M. N. Maidanik^a and **A. N. Tugov^{a, *}**

^a *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

**e-mail: ANTugov@vti.ru*

Abstract—To determine the effectiveness of the use of apparatuses for blowing heating surfaces of boilers, a generalized characteristic of the dynamic effect of a steam jet is used: its dynamic head, which depends on the parameters of the working agent, nozzle size, and layout of the apparatus. It is shown that an acceptable efficiency of steam blowing is achieved when the dynamic pressures over the entire area of the jet action are not lower than those required for effective removal of ash deposits. A method for calculating the steam flow rate and the dynamic pressure of the jets of steam blowers is given. Experimental studies and industrial experience in the use of steam blowing have shown that additional flow deceleration is observed when a jet propagates in tube bundles, as a result of which a greater drop in dynamic head can occur than with a freely propagating jet. The degree (coefficient) of weakening of the dynamic head (in relation to the dynamic head of the free jet) in any configuration of the bundle depends mainly on the width of the transverse gap between the pipes, the number of rows of pipes cleaned from deposits along the depth of the bundle, and much less on the relative longitudinal step of the pipes. It is shown that, based on estimates of the gas-dynamic parameters and the effective range of jets of steam blowers, it is possible to set the operating parameters of the steam and form the optimal arrangement of these devices for cleaning heating surfaces. To develop steam blowing systems, it is proposed to use a specialized computer program created on the basis of research results and generalization of many years of experience in operating steam blowing devices on domestic and foreign boilers.

Keywords: thermal power plant, solid fuel, boiler, heating surface, tube bundle, steam blowers, cleaning efficiency, dynamic jet pressure, steam parameters, erosive wear

Experimental Substantiation of the Sulfur Oxide Concentration Reduction Mechanism in Coal and Biomass Particle Mixture Pyrolysis Products

S. A. Yankovskii^{a, *}, G. V. Kuznetsov^{a, **}, and A. A. Galaktionova^{a, ***}

^a Tomsk Polytechnic University, Tomsk, 634050 Russia

**e-mail: jankovsky@tpu.ru*

***e-mail: kuznetsovgv@tpu.ru*

****e-mail: aag120@tpu.ru*

Abstract—The results of studies carried out by many researchers show that, in combusting mixtures of dispersed coal with biomass—even with a relatively small fraction of the latter—under conditions corresponding to the combustion process in the furnaces of steam- and hot-water boilers, the concentration of sulfur oxides in the combustion products of such mixtures (flue gases) decreases. This effect results in an essentially lower detrimental impact of coal-fired power plants on the environment. However, the mechanism through which sulfur oxides are sequestered with such combustion has not hitherto been unequivocally clarified. A few hypotheses have been formulated, according to one of which, sulfur acid vapors appear as a consequence of interaction between sulfur oxides and water vapor, followed by interaction of acid vapor with the metal oxides contained in the coal mineral part. It has been found from the results of experiments with weighted samples of wood–coal mixtures (under the conditions of densely “packed” particles) that the fraction of calcium and aluminum sulfates per unit coal mass in the ash of such mixtures after the thermal decomposition of both the components becomes completed is essentially (by a factor of 1.5–2.0) higher in comparison with that in the ash of homogeneous coal. However, the distances between individual coal and biomass particles are significantly larger in the furnace space than they are in a dense weighted sample (pour) of such mixtures. Therefore, for substantiating the sulfur oxide sequestration mechanism determined in the experiments with wood–coal mixture pours, it is necessary to confirm that the calcium and aluminum sulfates contained in the ash of wood–coal mixtures are produced under conditions in which coal and biomass particles are located at distances from each other commensurable with the size of these particles. Such experiments were carried out with mixtures of jet coal and pine wood particles at ambient medium temperatures from 400 to 800°C. It has been found that the concentrations of calcium and aluminum sulfates in the ash of mixtures after completion of pyrolysis in a closed space remain almost unchanged with increasing the distance between the fuel particles from its minimal value (with a dense contact in the mixture pour) to the value corresponding to the particle characteristic size. The deviations do not exceed $\pm 15\%$, which is insignificantly larger than the uncertainty of the experiments, in comparison with the ash produced after completion of the pyrolysis of dense pours of the same mixtures. An analysis of the results obtained from the accomplished experiments gives grounds to draw the following conclusion: the mechanism governing the sequestration of sulfur oxides produced during joint pyrolysis of coal and wood biomass particles in mixture pours corresponds to the sequestration conditions of these oxides during the pyrolysis of particles between which the distances are quite typical for the furnaces of steam- and hot-water boilers.

Keywords: coal, wood, particles, pyrolysis, elemental composition, solid combustion products, calcium and aluminum sulfates, sequestration, pour, steam- and hot-water boilers

Processing of Ash and Slag Waste from Coal Fuel Combustion at the CHPP of the Arctic Zone of Russia with Obtaining Porous Geopolymer Materials

E. A. Yatsenko^{a, *}, B. M. Goltsman^{a, **}, S. V. Trofimov^a, and G. I. Lazorenko^b

^a South Russian State Polytechnic University, Novocherkassk, Rostov oblast, 346428 Russia

^b Rostov State University of Communications, Rostov-on-Don, 344038 Russia

*e-mail: e_yatsenko@mail.ru

**e-mail: boriuspst@gmail.com

Abstract—In modern conditions, the most acute issue is improving the environmental situation around the world. One of the ways to solve it in Russia can be the disposal of ash and slag waste, since their storage in ash dumps requires huge territories, which thus fall out of the country's economic turnover. One of the promising areas for the disposal of ash and slag waste is road construction, since the development and well-being of the regions to a large extent depends on the availability and quality of a developed transport infrastructure. The main difficulties that arise in the construction and operation of roads in the Arctic zone in conditions of high humidity and permafrost are associated with an uneven increase in the volume of soil due to the freezing of the moisture contained in it. To solve this problem, heat-insulating materials are used, namely, porous geopolymers obtained by alkaline activation of aluminosilicate raw materials, such as ash and slag waste. In this work, ash and slag wastes from the Apatitskaya CHPP and Severodvinsk CHPP-1 were used. For their study, the methods of X-ray spectral fluorescence (XRF) and powder X-ray phase analysis (XRD) were used. According to the results of XRF analysis, the studied ash and slag wastes belong to the acidic category. According to XRD analysis, ash and slag wastes have a low content of crystalline phases represented by silicon dioxide (SiO₂) and hematite (Fe₂O₃). There is also an amorphous structure in the form of an alkaline and alkaline earth ferroaluminosilicate glass phase. To study the properties of geopolymers, compositions were developed using two pore-forming additives: aluminum powder and a 30% hydrogen peroxide solution. After the synthesis of geopolymers, their average densities were: 430 and 381 kg/m³ for ash and slag waste, respectively, from the Apatitskaya CHPP and 454 and 402 kg/m³, respectively, for the waste of Severodvinskaya CHPP-1. All samples of geopolymers are characterized by intense pore formation with an uneven distribution of pores. X-ray diffraction patterns of the obtained geopolymers showed a low intensity of pore formation and a low content of crystalline phases in all studied compositions.

Keywords: ash and slag wastes, geopolymers, porous structure, Arctic zone of Russia, road construction, X-ray fluorescence analysis, powder X-ray phase analysis

The Influence of Steel Alloying on the Flow-Accelerated Corrosion of Steels in the Loops of NPPs with VVERs

V. G. Kritskii^{a, *}, A. V. Gavrillov^a, N. A. Prokhorov^a, and E. A. Motkova^a

^a AO Atomenergoproekt, St. Petersburg, 197183 Russia

*e-mail: kritsky@atomproekt.com

Abstract—Ensuring the design service life of equipment and pipelines by reducing the flow-accelerated corrosion (FAC) in them and preventing deposition of corrosion products in the steam generator are among the key objectives pursued in designing the NPP's secondary coolant system. The optimization of design solutions consists in controlling the flow-accelerated corrosion processes by selecting a certain combination of inhibiting agents and using steels with the necessary alloying degree in different loop sections. To minimize the FAC during operation at elevated temperatures, it is necessary to increase the concentration of amines. To do so, a need arises to introduce a second point for metering inhibiting agents downstream of the deaerator, replace the amines used in VVER reactors by more efficient ones, or use alloyed steels for manufacturing the equipment. In view of constantly tightening environmental requirements for power units, which are designed for a service life of 60 years and longer, there is a need to decrease possible toxic water effluents in the case of using organic inhibiting agents while retaining the water chemistry (WC) quality in terms of minimal concentration of corrosion products in the steam generator's feed water. This can only be achieved by using alloyed steels for the loop sections in which inhibiting agents are unable to protect the structural material against FAC. In view of an adverse environmental impact caused by discharges of regeneration solutions from the secondary coolant working medium treatment plants, a need arises to optimize the combination of inhibiting agents and the scope of using alloyed steels in the NPP loops. The requirements for decreasing toxic water effluents prompt engineers to search for optimal solutions on selecting the type and concentration of inhibiting agents and using alloyed steels in sections where the FAC criterion is less than unity. The temperatures of coolants with different pH values in the secondary coolant circuit of NPPs with VVERs above which the FAC optimal minimization criterion is less than unity are determined. The influence of water chemistry and test conditions on the FAC ratio for different steels is considered. The correlation between the FAC ratio of steels and their chemical composition and magnetite equilibrium solubility in the coolant is shown.

Keywords: water chemistry, inhibiting agents, amines, flow-accelerated corrosion, flow-accelerated corrosion ratio of steels, mass transfer, alloying, chromium

Analysis of the Thermal Stress Concentration Coefficients in Tee Joints

E. R. Plotkin^a and **T. S. Kontorovich^{a, *}**

^a *All-Russia Thermal Engineering Research Institute, Moscow, 115280 Russia*

**e-mail: kontorovich_ts@mail.ru*

Abstract—The concentration of thermal stresses is one of the main factors leading to a decrease in thermal strength under cyclic loading conditions. It is characterized by the stress concentration factor K_t , the value of which can be determined by analytical or numerical methods as well as experimentally. In modern regulatory documents, various values of the thermal stress concentration coefficient are indicated. The results of studies carried out as part of the work on the justification of thermal and cyclic strength are presented. Their comparison with the data of current regulatory documents is given on the example of typical outlet collectors of superheaters for waste heat boilers of modern combined cycle gas turbines (CCGT). Formulas have been obtained that make it possible to calculate the concentration coefficient in a tee connection according to the known size ratios and parameters of the operating mode and to substantiate the operation modes of waste heat boilers. It is shown that taking into account a number of factors that determine the intensity of heat transfer in tee joints leads to a decrease in the concentration coefficients relative to the value of 2.0 currently accepted in some regulatory documents for all heat-transfer modes and ratios of the tee joints' dimensions. Reducing the values of the concentration factor included in the calculation when designing a part makes it possible to reduce metal consumption, lighten the design, and save money on its manufacture.

Keywords: thermal stress concentration factor, tee connection, superheater outlet manifolds, waste heat boiler, thermal strength, geometric dimensions, operating mode parameters