

Contents

Vol. 69, No. 9, 2022

General Subjects

Opportunities for the Application of Carbon Dioxide Capture and Storage Technologies in Case of Global Economy Decarbonization (Review)

S. P. Filippov and O. V. Zhdaneev

Water Treatment and Water Chemistry

Applying Film-Forming Amines for Rendering Corrosion Resistance to Structural Materials of Equipment and Piping of Power Units at Nuclear Power Plants (NPP) (Review)

V. F. Tyapkov and N. L. Kharitonova

Steam-Turbine, Gas-Turbine, and Combined-Cycle Plants and Their Auxiliary Equipment

Modeling of a Combined Cycle Gas Turbine (CCGT) Using an Adaptive Neuro-Fuzzy System

M. B. R. Rodríguez, J. L. M. Rodríguez, C. de H. Fontes

Analysis of the Efficiency of the KG2-6200 Condenser Based on Direct Measurement Data in Various Operating Modes and Simulation Results

M. Shavdinova

Nuclear Power Plants

Simulating the Behavior of Fission Product Aerosols in the Containment

D. A. Nazarov, D. S. Sinitsyn, N. A. Mosunova, and A. A. Sorokin

The New Generation of Separator-Superheaters for Steam-Turbine Units of Nuclear Power Plants (NPP) with VVER-Reactors

A. S. Shamarokov, V. M. Zorin, S. B. Pustovalov, and E. A. Mikhushkina

Heat and Mass Transfer and Properties of Working Fluids and Materials

Modern Methods for Numerical Simulation of Radiation Heat Transfer in Selective Gases (Review)

V. A. Kuznetsov

Renewable Energy, Hydropower

Results from Optimization Studies of Multistage Binary Cycles for Utilization of Low-Temperature Geothermal Heat Carrier

G. V. Tomarov and A. A. Shipkov

Environment Protection

Assessment of the Potential for Decreasing Greenhouse Gas Emission in Burning Fuels in Boilers
at Thermal-Power Plants (TPP) and Boiler Houses

P. V. Roslyakov, B. A. Rybakov, M. A. Savitenko, I. L. Ionkin, and B. Luning

Opportunities for the Application of Carbon Dioxide Capture and Storage Technologies in Case of Global Economy Decarbonization (Review)

S. P. Filippov^a, * and O. V. Zhdaneev^b

^a Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia

^b Russian Energy Agency, Moscow, 129085 Russia

**e-mail: fil_sp@mail.ru*

Abstract—There are a few economy and power industry decarbonization lines that mutually complement each other in view of constraints imposed on the scales of using each of them. The attractiveness of applying CO₂ capture and storage (CCS) technologies for these purposes stems from the possibility of reaching carbon neutrality while retaining the use of fossil fuels in the power industry for a long period of time. This is especially important with respect to coal as the most carbon-intensive fuel. The development of a CCS industry will open the possibility to make a smooth transition from the predominantly fossil-fuel based energy to energy on the basis of renewable and nuclear energy sources. It is shown that large-scale sequestration of carbon from the biosphere, which is the key biogenic chemical substance on the Earth, will not pose an essential hazard. It is important to ensure safety for people in the regions of storing large CO₂ amounts. Assessments of the capacity of the reservoirs for long-term CO₂ storage in various geological structures available on the Earth are given. It is revealed that this capacity is several times larger than the requirements for the entire 21st century. Such reservoirs are available in almost all regions on the Earth, although some individual countries may not have them at all. This can become a reason for development of local markets on rendering CO₂ storage services. A significant experience with development and implementation of CCS projects has been gained around the world. A global CCS industry can already be established on the basis of commercially mastered technologies. The aim to be pursued by the development of new technologies is to decrease the CCS costs. This relates primarily to technologies for capturing CO₂ from gaseous mixtures and storing it in rock formations. Since the CO₂ emission centers and places suitable for storing it are spaced apart from each other, the construction of large pipeline systems for CO₂ transportation over long distances will become inevitable. These pipeline systems can be commensurable in capacity and length with the existing gas networks.

Keywords: carbon dioxide, decarbonization, greenhouse gases, technology, carbon capture and storage, carbon cycle, carbon neutrality, power industry, economy

Applying Film-Forming Amines for Rendering Corrosion Resistance to Structural Materials of Equipment and Piping of Power Units at Nuclear Power Plants (NPP) (Review)

V. F. Tyapkova^a, * and N. L. Kharitonova^b, **

^a AO All-Russia Research Institute for Nuclear Power Plant Operation (VNIIAES), Moscow, 109507 Russia

^b National Research Center Kurchatov Institute, Moscow, 123182 Russia

**e-mail: yftiapkova@vniiaes.ru,*

***e-mail: kharitonova_nl@nrcki.ru*

Abstract—Current issues are examined whose solution could help to assess the effect of film-forming amines, in particular octadecylamine (ODA), on the corrosion state of thermal and mechanical equipment and piping of nuclear power plants and thereby accelerate the introduction of these technologies at nuclear power plants. The application of film-forming amines (FFA), film-forming amine products (FFAPs), and film-forming substances (FFS) has been demonstrated to be an innovative technology designed to minimize the corrosion rate of structural materials and reduce the intensity of deposit formation in the steam-water path of power units at nuclear power plants. In recent years, along with the increased interest in FFAs and FFAPs and the achieved positive results of their use, certain negative phenomena have been observed that caused the suspension of the introduction of the FFA/FFAPs technology at nuclear power plants. The

special aspects are examined of the results of pilot operation of the regimes with dosing ODA to the secondary circuit of power units at NPPs in Russia and abroad. Facts are presented demonstrating that many issues concerning the technologies for application of ODA and other FFAs at nuclear power plants are still open and require additional studies for their solution. Proposals are formulated that may be employed to obtain the missing data, which make it possible to assess the effect of FFAs on the corrosion condition of equipment and piping of nuclear power units and improve understanding of the FFA technology with regard to the description of the main fundamental processes occurring on dosing these chemicals to the NPP steam-water circuit.

Keywords: octadecylamine, film-forming amines, film-forming amine products, film-forming substances, film-forming amine dosing technology, corrosion protection, nuclear power plants, chemistry, erosion-corrosion

Modeling of a Combined Cycle Gas Turbine (CCGT) Using an Adaptive Neuro-Fuzzy System

M. B. R. Rodríguez^a, *, J. L. M. Rodríguez^a, **, and C. de H. Fontes^a, ***

^a Federal University of Bahia, Polytechnic Institute, Av. Milton Santos, Ondina, Salvador, 40170-110, Brazil

**e-mail: maidabrr@gmail.com*

***e-mail: jorgemoyer@gmail.com*

****e-mail: cfontes@ufba.br*

Abstract—The multiple advantages of the combined power cycles make their improvement a priority. The modeling of a Combined Cycle Gas Turbine (CCGT) for the identification/recognition of operating variables that can provide an increase in efficiency is a challenge in this type of thermal system. The simulation was carried out using an adaptive neuro-fuzzy inference system (ANFIS). The influence of three input variables on the thermal efficiency of the combined cycle was analyzed: the pressure ratio (compression ratio) used in the gas cycle, the pressure of the steam extraction for preheating of feed water (if applicable) and the heat lost to the outside in the steam turbines. It is shown that the ratio of pressures in the gas cycle has the most significant effect on the efficiency. The optimal value of pressure in steam extraction was obtained, corresponding to the maximum efficiency of the cycle, equal to 62.38%. A comparison of the efficiency values obtained using ANFIS and the results of parametric analysis showed their insignificant discrepancy. The proposed approach using ANFIS can be an alternative to the usual phenomenological model when modeling the operating modes of the combined cycle.

Keywords: modeling, combined cycle, gas turbine, steam turbine, ANFIS, overall thermal efficiency, optimization

Analysis of the Efficiency of the KG2-6200 Condenser Based on Direct Measurement Data in Various Operating Modes and Simulation Results

M. Shavdinova*, ******

Kazakh-German University, Almaty, 050010 Kazakhstan

**e-mail: shavdinova@dku.kz*

***email: nirvana-18@mail.ru*

Abstract—The main purpose of the condenser of a steam turbine unit is to condense the exhaust steam of the turbine and maintain the steam pressure behind the last stage under nominal conditions not higher than the calculated, which are determined on the basis of technical and economic indicators. Faults in the condensers lead to disruptions in the operation of the steam turbine, to its failures and breakdowns, loss of heat, water, and steam at the station, etc. In order to ensure the reliable operation of the condenser and improve the efficiency of its equipment, a mathematical model of the T-110/12.8 turbine condenser was developed, verified, and tested in relation to the conditions at the Almaty Power Plant (AlPP) of CHPP-2. It is shown that the model can be used to build new standard characteristics of the condenser at steam flow rates in the condenser above the nominal values and supply of circulating water to the main bundles and raw water to the built-in bundles. The model takes into account the peculiarities of determining the steam pressure in various zones of the condenser when cooling water is supplied to the main and built-in bundles of tubes. With the help of the developed module of the monitoring system for the technical condition of the condensing unit of the T-110/12.8 AlPP CHPP-2 steam turbine, it was found that the deviation of the actual condenser performance (including steam pressure) from the standard (calculated) values occurs mainly due to contamination of the condenser tubes. The influence of air suction in most modes is insignificant. The mathematical model allows one to change the input parameters, build dependency graphs, conduct a computational experiment, and calculate performance indicators. A feature of the mathematical model of the condenser is that it is built according to a technique that takes into account the peculiarities of determining the steam pressure in various zones of the condenser when cooling water is supplied to the main and built-in bundles. Based on the results of an industrial experiment, a comparison was made of the values of standard, calculated, and actual condenser pressures for each mode.

Keywords: condenser, steam turbine, mathematical model, average heat-transfer coefficient, steam flow rate, cooling water flow rate, diagnostic model

Simulating the Behavior of Fission Product Aerosols in the Containment

D. A. Nazarov^a, D. S. Sinitcyn^a, *, N. A. Mosunova^a, and A. A. Sorokin^a, **

^a Nuclear Safety Institute, Russian Academy of Sciences, Moscow, 115191 Russia

*e-mail: synitcyn@ibrae.ac.ru

**e-mail: sorokin@ibrae.ac.ru

Abstract—During a severe accident at an NPP involving loss of the primary coolant circuit and reactor core tightness, the majority of volatile and nonvolatile fission products are released into the containment atmosphere in the form of aerosols, the particles of which are multicomponent in composition and polydisperse in size. The particle sizes may vary from a few nanometers to several tens of micrometers. The size and mass of aerosol particles determine their lifetime in a suspended state in the atmosphere of the reactor premises. The radiation activity of particles depends on the content of radionuclides in them and is only indirectly connected with their mass and size. Therefore, in simulating the behavior of radionuclides, it is very important to take into account not only the change in the disperse characteristics of aerosol particles, e.g., their mass and size, but also the content of low- and even very low-mass but highly radioactive admixtures in the particles. The article presents a fission product aerosols' behavior model, which takes into account a change in the concentration, size, and composition of aerosols, including a change in the particle material density. The model is implemented in the fraction method approximation for a discrete mass of particles. For taking into account the effect that the composition of components has on the density of mixed aerosol material, the ideal solution approximation is considered. Test calculations for the model problem with two sources of aerosol particles having different composition and diameter in the modeled room volume were carried out. The first source consisted of CsOH particles, and the second one of UO₂ particles. It is shown that it is important when simulating the behavior of multicomponent fission product aerosols in premises to take into account the change in the composition of aerosols as a result of coagulation and, as a consequence, the change in aerosol particle material density, which depends both on the composition and density of individual components.

Keywords: fission products, radionuclides, containment, multicomponent aerosols, simulation, coagulation, deposition, aerosol density, severe accident, radioactive deposits

The New Generation of Separator-Superheaters for Steam-Turbine Units of Nuclear Power Plants (NPP) with VVER-Reactors

A. S. Shamarokov^a, *, V. M. Zorin^b, S. B. Pustovalov^c, and E. A. Mikhushkina^b

^a Research and Production Company EKIP, Moscow, 111020 Russia

^b National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

^c National Research Center Kurchatov Institute, Moscow, 123182 Russia

*e-mail: rasa7@mail.ru

Abstract—Results are presented from a comparison of the design, weight, size, and process characteristics of separator-superheaters (SSH) for steam-turbine units at nuclear power plants with pressurized water power reactors (VVER), which are based on a cartridge-type tube system (SSH-CTS) and are currently used, with a promising apparatus based on a manifold-platen tube system (SSH-MPS) with provisions for the heating-steam condensation and the removal of noncondensable gases released during condensation. The SSH-MPS separator considered in the article differs from the SSH-P, developed at the beginning of the 21st century by specialists of VNIIAM, by the design of the tube bundle in the superheater stages and the operation of the heating-steam condensation paths. Elimination of the thermohydraulic nonuniformity in and stable and reliable operation of tube bundles is SSH-MPS superheaters without temperature fluctuations and steam-gas plugs are attained due to dissolution of the gases released during steam condensation in the condensate cooling section. The tube bundles of each stage of the SSH-MPS superheater is a single section where steam condensation and condensate cooling are combined. This design eliminates all heating-steam losses since purging is not provided. In addition, heating-steam flowrates in superheater stages decrease due to the condensate cooling, and the effectiveness of the apparatus and the efficiency of the turbine unit increase. Application of SSH-MPS will considerably decrease the footprint of the system of intermediate separation and reheat of steam in the turbine hall and will also reduce the apparatus's metal intensity by half as compared to the SSH-CTS system. The outlined capabilities of the SSH-MPS system are essential in the reconstruction (upgrading) of existing and development of new power units at NPPs and optimization of design, process, and space-layout solutions for intermediate separation and reheat of steam systems for operating and newly designed steam-turbine units with a corresponding reduction in annual reduced costs, including CAPEX and OPEX.

Keywords: steam-turbine unit of NPP, separator-superheater, condensation, vertical cylindrical manifold, manifold-platen tube system, cartridge tube system, steam vent, thermohydraulic instability

Modern Methods for Numerical Simulation of Radiation Heat Transfer in Selective Gases (Review)

V. A. Kuznetsov*

Shukhov Belgorod State Technological University, Belgorod, 308012 Russia

*e-mail: kousnezow@mail.ru

Abstract—Radiative heat transfer in a gaseous environment of furnaces and ovens is the most important heat-transfer process controlling the efficiency of industrial installations. This explains the great interest of thermal engineers in modern methods of numerical simulation of radiative heat transfer. Heat transfer in high-temperature gases is mathematically described by the differential equation of radiative heat transfer together with the transport equations of thermal convection. The main problem is that triatomic gases, such as water vapor and carbon dioxide, selectively emit and absorb radiation energy, as a result of which their absorption coefficients become variable in spatial coordinates. The advances of recent decades in infrared spectroscopy have brought about favorable conditions for the development of well-substantiated models suitable for the calculation of absorption coefficients of the most important triatomic gases. The polylinear calculation of radiative transfer in a million spectral lines gave way to a narrow band model with a correlated absorption coefficient and then to global full spectrum models. Along with models of the absorption coefficient, methods for the numerical solution of the differential equation of radiative transfer are being improved. As a result, more than a dozen different models and methods can be used at present to calculate radiative heat transfer in industrial units. The proposed review partially eliminates the lack of publications that compare different approaches to the numerical study of radiation problems. It traces, up to the present time, more than 20 years of successive development of mathematical models of radiative heat transfer in selective gases. The main methods for the iterative solution of the differential equation of radiative heat transfer are also included in the review. At the same time, to eliminate complication of the model analysis, the review does not include excess information on boundary conditions and beam scattering. To ensure the unambiguity of the concepts used, the review is preceded by a short theoretical note.

Keywords: thermal radiation, selective gases, selective radiation absorption, radiation heat transfer, numerical simulation

Results from Optimization Studies of Multistage Binary Cycles for Utilization of Low-Temperature Geothermal Heat Carrier

G. V. Tomarov^a, * and A. A. Shipkov^a, *

^a *OOO Geoterm-M, Moscow, 111250 Russia*

**e-mail: geoatom.m@gmail.com*

Abstract—The creation of efficient technologies for converting low-temperature heat into electricity using binary power units operating on the organic Rankine cycle is an urgent problem of modern energy. Interest in these technologies is steadily growing since they make it possible to utilize the heat of waste coolant in various industries and geothermal power plants (GeoPPs). Currently, low-temperature resources, which are widespread throughout the world, are increasingly used as sources of geothermal coolant for generating electrical energy. One of the ways to increase the efficiency of binary technologies can be the use of multicascade binary energy complexes, which are several binary circuits connected in series. Due to the possibility of optimal selection of the working fluid in each circuit, the highest efficiency of an individual cascade and the energy complex as a whole is ensured. Preliminary estimates showed that the additional power that can be obtained by adding a new cascade decreases as the number of cascades increases. Optimization calculations were limited to comparing two- and three-stage binary power complexes with a single-stage binary power unit. The results of studies into the influence of the choice of an organic working fluid and the temperature of a geothermal coolant on the technical and economic characteristics of multicascade binary energy complexes with the utilization of a geothermal coolant with a temperature of 70°C are presented. It has been established that the efficiency of heat transfer to the binary cycle of multicascade energy complexes decreases with an increase in the temperature of the initial geothermal coolant. It is shown that the greatest decrease in the specific consumption of the geothermal coolant and the simultaneous increase in power during the transition from a single-stage power unit to two- and three-stage power complexes are achieved at low values of its temperature.

Keywords: multicascade binary energy complex, binary power unit, binary energy technologies, binary cycle, power plant, organic working fluid, geothermal coolant, power, specific consumption

Assessment of the Potential for Decreasing Greenhouse Gas Emission in Burning Fuels in Boilers at Thermal-Power Plants (TPP) and Boiler Houses

P. V. Roslyakov^a, *, B. A. Rybakov^b, M. A. Savitenko^b, I. L. Ionkin^a, and B. Luning^c

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b ANO Hydrogen Technology Solutions Center for Research and Scientific Development, Moscow, 127299 Russia

^c Clean Air Technologies AB, Skeppsbron 2, Malmo, 211 20 Sweden

**e-mail: RoslyakovPV@mpei.ru*

Abstract—Many countries around the world, including Russia, are performing extensive work towards meeting the Paris Agreement goals to reduce greenhouse gas emissions. One of the main industries that is an anthropogenic source of greenhouse gases is the coal-fired heat and power industry. A change-over from coal to natural gas becomes a promising measure for reducing carbon dioxide emission in the power industry. In the process, special attention is given to the combustion of natural gas mixed with hydrogen. This work examined engineering capabilities for burning hydrogen-containing gases (HCG) in conventional and condensing power facilities. Increasing the content of hydrogen in a mixture with natural gas when burning it in boilers has been demonstrated to affect the heat absorption of all heating surfaces in the boiler gas path, the gas temperature, and, ultimately, the boiler efficiency of the boiler, thereby requiring in-depth redesign of conventional gas-fired and pulverized coal-fired boilers. At the same time, the addition of hydrogen to natural gas extends the concentration range of stable combustion of such a mixture and increases the normal flame propagation velocity, which not only plays a positive role but also makes more intricate the practical implementation of the combustion of a hydrogen–natural gas mixture in burners and power facilities. Measures should be taken to prevent self-ignition of hydrogen-containing gases due to their higher fire and explosion hazard, including issues related to the location of process equipment and hydrogen transportation. A simultaneous decrease in atmospheric emissions of both water vapor and carbon dioxide during combustion of natural gas or hydrogen-containing gases in steam- and hot-water boilers can be attained by means of condensing heat recovery units that will improve the efficiency of fuel utilization and increase the thermal capacity of the power facility.

Keywords: boiler, greenhouse gases, natural gas, hydrogen, hydrogen-containing gases, Wobbe number