
Contents

Vol. 69, No. 10, 2022

General Energy Issues

Scenarios and Price of the Transition to Low-Carbon Energy in Russia

A. A. Makarov

The Economics of Carbon Dioxide Capture and Storage Technologies (Review)

S. P. Filippov

Scales and Consequences of Deep Decarbonization of the Russian Electric Power Industry

F. V. Veselov, I. V. Erokhina, A. S. Makarova, A. I. Solyanik, and L. V. Urvantseva

Automation and Heat Control in Power Engineering

Main Steam Temperature Control based on Variable Universe Fuzzy Dynamic Matrix Control

Lian Lian

Metals and Strength Analysis

Condition Monitoring of Heat Recovery Steam Boilers as a Basis for Elaborating Process Regulations for Their Operation

Yu. A. Radin, A. E. Zelinskii, and T. S. Kontorovich

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Distribution of Specific Steam Loads in Tube Bundles of Condensers for Cogeneration Steam Turbines

*K. E. Aronson, Yu. M. Brodov, A. Yu. Ryabchikov,
A. L. Demidov, and N. V. Zhelonkin*

Steam Boilers, Power-Plant Fuels, Burner Units, and Boiler Auxiliary Equipment

Kinetic Models of Methane-Hydrogen Mixture Combustion: Brief Review and Validation

*A. S. Semenikhin, S. S. Matveev, I. V. Chechet, S. G. Matveev, D. V. Idrisov,
N. I. Gurakov, D. V. Radin, S. S. Novichkova, N. I. Fokin, N. O. Simin,
A. A. Ivanovskii, and D. S. Tarasov*

Heat and Mass Transfer, Properties of Working Bodies and Materials

Temperature Dependence of the Thermal Coefficient of Linear Expansion

A. V. Kostanovskiy, M. G. Zeodinov, M. E. Kostanovskaya, and A. A. Pronkin

Simulation of Volume Condensation during Expansion of a Vapor-Gas Mixture
in the Flow Path of a Stage of a Turboexpander Unit

A. A. Sidorov and A. K. Yastrebov

Scenarios and Price of the Transition to Low-Carbon Energy in Russia

A. A. Makarov*

Energy Research Institute of the Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia

**e-mail: info@eriras.ru*

Abstract—For half a century now, the concept of decarbonization has dominated the global political and economic agenda, and Russia, despite the incompleteness of its scientific justification and the obvious threats to the development of the country's economy and energy, has recently joined it. A basic (extrapolation of the most optimistic of the latest approved by the government) scenario for the development of the country's economy until 2050 is presented, and it is transformed into a scenario of accelerated energy decarbonization (intensive). For these scenarios, forecasts have been developed for the consumption of the main types of fuel and electricity, and the required volumes of production of all types of primary energy have been optimized, taking into account the transformation of world energy markets. The rates and volumes of phasing out oil and especially coal production, the role of gas in the transition to low-carbon energy, the achievable volumes and the structure of noncarbon energy production are shown. Calculations of the required volumes of investments in the fuel and energy complex (FEC) and the contribution of the value added of its industries to the country's gross domestic product (GDP) showed that, in the intensive scenario, the fuel and energy complex loses its leading role in the Russian economy from the 2030s. Dominance in it in terms of contribution to the economy is moving from the oil and gas complex to the power industry, and greenhouse gas (GHG) emissions can be reduced to carbon neutrality by the mid-2050s (while maintaining the existing absorptive capacity of forests). The decarbonization of the energy sector will slow (relative to the baseline case) the growth of the Russian economy for 3 years in 2030–2050, and its cost to complete the energy transition will be even higher. The demolition of the geopolitical situation that occurred after the completion of the study and the preparation of the article will seriously change the scenarios for the development of the Russian economy and energy and, possibly, even the accepted paradigm of climate warming. But the methodology outlined here for the study and assessment of the degree of influence of the main factors of low-carbon policy on the energy and economy of the country will remain.

Keywords: decarbonization, economy, fuel and energy complex, low-carbon energy, fuel, noncarbon energy resources

The Economics of Carbon Dioxide Capture and Storage Technologies (Review)

S. P. Filippov*

Energy Research Institute, Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia

**e-mail: fil_sp@mail.ru*

Abstract—The deployment of CO₂ capture and storage (or carbon capture and storage (CCS)) technologies will enable carbon neutrality to be achieved during commercial utilization of fossil fuels. The performed studies have demonstrated that CCS technologies are quite energy-intensive and expensive. This primarily concerns the CO₂ capturing equipment, which is responsible for 60–80% of the CCS total expenditures. With a decrease in the partial pressure of CO₂ in a gas mixture and the capacity of the capture plant, the cost of CO₂ extraction increases drastically. This applies particularly to thermal power plants (TPPs). Their provision with CO₂ capture systems increases the specific capital expenditures by 1.6–2.3 times and the cost of generated electricity by 1.4–1.6 times. The power required for operation of these system amounts to approximately 9–12% of the total plant output and up to 20% with certain technologies. The unit cost of CO₂ capture becomes much greater if the power plant capacity is below 200 MW. The deployment of the CCS industry will require construction of a branched pipeline system for transportation of large volumes of CO₂, comparable to the gas transmission system. This will extend the potential for application of CCS technologies. The specific expenditures for pipeline transportation of CO₂ are controlled by the transported amount and phase state of CO₂. Increasing the transported amount of CO₂ from 0.1 to 5.0 million t/year cuts down the unit cost of transportation by almost an order of magnitude. The expenditures for CO₂ storage depends essentially on the characteristics of the reservoir. The cheapest option of CO₂ storage is onshore depleted oil and gas fields. Development of the CCS technology basis requires generous state support.

Keywords: carbon dioxide, decarbonization, carbon capture and storage technology, carbon neutrality, power industry, economics, capital expenditures

Scales and Consequences of Deep Decarbonization of the Russian Electric Power Industry

F. V. Veselov^{a, *}, I. V. Erokhina^a, A. S. Makarova^a, A. I. Solyanik^a, and L. V. Urvantseva^a

^a *Energy Research Institute, Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia*

**e-mail: info@eriras.ru*

Abstract—The article considers possible scales of changes in Russia’s Unified Energy System (UES) generation capacity structure and the associated costs necessary for adapting the electric power industry to various, in terms of stringency, requirements for reducing carbon emissions and decreasing the electricity production carbon intensity in 2040–2050. To this end, production and economic indicators are predicted for the economic sector’s so-called “boundary” development scenarios, which differ essentially in the scales of such changes, and at which the electric power industry makes different contributions in decarbonization of the country’s economy. One of the scenarios was drawn up based on the assumption that the existing trends and rates of changes in the technological structure would remain the same, with which a stable level of electricity price and amount of CO₂ emissions will be reached by 2050. The second scenario implies that a transition will be made after 2030 to more intensive changes due to increasing the number and capacity of carbon-free power plants, improving the energy efficiency of thermal power plants (TPPs), and substituting their use of coal. Taken in combination, these measures will make it possible to reduce the CO₂ emissions from power plants by almost 40% by 2050. Two electric power industry development scenarios are compared with respect to the following indicators: installed capacity and electricity production, and their mix (share distribution) by power plant types, necessary amounts of commissioning the capacities of thermal and carbon-free power plants and the required capital investments, demand for fuel, financial requirements of the economic sector, and electricity price variation dynamics. The capital intensity of reducing the CO₂ emissions and electricity production carbon intensity is estimated, and the scales of unavoidable growth in the price of electricity for its consumers in Russia are shown.

Keywords: decarbonization, carbon emissions, carbon intensity, thermal power plants, carbon-free power plants

Main Steam Temperature Control Based on Variable Universe Fuzzy Dynamic Matrix Control

Lian Lian*

*College of Information Engineering, Shenyang University of Chemical Technology, 11th Street,
Shenyang Economic and Technological Development Zone, Tiexi District, Shenyang City, Liaoning Province, 110142 China*

**e-mail: lianlian_syuct@163.com*

Abstract—The main steam temperature is one of the important parameters that need real-time monitoring in the thermal process, which is directly related to the power generation efficiency and operation safety of the boiler. The main steam temperature is also one of the most difficult parameters to control because of its large inertia and nonlinearity. Based on the Fuzzy-DMC controller, the variable universe fuzzy dynamic matrix control (VU Fuzzy-DMC) controller is designed by introducing the idea of variable universe. By adjusting the scaling factor, the universe can be contracted or expanded with the error decreasing or increasing, so as to improve the adaptive ability and control accuracy of the fuzzy controller. The simulation results show that in the case of model matching and model mismatching, the variable universe VU Fuzzy-DMC controller has better control effect than PID-, DMC- and Fuzzy-DMC-control, greatly reduces the temperature overshoot and regulation time, and the system has strong robustness. The variable universe Fuzzy-DMC controller can quickly return to the set value with small overshoot after being disturbed, and the system has a good anti-interference performance. The designed control strategy is effective.

Keywords: main steam temperature, Fuzzy controller, variable universe, dynamic matrix control, disturbance

Condition Monitoring of Heat Recovery Steam Boilers as a Basis for Elaborating Process Regulations for Their Operation

Yu. A. Radin^{a,*}, A. E. Zelinskii^b, and T. S. Kontorovich^{a,**}

^a PAO Mosenergo, Moscow, 119526 Russia

^b AO Machine-Building Factory of Podolsk, Podolsk, Moscow oblast, 142103 Russia

*e-mail: vti-unit@yandex.ru

**e-mail: kontorovich_ts@mail.ru

Abstract—The article presents the results from analyzing the effectiveness of continuously monitoring the technical condition of combined-cycle plant (CCP) heat recovery steam generators (HRSG) with the aim of rendering aid to the thermal power plant personnel for correctly determining the main factors causing deviations or upsetting of HRSG operation modes and preventing the occurrence of equipment damages in the future. The technical condition of CCP HRSGs is estimated on the basis of accumulated damage caused by deviation of their operation mode from the optimal one, which is quantitatively expressed in terms of accumulated equivalent operation hours. Examples showing the drain system performance on the damageability of HRSG parts are considered, especially with taking into account increased risk of damages to occur at the places in which the drain lines are welded to the steam lines and headers. The article shows the need for practical use of special maintenance programs of HRSG equipment, for which an analysis of accumulated operation hours or equivalent number of startups is proposed as a technical condition assessment criterion. Along with startup modes, the analysis takes into account the load variation modes within the load adjustment range that are accompanied by a change of steam parameters as well as off-design modes characterized by large disturbances of gas and steam temperatures, such as load rejections. The use of such programs will make it possible to reduce the costs of routine equipment maintenance works in the future and to timely detect equipment damages, thereby preventing the occurrence of emergency situations.

Keywords: corrosion, heat recovery steam generator, equivalent operation hours, thermal fatigue, technical regulations, monitoring, diagnostics, damages, stresses, corrosion rate, creep, load rejection

Distribution of Specific Steam Loads in Tube Bundles of Condensers for Cogeneration Steam Turbines

K. E. Aronson^{a, *}, Yu. M. Brodov^a, A. Yu. Ryabchikov^a, A. L. Demidov^a, and N. V. Zhelonkin^a

^a Ural Federal University, Ural Power Engineering Institute, Ekaterinburg, 620002 Russia

*e-mail: k.e.aronson@urfu.ru

Abstract—Results of experimental and numerical studies are presented on the steam distribution among the main bundles and the built-in bundle of condensers in cogeneration turbines using a specific steam load defined as the ratio of the amount of steam condensed in the bundle to the bundle surface area. The experiments agree well with the standard characteristics of the condenser. To calculate the specific steam loads in the condenser tube bundles, the manufacturing plant calculation procedure was updated. It allows for determining a steam flow rate in each tube bundle based on the condition of the same steam pressure in all the zones (tube bundles) of the condenser. It has been demonstrated that the specific steam loads of tube bundles can differ from each other by a factor of 20 or more and depend on the flow rates of steam and cooling water to the condenser, the water temperature at the bundle inlet, the number of water passes in the built-in bundle, and other factors. The effect of specific steam loads in tube bundles on the steam pressure in the condenser has been established to be considerable at steam flow rates close to the nominal values. One of the methods for improving the thermal performance of the built-in tube bundle for additional heating of make-up water, the application of profiled tubes, is examined. The obtained results are important from the standpoint of increasing the heat load of the built-in tube bundle (BB) when make-up water for the heating network is supplied through it and circulation water is fed through the main bundles (MBs) and of rising the oxygen content in the main condensate at the condenser outlet owing to condensate overcooling caused by nonuniform distribution of steam among tube bundles.

Keywords: cogeneration steam turbine, condenser, built-in bundle, main bundle, specific steam load, circulation water, air inleakage

Kinetic Models of Methane-Hydrogen Mixture Combustion: Brief Review and Validation

A. S. Semenikhin^a, S. S. Matveev^a, I. V. Chechet^a, S. G. Matveev^a, D. V. Idrisov^a, N. I. Gurakov^{a, *},
D. V. Radin^a, S. S. Novichkova^a, N. I. Fokin^b, N. O. Simin^b, A. A. Ivanovskii^b, and D. S. Tarasov^b

^a *Korolev Samara National Research University, Samara, 443086 Russia*

^b *AO Power Machines, St. Petersburg, 195009 Russia*

**e-mail: nikgurakov@gmail.com*

Abstract—A brief review is presented of kinetic models of combustion of hydrogen and methane-hydrogen mixtures. For numerical simulation of nitrogen oxide concentrations during combustion of methane-hydrogen in combustion chambers, nine kinetic models were studied (three Konnov-2019 models with 51, 74, and 128 components two Stagni models with 55 and 59 components; CRECK-2020; Wang-2018; NUIGMech1.0; and GRI 3.0), and predictions by these models were verified against the experimental data of the world leading laboratories. The models were verified against the ignition delay time, normal flame propagation velocity, and distribution of NO concentration above the burner. The verification has revealed that the Konnov-2019 (128 components), Konnov-2019 (74 components), and NUIGMech1.0 models require proper selection of the solver parameters or preliminary reduction. The GRI 3.0 model considerably underestimates the high-temperature ignition time in the range of 1100–1450 K. The reduced Konnov-2019 model (51 components) accurately predicts the flame propagation velocity; however, it cannot predict NO concentrations for rich air-fuel mixtures. The CRECK 2020 (CH₄) model underestimates NO concentrations for stoichiometric mixtures. The predictions by the Stagni models underestimate NO concentrations and feature a considerable deviation from the normal flame propagation velocity for mixtures with a high hydrogen content (50%). The Wang-2018 model agrees well with the experimental data on the normal flame propagation velocity. This model yields the best predictions of NO concentrations and is most suitable for numerical simulation of designed combustion chambers.

Keywords: kinetic models, methane-hydrogen mixture, ignition delay time, nitrogen oxides, laminar flame propagation velocity

Temperature Dependence of the Thermal Coefficient of Linear Expansion

A. V. Kostanovskiy^{a, *}, M. G. Zeodinov^a, M. E. Kostanovskaya^a, and A. A. Pronkin^a

^a *Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

**e-mail: Kostanovskiy@gmail.com*

Abstract—The results from comparing temperature dependences of thermal coefficient of linear expansion of MPG-7 and MPG-6 structural-grade graphite and GIP-4 and DE-24 isotropic isostatic grades in the 1300–2300 K temperature range are presented. For the first time, the results of experimental research into the thermal coefficient of linear expansion of MPG-7 brand graphite in the 1650–2350 K temperature range on the samples cut perpendicularly and parallel to the direction of pressing are presented. The experiment was carried out in the steady-state heat mode. Comparison of the results obtained by measuring the thermal coefficient of linear expansion of MPG-7 brand graphite with similar data for MPG-6 structural brand graphite and DE-24 and GIP-4 isotropic isostatic graphite brands has shown that the latter brands are characterized by lower values of thermal coefficient of linear expansion. The conclusion is made on the expediency of introducing isotropic isostatic graphite grades in heat power engineering.

Keywords: thermal coefficient of linear expansion, graphite, temperature

Simulation of Volume Condensation during Expansion of a Vapor-Gas Mixture in the Flow Path of a Stage of a Turboexpander Unit

A. A. Sidorov^{a, *} and A. K. Yastrebov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: AlexSid-MPEI@yandex.ru

Abstract—The working fluid entering a turboexpander under actual operating conditions may contain some impurities that affect the flow characteristics, the resulting temperature at the outlet of the turboexpander unit (TEU) stage, and the service life of its flow path. The presence of impurities often causes erosive damage to the TEU impeller blades due to their bombardment by droplets of the formed condensate. Modern standard methods for calculating the effects of cavitation and volume condensation either cannot take into account the presence of these effects and the extent of their influence on the flow characteristics and the TEU flow path at the design stage or they have a poor accuracy and are only a tool for probabilistic prediction of the effects of cavitation and volume condensation. Thus, modern refrigeration equipment and the overall turbomachine building industry require such a tool that would be free from these disadvantages. The problem of volume condensation during the expansion of a vapor-gas mixture in the flow path of a specific TEU stage was solved for the first time using a condensation model, which is based on the kinetic equation for the droplet size distribution function in a nonstationary 3D formulation. The model was implemented as a special module integrated into the CFD-package. Three-dimensional nonstationary predictions are used as the basis for a comparative analysis of the effect of condensation on the thermogasdynamics of the process of expansion of an incondensable gas carrier and a condensable impurity in the flow path of a stage in a specific TEU model. Regions where volume condensation may occur are localized. Their location is used as the basis for an analysis of the potential consequences (whether this will have any effect on thermogasdynamics and whether regions susceptible to erosive wear will appear). In this paper, we propose a method for calculating the expansion of multicomponent mixtures in the flow path of the TEU stage with or without condensation.

Keywords: volume condensation, kinetic equation, turboexpander, CFD, condensation kinetics, distribution function