
Contents

Vol. 69, No. 11, 2022

Automation and Heat Control in Power Engineering

A Device for Optimal Control of an Autonomous Photovoltaic Power Supply Source:
Development and Test Results

Ya. A. Men'shikov, A. B. Tarasenko, and M. Zh. Suleimanov

Nuclear Power Plants

Analyzing the Thermal Characteristics of a Small Capacity NPP Thermal Power Circuit
with Nonaqueous Working Fluids

A. A. Sukhikh, I. S. Antanenkova, and Tran Quoc Think

Simulating the Thermal Interaction between Fuel and Sodium Coolant Using
the EUCLID/V2 Integrated Code

*E. V. Usov, V. I. Chukhno, I. A. Klimonov, A. A. Butov,
N. A. Mosunova, and V. F. Strizhov*

Metals and Strength Problems

Effect of Stresses Occurring under Modifying 20X13 Steel Exerted
on the Incubation Period of Dropping Impact Erosion

*A. F. Mednikov, A. V. Ryzhenkov, G. M. Brovka, G. V. Kachalin,
A. B. Tkhabisimov, and O. S. Zilova*

Renewable Energy Sources, Hydropower Engineering

Integrated Aluminum-Water Technology for Hydrogen Production

E. P. Volkov and E. I. Shkol'nikov

Environment Protection

Decreasing Vibrations and Noise from Power Facilities by Passive and Active Methods

A. V. Kiryukhin, O. O. Mil'man, L. N. Serezhkin, and E. A. Loshkareva

Heat and Mass Transfer and Properties of Working Fluids and Materials

LES-Based Conjugate Simulation of Mixed Mercury Convection for Downflow
in a Nonuniformly Heated Vertical Pipe

V. I. Artemov, M. V. Makarov, G. G. Yan'kov, and K. B. Minko

Crisis Phenomena and Heat-Transfer Enhancement during Boiling and Evaporation
in Horizontal Liquid Films

A. N. Pavlenko, V. I. Zhukov, and D. A. Shvetsov

**Steam Boilers, Power-Plant Fuels, Burner Units,
and Boiler Auxiliary Equipment**

A Pulverized Coal Fuel Electrical Ignition System and Its Application Experience

D. S. Sinel'nikov and A. V. Shikhotinov

A Device for Optimal Control of an Autonomous Photovoltaic Power Supply Source: Development and Test Results

Ya. A. Men'shikov^a, A. B. Tarasenko^a, and M. Zh. Suleimanov^{a, *}

^a *Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

**e-mail: smusi@mail.ru*

Abstract—The article describes a new method and device for automatically controlling the charge of a storage battery (SB) for an autonomous power supply source with the function of the photovoltaic array (PVA) maximum power point tracking control (an MPPT controller). The controller is intended for charging Li-ion batteries and can be used to operate with both lithium iron phosphate (LiFePO₄, 3.2 V) and lithium-ion (NiCoMnO, 3.7 V) batteries. The controller is constructed on the basis of a high-frequency synchronous buck converter. The controller's distinctive features are that it equalizes the voltages across the storage battery sections and controls its heater prior to perform the battery charging. Owing to the SB preheating, it becomes possible to discard the use of lead storage batteries, which are heavy-weight devices with a rather short service life, and make a shift to the use of reliable, compact, and durable Li-ion batteries, also under low temperature conditions, in which the use of such batteries is difficult or even impossible in view of a drop of their energy-storage capacity. An important feature of the developed controller is that its auxiliaries take power supply from a photovoltaic array and not only from the storage battery, as is the case in the absolute majority of the commercially available controllers, due to which it has a broader field of practical applications. The controller is equipped with the necessary set of protections, including those from photovoltaic array connection in inverse polarity, from SB overcharging and deep discharge, overcooling or overheating, and load overcurrent. The operating range of voltage across the photovoltaic array varies from 15 to 45 V. The storage battery maximal charging, as well as load current, is 20 A. The entire set of controller functions has been implemented on a single-sided printed-circuit board. A set of experimental studies of the device operation modes was carried out, which has confirmed the efficiency of built-in control algorithms. The proposed controller can be used in various fields of activity, in particular, for supplying power to remote telecommunication equipment, offence recording cameras, in agriculture (primarily in livestock farming), in tourism industry, etc.

Keywords: charge controller, maximum power point tracking controller, photovoltaic array, photovoltaic converter, photovoltaic array simulator, storage battery, buck converter

Analyzing the Thermal Characteristics of a Small Capacity NPP Thermal Power Circuit with Nonaqueous Working Fluids

A. A. Sukhikh^{a, b, *}, I. S. Antanenkova^b, and Tran Quoc Thinh^b

^a National Research Center Kurchatov Institute, Moscow, 123182 Russia

^b National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: sukhikhaa@mpei.ru

Abstract—Predesign assessment of prospects for developing small capacity nuclear power plant (SCNPP) thermal power circuits operating with various nonaqueous working fluids is given. The article presents the results obtained from an analysis of makeup versions of the SCNPP secondary (turbine) circuit, the primary circuit of which is an autonomous microfuel molten salt cooled reactor (MARS). The thermal process schemes of an open-loop air gas turbine unit without regeneration, a gas turbine unit with two-stage air compression in a compressor and regeneration, and a fluorocarbon turbine unit that uses octafluoropropane (C_3F_8) as working fluid and operates according to the organic Rankine cycle are considered. The possibility of reaching the highest thermodynamic efficiency of thermal energy conversion on the basis of a fluorocarbon turbine unit (FTU) that uses octafluoropropane as working fluid at temperatures up to 650°C is shown. The design cycle efficiency of such a unit exceeds 50%, whereas that of a gas turbine unit (GTU) without regeneration is no more than 33%. The main thermal, mass, and dimensional characteristics of the SCNPP thermal power circuit equipment for the proposed makeup versions are compared with one another. It has been found that the main technical problem faced in designing and introducing the thermal power equipment of the GTU-based secondary circuit will be the mass and dimension characteristics of the reactor core heat exchanger and the air-to-air regenerator in view of low heat-transfer coefficients. It is shown that the use of octafluoropropane as the turbine circuit's working fluid will make it possible to design the main apparatuses with essentially more compact mass and dimension characteristics and, hence, to decrease the hydraulic losses in them and reduce their cost. The obtained results testify that mass of regenerative apparatuses operating on octafluoropropane can be decreased in comparison with that of their air-cooled analogs by up to 15 times. Based on the obtained analysis results, a list of first-priority technical problems has been formulated, the solution of which will make it possible to successfully develop the SCNPP thermal power circuit.

Keywords: small capacity nuclear power plant, GTU, efficiency, heat exchangers, thermodynamic efficiency, octafluoropropane, organic Rankine cycle

Simulating the Thermal Interaction between Fuel and Sodium Coolant Using the EUCLID/V2 Integrated Code

E. V. Usov^{a, *}, V. I. Chukhno^a, I. A. Klimonov^a, A. A. Butov^a, N. A. Mosunova^a, and V. F. Strizhov^a

^a Nuclear Safety Institute, Russian Academy of Sciences (IBRAE RAS), Moscow, 115191 Russia

*e-mail: usovev@gmail.com

Abstract—This article addresses the development of approaches to numerically analyzing the processes of interaction between liquid metal sodium coolant and destructed fuel-pin components (fuel and steel in solid and liquid states). Such processes may occur during a severe accident involving core destruction, and also when fuel-pin components (fuel or cladding) heated to a high temperature release into the flow of relatively cold liquid coolant or when the molten fuel begins to melt the corium catcher. A dramatic growth of power caused by self motion of pins and stoppage of forced coolant circulation without actuation of the reactor plant's active and passive safety systems are among possible events leading to accidents with such consequences. For simulating the thermal interaction, it is proposed to use a multicomponent thermally nonequilibrium model based on the solution of a system of mass, energy, and momentum conservation equations with the relevant relationships that take into account the specific features of thermal and mechanical interaction between the melt and coolant. Simulation of the processes is very important for determining pressure jumps in the reactor plant caused by release of destructed fuel-pin components into the coolant flow. Thermal interaction of fuel-pin components with the coolant may cause intense coolant evaporation and, as a consequence, the occurrence of drastic pressure jumps determined by the intensity of heat transfer from components to coolant and the amount of vapor produced. To find the rate of heat transfer between various components, a chart of heat-transfer modes and closing relationships corresponding to each mode are used.

Keywords: fast reactor, melt, fuel, sodium coolant, integrated codes EUCLID/V2, SAFR, HYDRA-IBRAE/LM

ИССЛЕДОВАНИЕ ВЛИЯНИЯ НАПРЯЖЕНИЙ

Effect of Stresses Occurring under Modifying 20X13 Steel Exerted on the Incubation Period of Dropping Impact Erosion

A. F. Mednikov^{a, *}, A. V. Ryzhenkov^a, G. M. Brovka^b, G. V. Kachalin^a,
A. B. Tkhabisimov^a, and O. S. Zilova^a

^a National Research University Moscow Power Engineering Institute (MPEI), Moscow, 111250 Russia

^b Belarusian National Technical University, Minsk, 220013 Republic of Belarus

*e-mail: MednikovAIF@mpei.ru

Abstract—The paper presents the results of studies on stresses occurring in 20X13 grade steel samples under different-types surface modification, such as boronizing, ion nitridizing, Cr—CrC ion-plasma coatings, pulsed laser treatment, and their combinations. The studies on the stresses has been carried out according to a technique based on measuring the deformation (bending) of the sample. From the surface profiles measured before and after the modification, normal bending values have been obtained and then used in order to evaluate the stress change. Resulting from the studies, it has been found that the presence of compressive stresses in the surface layer can be judged in the course of pulsed laser treatment by the character of normal bending. In the case of applying a Cr—CrC coating after a pulsed laser treatment, the surface bending exhibits a decrease, which indicates a decrease in the final level of compressive stresses. Upon combining the types of surface modification, including the deposition of a Cr—CrC coating followed by a pulsed laser treatment, transition from compressive to tensile stresses in the surface layer is observed with an increase in the coating thickness. Reducing the depth of the nitridized layer leads to a decrease in tensile stresses. The formation of Cr—CrC coatings having different thicknesses on the 20X13 grade steel surface leads to the formation of different-level stresses. Combining Cr—CrC-based coatings with different thickness values having several types of nitridizing can lead to stress reduction in these combinations and to an erosion resistance level superior to that of stellite. The obtained specific input energy depending on internal stresses in the surface layer—indicating the fact that the incubation period of the erosive wear process is finished—can be used to predict the erosion resistance level of the surface after modification. Such a prediction can be performed according to the measured stress level at a stage of choosing a protection method.

Keywords: dropping impact erosion, protective coatings, stresses, strain measurement, ion-plasma coatings, diffusion coatings, pulsed laser treatment

ВОЛКОВ, ШКОЛЬНИКОВ

Integrated Aluminum-Water Technology for Hydrogen Production

E. P. Volkov^a and E. I. Shkol'nikov^{a, *}

^a *Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia*

^{*}*e-mail: Ishkolnikov@mail.ru*

Abstract—In this paper, the features of the hydrothermal oxidation of dispersed aluminum are outlined and the prospects of its use for the mass production of “carbon-free” hydrogen are substantiated. In the course of hydrothermal oxidation, aluminum reacts with water or steam. In this case, hydrogen without the admixture of carbon or its compounds and thermal energy are formed. The solid product of aluminum oxidation is represented by aluminum hydroxide. This paper describes an integrated low-waste aluminum-water technology using such a single consumable agent as electricity. The technology involves the reduction to the metal of the obtained aluminum hydroxide within the framework of a single production. The aluminum regenerated in the electrolysis process can be again returned to the cycle for obtaining hydrogen from water in the hydrothermal oxidation reaction. If relatively recently developed inert anodes, as well as electricity generated at hydroelectric power plants or nuclear power plants, are used in the electrolysis of aluminum, then the technology has no carbon traces. The weight-energy characteristics and the composition of the products of each of the main processes used in the integrated aluminum-water technology are analyzed, namely the reduction of aluminum from Al_2O_3 by means of electrolysis to return Al to the hydrogen-production cycle, the hydrothermal aluminum oxidation with the production of a steam-hydrogen mixture and a condensed mixture of water and boehmite, the separation of aluminum oxide Al_2O_3 from boehmite AlOOH , obtaining pure hydrogen from a steam-hydrogen mixture as well as water for reuse, and hydrogen compression. Serious attention is paid to the potentialities of utilizing the thermal energy of the steam-hydrogen mixture for hydrogen compression. Owing to the production low-grade heat in large amounts under implementing the technology of hydrothermal aluminum oxidation, a thermal sorption compressor can be used for compressing hydrogen to operating parameters (40–90 MPa). This makes it possible to reduce the operating costs for hydrogen compression by more than an order of magnitude compared to traditional mechanical compressors and, at the same time, to provide an increase in the efficiency of aluminum hydrothermal oxidation.

Keywords: hydrogen, aluminum hydrothermal oxidation, aluminum reduction, hydrogen compression, weight-energy balance

КИРЮХИН и др.

Decreasing Vibrations and Noise from Power Facilities by Passive and Active Methods

A. V. Kiryukhin^{a, b, *}, O. O. Mil'man^{a, b}, L. N. Serezhkin^b, and E. A. Loshkareva^b

^a ZAO Scientific-and-Production Implementation Enterprise Turbokon, Kaluga, 248010 Russia

^b Tsiolkovskii Kaluga State University, Kaluga, 248023 Russia

*e-mail: turbocon2@kaluga.ru

Abstract—A description is given of the causes by which the transmission of vibration and airborne noise from equipment to the environment should be controlled. The paths of this transmission and applicable ways for its reduction by passive and active methods are examined. It has been demonstrated that pipelines, even vibration-isolated from the equipment by means of expansion joints, can transmit and even amplify vibration from the installation in a wide frequency range. It is noted that reducing the vibration of pipelines is important for effective vibration isolation of equipment in power and transport machine building, shipbuilding, and of oil and gas pipelines at pump stations. Effective control of the vibration and noise transmission to the environment has been shown to require a preliminary comprehensive analysis of the importance of all paths of their transmission. A description is given of a dedicated universal research test facility for a comprehensive study of the possibility and methods for reducing the transmission of vibration and airborne noise from operating equipment with a flow of working fluid through piping using passive and active methods.

Keywords: power facility, vibration, pipeline expansion joint, working fluid, pressure fluctuations, airborne noise, dynamic forces, vibration stiffness, frequency range, vibration isolation, noise insulation, active vibration damping

АРТЕМОВ и др.

LES-Based Conjugate Simulation of Mixed Mercury Convection for Downflow in a Nonuniformly Heated Vertical Pipe

V. I. Artemov^a, M. V. Makarov^{a,*}, G. G. Yan'kov^a, and K. B. Minko^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: makarovmv2000@yandex.ru

Abstract—Studies of hydrodynamics and heat transfer for turbulent flow of liquid metals in channels having various spatial orientations in longitudinal and transverse magnetic fields under the conditions of uniformly and nonuniformly heated walls in a wide range of the Hartmann, Reynolds, and Grashof numbers are of significant interest in connection with the development of thermonuclear fusion technologies. In the overwhelming majority of accomplished experimental and numerical studies, the influence of channel wall thermophysical properties on the averaged and pulsation flow characteristics was not analyzed. In recent studies, the authors have shown that the use of a conjugate formulation, even with involvement of a simplified wall thermal model, makes it possible to obtain a significantly better agreement between the calculation results and reliable experimental data on rms pulsations of liquid temperature in the near-wall region in comparison with the results of direct numerical simulation of turbulence in the conventional formulation that does not take into account the pipe's thermophysical properties. The article presents verification of the LES subsystem of our own ANES code in the formulation conjugate with the wall without any simplifications of a real pipe wall, and with involvement of experimental data on turbulent mercury downflow in a nonuniformly heated pipe when there is no magnetic field. Problems with and without taking into account the wall properties at the Reynolds number equal to 10^4 , Grashof number equal to 6×10^7 , and Prandtl number equal to 0.025 are considered. In addition to this, calculations in a conjugate formulation with involvement of a few popular turbulent viscosity models are carried out. The calculation results are compared with experimental data. The effect that the consideration of wall properties has on various flow characteristics is analyzed.

Keywords: mixed turbulent convection, mercury, vertical pipe, nonuniform wall heating, numerical simulation, conjugate heat transfer, turbulence characteristics

Crisis Phenomena and Heat-Transfer Enhancement during Boiling and Evaporation in Horizontal Liquid Films

A. N. Pavlenko^{a, *}, V. I. Zhukov^{a, b}, and D. A. Shvetsov^{a, b}

^a *Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

^b *Novosibirsk State Technical University, Novosibirsk, 630073 Russia*

**e-mail: pavl@itp.nsc.ru*

Abstract—A brief overview of research in the field of heat transfer enhancement and increase of critical heat fluxes (CHF) during boiling and evaporation in thin horizontal layers of liquids is presented. The analysis of the effect of the height of the liquid layer on the efficiency of heat transfer at various heat fluxes is carried out. At low heat fluxes, a decrease in the thickness of the film intensifies heat transfer, at high heat fluxes heat transfer intensifies in films whose thickness is greater than the capillary constant. The heat transfer coefficient (HTC) first increases with increasing layer height, and then decreases to values corresponding to the pool boiling. The structures formed in thin layers of liquid are considered when the layer height and pressure change over a wide range. The mechanisms of formation of various structures and their effects on the heat transfer enhancement depending on the working parameters of the process are also discussed. It is shown that there are regimes with heat transfer enhancement during evaporation of a liquid layer at reduced pressures. Under such conditions, the heat transfer coefficient is higher than with bubble boiling in a layer of the same height at a higher pressure. This is due to the effects of structures formed in these modes. It is established that with the growth of the film thickness, CHF increases to values corresponding to the pool boiling conditions. At bubble boiling on capillary-porous surfaces, the heat transfer coefficients in thin films are about 3–5 times higher than on a smooth surface. It is shown that at low pressure there is an optimal film thickness at which the heat transfer coefficients are higher than on a smooth surface. More heat-conducting coatings of the same shape significantly increase the values of CHF in the entire pressure range for the heights of the liquid layer along the line of the capillary constant. It is revealed that with a characteristic step between the ribs of the coating equal to the capillary constant of the liquid, the highest heat transfer coefficients are achieved in experiments.

Keywords: boiling, evaporation, thin film, critical heat flux, heat-transfer enhancement, modified surface

A Pulverized Coal Fuel Electrical Ignition System and Its Application Experience

D. S. Sinel'nikov^{a, b, *} and A. V. Shikhotinov^c

^a Novosibirsk State Technical University, Novosibirsk, 630073 Russia

^b OOO Siberian Power Engineering Solutions, Novosibirsk, 630004 Russia

^c OOO ZiO Energy, Novosibirsk 630049 Russia

*e-mail: denis.sinelnikov@sibener.ru

Abstract—The article presents an original electrical ignition technology based on intensifying the electrochemical and ionization processes in the zone where the electrical discharge influences a pulverized coal mixture. The experience gained from applying this technology at operating power facilities is described. During the electrical ignition system's (EIS) operation, the high voltage in the interelectrode space initiates oscillatory excitation, molecule dissociation, and gas atoms' ionization processes. This gives rise to a drastically larger number of particles whose energy exceeds the chemical burning reaction energy barrier threshold, due to which the fuel mixture ignites at low temperature. With the EIS put into use, it becomes possible to do without the supply of supplementary fuel (fuel oil) for lighting the boiler at coal fired thermal power plants and to do away with the equipment associated with using supplementary fuel (fuel oil facility etc.). In addition, the use of this system can help replace fuel oil at boiler houses by cheaper fuel that also does not pollute the atmosphere. The article presents the results of industrial tests of the technology in PK-24 and PK-10Sh boilers in using different fuels: a mixture of grade B (3BR) Mugunsk and Azeisk brown coals, grade B (2BR) Irbeisk brown coal, grades D and DSSh Cheremkhovo black coal for the PK-24 boiler and grade B (2BR) brown coal from the Irsha-Borodino open cast mine for the PK-10Sh boiler. It is shown that the oil-free lighting (OFL) system performs efficiently and makes it possible to fully replace the existing lighting system with wood-fired muffles. The flame from the OFL lighting-up burner reliably ignites the pulverized coal fed through the main burner.

Keywords: electrical ignition, lighting, oil-free lighting, ecology, efficiency, coal fired boiler, backup fuel, coal, fuel oil