

Contents

Vol. 70, No. 1, 2023

General Subjects

Decarbonization of Heat and Power Generation at Solid Fuel-Fired Power Plants

G. A. Ryabov, A. G. Tumanovskii, and A. N. Epikhin

Nuclear Power Plants

Erosion and Corrosion of Pipelines and Equipment on the Power Uprate of Power Units at Nuclear Power Plants (NPP)

G. V. Tomarov and A. A. Shipkov

More Efficient Heat Recovery from the Condensate of Reheaters at New and Operating Nuclear Power Plants (NPPs)

E. N. Kulakov, V. D. Gaev, G. I. Kazarov, Yu. G. Sukhorukov, and A. V. Popov

Automation and Heat Control in Power Engineering

The Heat-Storage Capacity of the Lakhta Center Multifunctional Complex Tower Building

*N. V. Varlamov, A. S. Gorshkov, Yu. V. Yuferev, A. Yu. Lezer,
A. E. Zhirnov, and N. A. Parashchenko*

Probabilistic Assessment of the Performance of a Power Plant Equipment's Emergency Conditions Early Detection Model Based on the Least Potentials Method

A. A. Korshikova and O. M. Idzon

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Thermochemical Recuperation of the Exhaust Gas Heat in Combined-Cycle Units: Thermodynamic Analysis

D. I. Pashchenko

Steam Boilers, Power Plant Fuels, Burners, and Boiler Auxiliary Equipment

Determining the Steam Boiler Furnace Gas Temperature and Emissivity during Flame Combustion of Peat

V. A. Kuz'min, I. A. Zagrai, and N. A. Shmakova

Heat and Mass Transfer and Properties of Working Fluids and Materials

Modelling of the Liquid Jet Discharge into a Liquid-Filled Space by the VOF Method

V. I. Melikhov, O. I. Melikhov, G. Yu. Volkov, S. E. Yakush, and B. Salejh

Environment Protection

Solid Oxide Fuel Cells' Prospects for Landfill Gas Utilization in Russia

*D. A. Agarkov, S. I. Bredikhin, S. V. Kiseleva, D. V. Matveev, A. V. Samoylov,
A. B. Tarasenko, Yu. S. Fedotov, and E. V. Tsypis*

Decarbonization of Heat and Power Generation at Solid Fuel-Fired Power Plants

G. A. Ryabov^a, *, A. G. Tumanovskii^a, and A. N. Epikhin^a

^a All-Russia Thermal Engineering Institute (OAO VTI), Moscow, 115280 Russia

*e-mail: georgy.ryabov@gmail.com

Abstract—A wide range of problems related to the reduction of greenhouse gas emissions during generation of electricity and heat is considered. An analysis of many recent publications has revealed that the fast and efficient decarbonization of the power industry can induce serious problems without any backup with fossil fuel, especially coal. Coal technologies have been demonstrated to become a bridge to the implementation of cleaner energy and should be considered as future zero-emission options. The performance indices of technologies offering high efficiency and low emissions are presented. As to the conditions of Russia in the short-term future, the main method to considerably cut down atmospheric CO₂ emissions from TPPs, in particular coal-fired ones, can be combined heat and power generation. The top priority in the field of coal-fired generation in Russia is still the development and mastering of coal-fired power units for ultra-supercritical (USC) steam conditions. It is shown that technologies for the capture, storage, and use of CO₂ are extremely important for solving the problems of climate change. Various CO₂ capture technologies and issues of its transportation and storage are discussed. The results of OAO VTI developments in this field are presented.

Keywords: greenhouse gas emissions, decarbonization, coal power industry, CO₂ capture, storage, and use technologies, renewable energy sources

Erosion and Corrosion of Pipelines and Equipment on the Power Uprate of Power Units at Nuclear Power Plants (NPP)

G. V. Tomarov^a, * and A. A. Shipkov^a, *

^aOOO Geoterm-M, Moscow, 111250 Russia

*e-mail: geoatom.m@gmail.com

Abstract—The development of the modern nuclear industry is characterized by the conversion of operating power units to operation at a thermal power level above the current rated power level to enhance generation of electricity and reduce its cost. This process is referred to as a power uprate (PU). This can be done by increasing the thermal power of a reactor units and improving the efficiency of the turbine unit. In Russia and abroad, the thermal power of NPP power units is usually increased by 2–20% above the nominal level. Such measures are most widely implemented in the United States and Europe. Increasing the thermal power of a power unit above the rated value may require retrofitting of turbines, condensers, electric generators, and other equipment. The power uprate changes the operating conditions of equipment and pipelines of the power units, including such working fluid conditions as temperature, pressure, and steam wetness. This, in turn, can affect the erosion-corrosion rate of the metal of the working surfaces in the process circuit and decrease the residual service life until the maximum allowable thinning of the walls of equipment and pipelines is attained. Computational studies of foreign specialists demonstrate that the erosion-corrosion rate of individual pipelines and groups of equipment after the power uprate can increase by more than 50%. Because of this, obtaining a license for the power uprate of an NPP power unit in the United States requires computational studies using software tools to identify pipelines and equipment where the erosion-corrosion rate can increase. Since 2009, the RAMEK software code has been used at Russian nuclear power plants to predict the erosion-corrosion rate of pipeline and equipment elements. It is noted that, in practice, the power uprate of a power unit can enhance not only the erosion-corrosion rate in elements with a complex geometry in the flow path but also the effect of cavitation and droplet impact erosion. The expediency is pointed out of computational and experimental studies to assess the effect of changes in the operating conditions on the rate and distribution of erosion-corrosion wear of pipeline elements and equipment.

Keywords: nuclear power plant, power unit, power uprate, erosion-corrosion, secondary circuit, pipelines and equipment, residual service life

More Efficient Heat Recovery from the Condensate of Reheaters at New and Operating Nuclear Power Plants (NPPs)

E. N. Kulakov^{a,*}, V. D. Gaev^b, G. I. Kazarov^c, Yu. G. Sukhorukov^a, and A. V. Popov^a

^a OAO Polzunov Scientific and Development Association on Research and Design of Power Equipment (NPO TsKTI),
St. Petersburg, 191167 Russia

^b AO Power Machines, St. Petersburg, 195009 Russia

^c Rosenergoatom Concern, Moscow, 109507 Russia

*e-mail: KulakovEN@ckti.ru

Abstract—A variety of technical solutions for the design arrangements of systems of turbine units (TU) at NPPs is the result of ongoing search for ways to increase the efficiency of electricity generation. A critical element of NPP TU systems, which has a pronounced effect on the efficiency and reliability of the power unit, is the steam separation and reheat (SRH) system. Therefore, this system should have an optimal list and structure of the employed equipment. The Russian and global experience in the design and operation of NPP TUs has demonstrated that the high-potential flow of heating steam condensate (HSC) of the secondary reheater of the SRH system can be utilized using three methods: by gravity into the last high-pressure heater in the feedwater flow, into a special condensate cooler, and by pumping into the feedwater path. These methods differ in thermal efficiency, cost, and performance indicators. The article compares the feedwater heating processes for various options of the heat recovery of the high-potential HSC flow from the steam reheaters of NPP turbine units. A feasibility study of their effectiveness has been performed, taking into account the net power of the turbine unit, the specific of the employed equipment, experience in its design and operation, and price characteristics. Recommendations are prepared on the selection of a system for heat recovery of HSC from the secondary reheater and on the type of equipment used. For operating NPPs with low-speed TUs, a conceptual proposal was developed to increase the net electric power by up to 1.6 MW by the installation of a water-jet ejector for pumping the HSC from the secondary reheater into the feedwater path.

Keywords: water-moderated water-cooled power reactor, steam turbine unit, heating steam condensate, high-pressure heater, equipment cost performance, hydroturbine pump, water-jet ejector

The Heat-Storage Capacity of the Lakhta Center Multifunctional Complex Tower Building

N. V. Varlamov^a, *, A. S. Gorshkov^a, Yu. V. Yuferev^a, A. Yu. Lezer^a,
A. E. Zhirnov^a, and N. A. Parashchenko^a

^aAO Gazprom Promgaz, Vidnoe, 142702 Russia

*e-mail: N.Varlamov@promgaz.gazprom.ru

Abstract—Translucent facade structures are increasingly more often used currently in constructing skyscrapers and high-rise buildings, especially in constructing office complexes. In a number of cases, the facade glazing-to-wall ratio of such structures is 0.8 or higher. Within the framework of this study, the thermal operation conditions of the tower, which is dominant in the Lakhta Center multifunctional complex, is considered. The studied object's space-heating system switching-on and switching-off modes, which characterize the building's indoor microclimate parameters at the heating season beginning and end, as well as in the case of heat supply emergency disconnection, are modeled. A heat-balance equation is set up that takes into account the heat gains and heat losses for the tower. The influence of the heat-storage capacity of the most bulky and heat-absorptive civil structures located within the building's heated volume is taken into account. The advisability of using the coldest day temperature of the specified exceedance probability as the design outdoor air temperature in designing the space-heating system of glazed buildings is substantiated. An equation describing the variation of the indoor air temperature t_{in} in the case of the space-heating system's emergency disconnection is obtained. The t_{in} variation pattern at outdoor air temperatures t_{out} varying from -28 to 8°C at 4°C steps is shown. For each selected t_{out} value, the tentative time taken for t_{in} to reach its permissible value after the emergency disconnection of the building's space-heating system is evaluated. It has been determined that the amount of heat that has to be spent for heating all bulky structural elements located inside of the building heated volume by 1 K makes 160.84 GJ, and the heat losses through the building glazed facades are 179.1 kW/K. The heat-storage coefficient of the considered object under study, which shows the time for which the initial difference of temperatures will decrease by e times after disconnection of the space-heating system, has been found to be approximately 250 h. This means that the tower has a sufficient thermal energy storage, which allows a comfortable indoor air temperature to be maintained for a long period of time.

Keywords: skyscraper, high-rise building, Lakhta Center, external enclosing structure, translucent facade, facade glazing-to-wall ratio, heat-transfer coefficient, space heating, emergency disconnection, heat-storage capacity, microclimate, indoor air temperature

Probabilistic Assessment of the Performance of a Power Plant Equipment's Emergency Conditions Early Detection Model Based on the Least Potentials Method

A. A. Korshikova^a, * and O. M. Idzon^a

^a *OOO Incontrol, Moscow, 115280 Russia*

*e-mail: korshikova@incntrl.ru

Abstract—This article is a continuation of the previously published paper [1], which describes a technique developed at OOO Incontrol on the basis of the potentials method, the essence of which is to calculate a certain indicator that characterizes the extent to which the current state of the power unit process equipment deviates from the states recognized as normal. Mathematically, this indicator is similar to the electrical potential produced by a point that characterizes the state of equipment in a multidimensional space of states formed by the process parameters that are measured in this equipment and represent the coordinates of this state space. Thus, the problem of detecting abnormal operation of the power unit process equipment boils down to calculating the abnormality criterion (a “potential”), which takes values from 0 to 1. Although the method described in [1] has shown quite positive operability, it nonetheless has a number of essential shortcomings. For example, the calculated abnormality indicator characterizing the malfunctioning of the process equipment being diagnosed is interpreted in a rather unobvious manner. As a result, to avoid incorrectly positive results, its value has to be “roughened” with simultaneously increasing incorrectly negative positive indications. Another shortcoming is that, in its existing form, the method diagnoses the approach to an abnormal mode and its onset, but it does not say anything about when the possible malfunction may occur. Finally, the possibility of determining the process parameters that have introduced the greatest contribution in the abnormality diagnostics has not been implemented. In the present article, we show a transition from the “potential,” which is a rather abstract abnormality indicator, to a probabilistic assessment of the state of power unit process equipment. This will open up the possibility not only to diagnose the beginning of a developing malfunction but also its onset time. In addition, the model described in this article makes it possible, in the case of detecting an abnormality, to produce, for the process engineer, a ranked list of the diagnosed equipment's process parameters that had the greatest effect on the abnormality occurrence probabilistic assessment. The proposed model has been constructed based on archived data accumulated over a long time of equipment operation and was checked on the period that contained an abnormality. Based on the obtained testing result, it can be stated that the proposed method features validity and clarity.

Keywords: process equipment, abnormality detection, predictive analytics, least potentials method, probabilistic assessment

Thermochemical Recuperation of the Exhaust Gas Heat in Combined-Cycle Units: Thermodynamic Analysis

D. I. Pashchenko*

Samara State Technical University, Samara, 443100 Russia

*e-mail: pashchenkodmitry@mail.ru

Abstract—A scheme of a combined-cycle unit with thermochemical recuperation of flue gas heat using methane steam reforming is considered. The essence of thermochemical recuperation is the recovery of flue gas heat for the endothermic methane reforming yielding a new synthetic fuel. The results are presented of a thermodynamic analysis of the combined-cycle unit thermal cycle with a gas turbine inlet temperature of 1500 and 1600°C at a pressure in the combustion chamber from 2 to 4 MPa. The thermodynamic analysis of the thermal cycle of a combined cycle unit was performed using the Aspen HYSYS software package, and the thermodynamic analysis of methane steam reforming was performed using the Gibbs free energy minimization method. The efficiency of thermochemical recuperation of flue gas heat has been demonstrated to depend on the process conditions, such as pressure, temperature, and composition of the initial reaction mixture. Increasing the temperature and the steam to methane ratio increases the reaction enthalpy and the efficiency of methane reforming, while an increase in the pressure decreases these parameters. It has been found that the thermochemical recuperation of heat can increase the effectiveness of a conventional combined-cycle unit by 3–5%. For example, the efficiency of a combined-cycle unit is 59% without thermochemical recuperation or 64% with thermochemical recuperation at a turbine inlet temperature of 1600°C and a compression ratio of 30. The thermal and material balances of a combined-cycle unit with thermochemical heat recuperation are presented in the form of energy and material flows, according to which 45% of the exhaust gas heat is recuperated in the fuel cycle of the gas turbine unit and approximately 45% of the exhaust gas heat is consumed in the steam turbine cycle.

Keywords: combined-cycle unit, methane reforming, thermodynamic analysis, thermochemical recuperation, methane steam reforming, energy efficiency, reaction enthalpy

Determining the Steam Boiler Furnace Gas Temperature and Emissivity during Flame Combustion of Peat

V. A. Kuz'min^a, I. A. Zagraia^a, *, and N. A. Shmakova^a

^a Vyatka State University, Kirov, 610000 Russia

*e-mail: zagraia@yandex.ru

Abstract—The article presents an integrated experimental and theoretical determination of the emissivity and temperature of heterogeneous combustion products obtained from flame combustion of peat. The emissivity value determined from pyrometer readings depends on a large number of factors individually in each particular case, and its choice should be properly substantiated. Calculation studies of the emissivity of furnace gases (complete combustion products) with varying the temperature were carried out for the Optis CTlaser F2 and F6 pyrometers operating at wavelengths equal to 4.24 and 4.64 μm , respectively. The dependences of the theoretical (true) temperatures T_{theor} on the emissivity are found. The experimental measurements of furnace gas brightness temperature were carried out at different heights of the BKZ-210-140F boiler furnace. Dependences of the measured temperature T_{exp} on the emissivity set on the pyrometer are obtained. By using the intersection points of the experimental T_{exp} and theoretical T_{theor} functions, the sought temperatures at the corresponding boiler heights were determined. For the Optis CTlaser F2 pyrometer, the furnace gas temperature in the flame root part ($H = 9 \text{ m}$) is equal to 1182 K; it is 978 K in the flame middle part ($H = 14 \text{ m}$) and 1031 K in the flame tail part ($H = 16 \text{ m}$). For the Optis CTlaser F6 pyrometer, these temperatures were found to be 1154, 1034, and 1042 K, respectively. The TEMPER software that the authors have developed makes it possible to determine the furnace gas temperature with reference to the CO_2 absorption band in the BKZ-210-140F steam boiler during the combustion of solid fuels (peat and coal). The block diagram of solving the temperature and emissivity determination problem is given. Based on the known mass fraction of CO_2 , the software produces the results on emissivity and temperature for the specified heights. By using the software, it will be possible to monitor the fuel-combustion temperature conditions to prevent the furnace slagging process from occurring and minimize nitrogen oxide emissions.

Keywords: temperature, pyrometry, emissivity, furnace gases, steam boiler, peat flame combustion, heating surface slagging

Modelling of the Liquid Jet Discharge into a Liquid-Filled Space by the VOF Method

V. I. Melikhov^{a, b, *}, O. I. Melikhov^{a, b}, G. Yu. Volkov^a, S. E. Yakush^c, and B. Salejh^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b Electrogorsk Research and Development Center for Nuclear Power Plants' Safety, Electrogorsk, 142530 Russia

^c Ishlinsky Institute for Problems in Mechanics of the Russian Academy of Sciences, Moscow, 119526 Russia

*e-mail: vladimir.melikhov@erec.ru

Abstract—The penetration of a liquid jet into a space filled with another liquid for the case of large difference in density between these liquids is examined as applied to the fragmentation and mixing of jets during various accident scenarios at nuclear power plants (discharge of corium melt into water or water into a volume filled with liquid lead). The hydrodynamic equations for several immiscible liquids with sharp interfaces were solved using the Volume of Fluid (VOF) method. Mathematical models of multiphase flows, implemented numerically in the OpenFOAM open source package, are presented. A series of verification and research calculations was performed in a two-dimensional (plane) approximation, and the obtained results were compared with the published data. The results of calculation of the penetration of a Wood's metal melt jet into a deep water-filled vessel, performed using this approach, revealed successive stages in the evolution of a fragmenting jet. A good qualitative and quantitative agreement of the predictions with the published results of the calculation of this process by the ANSYS Fluent code were attained. The regularities of mixing of a water jet discharged into a volume filled with initially stagnant liquid (molten) lead are studied. It has been demonstrated that the fragmentation of the water jet occurs almost immediately after it enters the liquid lead in this case. The effect of the grid cell size on the characteristics of phase mixing was examined. The predicted characteristic sizes of the formed fragments, their dispersed composition, and the interfacial surface area during mixing are presented. Nomograms of the size distribution for the fragments formed during the jet breakup were plotted for both studied problems. It is shown that the melt fragments formed in this process are much smaller than the minimum limit size of melt droplets freely falling in water.

Keywords: severe accidents, jet fragmentation, VOF method, numerical simulation, liquid lead, hydrodynamic instability, interfacial surface, liquid mixing, dispersion composition

Solid Oxide Fuel Cells' Prospects for Landfill Gas Utilization in Russia

D. A. Agarkov^a, S. I. Bredikhin^a, S. V. Kiseleva^{b, c, *}, D. V. Matveev^a, A. V. Samoylov^a, A. B. Tarasenko^c, Yu. S. Fedotov^a, and E. V. Tsypis^a

^a Osipyan Institute for Solid State Physics, Russian Academy of Sciences, Chernogolovka, Moscow oblast, 142432 Russia

^b Moscow State University, Moscow, 119991 Russia

^c Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

*e-mail: k_sophia_v@mail.ru

Abstract—The problem of municipal solid wastes' (MSW) utilization is one of the most actual all over the world nowadays. In Russia, landfills are still the main way for MSW utilization. However, waste decomposition, leading to landfill gas generation, causes, on the one hand, a lot of complaints from local people mainly due to hydrogen sulphide emissions. On the other hand, landfill gas, containing 40–60 vol % of methane, can be considered as calorific fuel. Solid oxide fuel cells (SOFCs), due to high operation temperatures, can be considered as an efficient device for landfill gas conversion to electricity and heat. Withal some companies and laboratories are developing SOFCs with direct methane oxidation to increase conversion efficiency on account of steam reformer expulsion. In this research, issues of landfill gas' useful utilization are considered. Experiments on different materials' application for model gas mixtures' direct conversion into energy by means of an SOFC and foreign experience in the field of landfill gas purification and estimation of its volumes in Russia are taken as initial data. The estimation results obtained allow the authors to consider SOFC application for landfill gas conversion as a significant market niche for Russian hydrogen technologies. Energy efficiency and environmental issues can also be improved by SOFC application in this niche.

Keywords: fuel-cell based generators, solid oxide fuel cells, laboratory scale technology, municipal solid wastes, landfill gas, technical potential