
Contents

Vol. 70, No. 4, 2023

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Features of the Development and Operation of Multistage Steam Jet Ejectors

*K. E. Aronson, A. Yu. Ryabchikov, N. V. Zhelonkin, D. V. Brezgin,
A. L. Demidov, and D. Yu. Balakin*

A Comparative Analysis of the Energy Performance Characteristics
of Turbine Condenser Evacuation Devices

Yu. G. Sukhorukov, G. I. Kazarov, V. D. Gaev, Yu. V. Smolkin, and E. N. Kulakov

Renewable Energy Sources and Hydropower

Russian Geothermal Electric Power Industry: State and Development Prospects

V. A. Butuzov and G. V. Tomarov

Water Treatment and Water Chemistry

Cleaning Aqueous Media from Iron Oxides by High-Gradient Magnetic Filtration (Review)

B. A. Gusev, A. A. Efimov, L. N. Moskvina, and V. V. Panchuk

Nuclear Power Plants

Validation of the Severe Accident Module of the EUCLIDE/V2 Integral Code on the Basis
of Experiments on a Failure of Simulators of Single Fuel Rods and Fuel Assemblies

*T. A. Saikina, E. V. Usov, V. I. Chukhno, P. D. Lobanov,
S. I. Lezhnin, and N. A. Pribaturin*

Steam Boilers, Power Plant Fuel, Burner Units, and Boiler Auxiliary Equipment

Studying the Sunflower Husk Ash Properties after Husk Treatment Using Various
Torrefaction Methods

*A. V. Nebyvaev, O. Yu. Milovanov, D. V. Klimov, S. N. Kuz'min,
A. V. Ryzhenkov, V. A. Dubina, and R. V. Zavizhenets*

Heat and Mass Transfer and Properties of Working Fluids and Materials

Simulation of Bulk Condensation in a Flow of a Vapor–Gas Mixture through a Nozzle
by CFD-Methods Using a Special Computational Module

A. A. Sidorov and A. K. Yastrebov

Environmental Protection

Problems of Hydrodynamics and Heat Transfer in Interconnected Bed Reactors for CO₂ Capture and Obtaining Hydrogen

G. A. Ryabov and O. M. Folomeev

Features of the Development and Operation of Multistage Steam Jet Ejectors

K. E. Aronson^{a, *}, A. Yu. Ryabchikov^a, N. V. Zhelonkin^a, D. V. Brezgin^a,
A. L. Demidov^a, and D. Yu. Balakin^a

^a Yeltsin Ural Federal University, Ural Energy Institute, Yekaterinburg, 620002 Russia

*e-mail: kearonson@urfu.en

Abstract—The results of studies into geometric characteristics for multistage steam jet ejectors are presented. Various manufacturers' approaches during multistage ejector design optimization are analyzed accounting for the pressure increase levels' distribution and the nozzles' critical diameters of the ejector stages. It was found that, for cogeneration and condensing turbines, an approach to the distribution of geometric and technological parameters over the ejector stages can vary. For cogeneration turbines, the diameters of the nozzles' critical sections decrease with an increase of stage number, while they increase for condensing turbines. It is shown that there is a correlation in multistage ejectors between the distribution of steam flow rates between stages and the main geometric parameter of the ejector's first stage. The test results of three- and two-stage ejectors with outward coolers designed by the authors are presented. The main three-stage ejector is employed in the scheme of steam-air mixture evacuation from the turbine condenser, and the two-stage ejector with a precooler is designed to evacuate air from the scheme of the turbine water-heating plant. The ejector of the water-heating plant is connected to the main condensate line behind the main ejectors. Steam condensate is removed from the ejector to the condensate pot of the first network water heater. Multistage ejectors are equipped with an extended scheme for pressure measuring along the ejector' steam-air path: in the intake chamber, after the diffuser, and in the intercooler. It is shown that an increase in the pressure of the steam-air mixture, which cannot be explained by the obvious diffuser effect, that is, by the pressure increase as flow decelerates, is observed in the ejectors' coolers (between the stage diffuser and the intake chamber of the next stage). When analyzing the operating modes of multistage ejectors, the possibility of their self-regulation is revealed when the steam-air mixture is not compressed in one of the stages.

Keywords: multistage ejector, geometric characteristics, pressure difference, condenser, chamber, cooler, steam-air mixture

A Comparative Analysis of the Energy Performance Characteristics of Turbine Condenser Evacuation Devices

Yu. G. Sukhorukov^a, G. I. Kazarov^b, V. D. Gaev^c,
Yu. V. Smolkin^a, and E. N. Kulakov^{a,*}

^a OAO Polzunov Research and Production Association for Investigation and Design of Power-Generating Equipment (OAO NPO TsKTI), St. Petersburg, 191167 Russia

^b AO Concern Rosenergoatom, Moscow, 109507 Russia

^c AO Power Machines, St. Petersburg, 195009 Russia

*e-mail: KulakovEN@ckti.ru

Abstract—Efficient operation of turbine condensers is an important prerequisite for economically efficient and reliable operation of the turbine units at thermal- and nuclear power plants. Noncondensable gases entering the condenser shell space significantly affect the heat transfer intensity and, hence, the pressure at the end of the steam expansion process in the turbine. Therefore, it is important to take measures for constantly removing these gases with the minimal energy expenditures. The article considers the operation principles and operational and design characteristics of air evacuation devices used in the condensers of thermal- and nuclear power plant turbine condensers, such as water jet and steam jet ejectors, and liquid-packed ring pumps. Comparison of these devices in terms of their energy performance criteria is carried out. Conditions for ensuring adequate energy performance of water jet ejectors are shown. Based on the results obtained from the tests of water jet ejectors and liquid-packed ring pumps, it is shown that liquid-packed ring pumps do not have any essential advantages in using them as devices for evacuating noncondensable gases from steam turbine condensers. The characteristics of steam jet ejectors used at Russian thermal and nuclear power plants are given. The notion of a steam jet ejector energy efficiency is introduced. The reserves for improving the energy performance of steam jet ejectors are shown. It can be seen from the numerical analysis results that the use of steam jet ejectors is more energy efficient for the power units of nuclear power plants constructed on the basis of the AES-2006 and VVER-TOI conceptual designs than the use of liquid-packed ring pumps. In addition, liquid-packed ring pumps are essentially more costly and complex in operation. In view of a long-standing positive experience of using water jet and steam jet ejectors at thermal and nuclear power plants and their good performance, it is recommended to consider them as air evacuation devices for advanced nuclear power plant turbine units.

Keywords: steam jet ejector, water jet ejector, liquid-packed ring pump, noncondensable gases, efficiency, air entrainment ratio

Russian Geothermal Electric Power Industry: State and Development Prospects

V. A. Butuzov^{a, *} and G. V. Tomarov^b

^a *Trubilin Kuban State Agrarian University, Krasnodar, 350044 Russia*

^b *OOO Geoterm-M, Moscow, 111250 Russia*

**e-mail: ets@nextmail.ru*

Abstract—The article presents data on the resource base of Russia's geothermal steam–water fields located in the Kamchatka Peninsula and Kuril Islands with the approved reserves of 285.5 kg/s and production in 2020 amounting to 13 million t. The prospective steam–water mixture reserves are estimated at up to 1100 MW according to the volume method and with the natural discharge of steam-hydrotherms. The results of studies accomplished by the Institute of Volcanology and Seismology, Russian Academy of Sciences and the Institute of Geothermy and Renewable Energy Problems of the Joint Institute for High Temperatures, Russian Academy of Sciences, are given. The prospects of explorations on drilling wells at the foot of volcanoes in the Kamchatka Peninsula for obtaining fluids with supercritical parameters (above 450°C and 25 MPa) are estimated. The activity conducted by AO Teplo Zemli (Heat of the Earth) on producing a steam–water mixture in the Kamchatka Peninsula is described. The chronology and description of technical solutions on geothermal power plants in Russia are given. The key technical characteristics, thermal process cycle diagrams, and operation results of the Puzhetka, Verhkne-Mutnovsky, and Mutnovsky geothermal power plants (GeoPPs) with the total installed capacity equal to 74 MW and amount of electricity production in 2020 equal to 428 GW h are presented. The article analyzes the results of modern studies carried out in Russia on binary geothermal power units with a geothermal fluid having a temperature from 120 to 180°C, on combining binary power units with hydrogen-assisted geothermal steam superheating and expanding the Mutnovsky GeoPP with direct-cycle and combined cycle power units with increasing the plant capacity by 50–63 MW. Proposals on increasing the target financial support, constructing experimental installations and demonstration facilities, and establishing a center for geothermal power engineering competences are suggested.

Keywords: geothermal fields, steam–water mixture, geothermal resources, geothermal power plant, steam turbines, binary power units, wells, separators, reinjection, hydrogen-oxygen steam generators

Cleaning Aqueous Media from Iron Oxides by High-Gradient Magnetic Filtration (Review)

B. A. Gusev^a, A. A. Efimov^a, L. N. Moskvina^b, and V. V. Panchuk^{b, *}

^a *Aleksandrov Research Technological Institute, Sosnovyi Bor, Leningrad oblast, 188540 Russia*

^b *St. Petersburg State University, Institute of Chemistry, Peterhof, St. Petersburg, 198504 Russia*

**e-mail: vitpan@mail.ru*

Abstract—The experience of developing methods of magnetic filtration (MF) for the purification of various aqueous media from impurities of iron oxides has been studied. An analysis of the reasons for the successes and failures of previous researchers in the development of methods and means of magnetic filtration has been carried out. Theoretical prerequisites for new technical solutions for high-gradient magnetic filters (HGMF) are considered. Laboratory experiments were performed on a high-gradient filter with a superconducting magnetic system using model solutions to determine the basic characteristics of the method. It has been established that it is sufficient to use permanent magnets based on rare earth elements (NdFeB, SmCo) as a magnetic field source to calculate the required magnetic field strength gradient. Designs of high-gradient filters with systems based on permanent magnets, as well as a program for numerical simulation of the process of processing particles of corrosion products of various phase and dispersed composition in a high-gradient magnetic field for these filters, have been developed. The tests results of VGMF of various designs for water treatment of spent fuel assemblies' (SFA) storage pools on a full-scale test bench—a prototype of a transport nuclear power plant (NPP) and a VVER-440 reactor plant—are presented. The efficiency of purification of the coolant of the first circuit from activated corrosion products by ion-exchange and high-gradient magnetic filters was compared when performing reagent-free decontamination of equipment. Certification of the innovative design of the VGMF with a system based on permanent magnets, which can be used to purify the water of heat supply systems of urban utilities from corrosion products, was carried out.

Keywords: water coolant, magnetic filtration, iron-corrosion products, phase composition, high-gradient magnetic filter, permanent magnets, filter matrix

Validation of the Severe Accident Module of the EUCLIDE/V2 Integral Code on the Basis of Experiments on a Failure of Simulators of Single Fuel Rods and Fuel Assemblies

T. A. Saikina^a, E. V. Usov^{a, *}, V. I. Chukhno^a, P. D. Lobanov^a, S. I. Lezhnin^a, and N. A. Pribaturin^a

^a Nuclear Safety Institute, Novosibirsk Branch, Russian Academy of Sciences, (IBRAE RAS),
Novosibirsk, 630090 Russia

*e-mail: usovev@gmail.com

Abstract—The development of computer codes for modeling accidents in a reactor unit requires validation of the models built into these codes. In this work, the EUCLID/V2 integrated code developed at IBRAE RAS was validated as applied to the simulation of severe accidents with a failure of the core of liquid-metal cooled fast breeder reactors (LMFBR), against experiments on melting of the cladding of fuel-rod simulators carried out at the Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences (IT SB RAS), and SCARABEE BE + 3 experiments performed at the Commissariat à l’Energie Atomique (CEA) in France. The investigations performed at IT SB RAS included measurements of the cladding surface temperatures without liquid-metal cooling of the fuel-rod simulator, which is typical for accidents involving an instantaneous blockage of the flow section in the fuel assembly (FA) or with loss-of-coolant for type BN-1200M reactor units (RUs). To create such conditions, experiments with fuel rods were carried out in an argon atmosphere at room temperature (25°C) and a pressure of approximately 10^5 Pa, and the surface temperature of the fuel-rod simulator was recorded with a pyrometer. In France, the SCARABEE BE + 3 series experiments were carried out in the SCARABEE reactor to study the consequences of a hypothetical accident with a complete instantaneous blockage of the flow cross-section in a sodium-cooled fast reactor. To determine the effect of uncertainty in the initial data, diversified calculations were made. The validation was done by comparing the predictions with the experimental values of temperatures in the range between 500 to 1800 K (experiments of IT SB RAS). The maximum calculation error did not exceed 200 K. For the experiments in the SCARABEE reactor, it was not greater than 88 K for the fuel-rod claddings and 100 K the coolant. The obtained data will be used to estimate uncertainty in the predictions by the models of severe accidents with thermal destruction of fuel rods in fast reactors.

Keywords: validation, fast reactors, fuel rods, fuel assembly, nuclear fuel, sodium coolant, EUCLID/V2, SAFR, HYDRA-IBRAE/LM

Studying the Sunflower Husk Ash Properties after Husk Treatment Using Various Torrefaction Methods

A. V. Nebyvaev^{a, *}, O. Yu. Milovanov^a, D. V. Klimov^a, S. N. Kuz'min^a, A. V. Ryzhenkov^a,
V. A. Dubina^b, and R. V. Zavizhenets^b

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b OAO Head Special Design Office on Equipment Packages for Microclimate, Brest, 224014 Republic of Belarus

*e-mail: ar.nebivaev2017@yandex.ru

Abstract—Plant cultivation waste (straw and husk of sunflower, rice, miller, and other cereal crops) feature low moisture and ash content, and their heating value is close to or even higher than that of many power plant coals. The utilization of such waste for energy-generation purposes could help solve environmental problems connected with decreasing greenhouse gas emissions. At the same time, the chemical composition of the ash from this waste results in its having a low melting temperature, which causes the furnace slagging to occur and a rapid growth of ash deposits on the boiler convective heating surfaces. The well-known methods for waste pretreatment before combustion (water flushing and hydrothermal carbonization) feature excessive energy consumption and low yield. Therefore, it is proposed to estimate the effect on ash-melting properties of such a treatment method as torrefaction. Two biomass torrefaction methods were used: in the medium of gaseous torrefaction products in a plate reactor with a mechanically stirred biomass bed and fluidized bed torrefaction in a superheated steam medium. The chemical composition of the ash from biochars obtained using both methods is studied. Based on the known data, prediction criteria were calculated using which it is possible to estimate the possibility of biochar ash to melt, slag agglomerates to emerge, ash deposits to form on the boiler convective heating surfaces, and agglomerates to form during sunflower husk fluidized bed combustion. As is known, the use of prediction criteria often yields contradictory results. In view of this circumstance, for estimating the melting properties of ash from biochars and similar biomass, a 3D diagram was used, with the concentrations of various oxides contained in the ash marked on its axis. By using this diagram, the melting properties of the obtained biochars can be compared with those of other biomass kinds. This allows the following conclusion to be drawn: biochar produced as a result of torrefaction performed in a superheated steam medium is close in its fuel characteristics to wood waste; i.e., it can be combusted alone without additions or mixtures with other kinds of fuel having a refractory ash.

Keywords: sunflower husk, ash, torrefaction, gasification, fluidized bed, prediction criteria, biofuel, melting temperature, metal oxides

Simulation of Bulk Condensation in a Flow of a Vapor–Gas Mixture through a Nozzle by CFD-Methods Using a Special Computational Module

A. A. Sidorov^{a, *} and A. K. Yastrebov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: AlexSid-MPEI@yandex.ru

Abstract—Bulk condensation belongs to the most widely used thermodynamic processes. However, the complexity of its simulation often reduces numerical studies to a one-dimensional formulation of the problem and simple channel shapes. This work presents a bulk condensation computational module based on the solution to the kinetic equation by the method of moments for the droplet size distribution function. The module has been upgraded considering the user-defined scalars (UDS) and integrated into the CFD-package. This module upgrading has considerably improved the stability and accuracy of the solution and also has cut down the computational time. The developed condensation model and its implementation using the module have been verified for one-, two-, and three-dimensional formulations in steady state and unsteady approximations against two sets of third-party experimental data by an example of a solution to the problem of bulk condensation during supersonic expansion of a vapor–gas mixture in a nozzle. This yielded the distributions of pressure, temperature, density, degree of supersaturation, mass fraction of condensate, number density, and average droplet size both in cross sections and along the centerline of the examined nozzles. An important conclusion has been confirmed that we should consider not only the formation of droplets but also their growth since it is this process that has the main effect on the thermogasdynamics of the process. The solutions of the 2D and 3D problems are almost identical, which allows us to conclude that 2D formulations may be employed for solving similar problems with a simple channel geometry.

Keywords: bulk condensation, nucleation, vapor–gas mixture, thermogasdynamics, finite volume simulation, CFD-methods, numerical methods, kinetic equation

Problems of Hydrodynamics and Heat Transfer in Interconnected Bed Reactors for CO₂ Capture and Obtaining Hydrogen

G. A. Ryabov^{a,*} and O. M. Folomeev^a

^a *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

**e-mail: Georgy.ryabov@gmail.com*

Abstract—The technology of combustion and gasification in chemical cycles with interconnected fluidized bed (CF) and circulating fluidized bed (CFB) reactors is being intensively developed due to the decarbonization of energy and the possibility of obtaining useful products from organic fuels. This technology is still at the stage of fundamental and applied research at laboratory and pilot plants with a capacity of up to 3 MW. However, some recent studies strongly suggest that it can achieve relatively low CO₂ capture costs (at the level of 30 euro/t). New directions in research are associated with the use of three reactors with metal oxides (mainly natural oxides and iron oxides) to produce hydrogen and methanol. The main problems of hydrodynamics and heat transfer in systems with chemical cycles are considered. To equalize temperatures between interconnected reactors—wherein reactions occur with the absorption of heat in one, while they occur in the other with its release—a very large consumption of circulating material is required. It is shown that the solution to the problem of the removal of a sufficient number of particles and the influence of their size, velocity, and mass of the layer on it is extremely important. Another problem is to provide a very high degree of capture in cyclones (at the level of 99.9%), which is determined by the speed regime and particle size. Finally, the trapped particles must be reliably transported between reactors. It is shown that the proportion of the conductive-convective component of heat transfer increases at high concentrations of particles. This problem, as well as the problem of heat transfer, in the environment of steam and oxygen or oxygen and CO₂ is also relevant. Some results of experimental studies carried out at the All-Russia Thermal Engineering Institute on a large aerodynamic installation are presented.

Keywords: CO₂ capture, disposal, and use technologies, chemical cycles, interconnected fluidized bed reactors, hydrogen production, hydrodynamics, heat transfer