
Contents

Vol. 70, No. 5, 2023

Nuclear Power Plants

The Concept of a Nuclear Power Unit on the Basis of a Low-Power Multipurpose Test Research Reactor with Supercritical Light-Water Coolant

A. A. Sedov, V. Yu. Blandinskii, Ya. A. Kotov, D. S. Kuzenkova, A. S. Lapin, V. A. Nevinita, S. B. Pustovalov, A. S. Stepanov, S. A. Subbotin, P. A. Fomichenko, B. I. Fonarev, and A. A. Frolov

Analysis of the Sensitivity and Uncertainty of Calculation Using the KORSAR/GP Code for Accidents with a Failure of Storage Pools' Cooling System

V. E. Karnaukhov, M. M. Bedretdinov, P. S. Gagulin, R. M. Sledkov, and O. E. Stepanov

Steam Boilers, Power-Plant Fuels, Burner Units and Boiler Auxiliary Equipment

Thermal Effects of Torrefaction of Vegetable Biomass: Experiment and Mathematical Modeling

V. M. Zaichenko, G. A. Sychev, and A. L. Shevchenko

A LIF Study of the Temperature Field behind the Pilot Flame Front of a Gas Turbine Type Model Combustor

A. G. Savitskii, D. K. Sharaborin, V. M. Dulin, and D. M. Markovich

Water Treatment and Water Chemistry

Methods for Diagnosing and Predicting the Behavior of Impurities over the Power Unit Path in the Cycle Chemistry-Monitoring Systems at Thermal Power Plants (Review)

O. V. Egoshina, S. K. Zvonareva, and N. A. Bol'shakova

Environmental Protection

Effectiveness of CO₂ Capture by *Arthrospira platensis* Microalgae from a Mixture Simulating Flue Gases

M. S. Vlaskin, S. V. Kiseleva, N. I. Chernova, A. V. Grigorenko, K. G. Ryndin, O. S. Popel', S. Ya. Malanii, O. V. Slavkin, F. de Farias Naves, and V. Kumar

Renewable Energy Sources and Hydropower

Renewable Energy Sources, Hydropower Materials for Fuel Cells Based on Barium and Strontium Cobaltites Synthesized on a Solar Furnace

M. S. Paizullahanov, O. R. Parpiev, U. R. Salomov, Zh. Z. Shermatov, G. Sh. Karimova, and S. S. Sabirov

Steam-Turbine, Gas-Turbine, and Combined-Cycle Plants and Their Auxiliary Equipment

Use of a Modern Flow Traversing System for More Accurately Measuring
the Gas Dynamic Parameters in the Turbine LPC Last Stages in Studies
on a Full-Scale Test Bench

*A. V. Moskalenko, A. M. Tyukhtyaev, D. M. Kovalev, A. G. Dolganov,
A. A. Ivanovskii, V. A. Chernikov, and V. A. Rassokhin*

The Concept of a Nuclear Power Unit on the Basis of a Low-Power Multipurpose Test Research Reactor with Supercritical Light-Water Coolant

A. A. Sedov^a, V. Yu. Blandinskii^a, Ya. A. Kotov^a, D. S. Kuzenkova^a, A. S. Lapin^a,
V. A. Nevinitsa^a, S. B. Pustovalov^{a,*}, A. S. Stepanov^a, S. A. Subbotin^a, P. A. Fomichenko^a,
B. I. Fonarev^a, and A. A. Frolov^a

^a National Research Center (NRC) Kurchatov Institute, Moscow, 123184 Russia

*e-mail: Pustovalov_SB@nrcki.ru

Abstract—Herein is presented a preliminary concept of a nuclear power installation (NPI) based on a low-power multipurpose test research reactor with a supercritical pressure light water coolant (LMTRR-SCP), which can operate as a test or research reactor, and has the following capabilities: substantiation of operating conditions for a supercritical water-cooled power reactor in the fast neutron spectrum; adjustment of the design operating regimes of the reactor with supercritical coolant conditions (including reactor startup, attainment of the energy power level, switch-over between power levels, rated power operation, shutdown, etc.); reactor irradiation of promising types of nuclear fuel, absorbing and structural materials for nuclear installations with fast, intermediate, or thermal neutron spectrum; comprehensive experimental and numerical investigations to obtain information required for development and verification of numerical codes; evaluation of new types of equipment for various process systems (including elements of emergency cooling systems, steam generators, etc.), instruments, and control, monitoring, and diagnostics systems for power reactors of various types. Investigations into the closed nuclear fuel cycle (CNFC) problem; utilization of actinides and handling of long-lived fission products, including pilot demonstration closure of the fuel cycle; mastering of processes for the manufacture of radionuclide products for various applications; production of modified materials; and use of the reactor's thermal energy for heat and power generation. A potential also exists for the development of international cooperation within the scope of joint research programs on the basis of LMTRR-SCP.

Keywords: VVER-SCP, LMTRR-SCP, supercritical pressure (SCP) light-water coolant, test reactor, research reactor, low-power reactor, reactor unit, nuclear power installation

Analysis of the Sensitivity and Uncertainty of Calculation Using the KORSAR/GP Code for Accidents with a Failure of Storage Pools' Cooling System

V. E. Karnaukhov^a, M. M. Bedretdinov^a, P. S. Gagulin^{a, *}, R. M. Sledkov^a, and O. E. Stepanov^a

^a OKB Gidropress, Podolsk, Moscow oblast, 142103 Russia

*e-mail: gagulinps@yandex.ru

Abstract—An analysis into the sensitivity and uncertainty of the results obtained on the basis of the computational model of the experimental stand ALADIN, performed on the basis of the computational software tool KORSAR/GP, was carried out. The ALADIN facility is designed for experimental monitoring of the processes occurring in the near-reactor pools of spent nuclear fuel at NPPs in case of violation of its cooling (boiling of water and drying of stored spent fuel assemblies), which is of great importance for justifying the safety of NPPs, especially in the conditions of the existing limited data bank for similar processes in the spent fuel pool. The results obtained using the calculation model and the experimental data were published earlier and showed good agreement. Sensitivity and uncertainty analysis was carried out on the basis of the PANDA software tool, which implements special statistical methods. Based on the results of the analysis, the parameters whose uncertainty has the greatest impact on the temperature of the fuel assembly simulator and the water level in the test bench were determined. It is shown that it is permissible for the considered model to use a simplified approach to the analysis of uncertainty based on the consideration of only the limiting options for the deviation of the uncertain parameters of the model. In this case, one can certainly cover the entire tube of uncertainty of the results. In this case, the number of calculation options is significantly reduced, and the uncertainty tube expands to the maximum possible limits determined by the superposition of the most unfavorable deviations. The ALADIN stand simulates one fuel assembly under accident conditions in the spent fuel pool. If the obtained result is correct for the considered model then, with the similarity of the processes occurring in the pool and thermophysical characteristics, there is a potential possibility that a simplified approach to sensitivity and uncertainty analysis can also be applied in the analysis of the safety of spent fuel pools.

Keywords: sensitivity and uncertainty analysis, safety justification, accident analysis, pressurized water power reactor, spent nuclear fuel pool, KORSAR/GP program for thermal-hydraulic calculations, PANDA/KORSAR software package

Thermal Effects of Torrefaction of Vegetable Biomass: Experiment and Mathematical Modeling

V. M. Zaichenko^{a, *}, G. A. Sychev^a, and A. L. Shevchenko^a

^a Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

*e-mail: shev@jiht.ru

Abstract—The results of experimental and computational studies of torrefaction (low-temperature pyrolysis) of granular plant biomass are presented. As a result of this process, high-quality solid hydrophobic biofuel with increased calorific value is obtained from biomass of various types (including waste). Unlike fossil coal, torrefied fuel contains virtually no sulfur and heavy metals, has a lower ash content, and is a carbon-neutral product. The carbon dioxide released during the combustion of plant biofuels is completely absorbed during the period of plant growth. Biofuels are a renewable resource. The annual increase in biomass is 400 billion t, and the rate of energy accumulation by terrestrial biomass is 3×10^{21} J/year. The article considers a vertical reactor with a dense layer of pellets moving towards the heating gas flow under the action of its own weight and features of its operation, taking into account the possible implementation of the concept of a controlled exothermic reaction. To ensure the set mode, the plant has two control units: for controlling and maintaining the set temperature of the coolant at the reactor inlet and for controlling the opening of dampers for unloading finished products into the cooling zone. Experimental and calculated data are presented for three characteristic operating modes of the installation: with limitation of the exothermic reaction due to the control of the inlet temperature, with a controlled exothermic reaction, and with the production of biochar. The second mode turned out to be the most energy efficient. The deviation of the calculated data from the experimental data was no more than 4%. It is shown that the use of an exothermic reaction can significantly increase the energy efficiency of the process of obtaining carbon-neutral solid biofuel.

Keywords: biofuel, waste disposal, torrefaction, energy efficiency, exothermic reaction, moving bed reactor, coolant, biochar, pyrolysis, cooling

A LIF Study of the Temperature Field behind the Pilot Flame Front of a Gas Turbine Type Model Combustor

A. G. Savitskii^{a, b, *}, D. K. Sharaborin^{a, b}, V. M. Dulin^{a, b}, and D. M. Markovich^{a, b}

^a *Kutateladze Institute of Thermal Physics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

^b *Novosibirsk State University, Novosibirsk, 630090 Russia*

**e-mail: a.savitskii@g.nsu.ru*

Abstract—The problem of reducing the amount of harmful emissions during the operation of gas turbine units (GTUs) has become especially important in recent years. In this regard, for optimizing the flow thermal and gas dynamic processes, the flow velocity and the combustion process in the GTU combustion chambers have to be studied in detail. Such optimization makes it possible not only to secure highly complete fuel combustion and stable operation of the burners in a wide range of the fuel to oxidizer ratios but also to decrease the amount of harmful emissions. The article deals with studying the temperature field structure of the pilot flame produced by a model gas turbine two-zone burner. The instantaneous temperature distribution in the flame was recorded using the method based on thermally-assisted two-line planar laser-induced fluorescence (PLIF) in exciting the $Q_1(8)$ transition band (1–0) of the $A^2\Sigma^+ - X^2\Pi$ OH hydroxyl radical electron system. The study was carried out for the case of combusting a partially agitated methane and air mixture with a significant air excess factor $\alpha = 1.54$ under standard conditions in swirl flow at the Reynolds number $Re = 1.5 \times 10^4$. The procedure of calibrating a thermally assisted PLIF system with using a thermocouple is described in detail. The article also presents instantaneous temperature distribution patterns downstream of the flame front in the range 1500–2000 K. The obtained data show that the temperature field features a significant heterogeneity due to the flame being stabilized at the central fuel flame periphery by a swirl mixing air flow. The conditional averaging of the temperature field with taking into account the alternation caused by the flame’s front motion testifies that the temperature at the front base is close to the minimal adiabatic temperature values of the preagitated mixture near the “lean” ($\alpha > 1$, i.e., when the amount of oxidizer (air) is larger than that necessary for complete fuel combustion) flammability limit.

Keywords: vortex combustion chamber, turbulent swirl flame, laser-induced fluorescence, panoramic thermometry, methane–air mixture, alternation ratio

Methods for Diagnosing and Predicting the Behavior of Impurities over the Power Unit Path in the Cycle Chemistry-Monitoring Systems at Thermal Power Plants (Review)

O. V. Egoshina^{a, *}, S. K. Zvonareva^a, and N. A. Bol'shakova^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: yegoshinaov@mpei.ru

Abstract—Assurance of reliable and failure-free operation of power-generating equipment at thermal power plants is closely linked with improvement of methods for diagnosing and predicting the behavior of impurities over the process path of power units. The article discusses the current state and development prospects of techniques for diagnosing and predicting the behavior of impurities using cycle chemistry-monitoring systems. The application of mathematical models in such systems is studied, on the one hand, as a method for displaying the current information on the behavior of impurities over the power unit process path and, on the other hand, as a method for predicting their behavior. The possibility to use mathematical models when the water quality degrades, when the concentration of hydrocarbonates in the path increases, and also in analyzing the quality of ultrapure waters is examined. The article presents models based on the measurements of water sample conductivity upstream and downstream of the H-cation exchange filter, and pH values. The possibility to determine, by calculation, the rate of corrosion processes over the process path of a nuclear power plant unit using the hydrogen number, mass action law equations, material balance equations, and normalization conditions is analyzed. Impurity behavior prediction models based on neural networks are analyzed. The main types of mathematical models based on the water ionic composition, material balance, and neural networks that are used in cycle chemistry-monitoring systems are given; their advantages and drawbacks are pointed out, and current trends in the development of these models are formulated.

Keywords: thermal power plant, water chemistry, cycle chemistry-monitoring system, prediction, diagnostics, water and steam quality, hydrogen ion exponent, electrical conductivity, material balance

Effectiveness of CO₂ Capture by *Arthrospira platensis* Microalgae from a Mixture Simulating Flue Gases

M. S. Vlaskin^{a, b, c, *}, S. V. Kiseleva^{a, d}, N. I. Chernova^{a, d}, A. V. Grigorenko^a, K. G. Ryndin^a, O. S. Popel'^a, S. Ya. Malanii^e, O. V. Slavkin^e, F. de Farias Naves^f, and V. Kumar^{b, c}

^a Joint Institute for High Temperatures, Russian Academy of Sciences, Moscow, 125412 Russia

^b Graphic Era Hill University, Dehradun, 248002 India

^c Peoples Friendship University of Russia, Moscow, 117198 Russia

^d Research Laboratory for Renewable Energy Sources, Moscow State University, Moscow, 119991 Russia

^e Lukoil-Engineering, Moscow, 109028 Russia

^f University of the State of Santa Catarina, Florianópolis, Brazil

*e-mail: vlaskin@inbox.ru

Abstract—Decarbonization of the power industry requires the search of methods for cutting down the greenhouse gas emissions into the environment, including utilization of carbon dioxide generated during combustion of hydrocarbon fuels at power facilities. One of the promising methods is the capture of carbon dioxide by biota, not only by terrestrial plants but also by aquatic organisms, including specially cultivated microalgae. In this work, the efficiency of the capture of carbon dioxide with a concentration of approximately 6% from a gas–air mixture by *Arthrospira platensis* (Nordst.) Geitl microalgae was studied. This concentration has been selected on the basis of experimentally determining the CO₂ content in flue gases formed at industrial gas-piston power plants. The experiments were performed using a closed photobioreactor with a capacity of 100 dm³ installed in a gas chamber enabling elevated CO₂ concentrations in an air–gas environment to be created. The maximum growth rate of the microalgae biomass is 0.140 g/(dm³ · day). The effectiveness of CO₂ capture by microalgae was 0.220 g/(dm³ · day) based on the results of determination of the microalgae productivity by biomass and 0.235 g/(dm³ · day) based on the results of direct measurement of CO₂ concentration in the chamber. The concentration of the main nutrients (such as bicarbonates, phosphates, and nitrates) in the medium decreased by 25–50% during the experiment period. A comparative analysis of the consumption of carbon-containing components of the medium (HCO₃⁻, CO₃²⁻) by microalgae during the bubbling of cultural liquids with a gas–air mixture with different carbon dioxide content was performed. In general, good viability of *A. platensis* microalgae (high quality of biomass and high rate of its growth) was demonstrated when it was cultivated in an atmosphere with a high concentration (6%) of CO₂.

Keywords: microalgae, *Arthrospira platensis*, flue gases, photobioreactor, gas-piston engine-generators, carbon dioxide capture

Renewable Energy Sources, Hydropower Materials for Fuel Cells Based on Barium and Strontium Cobaltites Synthetized on a Solar Furnace

M. S. Paizullahanov^{a,*}, O. R. Parpiev^a, U. R. Salomov^b, Zh. Z. Shermatov^a,
G. Sh. Karimov^c, and S. S. Sabirov^d

^a *Institute of Materials Science, Academy of Sciences of the Republic of Uzbekistan,
Tashkent, 100085 Republic of Uzbekistan*

^b *Fergana Polytechnic Institute, Fergana, 150107 Republic of Uzbekistan*

^c *National Research Institute of Renewable Energy Sources, Tashkent, 100085 Republic of Uzbekistan*

^d *Fergana Branch of the Tashkent University of Information Technologies, Fergana, 150107 Republic of Uzbekistan*
**e-mail: fayz@bk.ru*

Abstract—Study was carried out on materials based on perovskite structures of cobaltite compositions of strontium $\text{SrCoO}_{3-\delta}$ and barium $\text{BaCoO}_{3-\delta}$, obtained by synthesis from a melt of a stoichiometric mixture of cobalt oxide with strontium carbonates $\text{Co}_2\text{O}_3 + \text{SrCO}_3$ or barium $\text{Co}_2\text{O}_3 + \text{BaCO}_3$ in a stream of high (150 W/cm^2) density concentrated solar radiation in a solar furnace, followed by quenching in water and sintering at a temperature of 1300 K. Hexagonal barium and strontium cobaltites had a developed fine microstructure (grains in the form of densely packed polyhedrons of various shapes 2–5 μm in size), a semiconductor character of electrical conductivity, and a low thermal expansion coefficient (average $12.6 \times 10^{-6} \text{ K}^{-1}$) in the temperature range 300–1100 K. The change in the electrical resistance of materials is due to the high affinity of cobalt ions for oxygen, which causes oxygen sorption and, as a result, leads to changes in the electronic structure of cobalt ions, as a result of charge transitions $2\text{Co}^{3+} = \text{Co}^{2+} + \text{Co}^{4+}$. This circumstance indicates the possibility of using materials based on barium and strontium cobaltites as selective absorbers, oxygen membranes, or cathode materials for the manufacture of solid-oxide fuel cells in the production of electrical energy as well as materials for hydrogen storage.

Keywords: barium and strontium cobaltites, solar furnace, melting, hardening, sintering, ceramics, solid-oxide fuel cells, oxygen absorbers, charge transitions

Improving the Accuracy of Measurements of Gas-Dynamic Parameters in LPC Last Stages in Studies Using Modern Flow Traversing System on a Full-Scale Test Bench

A. V. Moskalenko^{a, *}, A. M. Tyukhtyaev^a, D. M. Kovalev^a, A. G. Dolganov^a, A. A. Ivanovskii^a,
V. A. Chernikov^b, and V. A. Rassokhin^b

^a JSC Power Machines—Leningradsky Metallichesky Zavod, St. Petersburg, 195009 Russia

^b Peter the Great St. Petersburg Polytechnic University, St. Petersburg, 195251 Russia

*e-mail: moskalenko_av@power-m.ru

Abstract—The need of traversing the flow gas-dynamic parameters, when trying out new last stages of a steam turbine’s low-pressure cylinders (LPC), is shown. The specific features of pressure measurements according to the pneumometric method by means of probes in the last stages operating in a wet steam (two-phase) medium, with the probe’s receiving holes and pneumatic lines becoming blocked with condensate, are shown. The changeover for using small-size probe heads featuring better measurement accuracy in comparison with large-size heads is substantiated. A universal algorithm for purging the pneumatic lines periodically with atmospheric air for various probes with receiving holes of certain diameters is proposed. The universal algorithm is obtained by supplementing the system with a subroutine that automatically monitors the time delay after closing the purging valves prior to carrying out measurements at the traversing point. At that, excluded are incomplete removal of residual purging air with condensate from the pneumatic lines and excessive time delay before measurements. The algorithm is implemented in improving the previously developed traversing system. Better accuracy of measuring the pressures and flow meridian angles is achieved owing to the use of high-precision transducers in each of the probe measurement channels with the absolute pressure range 0–30 kPa with the accuracy equal to 0.05% of the upper measurement limit. The time taken to process the traversing results is decreased by adding three measurement channels to the system, which operate synchronously with the probe and characterize the turbine operation mode. A modern system for traversing the flow in the gap between blade rings of the last stages has been developed. The results of this development are used in studying the advanced steam turbine LPC compartment on the full-scale test bench at JSC Power Machines.

Keywords: steam turbine, low-pressure cylinder, wet steam flow, last stage, probe, pneumometric measurement method, traversing system, periodic purging, automatic monitoring of time delay after purging, sampling