

Contents

Vol. 70, No. 6, 2023

Renewable Energy Sources

Study of the Influence of Climate Variability on the Operation of Wind Generation on the Territory of Russia

E. V. Fedotova, V. V. Klimenko, and Yu. A. Kozlova

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Integrated Gasification Combined Cycle (IGCC) Units: History, State-of-the Art, Development Prospects (Review)

V. A. Batorshin, S. I. Suchkov, and A. N. Tugov

Studies of Erosive Wear of the Blading in Axial Compressors of Gas Turbines (Review)

V. L. Blinov, I. S. Zubkov, S. V. Bogdanets, O. V. Komarov, and G. A. Deryabin

Results from the Study of a Control Valve with Reverse Steam Supply

V. G. Gribin, O. M. Mitrokhov, A. V. Sherstneva, and P. M. Nesterov

Water Treatment and Water Chemistry

Estimation of Hydrocarbonates' Effect on Ammonia Concentration and pH in Conditions of Feed-Water Quality Deterioration

O. V. Yegoshina, S. K. Zvonareva, and A. O. Ivanova

Import Substituting Water-Chemistry Technologies on the Basis of Amine-Containing Reagents for Combined-Cycle Power Plant Steam Generators

B. M. Larin, S. Yu. Suslov, A. V. Kirilina, V. V. Kozlovskii, and A. A. Zidekhanova

Prediction Methods Based on Electrical Conductivity and pH Measurements in Water Coolant Chemical-Monitoring Systems

A. B. Larin, S. V. Kiet, K. V. Zotova, and E. G. Ukhalova

Study of the Influence of Climate Variability on the Operation of Wind Generation on the Territory of Russia

E. V. Fedotova^{a, b, *}, V. V. Klimenko^{a, b}, and Yu. A. Kozlova^{a, b}

^a National Research University Moscow Energy Institute, Moscow, 111250 Russia

^b Institute for Energy Research, Russian Academy of Sciences, Moscow, 117186 Russia

*e-mail: evkasilova@gmail.com

Abstract—The work is devoted to studying the features of the wind-speed dynamics in the regions of Russia in which wind-energy facilities are concentrated. For calculations, the latest generation reanalysis data set ERA5 for the period 1950–2021 was used. An analysis of the synchronism of wind-speed changes on the cross-continental scales of Northern Eurasia has been carried out. It is shown that the characteristic size of the area of synchronous change in wind speed is hundreds of kilometers, while one can find locations with an inconsistent change in wind speed in those territories of Russia where the input wind generation is mainly concentrated. An empirical study of the performance of a wind power plant (WPP) has been carried out on various time scales: from hourly to multidecade. It is shown that the characteristic variability of the average annual installed capacity utilization factor (ICUF) of wind turbines is 10–20%. In this case, the extreme values of the ICUF in the entire considered period turn out to be two to three times higher. Averaging over the territory levels this value down to 10% in the case of typical values and up to 25–35% for extreme ones. A coefficient is proposed to estimate the daily unevenness of wind turbine power generation and the additional power reserve that will be required during the selected day in order to level the influence of wind turbine power fluctuations. It is shown that the wind turbine is characterized during the day by high values of the coefficient of nonuniformity, which, taking into account the specifics of power systems in a certain area, means an increase in the need for an adjustment reserve. Averaging over the entire territory of each of the considered regions makes it possible to slightly increase the “guaranteed” generation of wind turbines and reduce its daily nonuniformity. At the same time, the choice of locations with minimal cross-correlations of the wind speed turns out to be almost as effective for reducing the daily nonuniformity as averaging over a large area. Tasks are identified, the solution of which will make it possible to simplify the integration of wind generation into the power systems of Russia by minimizing risks for the reliability of power supply and optimizing the use of available opportunities to increase its flexibility.

Keywords: wind energy, climate change and variability, wind speed, climate scenarios, reliability of power supply, installed capacity utilization factor

Integrated Gasification Combined Cycle (IGCC) Units: History, State-of-the Art, Development Prospects (Review)

V. A. Batorshin^{a, *}, S. I. Suchkov^a, and A. N. Tugov^a

^aAll-Russia Thermal Engineering Institute, Moscow, 115280 Russia

**e-mail: VABatorshin@vti.ru*

Abstract—Integrated gasification combined-cycle (IGCC) units, which use solid fuels (coal, petroleum coke, etc.) for combined-cycle power generation, have been under development for approximately half a century. At present, the countries of the Asian region show the greatest interest in this type of power plants. Two large IGCC power units entered into commercial operation at Nakoso and Hirono thermal power plants (TPPs) in Japan; in addition, the Osaki CoolGen project is advancing greatly. The People's Republic of China and the Republic of Korea are also improving their IGCC projects. Development of more efficient technologies for generator gas cleaning and application of the next generation of gas-turbine units (GTUs) at new IGCC units have cut down harmful emissions and increased the efficiency up to 48%. The 21st century has brought increased interest in IGCC units due to the ability of their equipment to capture CO₂. Besides the above-mentioned advantages, IGCC units also have disadvantages, the biggest of which is their high cost. That is why, despite many IGCC projects to be deployed in the 2000s, most of these projects were subsequently canceled, and the plants built in the 1990s are being gradually decommissioned. The promising direction for future application of IGCC units is the production of hydrogen for fuel cells with simultaneous CO₂ capture. The poly-generation technology already used at some facilities, which enable the generation and delivery to the consumer of not only electricity but also gasification by-products, will also render support to the solution of the economic problems of IGCC units.

Keywords: solid fuel, integrated gasification, combined-cycle unit, effectiveness, capital expenditures, specific cost, reliability, fuel cell, CO₂ capture

Studies of Erosive Wear of the Blading in Axial Compressors of Gas Turbines (Review)

V. L. Blinov^{a, *}, I. S. Zubkov^a, S. V. Bogdanets^a, O. V. Komarov^a, and G. A. Deryabin^a

^a Ural Federal University, Ekaterinburg, 620002 Russia

*e-mail: vithomukyn@mail.ru

Abstract—During operation, all components of a gas-turbine unit (GTU), including the blading of the axial compressor, are affected by the flow in the GTU flowpath, which results in the development of defects and deterioration of the main performance characteristics (efficiency, effective power, etc.). One of the most serious defects is erosive wear since it can cause destruction of one blade or all the blades in the compressor. This can lead to preliminary removal of a GTU from operation. Therefore, the erosion resistance of compressor blades is one of the main parameters controlling the service life of a gas-turbine unit. That is why studies of the erosive wear of axial compressors during operation of GTUs are urgent. This paper provides a review of the available publications on the erosive wear of blades and vanes in an axial compressor of gas-turbine units. The major erosion mechanisms classified by the type of particulates acting on blade material are examined. The geometric parameters of the compressor blading are found whose change due to erosive wear can disturb the flow aerodynamics and deteriorate the performance of individual elements and the overall GTU. The main three lines of erosive wear studies may be listed as follows: prediction of erosive wear, assessment and prediction of erosion consequences, and development of protective measures to control erosion during operation of a gas-turbine unit. The most frequently examined and promising subjects of erosion studies are outlined as applicable to gas turbine and compressor machine building. The state-of-the-art of studies in this field is analyzed.

Keywords: gas-turbine unit, axial compressor, set of blades, flowpath, erosive wear, particulates, numerical simulation

Results from the Study of a Control Valve with Reverse Steam Supply

V. G. Gribin^{a, *}, O. M. Mitrokhov^a, A. V. Sherstneva^a, and P. M. Nesterov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: GribinVG@mpei.ru

Abstract—Various design options for control valves and methods for arranging steam-distribution elements are considered. It was revealed that the traditional direct-flow control valve scheme does not always meet the requirements for the placement of equipment in a steam-turbine plant and leads to additional energy losses. It is proposed to use a control valve of a fundamentally new design: with reverse steam supply. An experimental setup for studying a control valve with reverse steam supply has been designed and created, and a diagram of changes in its characteristics has been drawn up. Using the proposed scheme, it is possible to study both the basic design of a control valve with a reverse steam supply and its improved versions on the experimental plant according to the proposed scheme. Using the measurement scheme, it is possible to determine the mass flow rate of the working medium, the hydraulic resistance of the valve path, and the power and vibrodynamic characteristics of the control valve. The results of mathematical modeling and experimental study of the flow path of the control valve block with reverse steam supply are presented. Design changes of the lower half of the valve box are proposed, due to which pressure losses and hydraulic losses are reduced and static and dynamic forces acting on the stem are reduced. The possibility of creating an economical and reliable valve with reverse steam supply, which can be used in steam-turbine steam-distribution systems, is shown. It is advisable to use the developed design of a control valve with reverse steam supply to simplify the layout of a steam-turbine plant with valve boxes located on the turbine casing.

Keywords: control valve, steam-return valve, nonreturn valve, steam box, unevenness, pressure recovery, hydraulic resistance

Estimation of Hydrocarbonates' Effect on Ammonia Concentration and pH in Conditions of Feed-Water Quality Deterioration

O. V. Yegoshina^{a, *}, S. K. Zvonareva^a, and A. O. Ivanova^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: yegoshinaov@mpei.ru

Abstract—Violations in water- and steam-quality standards cause emergencies at thermal power plants. In such conditions, chemical monitoring provides reliable and quick information about the normalized parameters of water and steam quality by direct measurement or indirect determination of the quality indicators of the analyzed medium. The expansion of functionality and effective detection of fast-flowing disturbances in cycle-chemistry monitoring systems is possible by predicting and analyzing the behavior of impurities along the path of the power unit. However, a large volume of chemical control performed with the help of laboratory chemical control analyzers reduces the reliability of water- and steam-quality monitoring systems. In the early stages, it is advisable to carry out the occurrence of violations of the quality of water and steam at the expense of automatic devices, including conductometers and pH meters, since such devices are the most reliable in industrial operation. Currently, algorithms for calculating pH and ammonia concentration based on continuous measurements of electrical conductivity continue to be improved. Within the framework of the work, the possibility of using an indirect algorithm based on the measurement of specific electrical conductivity in conditions of deterioration of feed water quality is investigated. The pH and concentration of ammonia were determined on the basis of measurements of specific electrical conductivity with dosing of hydrocarbonates in laboratory conditions. An experiment was performed, as a result of which it was revealed that, in case of water-quality deterioration, the error in calculating pH and ammonia increases.

Keywords: thermal power plant, power unit, cycle chemistry, cycle chemistry monitoring, automatic chemical control, water and steam quality

Import Substituting Water-Chemistry Technologies on the Basis of Amine-Containing Reagents for Combined-Cycle Power Plant Steam Generators

B. M. Larin^{a,*}, S. Yu. Suslov^b, A. V. Kirilina^b, V. V. Kozlovskii^b, and A. A. Zidekhanova^b

^a *Ivanovo State Power Engineering University, Ivanovo, 153003 Russia*

^b *OOO Water Technologies Engineering, Moscow, 115280 Russia*

**e-mail: info@wteng.ru*

Abstract—The last decade has seen the widespread use of water chemistry with metering polyamines into the coolant of steam boilers and heat-recovery steam generators (HRSG) of combined-cycle power plants (CCPP) at thermal power plants in Russia and Western Europe. Water chemistry with complex reagents of the Helamin and Cetamin trademarks began to oust the conventional all-volatile water chemistry. However, such factors as high cost and unclear component composition of imported reagents generated the need to develop similar domestically produced reagents. Complex reagents of the VTIAMIN and, in particular, VTIAMIN KR-33 types have become such ones. Due to selecting the concentrations of individual components in the complex reagent's composition, it has become possible to loosen the previously formed deposits and remove them from the heat-transfer equipment surfaces and obtain a significantly lower formation rate of new deposits, and, hence, the corrosion rate of heat-transfer surfaces. The article presents the results obtained from pilot commercial tests of the VTIAMIN KR-33 reagent in the HRSGs of CCPP-based power units in using various thermal cycle process circuits. These tests were carried out with the aim to solve various process-related tasks within the framework of implementing the program of substituting the imported polyamine water-chemistry technology. It has been found in the course of performing pilot commercial tests in 110-MW CCPP units that it is possible to jointly use VTIAMIN KR-33 and VTIAMIN D-2 reagents to reduce the corrosion rate of copper-containing alloys and stabilize the copper content over the power unit's steam–water path. The tests revealed an increased content of carbonic acid in the steam, which entails violation of the steam quality standards in terms of the H-cationized sample electrical conductivity indicator. The thermal cycle process circuits with sequential (the 110-MW CCPP) and parallel (the 450-MW CCPP) feeding of low- and high-pressure drums (LPD and HPD) were compared with each other. It has been shown that the violation of the standard water chemistry in the case of a high carbonic acid content in the 110-MW CCPP unit's path results from inefficient operation of the deaerator built into the LPD design.

Keywords: steam power-generating boilers, heat-recovery steam generators, combined-cycle power plants, polyamine water chemistry, carbonic acid, pilot commercial tests, copper-containing alloys, complex organic reagents

Prediction Methods Based on Electrical Conductivity and pH Measurements in Water Coolant Chemical-Monitoring Systems

A. B. Larin^{a, *}, S. V. Kiet^b, K. V. Zotova^a, and E. G. Ukhalova^a

^a *Ivanovo State Power Engineering University, Ivanovo 153003 Russia*

^b *OOO NPP Tekhnopribor, Lyubertsy, Moscow oblast, 140002 Russia*

**e-mail: yaandy_81@mail.ru*

Abstract—A shift for applying new technologies at thermal and nuclear power plants makes it possible to achieve more efficient operation of power units; in this case, however, more stringent requirements are posed to the water-coolant quality. Foreign and Russian national regulatory documents are supplemented with coolant quality indicators, in particular, the electrical conductivity of direct χ and H-cationized χ_H samples of all water and steam flows and the concentrations of chlorides and organic substances in feed water and steam at $\chi_H = 0.2\text{--}0.3 \mu\text{S/cm}$. Continuous automatic measurements are supported under these conditions with sufficient reliability by conductivity meters and partially by pH meters, and the progress in the development of information technologies opens the possibility to implement procedures for predicting certain quality indicators based on measurement results. The article presents analytical expressions for predicting the pH value and concentrations of organic acids in condensate and feed water, phosphates and sodium in boiler water, chlorides, bicarbonates, and electrical conductivity of a degassed steam sample. The possibility of using computation algorithms for analyzing the water chemistry (WC) state is shown, and the system of equations for the ionic equilibria mathematical model that is used in the domestically produced instrument for analyzing the feed-water quality of power-generating boilers is given.

Keywords: automatic chemical monitoring, water chemistry, prediction of coolant quality indicators, feed water and steam condensate quality analyzer, hydrogen ion exponent (pH value), electrical conductivity, salt content, carbonic acid