

Contents

Vol. 70, No. 7, 2023

Water Treatment and Water Chemistry

An Analysis of Models Describing the Hideout Phenomenon in the Steam-Generating Equipment of Nuclear and Thermal Power Plants

V. S. Polonskii, I. I. Belyakov, D. A. Gorr, and M. A. Mironenko

The Effect of Operating Conditions on the Quality of Saturated Steam in Drum-Type Power Boilers

T. I. Petrova and O. V. Egoshina

Environmental Protection

An Exergetic Analysis of New Thermodynamic Cycles Involving Carbon Dioxide Capture

*A. S. Kosoi, A. A. Kosoi, O. S. Popel', Yu. A. Zeigarnik,
M. V. Sinkevich, and S. P. Filippov*

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Development of an Unshrouded Blade for Stage Two of a GTE-65.1 Turbine

A. V. Granovskii, I. V. Afanas'ev, V. K. Kostezh, N. I. Fokin, and M. G. Cherkasova

Nuclear Power Plants

Simulation of the Coolant Hydrodynamics in the Outlet Section of the Fuel Assembly of the Cartridge Core of the RITM Type Reactor

*S. M. Dmitriev, T. D. Demkina, A. A. Dobrov, D. V. Doronkov, D. S. Doronkova,
A. N. Pronin, A. V. Ryazanov, D. N. Solntsev, and A. E. Khrobostov*

Heat and Mass Transfer and Properties of Working Fluids and Materials

Simulation of Halon Condensation Processes in Vertical Pipes by the VOF Method

K. B. Minko, G. G. Yankov, V. I. Artemov, and A. V. Ptakhin

An Analysis of Models Describing the Hideout Phenomenon in the Steam-Generating Equipment of Nuclear and Thermal Power Plants

V. S. Polonskii^a, I. I. Belyakov^b, D. A. Gorr^{c,*}, and M. A. Mironenko^c

^a OOO Interenergo, Moscow, 121096 Russia

^b OAO Polzunov Scientific and Development Association on Research and Design of Power Equipment (CKTI), St. Petersburg, 191167 Russia

^c OOO Special Design Bureau of Boiler Plants, Barnaul, 656056 Russia

*e-mail: gorr_da@skb-ku.com

Abstract—The salt hideout phenomenon in boiler water attracted the close attention of specialists as long ago as the 1940s–1950s. By the end of the 1980s, the majority of researches had arrived at the conclusion that the governing role in the hideout phenomenon is played by the deposits of structural material corrosion products on the steam-generating surfaces of the equipment of nuclear and thermal power plants. The steam-generation process takes place under confined conditions, which causes degraded mass transfer between the flow core and the heat-transfer surface. This results in that water impurities concentrate in the pores of deposits and even precipitate in a solid phase form. As the steam boiler/steam generator power output increases, the concentrations of certain impurities and chemical agents in boiler water decrease; this effect is called hideout, and as the load decreases, their concentrations increase (hideout return). In the last decades, a few physical and mathematical models have been developed in which the hideout phenomenon is considered from the viewpoint of boiler water impurities becoming concentrated not in the layer of permeable deposits but in the viscous sublayer of liquid at the steam-generating surface. Thus, the thermodynamic model rests on the postulates of nonequilibrium thermodynamics and is descriptive in nature. The mass-transfer model based on the laws of mass and energy conservation in the viscous sublayer incorporates an analytical expression for the impurity concentration ratio. However, this model also in fact contains only a qualitative description of the hideout process without performing its detailed comparison with experimental data. The article presents an analysis of these models and their comparison with reliable data obtained by domestic and foreign researchers, and it is shown that the key statements laid down at the heart of models based on impurity concentration in the liquid viscous sublayer are erroneous in nature. Adequate fundamental principles of mass transfer under hideout conditions are of significant theoretical and practical importance for working out operation regulations and securing reliable operation of installations with boiling coolant at nuclear and thermal power plants.

Keywords: hideout, hideout return, water chemistry, steam generator, heat-recovery steam generator, deposits, structural material corrosion products, impurity concentration, hideout corrosion, heat-and-mass transfer, pressurized water reactor, boiling reactor, evaporator

The Effect of Operating Conditions on the Quality of Saturated Steam in Drum-Type Power Boilers

T. I. Petrova^a and O. V. Egoshina^{a,*}

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: yegoshinaov@mpei.ru

Abstract—The effect of the operating conditions on the quality of saturated steam in stationary natural circulation boilers with a superheated steam pressure at the boiler outlet of 3.9 MPa or higher (up to 15.5 MPa) is examined. At present, the need is still urgent in the domestic power industry for thermochemical testing of boilers of various pressures to standardize the quality of boiler water and steam in accordance with the requirements of the applicable regulations for water chemistries. The demand for such testing results from the need to find the cause of salt deposition in the flow path of steam turbines and develop measures to prevent the formation of deposits on turbine blading. The results of these tests have confirmed the correlation among the boiler water salt content, entrainment factor, water level in the boiler drum, and steam quality. In high-pressure drum boilers, the main impurities are iron and copper oxides, i.e., the products of corrosion of power equipment provided that the demineralized water has a high quality with a maximum specific conductivity of 0.5 $\mu\text{S}/\text{cm}$ and no cooling water inleakage occurs in the condenser. Results of the effect of a correcting chemical on the distribution coefficient of iron and copper are presented. The use of ammonia as a correcting chemical decreases the distribution coefficient for iron and copper and, hence, reduces the contamination of steam with corrosion products. The water chemistry has been demonstrated to affect the concentration of corrosion products of iron and copper in the boiler water, i.e., the blowdown efficiency, which is related with changes in the form of these compounds in water. It is pointed out that the contamination of steam with corrosion products is related with droplet entrainment since the saturated steam pressure hardly has any effect on the distribution coefficients for iron and copper. How one and the same impurity enters the steam depends on the water chemistry controlling the form of existence of this compound.

Keywords: thermal power plant, natural circulation steam boiler, water chemistry, saturated steam, entrainment factor, impurity distribution coefficient

An Exergetic Analysis of New Thermodynamic Cycles Involving Carbon Dioxide Capture

A. S. Kosoi^{a, b}, A. A. Kosoi^{a, c}, O. S. Popel^{a*}, Yu. A. Zeigarnik^a, M. V. Sinkevich^{a, *}, and S. P. Filippov^d

^a Joint Institute for High Temperatures (JIHT), Russian Academy of Sciences, Moscow, 125412 Russia

^b PAO Academician Raspletin NPO ALMAZ, Moscow, 125190 Russia

^c National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^d Energy Research Institute, Russian Academy of Sciences, Moscow, 117186 Russia

* e-mail: smvmikl@mail.ru

Abstract—The article presents the results of an exergetic analysis of two new thermodynamic cycles: the Allam cycle and the cycle of a compressorless combined-cycle plant (the JIHT cycle). Their fundamental feature is that the carbon dioxide produced during fossil-fuel combustion can be removed directly from the power-installation cycle. Owing to this feature, such installations become extremely attractive for performing energy decarbonization. The JIHT cycle based installations are more versatile because they can be used for generating not only electricity but also heat for district heating purposes; in addition, they open the possibility to remove carbon dioxide from the cycle not in gaseous but in liquid form, which is more convenient for transportation to a consumer and/or for storage. It is shown that the electrical efficiency of an installation based on the Allam cycle makes 58.1% and that of the JIHT cycle installation operating in the cogeneration mode makes 45.5% with the total fuel efficiency equal to 92.5%. If there is no heat supply, the JIHT cycle electrical efficiency approaches that of the Allam cycle. The calculations are supported by detailed presentation of the considered cycles on a T, s diagram. The processes in which the main exergy loss occurs are highlighted. A conclusion is drawn that the installations considered can really compete with the conventional power installations with carbon dioxide capturing by means of sorption and membrane methods. To verify the procedure and computation model, an exergetic analysis was preliminarily performed for a conventional GTU-110 simple cycle gas-turbine unit, a 325 MWe combined-cycle plant (CCP) based on this unit, and a Capstone C30 microturbine with regeneration. The key scientific-technical problems that have to be solved for successfully harnessing the considered innovative cycles are highlighted. They include the development of a regenerative heat exchanger with a recovery ratio higher than 95% operating at a temperature of approximately 1000 K, an oxy–fuel combustion chamber for a pressure above 30 MPa, and a combined-cycle turbine with working fluid with an inlet temperature of higher than 1400 K and pressure above 30 MPa. These problems do not seem to be more complex than those that were set forth and successfully solved in the development of modern high-temperature high-capacity gas-turbine units.

Keywords: decarbonization, power installation, oxy–fuel combustion, thermodynamic cycle, exergetic analysis, exergy, anergy, gas-turbine unit, carbon dioxide

Development of an Unshrouded Blade for Stage Two of a GTE-65.1 Turbine

A. V. Granovskii^{a, *, **}, I. V. Afanas'ev^a, V. K. Kostezh^a, N. I. Fokin^b, and M. G. Cherkasova^b

^a Lulka Development Design Bureau, Moscow, 129301 Russia

^b AO Power Machines—ZTL, LMZ, Electrosila, Energomachexport, St. Petersburg, 195009 Russia

*e-mail: andrey.granovskiy@okb.umpo.ru

**e-mail: andrey.granovskiy@yandex.ru

Abstract—The development of domestic gas turbine units designed for driving electric generators or mechanical equipment at gas-pumping stations has become a crucial technological area for the power industry. At present AO Power Machines is developing the GTE-65.1 gas turbine unit (GTU), whose prototype is the GTE-65.0 GTU designed in the early 2000s. The boundary conditions adopted in designing the flow path in the modified GTE-65.1 were the shapes of the meridional outline and of the blade rows in the GTE-65.0 turbine and the main parameters under the rated operating conditions. The possibility of creating a stage two unshrouded blade for the modified GTE-65.1 turbine is examined. This solution will reduce the cooling air flowrate, decrease the cooling losses and aerodynamic losses at the blade periphery, and eliminate problems of bringing the strength of the cooled shroud and of the blade proper to the required level by reducing stresses in the blade body and contour stresses in the wheel disk. The operating (service) costs in this case are the comparative costs for the restoration (reconditioning) of the blade with or without a cooled shroud to be incurred after the first interval of the operating cycle corresponding to approximately 25 000–33 000 equivalent gas hours. The results of computational studies performed by the 3D NS and Fluent software packages have demonstrated that an efficient rotor blade for stage two of the GTE-65.1 GTU can be designed without any shroud.

Keywords: shroud deformation, shrouded blades, unshrouded blades, tip clearance, gas dynamic losses, blade cooling scheme, loss factor, air flowrate

Simulation of the Coolant Hydrodynamics in the Outlet Section of the Fuel Assembly of the Cartridge Core of the RITM Type Reactor

**S. M. Dmitriev^a, T. D. Demkina^a, A. A. Dobrov^a, D. V. Doronkov^{a,*}, D. S. Doronkova^a, A. N. Pronin^a,
A. V. Ryazanov^a, D. N. Solntsev^a, and A. E. Khrabostova^a**

^a Nizhny Novgorod State Technical University (NNSTU), Nizhny Novgorod, 603950 Russia

**e-mail: nevid000@mail.ru*

Abstract—The results of experimental studies into the hydrodynamics of the coolant at the outlet section of the cassette fuel assembly (FA) of the RITM-type reactor of a low-power ground-based nuclear power plant are presented. The purpose of the work is to analyze the distribution of the axial velocity and flow rate of the coolant at the exit from the fuel bundle, in the modernized head of the fuel assembly, near the coolant extraction pipe and the openings of the upper base plate as well as to determine those areas of the fuel bundle from which the coolant flow is most likely to enter the pipe selection to the resistance thermometer. To achieve this goal, experiments were carried out on a research stand with an air working medium on a model of the outlet section of a fuel cassette, which includes an outlet fragment of a fuel bundle with spacer grids, models of an upgraded fuel cassette head, an upper support plate, and a coolant extraction pipe. When studying the flow of the coolant flow in the outlet part of the fuel cassette, the pneumometric method and the method of injection of a contrasting impurity were used. An area covering the entire cross section of the model was chosen as the area under study. The picture of the coolant flow is represented by cartograms of the distribution of its axial velocity and flow rate as well as cartograms of the distribution of the contrasting impurity in the cross section of the experimental model. The results of the experiments can serve as a basis for making engineering decisions when designing new cores of RITM type reactors. The obtained database of experimental data can be used for validation of modern CFD programs and one-dimensional thermal-hydraulic codes used to justify the thermal reliability of cores.

Keywords: nuclear reactor, core, fuel cassette, fuel rod, spacer grid, upgraded head, coolant extraction tube, axial velocity, axial flow rate, contrast agent, research stand, experimental model

Simulation of Halon Condensation Processes in Vertical Pipes by the VOF Method

K. B. Minko^{a, b, *}, G. G. Yankov^{a, b}, V. I. Artemov^b, and A. V. Ptakhin^{a, c}

^a Kaluga State University, Kaluga, 248023 Russia

^b National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^c NPVP Turbokon, Kaluga, 248010 Russia

*e-mail: minkokb@gmail.com

Abstract—The study of steam-condensation processes inside pipes of different orientation in space is an urgent task for many industrial applications, including the creation of heat-recovery plants based on the organic Rankine cycle. This paper presents the results of the validation of a mathematical model of a two-phase flow, which is based on the Volume of Fluid (VOF) on experimental data on the condensation of the downward flow of freon R-113 in a vertical round pipe. The data obtained by numerical simulation, both in terms of integral and local characteristics, are compared with experimental data for regimes with mass flux densities from 26 to 294 kg/(m² · s), saturation pressures from 10⁵ to 3 × 10⁵ Pa, and heat-flux densities up to 80 kW/m² for pipes with diameters of 9.0, 14.0, and 20.8 mm. The validation results showed the efficiency of the algorithm previously proposed by the authors for determining the relaxation coefficient in the Lee model for calculating condensation inside pipes. The best agreement between the calculations and the experimental data was found when using versions of Menter's SST turbulence model. Several simplified one-dimensional models of steam condensation inside pipes have been tested. Recommendations on the choice of the computational grid for the studied class of problems are presented. To describe the processes of halon condensation by the VOF method, the characteristic thickness of the liquid film should account for at least ten control volumes, and the longitudinal size of the film should not exceed half the capillary constant. It is shown that it is possible to calculate the heat-transfer characteristics using a coarser grid (with a longitudinal step of up to two capillary constants); however, in this case, waves do not appear on the film surface, which significantly affects the hydraulic characteristics of the flow.

Keywords: condensation inside pipes, freon, vertical pipe, numerical simulation, VOF method, modified Lee model, moving steam