

---

---

# Contents

---

---

**Vol. 70, No. 11, 2023**

---

---

## **Nuclear Power Plants**

Simulation of Melt Behavior in the Sodium-Cooled Reactor Core Catcher  
Using the EUCLID/V2 Integrated Computer Code HEFEST-FR Module

*A. A. Butov, D. D. Kamenskaya, I. A. Klimonov, N. A. Mosunova,  
E. V. Usov, S. V. Tsaun, and V. I. Chukhno*

Hydrodynamics of the Coolant in the Outlet Section of a Fuel Cartridge with Heads  
of Different Designs of the Reactor Core RITM of a Low-Power Nuclear Plant

*S. M. Dmitriev, T. D. Demkina, A. A. Dobrov, D. V. Doronkov, D. S. Doronkova,  
M. A. Legchanov, A. N. Pronin, A. V. Ryazanov, D. N. Solntsev, and A. E. Khrobostov*

---

## **Heat and Mass Transfer, Properties of Working Bodies and Materials**

Simulation of the Condensation Processes of HFC R113 in a Horizontal Pipe by the VOF Method

*G. G. Yankov, O. O. Milman, K. B. Minko, and V. I. Artemov*

Diagnostics of Transient Heat-Transfer Regimes during Boiling in a Large Volume  
on the Basis of the Wavelet Transformation of Temperature Fluctuations

*Yu. E. Litvintsova, D. M. Kuzmenkov, K. Yu. Muradyan, M. I. Delov, and K. V. Kutsenko*

Flow Conditioners for Pipelines with Sources of Acoustic Noise

*N. S. Dushin, A. A. Valeev, S. A. Kolchin, and O. A. Dushina*

Heat and Mass Transfer and Gas Distribution in a Steam-Water Volume  
with Noncondensable Gas

*A. A. Falkov, I. N. Kulakov, and E. A. Slepneva*

Approximate Analytical Solution of the Problem of Thermal Conductivity in a Pipe Wall  
with Variable Heat-Transfer Coefficients along the Perimeter

*V. A. Kudinov, E. V. Kotova, R. M. Klebleev, T. E. Gavrilova, and E. V. Stefanyuk*

---

## **Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment**

Some Features Relating to the Occurrence of Low-Frequency Vibration in Large Steam Turbines  
and Methods for Removing It

*A. I. Kumenko, A. M. Mironov, M. I. Shklyarov, and S. Yu. Evdokimov*

Analyzing the Change in the Acid Number of Fire-Resistant Fluids during Their Operation  
in Automatic Closed Loop Control Systems of Steam Turbines at Thermal Power Plants

*A. V. Okhlopkov, D. V. Shuvarin, K. A. Orlov, V. F. Ochkov, and A. V. Ryzhenkov*

Problems Connected with Operation of Fire-Resistant Oils and Ways for Solving Them

*R. V. Akulich and N. V. Arzhinovskaya*

---

## **Renewable Energy Sources and Hydropower**

Methods for Rendering Biosafety of Elements in Flow Paths of Hydraulic Turbines

*A. V. Volkov, V. Yu. Lyapin, A. A. Druzhinin, M. A. Biryulin,  
M. Tkach, I. V. Kachanov, and P. G. Ernandes*

Geoinformation Systems for Renewable Energy (Review)

*S. V. Kiseleva, N. V. Lisitskaya, O. S. Popel', Yu. Yu. Rafikova,  
A. B. Tarasenko, S. E. Frid, and V. P. Shakun*

---

## **Automation and Thermal Control in the Power Industry**

Experience in the Development and Implementation of Modern Systems of Automatic Frequency and Power Control of Large Power Units with Direct-Flow Boilers

*V. A. Bilenko, I. V. Tuzov, and D. Yu. Nikolsky*

---

## **Water Treatment and Water Chemistry**

Simulation of Droplet Entrainment in Multistage Flash Evaporating Units

*V. P. Zhukov, I. A. Kokulin, V. N. Vinogradov, and A. E. Barochkin*

---

Errata

---

---

# Simulation of Melt Behavior in the Sodium-Cooled Reactor Core Catcher Using the EUCLID/V2 Integrated Computer Code HEFEST-FR Module

A. A. Butov<sup>b</sup>, D. D. Kamenskaya<sup>a</sup>, I. A. Klimonov<sup>b</sup>, N. A. Mosunova<sup>a</sup>,  
E. V. Usov<sup>b</sup>, S. V. Tsaun<sup>a,\*</sup>, and V. I. Chukhno<sup>b</sup>

<sup>a</sup> Nuclear Safety Institute, Russian Academy of Sciences (IBRAE RAS), Moscow, 115191 Russia

<sup>b</sup> Novosibirsk Branch, Nuclear Safety Institute, Russian Academy of Sciences, Novosibirsk, 630090 Russia

\*e-mail: tsaun@ibrae.ac.ru

**Abstract**—For numerically simulating the melt behavior in the core catcher of a sodium-cooled reactor, the HEFEST-FR module—a software tool based on the SAFR computer code elaborated at the Nuclear Safety Institute, Russian Academy of Sciences, for simulating the meltdown and destruction of liquid metal-cooled fast reactor core components—has been developed and incorporated into the EUCLID/V2 integrated computer code. This module is intended for numerically simulating the melt retention and cooling-down processes in the reactor vessel with taking into account the heat transfer from the vessel's internal structures to the coolant. For this purpose, a 2D-problem (implying that there is no dependence of temperature on the azimuthal angle) of unsteady heat conduction for materials located in the reactor's core catcher tray is solved in a cylindrical coordinate system. The heat-conduction equation coefficients depend on time, coordinates, and temperature, the latter being the equation solution root. Boundary conditions of the first, second, and third kind are used, and heat loss by radiation at the boundary is specified. The total or volumetric decay heat power settles inside of the melt. For numerically solving the 2D heat-conductivity problem, an enthalpy approach based method is applied. The formulations used in the method make it possible to overcome, in a natural manner, the problem relating to discontinuity of material specific melting point enthalpy in solving the heat-conduction problem with taking phase transitions into account. The solution yields the temperature field in melting/freezing of materials (steels of various grades and fuel) in the fast reactor's core catcher tray. The results of verifying the HEFEST-FR module against the solution of an analytical problem have been demonstrated. Using the module, methodical computations of the fuel and fuel pin cladding melt behavior in the sodium-cooled reactor's core catcher have been carried out.

**Keywords:** HEFEST-FR, core catcher, integrated computer code, EUCLID/V2, fast reactor, sodium coolant, severe accident, melt

# Hydrodynamics of the Coolant in the Outlet Section of a Fuel Cartridge with Heads of Different Designs of the Reactor Core RITM of a Low-Power Nuclear Plant

S. M. Dmitriev<sup>a</sup>, T. D. Demkina<sup>a</sup>, A. A. Dobrov<sup>a</sup>, D. V. Doronkov<sup>a, \*</sup>, D. S. Doronkova<sup>a</sup>,  
M. A. Legchanov<sup>a</sup>, A. N. Pronin<sup>a</sup>, A. V. Ryazanov<sup>a</sup>, D. N. Solntsev<sup>a</sup>, and A. E. Khrobostov<sup>a</sup>

<sup>a</sup> *Alekseev Nizhny Novgorod State Technical University, Nizhny Novgorod, 603950 Russia*

*\*e-mail: nevid000@mail.ru*

**Abstract**—The results of experimental studies and a comparative analysis of the coolant hydrodynamics in the outlet section of the fuel cartridge behind heads of different designs are presented. The considered fuel assemblies are designed for installation in the core of a RITM-type reactor of a small ground-based nuclear power plant. The aim of the work was to study the distribution of the axial velocity and flow rate of the coolant at the outlet of the fuel bundle, behind the heads of different designs, and in front of the coolant extraction pipe and in the holes of the upper base plate as well as to determine the areas of the fuel bundle from which the coolant flow is most likely to enter the sampling pipe and, accordingly, to the resistance thermometer installed in this pipe. The experiments were carried out on a research aerodynamic stand with an air working medium on a model of the outlet section of the fuel cartridge, which includes a fragment of the outlet part of the fuel bundle with spacer grids, dummies of two types of heads, an upper support plate, and a coolant extraction pipe. When studying the coolant flow rate in the outlet part of the fuel cartridge, the pneumometric method and the method of contrast impurity injection were used. The measurements were carried out over the entire cross section of the model. The hydrodynamic picture of the coolant flow is represented by cartograms of the distribution of axial velocity, coolant flow rate, and contrast impurities in the cross section of the model. The results of the research were used by specialists from the design and calculation departments of Afrikantov OKBM to justify engineering solutions in the design of new cores of RITM reactors. The results of the experiments were compiled into a database and used in the validation of the LOGOS CFD program developed by the employees of RFNC-VNIIEF and ITMP Moscow State University as analogues to foreign programs of the same class, which include ANSYS, Star CCM+, etc. Experimental data are also used to validate one-dimensional thermal-hydraulic codes used in Afrikantov OKBM when substantiating the thermal reliability of the cores of reactor installations; the thermal-hydraulic code KANAL also belongs to this class of programs.

*Keywords:* fuel cartridge, head, fuel element, central displacer, drain windows, drain holes, base plate, extraction pipe, coolant hydrodynamics, flow mixing

# Simulation of the Condensation Processes of HFC R113 in a Horizontal Pipe by the VOF Method

G. G. Yankov<sup>a, b</sup>, O. O. Milman<sup>a, c</sup>, K. B. Minko<sup>b, \*</sup>, and V. I. Artemov<sup>b</sup>

<sup>a</sup> Tsiolkovsky Kaluga State University, Kaluga, 248023 Russia

<sup>b</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>c</sup> NPVP Turbokon, Kaluga, 248010 Russia

\*e-mail: [minkokb@gmail.com](mailto:minkokb@gmail.com)

**Abstract**—The results of a numerical analysis of the condensation of R113 freon vapor in a horizontal round pipe with a standard size of  $38 \times 3$  mm in the range of mass velocities from 50 to 150 kg/(m<sup>2</sup> s). Studies of the features of hydrodynamics and heat transfer in the stratified and stratified wave regimes of condensate flow are still relevant due to their insufficient knowledge. Thus, according to recent data, the heat-transfer intensities in the zone occupied by a brook and in the sections of the inner surface of a horizontal pipe wetted with a thin condensate film are comparable (have the same order of magnitude). Therefore, for an adequate assessment of the real contribution of the rill zone to the average heat transfer coefficient along the pipe perimeter, the existing methods should be refined. The VOF (Volume of Fluid) method was used to simulate a two-phase flow. The intensity of mass transfer was calculated using a modified Lee model in which the relaxation coefficient was determined automatically based on the algorithm proposed by the authors of this work in previous publications. To describe the turbulent transport, a version of Menter's SST turbulence model was used. Models of mass transfer, turbulent flows of a liquid film and vapor phase, VOF algorithms, and software tools that implement them were verified on experimental data on R113 freon condensation in a downward flow in a vertical pipe. Numerical modeling of condensation processes has been performed and the obtained data have been compared with the results of calculations using various methods recommended in the literature. Information is presented on the distribution of local characteristics along the length and perimeter of the pipe. It is noted that at low values of mass velocity [50 kg/(m<sup>2</sup> s)] at some distance from the pipe inlet, a hydraulic jump occurs, leading to a significant change in the distribution of the volume fraction of steam along the length of the channel.

**Keywords:** condensation, freon R113, horizontal pipe, numerical simulation, VOF method, modified Lee model, hydraulic jump

# Diagnostics of Transient Heat-Transfer Regimes during Boiling in a Large Volume on the Basis of the Wavelet Transformation of Temperature Fluctuations

Yu. E. Litvintsova<sup>a, b, \*</sup>, D. M. Kuzmenkov<sup>a</sup>, K. Yu. Muradyan<sup>a</sup>, M. I. Delov<sup>a</sup>, and K. V. Kutsenko<sup>a</sup>

<sup>a</sup> National Research Nuclear University Moscow Engineering Physics Institute, Moscow, 115409 Russia

<sup>b</sup> National Research Center Kurchatov Institute, Moscow, 115409 Russia

\*e-mail: ylitvintsova@mail.ru

**Abstract**—The aim of this work was to develop a method for diagnosing heat-transfer transition modes from convective to bubble boiling and from bubble to film boiling based on the analysis of heat-releasing surface temperature fluctuations using a discrete wavelet transform that has a number of advantages compared to the Fourier transform, which is traditionally used to obtain amplitude-frequency characteristics of temperature fluctuations and diagnosing a change in the heat-transfer mode. The developed method was tested on experimental data on heat transfer for the convective regime and bubble and film boiling of water and liquid nitrogen in a large volume at atmospheric pressure. It is shown that, in the convective heat-transfer mode, the energy of the coefficients of the wavelet expansion of the temperature fluctuations of the heat-releasing surface is mainly localized in the region of relatively low frequencies. When the nucleate boiling mode is reached, the energy distribution of the coefficients over the decomposition levels becomes more uniform and the appearance of high frequencies is noted. The forms of energy distributions of the expansion coefficients of temperature fluctuations for the convective heat-transfer regime and film boiling are similar, but the total energy of expansion coefficients for film boiling is an order of magnitude larger. According to the obtained results, new criteria for changing the heat-transfer regime are formulated that are based on determining the total energy of the coefficients of expansion of temperature fluctuations and the Shannon entropy of the distribution of the energy of the coefficients over expansion levels. The results of the work can be useful in creating a reliable automated system for diagnosing heat transfer, including in real time.

*Keywords:* temperature fluctuations, nucleate boiling, film boiling, boiling crisis, diagnostics, wavelet transform, convective regime, expansion coefficients

## Flow Conditioners for Pipelines with Sources of Acoustic Noise

N. S. Dushin<sup>a</sup>, \*, A. A. Valeev<sup>a</sup>, S. A. Kolchin<sup>a</sup>, and O. A. Dushina<sup>a</sup>

<sup>a</sup> *Institute of Power Engineering and Advanced Technologies of the Federal Research Center  
“Kazan Scientific Center of the Russian Academy of Sciences”, Kazan, 420111 Russia*

*\*e-mail: ndushin@bk.ru*

**Abstract**—The most popular way to transport natural gas is to use pipelines. However, complex spatial configuration of pipeline systems, as well as regulating devices and gate valves, break the uniformity and symmetry of the velocity profile, induce swirling flows, generate acoustic disturbance, and promote amplification of acoustic noise. It is almost impossible to estimate and take into account all these effects in gas metering. Therefore, the measurement uncertainty in complex conditions can be as high as 20%. It is reasonable to employ flow conditioners (FC) in order to increase the measurement accuracy. Their function is to form the flow with known characteristics. The existing FC models, however, were designed to deal with a limited set of flow histories and typically require calibration in combination with a flow meter. There are almost no FCs able to deal with a wide spectrum of flow histories and mitigate the effect of acoustics on the measurement accuracy. The study submits an approach to the design of the flow passage inside FC that addresses the described problems. The proposed FC has a cartridge containing a set of coaxial perforated streamwise cylinders nested within one another with a varied pitch along the diameter. An experimental model of the device demonstrated its effectiveness in velocity profile conditioning and reproducibility of profiles in steady and unsteady flows in pipelines of different spatial configurations. The Reynolds number range considered in the study spans from the lower threshold, at which the majority of flow meters operate, to the values at which the flow becomes self-similar. The acoustic efficiency was estimated for the frequency range of 5 Hz to 120 kHz. In general, the experimental model met all challenges successfully. At the same time, the shape of velocity profiles downstream of the device is somewhat different from the developed velocity profile in straight pipes. This problem will require optimization of the device geometry, which will be addressed in the future research.

*Keywords:* flow conditioner, flow meter, velocity profile, pipeline, pressure loss, acoustic noise, perforated plates, drag coefficient, Reynolds number

# Heat and Mass Transfer and Gas Distribution in a Steam-Water Volume with Noncondensable Gas

A. A. Falkov<sup>a, \*</sup>, I. N. Kulakov<sup>a</sup>, and E. A. Slepneva<sup>a</sup>

<sup>a</sup> *Afrikantov Experimental Design Bureau of Mechanical Engineering (OKBM), Nizhny Novgorod, 603074 Russia*

*\*e-mail: okbm@okbm.nnov.ru*

**Abstract**—Heat and mass transfer and gas distribution in a nonequilibrium steam-water volume with a phase separation level containing a noncondensable gas are considered. These processes relate primarily to the steam–gas pressure compensator (SGPC) of the integrated reactor and determine the behavior of the SGPC in normal and emergency modes. Similar processes occur in a pressurized water reactor and in a containment volume at the final stage of emergency regimes with loss of coolant. For low-power reactors of the RITM-200 type with a gas pressure compensator, it is necessary to take into account the phenomena associated with the behavior of noncondensable gases. A brief description is given of the GARRIC 2.2 computer program for calculating the distribution of noncondensable gases in the primary circuit and the characteristics of the SGPC of a pressurized water reactor of an integrated layout. The description of the processes of heat and mass transfer and gas distribution is based on the results of experiments carried out on SGPC models in a wide range of parameters and gas contents. Calculation of mass transfer, including vapor evaporation and condensation, and gas transfer on the mirror is carried out using the analogy model of heat and mass transfer under conditions of natural convection of the medium. The results of the verification of the GARRIC 2.2 program on the basis of experimental data obtained in the study of vapor condensation on the walls, evaporation on the free surface of water, and gas distribution in the vapor–gas volume at full-scale parameters are presented. The GARRIC 2.2 program was certified by Rostekhnadzor in 2014.

**Keywords:** pressurized water power reactor, pressure compensator, noncondensable gas, gas–vapor mixture, gas distribution, heat and mass transfer, evaporation, condensation, gas dissolution, phase separation level



# Approximate Analytical Solution of the Problem of Thermal Conductivity in a Pipe Wall with Variable Heat-Transfer Coefficients along the Perimeter

V. A. Kudinov<sup>a</sup>, E. V. Kotova<sup>a, \*</sup>, R. M. Klebleev<sup>a</sup>, T. E. Gavrilova<sup>a</sup>, and E. V. Stefanyuk<sup>a</sup>

<sup>a</sup> Samara State Technical University, Samara, 443100 Russia

\*e-mail: larginaevgenya@mail.ru

**Abstract**—Based on the definition of an additional function and additional boundary conditions in the integral heat balance method, an approximate analytical solution is obtained for a nonstationary two-dimensional heat conduction problem for an infinite hollow cylinder under boundary conditions of the third kind with variable heat-transfer coefficients in the circumferential direction. An additional function describes the change in temperature over time at one particular point in the spatial variable. Using it, one can reduce the solution of the original partial differential equation to the integration of an ordinary differential equation, from which the eigenvalues of the boundary value problem are found. That is, a different concept of determining eigenvalues based on the time equation with respect to an additional function is presented, in contrast to classical methods, where eigenvalues are found when solving the Sturm–Liouville boundary value problem for a region of a spatial variable. The assignment of additional boundary conditions is the solution of the original equation at the boundary points. It is shown that solving the equation at the boundary points leads to its solution inside the considered region as well. Additional boundary conditions are derived using the original differential equation and basic boundary conditions. Repeatedly differentiating the equation with respect to the spatial variable, and the boundary conditions with respect to time, by comparing the obtained relations, one can find any number of additional boundary conditions. The accuracy of solving the equation inside the considered region depends on the number of approximations, and, consequently, on the number of additional boundary conditions used. The approximate analytical solution obtained in this way is characterized by a simple design that is convenient for use in engineering applications.

**Keywords:** boundary conditions of the third kind, variable heat-transfer coefficients, integral heat-balance method, additional functions, additional boundary conditions, approximate analytical solution

# Some Features Relating to the Occurrence of Low-Frequency Vibration in Large Steam Turbines and Methods for Removing It

A. I. Kumenko<sup>a, \*</sup>, A. M. Mironov<sup>b</sup>, M. I. Shklyarov<sup>b</sup>, and S. Yu. Evdokimov<sup>b</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> AO Power Machines, St. Petersburg, 195009 Russia

\*e-mail: KumenkoAI@mpei.ru

**Abstract**—The article addresses general matters concerned with the occurrence of low-frequency vibration (LFV) in turbine units. It is pointed out that, despite the level of knowledge that has been achieved in regard to LFV, it still arises from time to time in power plant turbine units. Along with LFV caused by aero- and hydrodynamic excitation, LFV can also bear a subharmonic pattern. It is emphasized that the measures taken to remove LFV depend on the LFV occurrence origin. The article presents LFV occurrence and removal examples, including those relating to the use of honeycomb seals in high-pressure cylinders. With honeycomb seals, decreased sizes of channels and an increased channel component of overshroud forces caused by aerodynamic excitation are typically observed. It is pointed out that, in some cases that involve rotor rubbing against the stator, a multicomponent LFV with subharmonic and self-oscillation components is observed. It is shown that the regulatory documents do not contain criteria for estimating a multicomponent vibration in the low-frequency band. It is pointed out that multicomponent LFV can be a diagnostic indicator pointing to rubbing of the rotor against the babbit or seals. Recommendations on removing LFV of various origins are suggested. A diagnostic table that helps determine factors causing the LFV and that produces recommendations on increasing the turbine units operational reliability is given. It is stated for the first time that the turbine thrust bearing can behave as a source of oil excitation. It is also noted that the conditions under which a self-oscillation type LFV occur and its suppression methods should differ from the methods for suppressing self-excited LFV of a subharmonic nature.

**Keywords:** plain bearing, turbine unit, low-frequency vibration, subharmonic vibration, honeycomb seals, recommendations on reducing vibration, contradictions in the regulatory framework

# **Analyzing the Change in the Acid Number of Fire-Resistant Fluids during Their Operation in Automatic Closed Loop Control Systems of Steam Turbines at Thermal Power Plants**

**A. V. Okhlopkov<sup>a,\*</sup>, D. V. Shuvarin<sup>a</sup>, K. A. Orlov<sup>b</sup>, V. F. Ochkov<sup>a</sup>, and A. V. Ryzhenkov<sup>a</sup>**

*<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*<sup>b</sup> OOO Trieru, Moscow, 111250 Russia*

*\*e-mail: OkhlopkovAV@mpei.ru*

**Abstract**—Fire-resistant fluids and lubricants are products that are used in various industry branches for ensuring reliability and safety of equipment operating under conditions of high temperatures and pressures and flame impact. For the last 30–50 years, industry-grade fire-resistant fluids, which feature high thermal stability and do not ignite when coming in contact with flame, have become commercially available in the world market. The article presents the results obtained from long-term studies of such fluids during their operation in the automatic closed loop control systems of steam turbines (STs) of condensing and cogeneration units of thermal power plants (TPPs) located in different regions of Russia and abroad (more than 50 life cycles of these fluids have been analyzed). The reasons for using synthetic compounds in the power industry are described along with the properties in which they differ from petroleum oils, and trends and prospects of applying noncombustible liquids in Europe and Russia are formulated. The aims of the study were to determine the most essential reasons why the standard operation times of fire-resistant fluids were shortened and to develop a procedure for determining the product quality and predicting the life cycle of such fluids (the procedure itself will be addressed in our next publication). Intermediate study objectives were to substantiate the approximation of the input data obtained as a result of their collection and to divide the facilities at which these fluids are used into certain categories. The change in the performance characteristics of fire-resistant fluids during their operation in the control systems of steam turbines of various types at different thermal power plants is analyzed. The most significant factors influencing the extension of fire-resistant fluids' service life are reviewed, and measures aimed at preventing degradation of their quality have been analyzed (regeneration, use of oil purification plants, replenishing, etc.).

**Keywords:** fire-resistant fluids, automatic closed loop control system, steam turbines, acid number, varnish formation potential, oil purification installations, ion exchange

# Problems Connected with Operation of Fire-Resistant Oils and Ways for Solving Them

R. V. Akulich<sup>a, \*</sup> and N. V. Arzhinovskaya<sup>a</sup>

<sup>a</sup> *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

<sup>\*</sup>*e-mail: RVAkulich@vti.ru*

**Abstract**—In the mid 20th century, type OMTI fire-resistant oil (fire-resistant oil of the thermal engineering institute), whose production technology was developed by specialists of the All-Russian Thermal Engineering Institute (VTI), received wide use at Russian and also at some foreign power plants. Type OMTI oil is distinguished by its high fire-resistant qualities, good lubrication properties, high thermal oxidation and hydrolytic stability, and long service life. Its drawback, as of any phosphorus esters, is sensitivity to the presence of water and increased temperatures, the action of which destructs the fluid with generation of acidic products. This process is “autocatalytic” in nature with a rather quickly reached unacceptable acidic level, at which the replacement of oil may be required. Nowadays, in view of the fact that fire-resistant oils are widely used but have a high cost, matters concerned with supporting the operation of fire-resistant oils and also extending their service life are becoming of much relevance. Another important issue is searching for efficient methods to restore the qualitative characteristics of spent oils that have been accumulated at power industry enterprises with the aim of repeatedly using them as hydraulic fluid or raw material for obtaining new oil. For extending the service life of operating oils and restoring spent oils to the required characteristics, oil purification plants, in which the fluids are subjected to sorption purification and acid destruction products are removed, are required. To ensure the effectiveness of the implemented processes, the sorbent must comply with certain criteria. It should be noted that stable operation of the power industry is essential for the energy security of the state; therefore, it is necessary to commence work on developing the compositions of a new type of fire-resistant oils on the basis of *tert*-butylphenyls and also elaborating the technology for manufacturing them and estimating the possibility to implement the process at existing industrial chemical sites. The manufacture of the new type of oils must be accompanied by the development of corresponding regulatory documents.

**Keywords:** fire-resistant fluids, OMTI oil, triaryl phosphates, trixylenil phosphates, degradation, hydrolysis, acid number, oxychloride, regeneration, fire-resistant oil of a new type

# Methods for Rendering Biosafety of Elements in Flow Paths of Hydraulic Turbines

A. V. Volkov<sup>a</sup>, V. Yu. Lyapin<sup>a</sup>, A. A. Druzhinin<sup>a</sup>, M. A. Biryulin<sup>a</sup>, \*,  
M. Tkach<sup>a</sup>, I. V. Kachanov<sup>b</sup>, and P. G. Ernandes<sup>c</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

<sup>b</sup> Belarusian National Technical University, Minsk, 220013 Republic of Belarus

<sup>c</sup> Empresa de Mantenimiento a Centrales Eléctricas,  
Unidad de Servicios Técnicos 100 y 69, Marianao, Cuba, 11500 Ciudad de la Habana

\*e-mail: biriulinma@mpei.ru

**Abstract**—Hydroelectric power belongs to renewable energy sources and contributes a considerable percentage of the electrical energy generated in the world. Its advantages include no carbon dioxide emission, excellent maneuverability, and high energy effectiveness. However, disadvantages do also exist caused by the influence of hydropower facilities on the bioenvironment. This paper presents a review of the most characteristic effects of elements of the flow path of hydroturbines during their operation on biofauna (fish and plankton). The most popular design solutions are examined, which are aimed at reducing the risk of negative impact of the elements of the flow path of hydraulic turbines on the bioenvironment. Obviously, the implementation of these solutions will deteriorate the performance of hydraulic turbines. However, we should bear in mind that the main purpose of these solutions is to ensure the biological safety of facilities, while their energy characteristics do not receive proper attention. The paper presents in some detail an option for rendering environmental safety, which is the modernization of the runner hub by eliminating the gaps between the blades and the hub. Numerical simulation has revealed that the application of a runner with the modified hub increases the hydraulic resistance, decreases the flowrate, and, as a result, reduces the generated power. An analysis of the simulation results has suggested that, despite some decrease in the energy characteristics, we should investigate in more detail and improve the biologically safe version of the hydraulic turbine flow path. In addition, a conclusion has been made that the flow path can be further modified to compensate for power losses.

**Keywords:** hydroturbines, biosafe hydroturbines, runner spherical hub, CFD-simulation, biological resources, pressure difference, cavitation

## Geoinformation Systems for Renewable Energy (Review)

S. V. Kiseleva<sup>a, b, \*</sup>, N. V. Lisitskaya<sup>b</sup>, O. S. Popel'<sup>b</sup>, Yu. Yu. Rafikova<sup>a</sup>,  
A. B. Tarasenko<sup>b</sup>, S. E. Frid<sup>b</sup>, and V. P. Shakun<sup>a</sup>

<sup>a</sup> *Moscow State University, Moscow, 119991 Russia*

<sup>b</sup> *Joint Institute for High Temperatures, Russian Academy of Sciences (JIHT RAS), Moscow, 125412 Russia*

*\*e-mail: k\_sophia\_v@mail.ru*

**Abstract**—A brief review is presented of geoinformation systems (GIS) intended for collection, storage, integration, analysis, and graphical interpretation of spatial and temporal data on various technologies for the application of renewable energy sources (RESs) to make substantiated decisions on the development of RES-based energy (hereinafter referred to as renewable energy). The development of the geoinformation system “Renewable Energy Sources of Russia” (GIS “RES of Russia”) commenced in 2010 and was performed by specialists from the Faculty of Geography of Moscow State University and JIHT RAS. It is focused on the spatial mapping of solar and wind energy resources in the territory of Russia. The initial data for the assessment of these resources are formed mainly on the basis of satellite measurements, mathematical modeling, and verification of the results against ground-based meteorological observations. The geographic information system also contains data on existing and designed renewable energy facilities and scientific, educational, and commercial organizations engaged in this area. As the geoinformation system has been developing, it has been supplemented with information on the distribution of geothermal energy resources and the energy of small rivers over the territory of Russia as well as with estimates of the specific capacity of solar and wind energy installations, the gross and technical potential of crop, livestock, horticulture, and viticulture waste. The paper briefly describes the methods and approaches employed for the development of GIS, including those for improvement of the spatial resolution of resource data and calculation of the technical potential of renewable energy sources considering hi-tech advancements; lines for further development and improvement of the domestic geoinformation system are formulated.

**Keywords:** geoinformation system, renewable energy, resources, gross and technical potential, capacity of installation, energy-generating facilities

# Experience in the Development and Implementation of Modern Systems of Automatic Frequency and Power Control of Large Power Units with Direct-Flow Boilers

V. A. Bilenko<sup>a, \*</sup>, I. V. Tuzov<sup>a</sup>, and D. Yu. Nikolsky<sup>a</sup>

<sup>a</sup> AO Intermatic, Moscow, 115280 Russia

\*e-mail: bilenko@intermatic.energy

**Abstract**—This work reflects many years of experience in the development and implementation of an automated process control system at traditional power units with a capacity of 300 to 800 MW. It is part of a series of articles devoted to multiply connected automatic control systems, their development in accordance with modern requirements for maintaining the frequency and power of the power system. The interrelations of the main circuits of automatic control of power units and ways to neutralize the negative interrelations between them are described in detail. The problems of regulating the frequency and power of power units and solving power system problems are considered. A simplified matrix of the power unit control object is presented. Three types of autonomy (autonomy I, II, and III) and the relationship between the main leading and driven operating parameters of the power unit are considered. The advantages of the combined variant of the implementation of the automatic power control system (APCS) are shown, which makes it possible to use each technological solution regardless of the current mode of operation of the power unit. A method for neutralizing the interconnections between local automatic control systems (LACS) both in the APCS-1 structure and in the combined APCS is described in detail by switching on compensation devices with the implementation of the invariance of the main controlled variables during disturbances in the boiler's operation. Methods have been developed and improved to improve the dynamics of regulation of important technological parameters. The developed structural solutions for equipment automation are widely used in the implementation of distributed automated control systems. The schemes of the main channels of automatic control of the power units considered in the article are given, in the process of adjusting the process control systems of which positive results were obtained. The implementation of the optimal settings for the main control loops ensures an increase in the quality of the control processes of the power unit as a whole.

*Keywords:* raw coal feeders, pulverized coal power units, oil-gas power units, technological groups of power unit regulators, automatic control system, block diagram

# Simulation of Droplet Entrainment in Multistage Flash Evaporating Units

V. P. Zhukov<sup>a, \*</sup>, I. A. Kokulin<sup>a</sup>, V. N. Vinogradov<sup>a</sup>, and A. E. Barochkin<sup>a</sup>

<sup>a</sup> *Ivanovo State Power Engineering University, Ivanovo, 153003 Russia*

*\*e-mail: zhukov-home@yandex.ru*

**Abstract**—Evaporators are widely used in industrial processes to produce thermally treated distillate by evaporation with concentration of impurities in the bulk of water. As to their thermal efficiency, multistage flash evaporators (MFEs) belong to one of the most promising types of evaporating equipment, in which the consumption of thermal energy for evaporating water in each stage is compensated for by the recovery of this energy in heating the treated water during the condensation of the produced steam. Improvement of the methods for design and operation of these units on the basis of mathematical models of heat- and mass-transfer processes is an urgent problem facing developers and designers of evaporative equipment. Within the scope of the performed study, a combinatorial model is proposed for calculation of the size distribution of superheated water droplets during evaporation in the low-pressure zone of the dirty compartment of an MFE. A mathematical model was developed of a droplet separator designed to prevent water droplet entrainment and ingress of impurities into the distillate. The flowrates of distillate and treated water and the content of impurities in these flows were calculated for each stage of the evaporation unit, taking into consideration the water droplet entrainment from the dirty compartment. The effect of droplet entrainment in multistage evaporators on the quality of distillate was assessed. An approach has been proposed to the design of multistage evaporators providing the specified process indicator under different operating conditions. This approach can also be used in the construction of regime maps of equipment, implementation of measures to improve the efficiency of equipment, and development of systems for diagnostics of heating surface in the evaporators for proper condition.

*Keywords:* evaporators, droplet entrainment, heat and mass transfer, combinatorial model, matrix model, water separation, impurity concentration, mineralized water