

Contents

Vol. 71, No. 3, 2024

Nuclear Power Plants

Validation of the Numerical Model of the RVK-500 Hydrogen Recombinator

*S. G. Kalyakin, A. V. Koshcheev, M. K. Sedov, S. L. Solovyov,
E. V. Bezgodov, V. V. Stakhanov, and V. A. Simonenko*

5

Development of Design Solutions for a Phase Transition Battery under Conditions of Its Operation in a Single Energy Complex with an NPP

R. Z. Aminov, M. V. Garievsky, and D. M. Anoshin

18

Increasing the Power Output of VVER-Based NPPs through More Accurately Monitoring the Thermal Efficiency Indicators

Yu. V. Smolkin, S. A. Kanatov, D. A. Sobolev, D. V. Stepanov, and E. N. Kulakov

32

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Selection of a Heat-Recovery Turbine Unit for a Self-Contained Power Supply of Compressor Stations in Gas Mains

*V. E. Mikhailov, M. A. Vertkin, S. B. Esin, P. A. Kruglikov, D. A. Sobolev,
Yu. G. Sukhorukov, and L. A. Khomenok*

40

Steam Boilers, Energy Fuel, Burners and Auxiliary Equipment for Boilers

Concept of a Regional Liquefied Natural Gas Fuel Complex Based on a Thermal Power Plant

*V. B. Perov, M. V. Fedorov, O. O. Milman, D. N. Zhedyaevsky, A. N. Vivchar,
A. A. Ivanovsky, A. V. Okhlopov, K. S. Nikishov, and A. V. Skazochkin*

54

Prospects for Obtaining Carbon Sorbents from D and DG Grade Coals

S. A. Shevyrev, S. S. Azikhanov, A. R. Bogomolov, and A. B. Kuznetsov

63

Heat and Mass Transfer and Properties of Working Fluids and Materials

The Vapor–Liquid Phase Equilibrium Line for Water within the Framework of the Renormalization Group Theory

S. V. Rykov, I. V. Kudryavtseva, V. A. Rykov, V. F. Ochkov, and E. E. Ustyuzhanin

72

Hydrogen-Accumulating Materials Based on Titanium and Iron Alloys (Review)

M. V. Lototsky, M. W. Davids, V. N. Fokin, E. E. Fokina, and B. P. Tarasov

85

Renewable Energy Sources, Hydropower

Studying the Possibility of Applying Barium-Strontium Cobaltite in Hydrogen Energy

*M. S. Paizullakhanov, N. Kh. Karshieva, F. N. Ernazarov,
S. M. Abduraimov, and S. S. Sabirov*

102

Errata

108

Validation of the Numerical Model of the RVK-500 Hydrogen Recombinator

**S. G. Kalyakin^a, A. V. Koshcheev^{a, *}, M. K. Sedov^a, S. L. Solovyov^a, E. V. Bezgodov^b,
V. V. Stakhanov^b, and V. A. Simonenko^b**

^a AO VNIIAES, Moscow, 109507 Russia

^b Zababakhin RFNC-VNIITF, Snezhinsk, Chelyabinsk oblast, 456770 Russia

**e-mail: avkoscheev@vniiaes.ru*

Abstract—If severe accidents occur at nuclear power plants with light water coolant, large quantities of hydrogen may be released as a result of the zirconium-steam reaction. In order to avoid explosive consequences, passive catalytic hydrogen recombiners (PCHR) are installed in the containment building (CB) to remove hydrogen flamelessly. To substantiate the hydrogen explosion safety of nuclear power plants using computer modeling, calculations of the state of the vapor-gas atmosphere inside the CB are performed, taking into account the presence of PCHR. Experimental data are needed to validate computational models of recombinators. The article presents the results of a comparison of experimental and calculated data on the characteristics of the RVK-500 hydrogen recombiner. A brief description of the BM-P experimental stand is given, on which, for the first time in Russia, it was possible to study the operation of an industrial recombiner in abnormal operating modes (start modes and modes with leakage flow). To simulate abnormal operating modes of the recombinator, a CFD model is used, which describes the flow inside the recombinator in a simplified formulation (based on volumetric energy sources and the concentration of components of the vapor-gas medium). A description of the CFD model used to solve the problem of simulating the operation of the BM-P stand with the RVK-500 recombinator installed (inside the measuring chamber) is presented. For the experimental mode with leakage flow, a detailed comparison was carried out with the results of calculations performed using sensor readings (temperature and concentration of components of the vapor-gas medium). In total, calculated and experimental data on the performance of the recombinator were compared for seven experimental modes, including the normal operation mode of the recombiner under conditions of a “quiet” environment.

Keywords: hydrogen recombinator, CFD model validation, hydrogen explosion safety, accident modeling, experiment, nuclear power plant

Development of Design Solutions for a Phase Transition Battery under Conditions of Its Operation in a Single Energy Complex with an NPP

R. Z. Aminov^{a, *}, M. V. Garievsky^a, and D. M. Anoshin^a

^a *Gagarin Saratov State Technical University, Saratov, 410054 Russia*

**e-mail: oepran@inbox.ru*

Abstract—Given the growing share of nuclear power plants in the energy systems of the European part of Russia and the shortage of flexible generating capacities, there is a need to attract nuclear power plants to participate in covering the variable part of the electrical load schedule. The use of storage units, such as phase change thermal accumulators, capable of storing thermal energy received from nuclear power plant reactor units during off-peak hours in the power system and using it during peak load hours to generate electricity will improve the system efficiency of nuclear power plants. Based on the analysis, promising heat storage materials (HSM) with a phase transition were identified for operation in thermal storage systems at temperatures from 200 to 300°C, which is determined by the characteristics of the steam turbine plant of a nuclear power plant, including the parameters of feed water and fresh steam. For the adopted installation scheme with a phase-change storage unit (PSU) with an increase in the temperature of the feed water after the high-pressure heaters of a double-circuit nuclear power plant, the methodological basis for choosing design solutions for the storage system with lithium nitrate as a heat-storing material has been developed. Using the finite element method in a computer software package, modeling of unsteady heat exchange between this material and water for finned and unfinned pipes was carried out in relation to the elementary section of PSU. Based on the calculation results, graphs of the dependence of the thermal power of the section on the duration of PSU discharge were constructed. Methods are proposed for calculating the duration of PSU discharge and the mass of the required heat-storing material when reducing thermal power. For a scheme with an additional steam turbine unit with a capacity of 12 MW (for NPP power units with VVER-1200), the main characteristics of the phase change accumulator and the effectiveness of the proposed solution for different PSU discharge durations are determined.

Keywords: nuclear power plant, thermal storage, phase change battery, phase change material, mathematical modeling, finite element method

Increasing the Power Output of VVER-Based NPPs through More Accurately Monitoring the Thermal Efficiency Indicators

Yu. V. Smolkin^a, S. A. Kanatov^b, D. A. Sobolev^a, D. V. Stepanov^a, and E. N. Kulakov^a, *

^a *Polzunov Research and Production Association for Investigation and Design of Power-Generating Equipment (NPO TsKTI), St. Petersburg, 191167 Russia*

^b *AO Atomtekhnenergo, Moscow Branch, Tsentratomtekhnenergo, 109044 Russia*

**e-mail: scheme@ckti.ru*

Abstract—Monitoring of thermal efficiency is of utmost importance for securing efficient NPP operation. To this end, the measurement instruments should have accuracy sufficient for the possibility of determining the actual values of thermal cycle circuit parameters, thermal efficiency, and deviations of the turbine set characteristics from their standardized indicators. The error with which the reactor thermal power is determined using the reactor core thermal-physical parameters and the steam generator parameters is estimated. It is shown that the best accuracy of determining the reactor thermal power can only be achieved through improving the accuracy of determining the steam generator thermal power. An analysis has shown that the error of determining the reactor thermal power is by more than 95% due to the error of determining the feed water flowrate. If we succeed in achieving more accurate determination of the reactor thermal power, it will be possible to obtain more accurate data on the electricity generation during operation at the nominal parameters in the mode with a specified neutron power due to maintaining of the reactor plant's actual thermal power closest to its design value; in addition, it will be possible to extend the range of power outputs available for operation during operation in the mode of maintaining the specified electric power output by increasing its maximal value. Given the specified period of NPP operation, the maximum of its energy production serves as one of the criteria for economically efficient NPP operation. By using the developed mathematical model of the turbine set used in the NPP constructed according to the AES-2006 conceptual design (with a VVER-1200 reactor), the authors have revealed the effect of the error of determining the thermal cycle circuit parameters on the power unit electric power output and the parameters that have the highest influence on the error of estimating the electric power output. The influence of the error of determining the turbine thermal parameters, moisture separation and steam reheating, high- and low-pressure regeneration, and the turbine set low-grade heat part was analyzed, and the total error of determining the electric power output has been obtained based on the analysis results. These data make it possible to formulate the requirements for the accuracy of flowrate, temperature, and pressure measurements depending on the allowable error of determining the electric power output. An analysis of the operational data of the Leningrad-2 NPP, Novovoronezh-2 NPP, and Belarussian NPP power units has shown that the potential of increasing the electric power output due to improved accuracy of determining the thermal cycle circuit parameters makes 10–15 MW.

Keywords: NPP, turbine set, thermal efficiency, parameters, measurement error, power unit output, economic efficiency, measurement instruments

Selection of a Heat-Recovery Turbine Unit for a Self-Contained Power Supply of Compressor Stations in Gas Mains

V. E. Mikhailov^a, M. A. Vertkin^{a, *}, S. B. Esin^a, P. A. Kruglikov^a, D. A. Sobolev^a,
Yu. G. Sukhorukov^a, and L. A. Khomenok^a

^a *Polzunov Scientific and Development Association on Research and Design of Power Equipment,
St. Petersburg, 191167 Russia*

**e-mail: VertkinMA@ckti.ru*

Abstract—Two design options for a heat-recovery turbine unit (HRTU), which generates electricity for self-contained power supply of gas mains' compressor stations (GMCSs) using the heat of exhaust gases from gas-turbine engines (GTEs) driving gas-pumping units (GPUs), are examined. The working fluid of the recovery circuit is octafluorocyclobutane (c-C₄F₈, engineering name is RC318) in one of the two HRTUs and the exhaust gases of GPU GTE in the other HRTU. The HRTU operating on RC318 has a three-circuit cycle, including three turbines, three recuperative heat exchangers, three RC318 heaters, and one common condenser. An alternative design of HRTU is a vacuum-type GTU consisting of an overexpansion gas turbine, whose inlet is connected with the exhaust of GPU GTE, exhaust gas coolers, a cooled gas compressor, and an induced-draft fan. The excess power of this HRTU above the current power demand at the GMCS is used to create a vacuum at the exhaust of the gas turbine of the GPU GTE. The results are presented of the comparative balance calculations of parameters and characteristics of both HRTUs as applied to a 16-MW Ural GPU GTE. They were performed using the updated initial data and the same software library RefProp (in the CoolProp high-level interface) for the calculation of thermodynamic parameters of working fluids. It has been demonstrated that a more compact and easier to implement gas-type HRTU (with an overexpansion gas turbine), although having a lower power than the RC318-type HRTU, can still fully cover the demand of the GMCS for high-quality power. The power of the gas turbine unit, which exceeds the current power consumption at the GMCS, can be utilized to cut down the fuel consumption by the GPU GTE and also to solve the problem of substituting imported gas piston and diesel generators at the GMCS within the shortest possible time and with the lowest capital and operating expenditures.

Keywords: heat-recovery turbine unit, self-contained power supply of compressor stations, import substitution, octo fluorocyclobutane, overexpansion gas turbine, primary control of turbine generator shaft speed

**ПАРОВЫЕ КОТЛЫ, ЭНЕРГЕТИЧЕСКОЕ ТОПЛИВО,
ГОРЕЛОЧНЫЕ УСТРОЙСТВА
И ВСПОМОГАТЕЛЬНОЕ ОБОРУДОВАНИЕ КОТЛОВ**

**КОНЦЕПЦИЯ РЕГИОНАЛЬНОГО ТОПЛИВНОГО КОМПЛЕКСА
СЖИЖЕННОГО ПРИРОДНОГО ГАЗА
НА БАЗЕ ТЕПЛОЙ ЭЛЕКТРОСТАНЦИИ**

© 2024 г. В. Б. Перов^а*, М. В. Федоров^б, О. О. Мильман^с**, Д. Н. Жедяевский^д,
А. Н. Вивчар^е,^и, А. А. Ивановский^ф, А. В. Охлопков^е, К. С. Никишов^е, А. В. Сказочкин^г,^h

^аНаучно-производственное внедренческое предприятие “Турбокон”,
ул. Комсомольская Роцца, д. 43, г. Калуга, 248010 Россия

^бООО “Газпром энергохолдинг”, ул. Шкиперский Проток, д. 12, корп. 2, стр. 1, Санкт-Петербург, 199106 Россия

^сКалужский государственный университет им. К.Э. Циолковского,
ул. Степана Разина, д. 26, г. Калуга, 248023 Россия

^дРоссийский государственный университет нефти и газа (НИУ) им. И.М. Губкина,
Ленинский просп., д. 65, Москва, 119991 Россия

^еПАО “Мосэнерго”, просп. Вернадского, д. 101, корп. 3, Москва, 119526 Россия

^фПАО “Силовые машины”, ул. Ватутина, д. 3, Лит. А, Санкт-Петербург, 195009 Россия

^гООО “Криокон”, ул. Комсомольская Роцца, д. 43, г. Калуга, 248010 Россия

^hООО “ТЕРМОКОН”, ул. Комсомольская Роцца, д. 43, г. Калуга, 248010 Россия

^иРоссийский университет дружбы народов, ул. Миклухо-Маклая, д. 6, Москва, 117198 Россия

*e-mail: perov@turboconkaluga.ru

**e-mail: turbocon@kaluga.ru

Поступила в редакцию 09.06.2023 г.

После доработки 19.08.2023 г.

Принята к публикации 30.08.2023 г.

Предложена концепция создания на базе тепловых электростанций региональных топливных комплексов сжиженного природного газа (СПГ), обеспечивающих расширение и надежное функционирование рынка газового топлива. Концепция предусматривает перевод систем топливного резервирования объектов электроэнергетики на СПГ, который производится непосредственно на электростанциях, а также поставки СПГ с электростанций региональным потребителям. Приведено описание зарубежной установки для гашения пиков газопотребления – наиболее близкого аналога электростанции с системой топливного резервирования на СПГ. Сравнительный технико-экономический анализ проектов создания мазутного хозяйства и системы резервного топлива на СПГ для ТЭЦ-22 ПАО “Мосэнерго” показал, что при сопоставимых капитальных затратах резервирование с использованием СПГ может дать экономический эффект до 654 млн руб. в год в ценах 2023 г. Отмечено, что при наличии больших объемов хранения СПГ могут быть обеспечены пиковые отгрузки топлива потребителям, а нормативный запас будет восстановлен с помощью установки сжижения. Приведены данные для расчета затрат и инвестиций, необходимых для создания комплексов, гарантирующих поддержание нормативных аварийных запасов топлива в виде СПГ для энергоблока ПГУ-220 (1778 млн руб. без НДС). Предложена методика распределения затрат комплекса аварийного топлива, относимых на себестоимость электрической мощности и СПГ, реализуемого сторонним потребителям. Показано, что относительное увеличение капитальных затрат на возведение ПГУ-220 с аварийным топливом в виде СПГ по отношению к аналогичным затратам на энергоблок с аварийным дизельным топливом составляет 1%. Выполнена оценка себестоимости собственного производства СПГ. Экономия при первичном формировании нормативных аварийных запасов для энергоблока составила 72.45 млн руб. Сформулировано преимущество создания сети комплексов СПГ: запасы резервного и аварийного топлива на тепловых электростанциях обеспечивают надежное топливоснабжение региональных рынков.

Ключевые слова: сжиженный природный газ, тепловая электростанция, газомоторное топливо, дизельное топливо, мазут, резервное топливо, аварийное топливо, пиковое газопотребление, парогазовая установка, газотурбинная установка

Prospects for Obtaining Carbon Sorbents from D and DG Grade Coals

S. A. Shevyrev^{a, *}, S. S. Azikhanov^a, A. R. Bogomolov^a, and A. B. Kuznetsov^a

^a Gorbachev Kuzbass State Technical University, Kemerovo, 650000 Russia

*e-mail: ssa.pmahp@kuzstu.ru

Abstract—The industrial production of carbon sorbents from coal is a promising and relevant direction. The starting material is mainly brown coal, which is characterized by a high yield of volatile substances and low ash content. Of particular interest to the coal industry is the development of technology for producing sorbents from low-grade coals with a large specific surface area, high adsorption activity, and low cost. Existing methods for producing sorbents from coals that meet such criteria should be based on various thermophysical principles of influence on the source material. The work investigated one-stage and two-stage methods for producing sorbents from coal grades D and DG mined in Kuzbass. The one-stage technique consisted of steam gasification of the starting material in a fluidized bed. The two-stage technique was based on preliminary decarbonization in a muffle furnace followed by activation with superheated water vapor in a fluidized bed. As a result of experimental studies, samples of carbon sorbents were obtained from coals of low metamorphism. Analysis of textural characteristics showed that the specific surface area of the sorbents is up to 250 m²/g and adsorption activity up to 100 mg/g. It has been established that the composition of the mineral mass of the original coals significantly affects the adsorption activity of the resulting sorbents. Estimates show that the higher the ash basicity index, the higher the adsorption activity of the resulting carbon sorbent. With a one-stage method for producing sorbents from coal grades D and DG in a fluidized bed, a fairly high specific surface area is achieved with a relatively low adsorption activity in comparison with a two-stage method.

Keywords: thermal coal, steam gasification, textural characteristics, specific surface area, adsorption activity, sorbent, mineral mass, ash basicity index

The Vapor–Liquid Phase Equilibrium Line for Water within the Framework of the Renormalization Group Theory

S. V. Rykov^{a, *}, I. V. Kudryavtseva^a, V. A. Rykov^a, V. F. Ochkov^b, and E. E. Ustyuzhanin^b

^a *ITMO University, St. Petersburg, 197101 Russia*

^b *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: togg1@yandex.ru*

Abstract—The article proposes an equation system that includes functions describing the properties at the saturation line (pressure and density of vapor and liquid, saturated vapor pressure derivative, heat of vaporization, etc.). This system satisfies the requirements of the renormalization group theory. The saturation line model included in the equation system is in consistency with the Yang–Yang hypothesis in the critical point neighborhood. For describing the saturated vapor density, the Clausius–Clapeyron equation is involved. In writing the equation system, complexes characterizing the saturation line mean diameter behavior were used. The values of the complexes were selected in accordance with the recommendations suggested by Wang et al. for asymmetrical systems. Within the framework of the proposed water phase equilibrium line model, the critical indices were used, which were calculated on the basis of the critical point scale theory methods. Using the equation system, numerical values of the water property indicators are obtained in the range from the triple point temperature to the critical temperature. The uncertainty of the above-mentioned values is in satisfactory agreement with the uncertainty of the corresponding data on the properties calculated by Wagner and Pruss in the range from the triple point temperature to the critical temperature and the known experimental data. Various models of the saturation line and elasticity curve are compared with each other. It is shown that the proposed equation system conveys the available experimental information on the equilibrium water properties with a smaller uncertainty than the known models do. The information on the diameter calculated on the basis of the equation system in a wide interval of relative temperatures, including the critical point neighborhood, is of interest. The behavior of the mean diameter calculated near the triple point within the framework of different models is discussed.

Keywords: water, saturated vapor pressure, saturation line, mean diameter, Clausius–Clapeyron equation, critical indices, triple point, critical parameters, density, IAPWS-IF97

Hydrogen-Accumulating Materials Based on Titanium and Iron Alloys (Review)

M. V. Lototsky^{a, b}, M. W. Davids^b, V. N. Fokin^a, E. E. Fokina^a, and B. P. Tarasov^{a, c, d, *}

^a *Federal Research Center for Problems of Chemical Physics and Medical Chemistry, Russian Academy of Sciences, Chernogolovka, Moscow oblast, 142432 Russia*

^b *HySA Systems Center of Competence, University of the Western Cape, Bellville, 7535 South Africa*

^c *National Research University Higher School of Economics, Moscow, 101000 Russia*

^d *Moscow State University, Moscow, 119991 Russia*

**e-mail: tarasov@icp.ac.ru*

Abstract—The development of compact, safe, and efficient methods for storing hydrogen is one of the key problems of hydrogen energy. Currently used technologies for storing hydrogen in the form of compressed gas or cryogenic liquid require significant capital investments and maintenance costs for compressor and cryogenic equipment, are characterized by high energy costs, and their implementation requires special safety measures as well as the use of hydrogen-neutral structural materials. A promising way to solve these problems for medium-scale storage systems is the use of metal hydrides, which provide the simplest, most compact, and safe hydrogen storage compared to traditional methods. However, the high cost of hydride-forming materials hinders the implementation of this approach. The use of alloys based on the TiFe intermetallic compound would reduce the costs of metal hydride hydrogen storage by more than five times. This circumstance is the reason for the growing interest of specialists in the field of hydrogen energy technologies in hydrogen-storage materials based on titanium-iron alloys. Although hydrogen systems with the TiFe intermetallic compound and its derivatives have been studied for more than 50 years, the search for ways to increase the resistance of their hydrogen sorption characteristics to poisoning by oxygen-containing impurities in the gas and solid phases has become particularly relevant in recent years. This article provides an overview of research and development aimed at obtaining, studying the properties, and using titanium-iron alloys with improved hydrogen sorption characteristics. An analysis of the data presented in the scientific literature is presented, and approaches to the development of highly efficient hydride-forming materials based on the TiFe intermetallic compound and hydrogen-storage systems based on them are formulated.

Keywords: hydrogen energy, hydrogen materials science, hydrogen storage, metal hydrides, titanium-iron alloys, intermetallic compounds, hydrogen sorption properties, metal hydride technologies

Studying the Possibility of Applying Barium-Strontium Cobaltite in Hydrogen Energy

M. S. Paizullakhanov^{a, *}, N. Kh. Karshieva^a, F. N. Ernazarov^a, S. M. Abduraimov^a, and S. S. Sabirov^b

^a Institute of Materials Science, Academy of Sciences of the Republic of Uzbekistan, Tashkent, 100084 Uzbekistan

^b Fergana Branch, Tashkent University of Information Technologies, Fergana, 150118 Uzbekistan

*e-mail: fayz@bk.ru

Abstract—Anion-deficient structures based on $\text{Sr}_{0.5}\text{Ba}_{0.5}\text{Co}_{1-x}\text{Fe}_x\text{O}_{3-\delta}$ synthesized from a melt in a stream of concentrated solar radiation with a density of 100–200 W/cm² created in a large solar furnace (LSF) were studied. Briquettes in the form of tablets made on the basis of a stoichiometric mixture of carbonates and metal oxides ($\text{SrCO}_3 + \text{BaCO}_3 + \text{Co}_2\text{O}_3 + \text{Fe}_2\text{O}_3$) were melted in a water-cooled melting unit in the LSF focal zone. Drops of the melt flowed into the water in a container located 40 cm below the melting unit. Such conditions contributed to the cooling of the melt at a rate of 10³ C/s. The castings were ground to a grinding fineness of 63 microns, dried at 673 K, and samples were molded from the resulting powder using semidry pressing (at a pressure of 100 MPa) in the form of tablets with a diameter of 20 mm and a height of 10 mm. The tablets were sintered in air at a temperature of 1050–1250°C. The structure, water absorption, and electrical properties of the finished samples were studied. The crystal lattice of the material had a perovskite structure with a unit cell parameter $A = 4.04 \times 10^{-10}$ m of space group Pm3m. The area of homogeneity of compositions $\text{Sr}_{0.5}\text{Ba}_{0.5}\text{Co}_{1-x}\text{Fe}_x\text{O}_{3-\delta}$ corresponded to the interval $x = [0; 0.7]$, where x is the amount of element introduced instead of the main one. The most optimal composition in terms of stability of structure and properties was $\text{Sr}_{0.5}\text{Ba}_{0.5}\text{Co}_{0.8}\text{Fe}_{0.2}\text{O}_{2.78}$. The average crystallite size of the obtained materials is 30–40 μm. The grains are predominantly in the form of spherulites and curved cylinders. Samples of the material showed high resistance to water vapor. The values of structural parameters indicate that the material made from $\text{Sr}_{0.5}\text{Ba}_{0.5}\text{Co}_{0.8}\text{Fe}_{0.2}\text{O}_{2.78}$ can be used as a catalyst in the generation of hydrogen and synthesis gas through reforming and oxidation of methane.

Keywords: solar oven, melt synthesis, concentrated flow, hydrogen generation, catalyst, synthesis gas, perovskite catalytic structures

ПОПРАВКА

к статье А. А. Фалькова, И. Н. Кулакова, Е. А. Слепневой
“Тепломассообмен и газораспределение
в пароводяном объеме с неконденсирующимся газом”

DOI: 10.56304/S0040363624030111

В статье А. А. Фалькова, И. Н. Кулакова, Е. А. Слепневой “Тепломассообмен и газораспределение в пароводяном объеме с неконденсирующимся газом”, опубликованной в № 11 за 2023 г. (DOI: 10.56304/S0040363623110061), подписанная подпись к рис. 5 должна выглядеть так:

Рис. 5. Поток испарения и охлаждение поверхности водяного объема ($p = 0.1$ МПа).
1 – результаты расчета потока испарения; 2 – охлаждение поверхности; 3 – экспериментальные данные