

Contents

Vol. 71, No. 5, 2024

Nuclear Power Plants

Hydrodynamics of the Coolant at the Input to the FA Reactor of the RITM-Type
Small Nuclear Power Plant

*S. M. Dmitriev, T. D. Demkina, A. A. Dobrov, D. V. Doronkov,
D. S. Doronkova, A. N. Pronin, and A. V. Ryazanov*

5

Optimization of Weight and Size Characteristics and Unification of Heaters
of the Regeneration System of NPP Turbine Units

*E. N. Kulakov, Yu. G. Sukhorukov, D. G. Soenko, I. E. Vikharev, S. B. Esin,
F. A. Svyatkin, K. A. Grigoriev, and A. V. Popov*

22

Validation of the STEG Code against Experiments on Hydrodynamics
of a Horizontal Steam Generator

Kh. Abdi, N. Uregani Dzhafari, V. I. Melikhov, and O. I. Melikhov

32

Posttest Calculations of Thermal-Hydraulic Conditions for Test Benches
Simulating a Loss of Spent Fuel Pool Cooling Accident at BWR
and VVER-1000/1200 Reactors

*N. V. Ivanova, M. M. Bedretdinov, O. E. Stepanov, A. G. Karetnikov,
D. N. Moisin, and K. Schuster*

45

Steam-Turbine, Gas-Turbine, and Combined-Cycle Plants and Their Auxiliary Equipment

Experience with Application of Laser Diagnostics Systems in Experimental Studies
of Wet Steam Flows in the Flow Path of Turbomachines: Basic Results of Studies
and System Development Trends

*V. A. Tishchenko, A. A. Tishchenko, V. G. Gribin, V. V. Popov,
I. Yu. Gavrilov, K. A. Berdyugin, and D. G. Sokolov*

57

Estimating the Influence of Compressor Blade Erosion Wear on the Compressor's Integral
and Local Characteristics

V. L. Blinov, I. S. Zubkov, and G. A. Deryabin

74

Renewable Energy Sources, Hydropower

Study of Heating and Evaporation of Rotating Graphene Nanofluid
under the Influence of Solar Radiation

K. T. Chan, A. S. Dmitriev, I. A. Mikhailova, and P. G. Makarov

87

Comprehensive Development of Brines of the Berikei Geothermal Field

A. B. Alkhasov and D. A. Alkhasova

101

Hydrodynamics of the Coolant at the Input to the FA Reactor of the RITM-Type Small Nuclear Power Plant

**S. M. Dmitriev^a, T. D. Demkina^a, A. A. Dobrov^a, D. V. Doronkov^{a, *},
D. S. Doronkova^a, A. N. Pronin^a, and A. V. Ryazanov^a**

^aAlekseev Nizhny Novgorod State Technical University, Nizhny Novgorod, 603950 Russia

**e-mail: nevid000@mail.ru*

Abstract—The results of an experimental study into the features of the process of coolant flow formation in the inlet section of the fuel assembly (FA) of the core of a RITM-type reactor of a small nuclear power plant (SNPP) are presented. The purpose of the work is to evaluate the influence of different design elements of the inlet section on the formation of coolant flow. To achieve this goal, a series of experiments was completed on a research aerodynamic stand with an air working environment using a large-scale experimental model, including structural elements of the FA inlet section from the throttle washer to the fuel rod assembly unit to the diffuser, as well as a fragment of the fuel rod bundle between the absorber and spacer grids. The studies were carried out using the pneumometric method and the method of injection of a contrast impurity in several sections along the length of the model. Measurements were made over the entire cross section of the model. Features of the coolant flow are visualized by cartograms of the axial flow velocity of the working medium and the distribution of impurities in the cross section of the model. The research results were used by specialists from the design and calculation departments of OKBM Afrikantov to substantiate engineering solutions when designing new cores of RITM reactors. The results of the experiments were collected in a database and used in the validation of the CFD program LOGOS, created by employees of the All-Russian Research Institute of Experimental Physics and the Institute for Theoretical and Mathematical Physics of Moscow State University as analogues of foreign programs of the same class, which include ANSYS, Star CCM, etc. Experimental data was also used when validating one-dimensional thermal-hydraulic codes used at OKBM Afrikantov in substantiating the thermal reliability of reactor cores. The thermohydraulic code CANAL is also included in this class of programs.

Keywords: fuel cassette, inlet section, throttle washer, ball lock, diffuser, fuel rod bundle, absorption and spacer grids, cover, central displacer, coolant hydrodynamics, axial velocity, contrast impurity

Optimization of Weight and Size Characteristics and Unification of Heaters of the Regeneration System of NPP Turbine Units

**E. N. Kulakov^a, *, Yu. G. Sukhorukov^a, D. G. Soenko^b, I. E. Vikharev^b, S. B. Esin^a, F. A. Svyatkin^a,
K. A. Grigoriev^a, and A. V. Popov^a**

*^a Polzunov Scientific and Production Association for the Research and Design of Power Equipment (NPO TsKTI),
St. Petersburg, 191167 Russia*

^b AO Atomenergoproekt, Moscow, 105082 Russia

**e-mail: KulakovEN@ckti.ru*

Abstract—When designing new nuclear power plants, it is important to ensure cost-effective electricity production while complying with safety, reliability, and environmental protection requirements. One of the directions for solving this problem is to improve the equipment of nuclear power plants, in particular the search for the most suitable technical solutions for regenerative high- and low-pressure heaters (HPH and LPH) of steam turbine units (STU). Optimization of subheating of water to the saturation temperature of the heating steam (hereinafter referred to as subcooling) in the STU regeneration stages makes it possible to increase the power of the power unit or reduce the metal intensity of the heaters, depending on the expected economic indicators of the nuclear power plant, which leads to a reduction in the estimated cost of generated electricity. Unification of heaters will make it possible to simplify the processes of design, manufacturing, repair, and transportation of serial heat-exchange equipment, improve the layout of the machine room, and reduce equipment development costs. The article presents the results of calculations of the technical and economic indicators of the heat-exchange equipment of the STU regeneration system type K-1200-6.8/50 LMZ, and draws conclusions about the possibility of finding a preferable solution based on the criterion of annual economic effect. A special feature of the methodology used is the determination of the most appropriate values of water subheating in surface heaters of the STU regeneration system, depending on operating conditions, the situation on the electricity and equipment market, as well as economic policy. The possibility of increasing the economic efficiency of the power unit by optimizing the weight and size characteristics and unifying the heat-exchange equipment of the regeneration system is shown. An additional economic effect can be obtained by using chamber-type heaters in a horizontal design, combining two heating stages in one housing. A promising layout option is that in which the entire LPH group is represented by unified surface-type devices in a horizontal design located in the condenser branch pipe of a low-speed STU.

Keywords: Nuclear power plant, turbine unit, regeneration system, low-pressure heater, high-pressure heater, optimization of parameters, unification, economic efficiency

Validation of the STEG Code against Experiments on Hydrodynamics of a Horizontal Steam Generator

Kh. Abdi^a, N. Uregani Dzhafari^a, V. I. Melikhov^{a, b, *}, and O. I. Melikhov^{a, b}

^a National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

^b Electrogorsk Research and Development Center for Nuclear Power Plants Safety, Electrogorsk, 142530 Russia

*e-mail: MelikhovVI@mpei.ru

Abstract—A numerical analysis of the experiments addressed to studies of hydrodynamic processes in a horizontal steam generator has been performed using the STEG (STEam Generator) code. The main components of the experimental model include a staggered tube bundle, a submerged perforated sheet (SPS) with baffles, and a downcomer. An air–water mixture was used as a two-phase fluid. The working fluid flow in the model was driven by natural circulation induced by air supply to the lower, middle, and upper sections of the tube bundle. The gas void fraction was measured by the γ -radiography method. In addition, pressure drops along the height of the tube bundle and water levels in the model and above SPS were also measured. Each experiment was performed at a prescribed air load on the evaporation surface and water level in the model. The STEG code was developed at the Department of Nuclear Power Plants of NRU MPEI to model thermohydraulic processes in a horizontal steam generator. The mathematical model is based on a two-fluid approach to the description of a two-phase flow using balance mass, momentum, and energy conservation equations and semiempirical closing correlations for interfacial interactions and interactions with various surrounding structures (tube bundle, walls, etc.). The STEG code was used to perform calculations for nine experimental regimes differing in the perforation ratio of the submerged perforated sheet and the supplied air flowrate. The qualitative regularities of the two-phase air–water mixture circulation in the model of a horizontal steam generator and the effect of experimental values of the main parameters on the circulation have been established. Quantitative results of comparison of the predictions with the experiment demonstrate their good agreement since the relative errors in the predicted air void fractions and pressure drops do not exceed 10%.

Keywords: horizontal steam generator, tube bundle, submerged perforated sheet, simulation, computational code, two-phase flow, hydraulic resistance, interfacial interaction, air–water fluid

Posttest Calculations of Thermal-Hydraulic Conditions for Test Benches Simulating a Loss of Spent Fuel Pool Cooling Accident at BWR and VVER-1000/1200 Reactors

N. V. Ivanova^{a,*}, M. M. Bedretdinov^a, O. E. Stepanov^{a,**},

A. G. Karetnikov^a, D. N. Moisin^a, and K. Schuster^b

^aAO OKB Gidropress, Podolsk, Moscow oblast, 142103 Russia

^bInstitute of Power Engineering Technische Universität Dresden, Dresden, 01062 Germany

*e-mail: anata99@mail.ru

**e-mail: stepanov_oe@grpress.podolsk.ru

Abstract—The article presents the results of new investigations into possible loss of cooling of spent fuel assemblies (FAs) stored in near-reactor spent fuel pools of BWR and VVER reactor plants (RPs). The experiments were carried out in 2022 on the ALADIN installation (Germany, a BWR type RP) and the “Reflooding test bench” installation (Russia, a VVER type RP). In comparing the experimental data obtained on different test benches, it was noted that the thermal-hydraulic processes that were observed during water boiling, cooling, and subsequent heat-up of fuel assemblies had similar patterns for the above-mentioned reactor types. By using the KORSAR/GP computer code, posttest calculations of experiments were carried out, the results of which were compared with the basic experimental data on the maximum fuel rod temperature and water level. Good agreement between the calculated and experimental results was obtained. Deviations of the calculated data from the experimental results were estimated with respect to the water boiling onset and fuel rod heat-up onset moments, the moment at which the fuel rod temperature reaches its maximum value, and its absolute values. The obtained results can be used for validating thermal-hydraulic codes, substantiating their applicability, and for performing safety analysis under the conditions of accidents involving loss of spent fuel pool cooling at NPPs with VVER/PWR reactor plants.

Keywords: nuclear power plants, safety, design extension conditions, reactor plant simulation, thermal-hydraulic processes, experiment, calculation, code verification, fuel rods, fuel assembly, spent fuel pool, coolant

Experience with Application of Laser Diagnostics Systems in Experimental Studies of Wet Steam Flows in the Flow Path of Turbomachines: Basic Results of Studies and System Development Trends

V. A. Tishchenko^a, A. A. Tishchenko^{a, *}, V. G. Gribin^a, V. V. Popov^{a, **}, I. Yu. Gavrilov^a, K. A. Berdyugin^a, and D. G. Sokolov^a

^a National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia

**e-mail: TishchenkoAA@mpei.ru*

***e-mail: PopovVitV@mpei.ru*

Abstract—The findings in application of laser diagnostic systems for the investigation of wet steam flows in flow paths of steam turbines, specifically, in channels of various configurations, are reviewed. The experimental results accumulated over more than a decade enabled the authors to generalize and formulate the essential features of the movement of coarse erosion-hazardous droplets downstream of turbine cascades and in interblade channels. The regions with liquid phase particles are found using the data of visual analysis. The results of application of the particle image velocimetry/particle tracking velocity (PIV/PTV) methods, which implement algorithms for determining vector fields of particle velocities, are presented. The features of the distribution of kinematic characteristics of the liquid phase in various regions of turbine cascades, which affect the erosion wear rate, are discussed. Data are presented on the effect of the blade profile on the formation of trajectories of droplet flows, and methods for improving the separation ability of a blade operating in a wet steam flow are proposed. Using the experimental database on liquid phase velocity fields in turbine channels of various configurations, a semiempirical model of the flow of large erosive-dangerous droplets is formulated. It describes their movement in a cocurrent steam flow and interaction with the walls of the interblade channels. A review is presented of engineering solutions that were obtained on the basis of theoretical and experimental studies of wet steam flows using laser diagnostic systems. The concept of blade surface heating, heating steam jet injection, and optimization of the in-channel separation system is examined. The principles are formulated for the development of approaches based on laser flow diagnostic systems in the field of application of neural networks, which should considerably extend the capabilities of experimental studies since they offer the potential for increasing the amount of data obtained by implementing such experimental methods.

Keywords: steam turbines, turbine cascade, erosion-hazardous droplets, two-phase hydrodynamics, neural networks, droplet trajectories, cocurrent steam flow

Estimating the Influence of Compressor Blade Erosion Wear on the Compressor's Integral and Local Characteristics

V. L. Blinov^{a,*}, I. S. Zubkov^a, and G. A. Deryabin^a

^a Ural Power Engineering Institute, Ural Federal University, Yekaterinburg, 620002 Russia

**e-mail: v.l.blinov@urfu.ru*

Abstract—Assessment, monitoring, and prediction of the technical condition of gas turbine unit (GTU) assemblies and components are among the key matters that have to be dealt with during the operation of GTUs. In this connection, various prediction systems that use statistical, experimental, and calculated data on the change in the axial compressor (AC) characteristics resulting from the occurring erosion are becoming of great demand. The article describes an approach to the development of models of erosively worn blades on the basis of freely accessible statistical data on the failures of units as a consequence of a blade compressor's erosion. The article also proposes a body of mathematics for specifying the blade wear degree, introducing the change in the eroded profile chord, and considering the wear nonuniformity along the blade height. The statement of the problem of numerically studying how the erosion degree and pattern affect the compressor stage performance parameters is described. The outcomes from intermediate studies on comparing different geometrical models of erosion are presented along with assessment of their applicability for flow computations in elaborating a prediction model. The results of computations of a transonic compressor stage have been obtained for different erosion wear degrees of its blading in a wide range of operation modes, and the revealed degradation pattern of the stage integral and local characteristics is analyzed. It has been found from analyzing various erosion wear degrees for the stage considered that, if there is an erosion wear, the compressor pressure ratio may drop by up to 3.31%, the ratio of temperatures by up to 1.55%, the adiabatic efficiency by up to 1.15% (abs.), and mass flowrate at the stage choke line up to 1.26%. With decreasing the rotor rotation frequency, the wear influence decreases, and 70% of the change in integral characteristics do not exceed 0.10% for the isodrome (a constant rotation frequency line). The article briefly outlines possible methods for analyzing the results for constructing the correlations between the erosion wear degree and the change in the compressor integral characteristics and also promising lines for development of studies.

Keywords: gas turbine unit, axial compressor, stage, blading, erosion wear, integral and local characteristics, computational gas dynamics

Study of Heating and Evaporation of Rotating Graphene Nanofluid under the Influence of Solar Radiation

K. T. Chan^a, *, A. S. Dmitriev^a, I. A. Mikhailova^a, and P. G. Makarov^a

^a National Research University Moscow Energy Institute, Moscow, 111250 Russia

*e-mail: tranqth.96@gmail.com

Abstract—Conversion of solar radiation into steam is presently one of the trends in “green” energy (solar thermal energy), ecology, and clean water production. For the first time, a study of the heating and evaporation of a rotating graphene nanofluid under the influence of radiation from a solar simulator was carried out. The influence of various factors on these processes, including the direction of irradiation, graphene concentration, and liquid rotation speed, is considered. It has been shown that the evaporation rate significantly depends on the graphene concentration and the method of irradiation of the samples. When samples are irradiated from the side, as the graphene concentration increases, the average evaporation rate increases and reaches a maximum value and then decreases. When samples are irradiated from above and the liquid–air interface is in direct contact with the incident radiation, only a decrease in the evaporation rate is observed as the graphene concentration increases. In this case, heating of graphene also depends on the method of irradiating the sample. When in direct contact with radiation, graphene is heated to a high temperature, while in the bulk it is heated less efficiently than the base liquid (distilled water). It has been shown that the rate of evaporation from the surface of a rotating graphene nanofluid and the temperature of its volume significantly depend on the rotation speed. Of all the samples studied, a graphene nanofluid with a volume concentration of 0.5% is heated most efficiently. The use of thermal insulation can improve heating by approximately 5%. An analytical calculation of the profile of the interfacial surface is presented and its area is determined at different speeds of rotation of the liquid. Some effects that arise during the rotation of a graphene nanofluid and their influence on the parameters of hydrodynamics and heat and mass transfer, which is important for fundamental and applied energy problems, have been identified.

Keywords: graphene nanofluid, rotating fluid, solar radiation, interfacial surface shape, heating and evaporation, evaporation rate, thermal insulation, heat loss, energy balance

Comprehensive Development of Brines of the Berikei Geothermal Field

A. B. Alkhasov^a, * and D. A. Alkhasova^a

^a Institute of Geothermal Problems and Renewable Energy, Joint Institute for High Temperatures, Russian Academy of Sciences, Makhachkala, Republic of Dagestan, 367030 Russia

**e-mail: alibek_alkhasov@mail.ru*

Abstract—It has been shown that complex processing of hydrothermal brines from the Berikei geothermal field can be highly effective. The development of the deposit's resources can be carried out in two stages. At the first stage, it is proposed to organize the production of chemical compounds based on self-flowing brines. After developing the technology for extracting chemical components from brine, it is recommended to move on to the second stage: implementing an integrated technology for utilizing thermal energy with the subsequent extraction of chemical components from the cooled brine. This technique allows one to use all the resources of the field. The thermal energy of the geothermal brine is recovered in a greenhouse and a geothermal steam-gas power plant (GSGP), which includes units of a binary geothermal power plant (GeoPP) and a gas turbine power plant (GTPP). In a binary GeoPP, the low-boiling working fluid is heated to a higher temperature by removing heat from the geothermal brine. Further heating of the working fluid to the evaporation temperature and its evaporation and overheating are carried out by the heat of the GTPP exhaust gases. The construction of a GSGP will allow for uninterrupted and autonomous supply of electricity to the entire complex. The development of all hydrothermal resources of the Berikei deposit will make it possible to annually obtain 2000 t of lithium carbonate and, thereby, provide a significant part of the needs of Russian industry as well as produce more than 580 000 t of table salt, which will solve the problem of import substitution of this product.

Keywords: geothermal resources, binary geothermal power plant, geothermal heat, low-boiling working fluid, geothermal-steam-gas power plant, highly mineralized brines, lithium carbonate, reconstruction of idle wells