
Contents

Vol. 71, No. 6, 2024

Environmental Protection

Review of Regulative and Technical Documentation in the Field of Ash and Slag Handling at TPPs

I. V. Putilova and N. A. Zroychikov

3

Heat and Mass Transfer and Properties of Working Fluids and Materials

Simulation of Film Condensation from Moving Vapor of Refrigerant-21 on a Horizontal Tube Bundle Using the VOF Method

K. B. Minko, V. I. Artemov, and A. A. Klement'ev

15

Investigation into Operation of Energy-Intensive Heat Exchangers with Many Plates

A. E. Baranov, A. E. Belov, D. N. Il'mov, V. A. Mavrov, A. S. Skorokhodov, and N. I. Filatov

34

Renewable Energy Sources, Hydropower

Profiling a Wind Wheel Blade Using Parametric Optimization and Computational Aerodynamics Methods

I. B. Voinov, V. V. Elistratov, I. A. Keresten, M. A. Konishev, M. A. Nikitin, and D. I. Sofronova

49

Metals and Strength Analysis

Static Strength Assessment of Turbine Blades in High-Capacity Power Units

A. N. Arkhipov, I. V. Puchkov, Yu. A. Ravikovich, O. V. Romanova, and A. A. Ivanovskii

60

District Heating Cogeneration and Heat Networks

Application Research of Differential Evolution Algorithm in Resistance Coefficient Identification of Heating Pipeline

Bingwen Zhao, Ruxue Yan, Yu Jin, and Hanyu Zheng

72

Discussions

Is SNPP Development a Fashion or an Essential Necessity? (Comment on the Article by V.O. Kindry, I.A. Maksimova, I.I. Komarova, S.K. Osipova, O.V. Zlyvko "Low Power Nuclear Plants: Technical Level and Prospects for Commercialization (Review)")

S. L. Soloviev

84

Review of Regulative and Technical Documentation in the Field of Ash and Slag Handling at TPPs

I. V. Putilova^{a, *} and N. A. Zroychikov^a

^a National Research University Moscow Energy Institute, Moscow, 111250 Russia

*e-mail: PutilovaIV@ecopower.ru

Abstract—Statistical data on the level of use of ash and slag from thermal power plants is provided. The results of an analysis of regulatory and technical documentation in the field of ash and slag management in the energy sector are presented. Laws, regulations, and other documents regulating the management of by-products of coal combustion are considered. It was noted that it is necessary to refine the existing documentation, introduce legally defined terms and definitions for a number of ash and slag processing products, and also legally consider ash and slag as mineral raw materials and not waste. Definitions of ash and slag are given in accordance with the current industry regulatory document, in which ash and slag are *ru* called waste but mineral residues of solid fuel. It is shown that various government agencies are preparing regulatory documents related to the involvement of ash and slag into economic circulation. However, the existing regulatory framework does not meet the goals of achieving the level of low-waste and waste-free production. It was noted that regional programs have currently been approved to increase the level of ash and slag utilization from thermal power plants in the constituent entities of the Russian Federation. Activities are presented that will make it possible to achieve the indicators for the level of utilization of ash and slag from thermal power plants in accordance with the Energy Development Strategy of the Russian Federation until 2035. It is explained how legally correct regulatory and technical documentation will make it possible to increase the level of ash and slag utilization in Russia and will help eliminate accumulated harm to the environment. It has been shown that the most large-scale, high-tech, environmentally friendly and economical use of fly ash is its replacement of up to 40% of cement in the construction of buildings and structures. Definitions of fly ash used in cements and concretes are given in the standards of different countries (EU countries, United States, Australia, India, China, Japan, Russia) depending on the type of ash formed. A comparative analysis of Russian and foreign national standards for the use of ash in cements and concretes was carried out in terms of physical and chemical characteristics, which are significant limiting factors when choosing directions and projects for the use of ash.

Keywords: environmental legislation, secondary resources, hazard class, ash and slag, coal thermal power plant, coal energy waste, coal combustion products, target indicators, organization standard, environmental safety

Simulation of Film Condensation from Moving Vapor of Refrigerant-21 on a Horizontal Tube Bundle Using the VOF Method

K. B. Minko^{a,*}, V. I. Artemov^a, and A. A. Klement'ev^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: minkokb@gmail.com

Abstract—Considerable progress has been made by now in developing mathematical models, algorithms, and available computational tools for simulating heat and mass transfer processes. Advanced approaches yield detailed information on various characteristics of mass transfer in two-phase fluids, in particular during film condensation of vapors. Models developed by various teams are implemented in CFD-codes (ANSYS Fluent, OpenFOAM, Star-CCM+, etc.). To check existing models and select the best one, cross-verification of models and algorithms implemented in various CFD codes and their verification against available and reliable experimental data are needed. In this paper, cross-verification of the VOF (Volume of Fluid) model and the algorithms implemented in the author's ANES code was carried out against the problem of vapor condensation on a single tube. The calculations were performed using the ANES and ANSYS Fluent CFD-codes. The predictions by the ANSYS Fluent code have been demonstrated to depend on the settings of the algorithms for solving the conservation equation for the liquid volume fraction. Recommendations are presented for setting this code to obtain better agreement of the predictions with experimental data and theoretical relationships. The ANSYS Fluent code was used for two-dimensional simulation of refrigerant-21 condensation in a small tube bundle. Characteristics of the tube bundle (bank) were equal to those of the tube bundle used in the experimental setup of the Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences (tube diameter $D_T = 16$ mm, transverse tube bundle pitch $S_1 = 26$ mm, longitudinal tube bundle pitch $S_2 = 15$ mm). Condensation of saturated vapor having a saturation temperature of $T_{sat} = 333.15$ K and arriving at the tube bundle at a velocity of up to 1.2 m/s was studied. The predictions demonstrate qualitative and quantitative agreement with the experimental data.

Keywords: film condensation, horizontal tube, tube bundle, interfacial boundary, numerical simulation, VOF method, cross-verification of the ANES and ANSYS Fluent codes

Investigation into Operation of Energy-Intensive Heat Exchangers with Many Plates

A. E. Baranov^a, A. E. Belov^a, D. N. Il'mov^{a, *}, V. A. Mavrov^a, A. S. Skorokhodov^a, and N. I. Filatov^a

^a State Scientific Center Keldysh Research Center, Moscow, 125438 Russia

*e-mail: ilmovdn@mail.ru

Abstract—Heat exchangers in a gas turbine circuit for advanced space power facilities are innovative developments in the field of elaboration of heat exchangers meeting a set of technical and operating requirements. A design of a heat-transfer matrix consisting of a set of biconvex stamped plates with a specific surface relief is proposed. It enables construction of heat exchangers meeting the requirements for strength, stiffness, weight, and size under the specified operating conditions. The results of testing of heat exchangers made of 288 and 450 plates are presented. A nonuniformity of the coolant distribution among heat-transfer panels was found. Under the same operating conditions, it makes the thermal efficiency of a heat exchanger made of 450 plates lower than that of a heat exchanger made of 288 plates. Based on the analysis of test results, a mathematical model has been developed for the thermal and gas-dynamic design calculation of a heat exchanger with an arbitrary number of plates, which takes into account the effect of nonuniformity of the coolant flow through the channels between the plates. The calculation calls for determination of a temperature distribution along the length of each channel considering variable thermophysical properties of the coolant. For the mathematical model, a dimensionless dependence of the resistance coefficient and the Nusselt number on the Reynolds number was found in the Reynolds number range from 500 to 2000. Universal dependences enable simulation in both hot coolant paths consisting of identical interplate channels and cold coolant paths consisting of the same complete and half channels. The correlations for the hydraulic resistance coefficient and the Nusselt number versus the Reynolds number agree well with the known dependences obtained for corrugated heat-transfer surfaces of the same class. The mathematical model has been verified against experimental data. The effect of the scheme of connection of heat exchangers with different number of plates to a gas circuit is examined. The connection schemes are analyzed, and one of them is recommended as the most suitable for practice.

Keywords: heat exchanger, header system, biconvex stamped plate, corrugated plate with intermittent turbulizers, Nusselt number, hydraulic resistance coefficient, Reynolds number

Profiling a Wind Wheel Blade Using Parametric Optimization and Computational Aerodynamics Methods

I. B. Voinov^a, V. V. Elistratov^a, I. A. Keresten^{a, *}, M. A. Konishev^a, M. A. Nikitin^a, and D. I. Sofronova^a

^a Peter the Great St. Petersburg Polytechnic University, St. Petersburg, 195251 Russia

*e-mail: keresten@compmechlab.com

Abstract—Due to the constant increase in energy consumption, remoteness from industrial centers, the need to import organic fuel for economic activities and livelihoods of the population, a wider deployment of wind power plants (WPPs) in hard-to-reach areas of the Arctic is required. The key element influencing the efficiency of a WPP is the wind wheel, the design of which is associated with certain difficulties due to the extreme climatic conditions in the Arctic. The presented work describes an approach to digital design of the aerodynamic shape of a wind turbine blade based on parametric optimization technology. The target indicator is the wind energy efficiency (WEE), which is calculated by direct numerical modeling of the aerodynamics problem using modern computational methods, as well as high-performance supercomputer technologies. The introduction of digital design and modeling principles has enabled the integration of geometric models and associated engineering modeling tools into the computer environment. The main concept of the approach is to describe the geometric characteristics of the blade with a finite number of parameters, changing which one can obtain the shape of the wind wheel blade in a wide range of possible configurations. For each shape, a computational CFD model is created, which, based on the numerical solution of the Navier–Stokes viscous flow equations, makes it possible to determine target indicators in the form of aerodynamic characteristics of the blade at a given wind speed. An example of the use of parametric optimization technology for the design of a wind wheel intended for operation in the Arctic regions is considered. The functionality of the concept for determining the shape of the blade in single-mode and multimode options for using a wind wheel has been demonstrated. It is shown that the obtained geometric characteristics make it possible to improve the target performance of a typical blade used in practice. For a WPP with a power of 100 kW with a wind wheel with a diameter of 24 m, solutions were obtained that provide a WEE value of 0.45 in the range of design wind speeds from 6 to 9 m/s.

Keywords: numerical modeling, wind wheel blade, wind power plant, parametric optimization, wind energy utilization factor

Static Strength Assessment of Turbine Blades in High-Capacity Power Units

A. N. Arkhipov^{a, *}, I. V. Puchkov^b, Yu. A. Ravikovich^a, O. V. Romanova^c, and A. A. Ivanovskii^c

^a *Moscow Aviation Institute, Moscow, 125993 Russia*

^b *Independent Expert, Moscow, 140082 Russia*

^c *AO Power Machines, St. Petersburg, 195009 Russia*

**e-mail: arkhipov.48@list.ru*

Abstract—The article considers assessment methods and criteria of damage inflicted to turbine blades under the effect of static loads in carrying out 3D structural analyses of modern foreign and domestically produced high-capacity power units. Factors that should be considered in performing strength and longevity analyses of the rotor blades of high-capacity turbines when subjected to short- and long-term static loading are pointed out. The article also describes 3D techniques for carrying out elastoplastic assessment of short-term static strength using a procedure for determining the limit rotation speed to blade fracture, airfoil residual displacements and strains, shank ultimate strength and displacement, dovetail tearing-off, shear, flexural strength, etc. The article presents mutually complementary techniques for determining the bearing capacity as well as global and local long-term strength with using cumulative strain predictions by creep curves. Criteria used in different longevity assessment methods are described, including those applied at different design stages and in using thermal protection coatings. Cases are considered in which creep strains are determined in the absence of data on creep curves by carrying out elastoplastic analyses by isochronous curves and longevity analysis using the Larson—Miller curves. The need to take multiaxiality into account in estimating local creep in places of stress concentration is shown, and the applicability limits and criteria of such assessment that make it possible to increase the predicted longevity by up to two times are described. Examples of tensile and compressive stress relaxation in estimating cumulative creep strain are given. Matters of creep interaction with other types of damage, including high-cycle and low-cycle (thermal cycling) fatigue, and various turbine loading kinds are considered.

Keywords: turbine blade, loading, creep, turbine acceleration, short-term static strength, long-term strength, creep curves, isochronous creep curves, fraction criteria, multiaxiality, stress relaxation

Application Research of Differential Evolution Algorithm in Resistance Coefficient Identification of Heating Pipeline

Bingwen Zhao^{a, b}, Ruxue Yan^{b, *}, Yu Jin^c, and Hanyu Zheng^b

^a Keyi College of Zhejiang Sci-Tech University, Shaoxing, 312369 China

^b College of Architectural Engineering of Zhejiang Sci-Tech University, Hangzhou, 310018 China

^c Shanghai Linxiang Environmental Protection Corporation, Shanghai, 200232 China

*e-mail: 1305128799@qq.com

Abstract—The district heating system is an important heating mode in the northern cities of China. In recent years, the scale of the district heating system is expanding day by day, the pipe network structure is more and more complex. The problem of hydraulic imbalance of the pipe network is gradually emerging, therefore, it is urgent to establish an accurate and perfect hydraulic simulation model of heating network to assist operation management. Pipe network simulation modeling is one of the important prerequisites to solve the hydraulic imbalance problem of heating pipe network. However, with the increase of service time, the actual resistance coefficient of heating network becomes difficult to obtain, which is one of the key reasons for the low accuracy of pipe network simulation model. In order to overcome this difficulty, this paper proposes to use the resistance coefficient identification model based on the differential evolution algorithm (DEA) to identify the resistance coefficient of the heating pipe network. Based on graph theory, network matrix and the law of conservation of mass, the hydraulic model of the heating pipe network is built, and the nodal pressure method is used to solve the model. On the basis of comprehensive consideration of the mainstream intelligent algorithm, the differential evolution method is selected as the algorithm to identify the resistance coefficient of pipeline. In order to verify the identification effect, the feasibility of the model was verified by calculating the data of three different operating conditions of the practical engineering named “K district heating system”. The results demonstrated that the relative errors of the identified resistance coefficients are all within 10%, and 98% of the identified values are less than 5%.

Keywords: district heating, differential evolution algorithm, identification of resistance coefficient, pipeline hydraulic model, optimization design

**Is SNPP Development a Fashion or an Essential Necessity?
(Comment on the Article by V.O. Kindry, I.A. Maksimova, I.I. Komarova,
S.K. Osipova, O.V. Zlyvko “Low Power Nuclear Plants:
Technical Level and Prospects for Commercialization (Review)”)**

S. L. Soloviev*

All-Russia Research Institute for Nuclear Power Plants Operation, Moscow, 109507 Russia

**e-mail: SLSoloviev@vniiaes.ru*

Abstract—This report examines the issue of economic feasibility of constructing small nuclear power plants (SNPPs). The preparation of this commentary is due to a number of controversial theses presented in the article by V.O. Kindry, I.A. Maksimova, I.I. Komarova, S.K. Osipova, O.V. Zlyvko “Low-Power Nuclear Power Plants: Technical Level and Prospects for Commercialization (Review)”, published in the journal “Thermal Energy” no. 4 of 2024. The article notes the need to use new circuit solutions and working fluids for SNPPs. However, an analysis of the prerequisites for the creation of SNPPs allows for the conclusion that the use of complex thermal schemes for such stations is inappropriate. The article rightly notes that SNPPs can only be competitive in remote areas that are difficult to access for the import of fossil fuels. But the inaccessibility of the territories is a determining and largely limiting factor for the creation and operation of SNPPs themselves on these sites.

Keywords: low-power nuclear power plants, economics, Brayton cycle, LCOE, Shelf-M, RITM-200N, cost of electricity production