

Contents

Vol. 71, No. 8, 2024

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Design Solutions for the Main Heat Exchangers in the Organic Rankine Cycle Circuit (Review)

*I. S. Atanenkova, Yu. A. Geller, M. M. Vinogradov, E. A. Gorbunova,
D. S. Pisarev, and V. I. Kuznetsov*

Heat Turbine Mass Transfer Turbine Properties of Working Fluids Turbine Materials

Phase Change Materials for Applications in Building Thermal Energy Storage (Review)

Md Ahsan Habib and Muhammad Mustafizur Rahman

Regularities of Bubble Formation on the Holes of Immersed Hole Sheets of Bubble Devices

V. A. Devyanin

Water Treatment and Water Chemistry

Water Chemistries of VVER-SCW Nuclear Facilities: The Choice and Justification (Review)

N. L. Kharitonova and V. F. Tyapkov

Nuclear Power Plants

Analysis of the Influence of Aerosol Particle Size Distribution on the Behavior of Fission Products during Simulation of an Accident at an NPP with VVER

S. S. Savekin and Yu. B. Shmelkov

Steam Boilers, Power Plant Fuel, Burners, and Boiler Auxiliary Equipment

Description of the Tilttable Vortex Burner Design and Modeling Its Operation during Coal and Natural Gas Combustion

I. A. Ryzhii, A. V. Shtegman, D. V. Sosin, and A. S. Natal'in

Design Solutions for the Main Heat Exchangers in the Organic Rankine Cycle Circuit (Review)

I. S. Atanenkova^{a, *}, Yu. A. Geller^a, M. M. Vinogradov^a, E. A. Gorbunova^a,
D. S. Pisarev^a, and V. I. Kuznetsov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: atanenkovais@mail.ru

Abstract—The results are presented of the search for and systematization of information on typical design solutions for the main heat exchangers of installations with low-boiling working fluids. The organic Rankine cycle (ORC) has been widely accepted as a way for converting waste (exhaust) heat into electrical energy. An increase in the installed capacity of operating commercial ORC power plants and their total capacity is noted in the world every year. At the same time, design options for the main heat exchangers (heater, evaporator-superheater, condenser, regenerative heat exchanger) are not available in open access and presented in catalogues: information about them is not disclosed by the manufacturers and information available in publications is limited and disembodied. An attempt is made in this paper to systematize the available information and, based on an analysis of world and domestic experience in industrial production, formulate an idea of potential engineering solutions for heat and mass transfer installations, which can be offered as prototypes of the considered apparatuses. At the same time, the search for such solutions was focused primarily on apparatuses used in the refrigeration industry, conventional steam turbine power units, and modern ventilation and air-conditioning systems. The advantages and disadvantages of such apparatuses are examined. The results are presented of a comparative analysis of their design, power range, operational features, and the potential effect of these factors on the operation of the overall ORC installation. Approaches to the selection of heat-exchange equipment for ORC installations given in the available publications and proven in practice have been investigated and described.

Keywords: organic Rankine cycle, ORC-unit, design, steam generator, evaporator, condenser, regenerative heat exchanger, heat-transfer coefficient, refrigeration equipment, heat carrier, thermal oil, Freon, finning

Phase Change Materials for Applications in Building Thermal Energy Storage (Review)

Md Ahsan Habib^{a, *} and Muhammad Mustafizur Rahman^{a, **}

^a *Wichita State University, Wichita, Kansas, 67260 USA*

**e-mail: mxhabib1@shockers.wichita.edu*

***e-mail: muhammad.rahman@us.af.mil*

Abstract—A unique substance or material that releases or absorbs enough energy during a phase shift is known as a phase change material (PCM). Usually, one of the first two fundamental states of matter – solid or liquid – will change into the other. Phase change materials for thermal energy storage (TES) have excellent capability for providing thermal comfort in building's occupant by decreasing heating and cooling energy demands. Because of its latent heat property, a PCM has a high energy density. The building uses PCMs mainly for space heating or cooling, control of building material temperature and increase in building durability, solar water heating, and waste heat recovery from high heat loss locations. Phase change materials for thermal energy storage has been proven to be useful for reducing peak electricity demand or increasing energy efficiency in heating, ventilation, and air-conditioning systems. The primary grid benefit of PCM based thermal energy storage system is load shifting and shedding, which is accomplished by re-charging the storage system during off-peak times and substituting heating, ventilation, and air-conditioning system operation during peak times. This study examines PCM based thermal energy storage systems in building applications and benefits, focusing on their substantial limitations, and closes with recommendations for further improvement of design for use.

Keywords: thermal energy storage, phase change material, thermal comfort, heating, cooling, paraffin, salt hydrate, energy efficiency, benefits and improvements of design

Regularities of Bubble Formation on the Holes of Immersed Hole Sheets of Bubble Devices

V. A. Devyanin*

National Research University Moscow Energy Institute, Moscow, 111250 Russia

**e-mail: slava.devyanin@gmail.com*

Abstract—Based on literature data, an analysis of the modes of bubble formation on holes immersed in the working environment of bubbling apparatuses was carried out. The limits of applicability of calculated dependencies for determining the average bubble diameter between different areas of bubble formation on single holes under conditions of constant gas flow into the bubble and constant gas pressure in the resulting bubble are given. When comparing calculated and experimental data on the sizes of the formed bubbles, it was found that, for the jet mode, there is no single calculated dependence that can at the same time quite accurately reflect the influence of both the hole diameter and the physical properties of the two-phase medium on the bubble sizes. Despite the fact that a number of studies have shown experimentally and theoretically that the movement of liquid caused by rising bubbles in front has a significant effect on the size of the bubbles, there are no verified calculated dependencies at present in the literature that take into account this effect over the entire range of gas flow through holes of different diameters under different physical properties of the working environment. Based on the balance of forces acting at the moment of bubble separation, a model is proposed that also takes into account the influence on the size of bubbles formed near the hole by the movement of liquid caused by rising bubbles in front. As a result of generalizing a large amount of experimental data available in the literature, a generalized dependence of the dimensionless average diameter of bubbles on Bond, Froude, and Reynolds numbers was obtained for constant flow conditions for bubble and jet modes. The derived relationship is valid for holes with different internal diameters and a wide range of physical properties of the working medium. The lower and upper limits of applicability of the formula for bubble and jet modes of bubble formation have been established.

Keywords: bubble formation, bubble mode, jet mode, immersed perforated sheet, single holes, model of bubble formation, bubble diameter, generalizing calculated dependence

Water Chemistries of VVER-SCW Nuclear Facilities: The Choice and Justification (Review)

N. L. Kharitonova^{a, *} and V. F. Tyapkov^{a, **}

^a National Research Nuclear University MEPHI (Moscow Engineering Physics Institute), Moscow, 115409 Russia

*e-mail: NLKharitonova@mephi.ru

**e-mail: vladimirtyapkov@yandex.ru

Abstract—The article discusses the potential problems that have to be solved in the framework of development and justification of the water chemistry (WC) conditions required to ensure corrosion resistance of the structural materials used in the core and coolant circuit of the power-generating reactor used in the supercritical water cooled VVER-SCW nuclear power facility (NPF). In reactors cooled with water at supercritical temperature and pressure, the integrity of their physical barriers (fuel-rod claddings and reactor coolant circuit boundaries) depends in many respects on the possibility of maintaining the necessary water chemistry conditions that will guarantee the corrosion resistance of equipment and pipeline structural materials for the power unit's entire service life. The most complex challenge in this regard is to inhibit corrosion and flow-accelerated corrosion processes and to minimize the formation of deposits on the surface of equipment operating in the domain of near-critical and supercritical conditions. The article formulates the limitations that are suggested to be considered in transferring the experience gained from the standardization of water chemistry in supercritical pressure (SCP) power units at thermal and nuclear power plants to the VVER-SCW NPFs. An analysis is carried out that makes it possible to estimate the effect the chemical composition of a supercritical water coolant has on the corrosion state of candidate structural materials for fuel-rod claddings with the aim to get better insight in the main processes occurring in aqueous solutions and for developing (elaborating) a WC conduction technology as applied to ensuring the integrity of the VVER-SCW NPF physical safety barriers.

Keywords: reactor plants for supercritical conditions, safety, water coolant, VVER-SCW, water chemistry, concentration, water coolant physicochemical properties, flow-accelerated corrosion processes, deposit formation, radiolysis

Analysis of the Influence of Aerosol Particle Size Distribution on the Behavior of Fission Products during Simulation of an Accident at an NPP with VVER

S. S. Savekin^{a,*} and Yu. B. Shmelkov^a

^a National Research Center Kurchatov Institute, Moscow, 123182 Russia

**e-mail: starsavrus@gmail.com*

Abstract—Due to the potential danger of exposure to aerosol particles on the human body, maximum permissible concentrations of harmful substances are limited by current regulatory documentation. The formation of aerosol particles is possible during beyond design basis accidents at nuclear power plants. The consequences of the radioactive impact of radioactive aerosol particles formed during an accident at a nuclear power plant on the human body are significantly more severe than from the mechanical impact of such particles. An important characteristic of radioactive aerosol particles is their polydispersity (unevenness in size) since particles of different sizes during an accident at a nuclear power plant have different rates of removal from the atmosphere of the nuclear power plant's containment shell. Thus, when considering the movement of particles in the containment and the release of aerosol particles into the environment, it is important to correctly model the size distribution of aerosol particles. This paper presents the results of calculating the count and weight distributions of aerosol particles by size in the TOSQAN and Phebus-FP experiments. Methods are given for describing polydisperse systems (using particle size distribution or “average” sizes characterizing the entire distribution) and their influence on processes associated with the transfer of aerosol particles in a protective shell, and practical recommendations for working with particle size distributions are given. A comparison is made of the use of average size distribution characteristics and the lognormal distribution of aerosol particles to estimate the release during a hypothetical accident at a nuclear power plant with VVER.

Keywords: reactor plant, aerodisperse systems, aerosol particles, size distributions, nuclear power plants, VVER, accident modeling, TOSQAN and Phebus-FP experiments

Description of the Tiltable Vortex Burner Design and Modeling Its Operation during Coal and Natural Gas Combustion

I. A. Ryzhii^{a,*}, A. V. Shtegman^a, D. V. Sosin^a, and A. S. Natal'in^a

^a *All-Russia Thermal Engineering Institute, Moscow, 115280 Russia*

**e-mail: ryzhy1987@mail.ru*

Abstract—The computational studies carried out previously taking as an example the BKZ-210-140 boiler installed at Tomsk-2 state-owned district power plant (SDPP) have shown that, given the existing scatter in the characteristics of coals fired at the power plant, the temperature of gases at the boiler furnace outlet may vary in a wide range (more than 100°C). Such variability of the operational parameters entails a number of problems, including difficulties with keeping a stable superheated steam temperature, increased risk of heating surfaces becoming slagged, and less efficient fuel combustion. A conclusion has been drawn based on the obtained computation results that the possibility of adjusting the flame's initial section vector by $\pm 15^\circ$ will make it possible to solve the above-mentioned problems to a significant extent. A tiltable burner is the key component of the combustion system with adjusting the flame position. Based on an analysis of the current operation conditions of the Tomsk-2 SDPP BKZ-210-140 boiler, technical solutions were developed on the design of a tiltable vortex burner intended for combusting pulverized coal as well as natural gas and fuel oil. The burner's outlet part is made so that it is possible to tilt it by $\pm 15^\circ$ in the vertical plane and by $\pm 5^\circ$ in the horizontal plane, which will make it possible to adjust the combustion mode in an efficient manner. The furnace process is simulated in the ANSYS Fluent software package under different boiler operation conditions. The simulation results show that, in the case of using the new burners, it is possible to improve the furnace process efficiency. By tilting the burner by $\pm 15^\circ$ in the vertical plane, it becomes possible to obtain the temperature adjustment range at the furnace outlet equal to 120°C. Based on the adopted technical solutions, design documentation for the burner has been developed. An experimental sample of the low-toxic tiltable vortex burner installed in the Tomsk-2 SDPP BKZ-210-140 boiler has been manufactured.

Keywords: steam boiler, coal characteristics, slagging, combustion efficiency, tiltable burner, burner design, air-fuel mixture flow splitters, furnace process modeling, radiant heat transfer, incomplete combustion, solid particles, nitrogen oxides