

Contents

Vol. 72, No. 1, 2025

Steam-Turbine, Gas-Turbine, and Combined-Cycle Power Plants and Their Auxiliary Equipment

Ammonia as a Fuel for Gas-Turbine Units with Thermochemical Recuperation
of Exhaust Gas Heat

D. I. Pashchenko

Development of a Theoretical Model for Predicting Performance of a Gas Ejector
in Different Boundary Conditions and Working Fluids

Saeed Akbarnejad and Masoud Ziabasharagh

Advanced Exergy Analysis and Performance Ranking of Components
of a Combined Cycle Power Plant

*Uchenna G. Azubuike, Howard O. Njoku,
Mkpamdi N. Eke, and Onyemaechi V. Ekechukwu*

Performance Improvement of Power Plant at Aberrant Steam Temperature Condition
through E3 Analysis

Goutam Khankari, D. V. Rajan, and Sujit Karmakar

Heat and Mass Transfer and Properties of Working Fluids and Materials

Heat Transfer and Pressure Drop in Main Heat Exchangers
of a Thermal Oil ORC-Unit (Review)

*I. S. Antanenkova, Yu. A. Geller, M. M. Vinogradov, E. A.
Gorbunova, and V. I. Kuznetsov*

Renewable Energy Sources, Hydropower

Assessing the Economic Efficiency of Using Wind Turbines Jointly with Boiler Houses for Heat
Supply in Remote and Isolated Regions of the Westernmost Part of Russia's Arctic Zone

A. V. Bezhan

Water Treatment and Water Chemical Regime

Environmental Consequences of Using Ammonia-Ethanolamine Water Chemistry
in the Second Circuit of VVER-1200 Nuclear Power Plants

*V. G. Kritsky, A. V. Gavrilov, N. A. Prokhorov, E. A. Motkova,
N. A. Pelageecheva, M. S. Shvaleva, and A. V. Karpov*

Ammonia as a Fuel for Gas-Turbine Units with Thermochemical Recuperation of Exhaust Gas Heat

D. I. Pashchenko^{a, b, *}

^a *Guangdong Technion–Israel Institute of Technology, Shantou, 515063 China*

^b *Samara State Technical University, Samara, 443100 Russia*

*e-mail: dmitry.pashchenko@gtiit.edu.cn

Abstract—The prospects are examined for application of ammonia-fired gas turbine units (GTUs) with thermochemical recuperation of the exhaust gas heat. Examples of operating ammonia-fired gas turbine units are given, and the main operating restrictions for the use of existing gas turbine units are specified. A thermodynamic analysis of a simple gas turbine unit with thermochemical heat recuperation (TCR) was performed in a wide range of operating conditions: the gas temperature at the turbine inlet varied from 700 to 1300°C and the compressor pressure ratio from 5 to 20. It has been established that the thermochemical heat recuperation can increase the GTU efficiency by as much as 9%. The effectiveness of TCR application has been demonstrated to depend on such operating parameters as pressure and temperature. At a temperature above 500°C, the enthalpy of the ammonia decomposition reaction reaches a value close to the maximum of approximately 3.0 MJ/kg NH₃. Thermochemical recuperation leads to the decomposition of ammonia with production of a hydrogen-rich gas (up to 75% (by volume)), which is burned in the combustion chamber, thereby changing the combustion process characteristics. The flame propagation velocity in a gas mixture consisting of hydrogen, nitrogen, and ammonia in different proportions was calculated on the basis of the GRI-Mech 3.0 list of elementary reactions in the Chemkin-Pro module. It has been found that the products of complete thermochemical decomposition of ammonia have a flame propagation velocity that is approximately two times higher than that for methane and more than ten times higher than that for ammonia. Thus, the implementation of the thermochemical heat recuperation in ammonia-fired gas turbine units is expected to increase the energy efficiency and improve the combustion process stability.

Keywords: ammonia, hydrogen, gas turbine unit, flame propagation velocity, thermodynamic analysis, thermochemical recuperation, effectiveness

Development of a Theoretical Model for Predicting Performance of a Gas Ejector in Different Boundary Conditions and Working Fluids

Saeed Akbarnejad^a and Masoud Ziabasharhagh^{a,*}

^a Department of Mechanical Engineering, K. N. Toosi University of Technology,
Pardis Street, Molla-Sadra Avenue, Vanak Square, Tehran, Iran

*e-mail: mzia@kntu.ac.ir

Abstract—Ejectors are devices designed to suck fluid, steam or gas (primary fluid) from a closed space using a powerful jet of steam (secondary fluid), usually operated under specified boundary conditions using specific working fluids. If ejectors are to be used under new boundary conditions, predicting their performance requires either numerical or experimental studies. This paper presents a simple theoretical model capable of accurately predicting the performance of an ejector, given its geometry and boundary conditions, under different operating conditions. The model can predict the entrainment ratio, critical back pressure, and break-up back pressure using a given simple performance curve. The accuracy of the model is validated using computational fluid dynamics (CFD) simulations. Two ejectors with different geometries, dimensions, and boundary conditions are studied using ANSYS Fluent 19.2, and the results are compared with those from two other studies. The model successfully predicts the performance of all four ejectors across a wide range of operating conditions. Finally, the model is extended to any working fluid and temperature and validated numerically using air as the working fluid instead of water vapor. The results show that the model has an entrainment ratio error of less than 2%. It's worth noting that this model's applicability is contingent upon simultaneous changes to both the primary and suction streams by the same factor. Under these conditions, the model aligns closely with CFD-simulations.

Keywords: supersonic steam ejector, theoretical model, performance curve, entrainment ratio, critical back pressure, break-up back pressure, working fluid, pressure ratio

Advanced Exergy Analysis and Performance Ranking of Components of a Combined Cycle Power Plant

Uchenna G. Azubuike^{a, b}, Howard O. Njoku^{b, c, *}, Mkpamdi N. Eke^b, and Onyemaechi V. Ekechukwu^b

^a Department of Mechanical Engineering, Bells University of Technology, Ota, 112104 Nigeria

*^b Sustainable Energy Engineering Research Group, Department of Mechanical Engineering, University of Nigeria,
Nsukka, 410001 Nigeria*

^c Department of Mechanical Engineering Science, University of Johannesburg, Auckland Park, Johannesburg, 2092 South Africa

**e-mail: howard.njoku@unn.edu.ng*

Abstract—As conventional exergy analyses do not reveal the exergy destruction rates in a thermal system component caused by inefficiencies of interconnected components, actual potentials for improving the component performances cannot be provided by such analyses. This study analyses a combined-cycle gas turbine power plant using advanced exergy analysis methodologies, which address the shortcomings of conventional exergy analysis by evaluating the exergy destruction rates that are endogenous and exogenous, avoidable and unavoidable. Avoidable exergy destruction rates in the entire plant were found to be 31% of the total exergy destruction rates, indicating a significant potential for improving the plant. Exergy destruction rates for most of the plant components were largely endogenous (95.2%), signifying that contributions of cross-component interactions were limited. Avoidable endogenous exergy destruction rates account for 28.4% of the overall exergy destruction rates in the plant, while avoidable exogenous exergy destruction rates account for 2.1%. A component-level ranking of the plant components ranked the pumps in the plant as first for improvement whereas the highest priority was allocated to the combustion chambers (CC) by a plant-level ranking. A parametric study of the influence of CC operating conditions on the plant's performance showed that CC operating temperatures more significantly affected plant exergy destruction rates than the CC operating pressures.

Keywords: advanced exergy, avoidable and unavoidable exergy, endogenous and exogenous exergy, combined cycle, plant component, combustion chamber, gas turbine, heat recovery steam generator, operating temperature and pressure

Performance Improvement of Power Plant at Aberrant Steam Temperature Condition through E³ Analysis

Goutam Khankari^{a,*}, D. V. Rajan^a, and Sujit Karmakar^b

^a R&D Kolkata, Damodar Valley Corporation, DVC Hq., DVC Towers, Kolkata, 700054 India

^b Mechanical Engineering Dept., NIT Durgapur, West Bengal, 713209 India

*e-mail: goutam.khankari@dvc.gov.in

Abstract—Energy efficient and environment friendly power generation is the primary goal for any power generating industries. This paper proposes a thermodynamic approach based on E³ (energy, exergy and environment) analysis for performance improvement of power plant during low main steam and high reheat (RH) temperature conditions through a suitable operation technique. Thermodynamic modeling of a 500 MW Subcritical (SubC) coal based thermal power plant is carried in “Cycle-Tempo” at different conditions. Partial withdrawal of final feed water heater (high pressure heater – HPH-6) from service without RH spray condition during low main steam (MS) temperature and high RH steam temperature condition will help to increase the MS temperature by about 0.85–1.00°C and thereby, the net plant energy and exergy efficiency will be improved by about 0.09 and 0.08% point, respectively. Partial withdrawal of HPH-6 with RH spray condition will deteriorate the plant energetic and exergetic plant performance and this will guide the operation engineer for which extend withdrawal of HPH-6 can be done for getting higher plant performance. The net energy efficiency of turbogenerator (TG) cycle decreases with partial withdrawal of HPH-6 due to decrease in the feed water temperature by about 7°C and more relative energy rejection of the cycle. The net exergy efficiency of TG cycle increases due to less relative exergy destruction rate causing from improvement in steam quality. However, the use of RH spray increases the irreversibilities in the plant and the spray does not expand in high pressure turbine (HPT) which in turn decrease the exergy efficiency. The boiler energy efficiency increases due to decrease in fluegas exit loss as the fluegas exit temperature drops from about 140 to 133°C due to partial withdrawal of HPH-6. The exergy efficiency of boiler also decreases due to increase in exergy destruction in final super heater (FSH), reheat and economizer. For a 500 MW SubC coal power plant, hourly about 930 kg of coal and about 1183 kg of CO₂ emission can be saved and reduced through this operation technique namely, partial withdrawal of HPH-6 without RH spray condition for controlling low MS temperature. Hence, the proposed analysis will help to take proper operational technique for mitigating coal crisis and safeguarding the environment as well.

Keywords: coal power plant, high pressure heater, hot reheat temperature, energy, exergy, environment, main steam temperature, operation practice, reheat spray

Heat Transfer and Pressure Drop in Main Heat Exchangers of a Thermal Oil ORC-Unit (Review)

I. S. Antanenkova^a, *, Yu. A. Geller^a, M. M. Vinogradov^a, E. A. Gorbunova^a, and V. I. Kuznetsov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: antanenkova@mail.ru

Abstract—The purpose of the review is to find the best currently available correlations for calculating heat transfer and pressure drop in the main heat-transfer equipment items in organic Rankine cycle (ORC) units. The search is limited to the designs of apparatuses, which are the best ones in the opinion of the authors of this paper, for a conventional two-circuit ORC-unit, where thermal oil cools a heat source in the first circuit and transfers heat to refrigerant in the vapor generator (hereinafter referred to as the evaporator). Besides the evaporator, the second circuit of the unit includes a “refrigerant–water” or “refrigerant–air” condenser and a regenerative heat exchanger which heats up liquid refrigerant upstream of the evaporator with the exhaust vapor of the turbine (or expander). The criteria are presented for selecting working fluids for such units depending on the heat source temperature. The working fluids that have found the widest application at each temperature level (such as cyclopentane, benzene, toluene, MM, MDM, R1233zd, R245fa, R601, R601a, RC318, R134a) are listed, and their characteristics and thermodynamic properties are presented at specified condensation (25°C) and boiling (200, 120, and 70°C) points. The analysis of these data, including information on the proposed working fluids, has yielded nominal parameters of ORC-units. Thousands of fundamental and engineering works are devoted to the study of boiling and condensation processes, the interest in which has been growing over the past 10–15 years. The development of new energy conversion technologies and the appearance of new working fluids, materials, and methods of surface treatment has given a second wind. This paper reviews correlations for heat-transfer coefficients and hydraulic resistance factors in apparatuses with refrigerant boiling in round tubes, condensation in tubes and channels and in the shell side (on tube bundles), and heating and cooling of single-phase refrigerant in tubes and channels. The correlations for engineering calculation of the main heat-transfer equipment of ORC-units, which are the most convenient ones in the authors' opinion, are presented.

Keywords: organic Rankine cycle, ORC-unit, thermal oil, refrigerant, working fluid selection, boiling in tubes, condensation, shell-and-tube heat exchanger, plate heat exchanger, heat transfer, vapor quality, hydraulic resistance

Assessing the Economic Efficiency of Using Wind Turbines Jointly with Boiler Houses for Heat Supply in Remote and Isolated Regions of the Westernmost Part of Russia's Arctic Zone

A. V. Bezhan*

*Center for Physico-Technical Problems of Energy of the North, Kola Science Center, Russian Academy of Sciences,
Apatity, Murmansk oblast, 184209 Russia*

*e-mail: a.bezhан@ksc.ru

Abstract—The article addresses matters concerned with decreasing the prime cost of thermal energy in the remote and isolated regions of Russia's Arctic zone (AZ) that have a high wind energy potential by using wind turbines (WTs) jointly with boiler houses operating on expensive imported fossil fuel for heat-supply purposes. The use of wind turbines will make it possible to decrease the participation of boiler houses in the supply of heat to consumers, save fossil fuel, and, thereby, help decrease the prime cost of thermal energy. A procedure for calculating the leveled cost of thermal energy is developed and described in detail. The procedure is adapted to analyzing the efficiency of alternative options of using WTs jointly with boiler houses for heat-supply purposes, among which the alternative ensuring the minimal leveled cost of thermal energy is regarded as the most efficient one. By using the obtained technique, the economic efficiency of applying WTs jointly with boiler houses in the heat-supply systems of remote and isolated regions is evaluated taking the westernmost part of Russia's Arctic zone as an example. It has been determined that, in such regions, in which the final annual average cost of fossil fuel is more than 1.5 times higher than the fuel cost in the cities and industrial centers of the AZ westernmost part as a consequence of a high transport component, the WTs are most efficient when used jointly with boiler houses operating on diesel fuel. For boiler houses operating on fuel oil and coal, the effect from using WTs is not so high. It is also shown that the cheaper the fuel, the less efficient or even inefficient at all the use of WTs becomes in comparison with the heat-supply option from a boiler house without connecting a WT. For the regions considered, the joint production of thermal energy by WTs and boiler houses operating on diesel fuel, fuel oil, and coal makes it possible to decrease its leveled cost by 7–55, 5–20, and 2–7%, respectively.

Keywords: heat supply, efficiency improvement, wind turbine, boiler house, Russia's Arctic zone, fossil fuel, heat accumulators

Environmental Consequences of Using Ammonia-Ethanolamine Water Chemistry in the Second Circuit of VVER-1200 Nuclear Power Plants

**V. G. Kritsky^a, *, A. V. Gavrilov^a, N. A. Prokhorov^a, E. A. Motkova^a,
N. A. Pelageecheva^a, M. S. Shvaleva^a, and A. V. Karpov^b**

^aAO Atomenergoproekt, Saint Petersburg, 197183 Russia

^bOOO Spetsproekt, St. Petersburg, 190005 Russia

*e-mail: kritsky@spbaep.ru

Abstract—The ammonia-ethanolamine water chemistry regime used at NPPs with VVER-1200 ensures low rates of corrosion, mass transfer, and growth of corrosion product deposits. The content of corrosion products in the feedwater of the steam generator is less than 1 $\mu\text{g}/\text{dm}^3$. This significantly increases the period between flushing the steam generator to remove deposits. However, ethanolamine and ammonia are absorbed by the cationite in the ion-exchange filters of the second circuit purification systems, which leads to the need to regenerate the cationite and continuously dose reagents to maintain the required pH value in the feedwater. Waste solutions from regeneration containing ethanolamine and large amounts of ammonia must be treated to ensure that the concentrations of these substances do not exceed maximum permissible values when discharged into the environment. To remove ethanolamine and ammonia from regeneration solutions, special installations are created, the operation of which is based on various principles. A pilot plant for cleaning regeneration solutions was manufactured and installed at the Belarusian NPP with VVER-1200. An analysis of the pilot plant's operation showed that it successfully fulfills its function of protecting the aquatic environment but, at the same time, it is forced to release a significant amount of ammonia into the surrounding air. Removing ammonia is energy-consuming, environmentally unsafe, and requires the additional use of chemical reagents. In this regard, the water-chemical regime of the second circuit without ammonia is very promising. Possible options could be either switching from ammonia to dimethylamine or using ethanolamine as the only corrective reagent with the replacement of some of the structural materials of the second circuit with steels with a high chromium content, which have higher corrosion resistance compared to those currently used. Both options will simplify the wastewater treatment technology and reduce the environmental impact while maintaining the low corrosion rates achieved by using the ammonia–ethanolamine water chemistry regime.

Keywords: water chemistry, VVER-1200, ammonia, ethanolamine, dimethylamine, mass transfer, corrosion products, regeneration solution purification unit