

Contents

Vol. 72, No. 2, 2025

Steam Turbine, Gas Turbine, Combined-Cycle Gas Plants and Their Auxiliary Equipment

Influence of Discharge Collecting Chambers on the Efficiency
of a Turbogenerator Air Ventilator

V. G. Gribin, O. M. Mitrokhova, P. M. Nesterov, and S. N. Mitrokhov 5

The Influence of Air Inleakages on the Dynamic Characteristics of the Steam Turbine
Unit Condenser–Ejector System

*K. E. Aronson, A. Yu. Ryabchikov, D. V. Brezgin, D. Yu. Balakin,
N. V. Zhelonkin, and A. L. Demidov* 12

Heat and Mass Transfer, and Properties of Working Fluids and Materials

Modeling of R-142b Saturated Vapor Condensation in a Horizontal Tube Using
the VOF Method in the Wall Conjugate Statement

G. G. Yan'kov, K. B. Minko, O. O. Mil'man, and V. I. Artemov 19

Nucleate Boiling Heat Transfer of Dielectric Liquid HFE-7100 in Horizontal
Layers at Various Pressures

A. E. Brester, D. A. Shvetsov, V. I. Zhukov, and A. N. Pavlenko 30

CFD-Simulation of Bulk Condensation Considering the Finite Rate
of Interphase Heat Transfer

A. A. Sidorov and A. K. Yastrebov 41

Renewable Energy Sources and Hydropower

Renovation of Grid-Tied Solar Photovoltaic Plants: Problems and Prospects

A. B. Tarasenko and S. V. Kiseleva 56

Processing Carbon Dioxide Into Ethanol based on Thermal Energy Supported
by Solar Energy

U. Das, T. H. Dar, and C. Nandi 69

Steam Boilers, Energy Fuel, Burners, and Boiler Auxiliary Equipment

Investigation into Operation of a Semitower Boiler of a 158-MW Power Unit and Prospects
for Application of Such Boilers in Russia

V. M. Supranov, B. R. Sosa, B. Kh. F. Sosa, and K. A. Pleshanov 84

Environmental Protection

Development of Adsorbent out of Waste from a Thermal Power Plant's Water-Treatment Plant
for Removal of Carbon Dioxide

A. A. Filimonova, A. Yu. Vlasova, N. D. Chichirova, and R. F. Kamalieva

Influence of Discharge Collecting Chambers on the Efficiency of a Turbogenerator Air Ventilator

V. G. Gribin^a, O. M. Mitrokhova^a, P. M. Nesterov^{a, *}, and S. N. Mitrokhov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

**e-mail: NesterovPM@mpei.ru*

Abstract—This paper presents the results of computational-theoretical and experimental studies of a model of discharge collecting channels of a typical centrifugal fan in an air-cooled turbogenerator. An experimental test bench was created and a measurement system was developed to determine losses with different configurations of cooling air discharge channels. It was found that the original design of the turbogenerator fan's discharge collecting chamber has low aerodynamic efficiency due to high internal losses, which reduce the technical and economic performance of the turbogenerator. One cost-effective way to increase fan performance by reducing losses is through aerodynamic optimization of the collecting chamber contours. Analysis of computational-theoretical and experimental research results of the typical fan collecting chamber design showed that the system of guide ribs has the main influence on loss levels and aerodynamic efficiency, since these ribs simultaneously provide structural rigidity and reliability while forming the flow path geometry. An optimized flow path for the collecting chamber was developed and tested without requiring changes to the overall fan housing dimensions. The improvement in aerodynamic characteristics is associated with modifying the guide rib system design through flow channel reprofiling. The optimization of the fan collecting chamber design increased useful power output by reducing aerodynamic losses in the turbogenerator's air-cooling system. The design optimization, which ensures smooth increase in flow area with reduced positive pressure gradients in diffuser sections of the flow path, led to a relative efficiency increase of 24% while simultaneously reducing the metal consumption of the air-cooled turbogenerator centrifugal fan collecting chamber structure.

Keywords: air fan, turbogenerator cooling, collecting chamber, diffusers, air fan efficiency, guide ribs

The Influence of Air Inleakages on the Dynamic Characteristics of the Steam Turbine Unit Condenser–Ejector System

K. E. Aronson^{a, *}, A. Yu. Ryabchikov^a, D. V. Brezgin^a,
D. Yu. Balakin^a, N. V. Zhelonkin^a, and A. L. Demidov^a

^a Ural Federal University (UrFU), Yekaterinburg, 620002 Russia

*e-mail: k.e.aronson@urfu.ru

Abstract—The results obtained from experimental investigations of the dynamic characteristics of a condenser and new ejector are presented. The investigations were carried out at a thermal power plant under the turbine commercial operation conditions using an extended arrangement for measuring the ejector operation parameters and an automated data-acquisition system. The dependences of the ejector's first stage suction pressure on the dry (atmospheric) air flowrate and the pressure in the condenser and in the ejector's first stage receiving chamber on the steam-air mixture flowrate during their joint operation are obtained. It is proposed to determine the maximal volumetric throughput of the ejector operating on dry air with using the minimal slope factor as a function of the air flowrate. With an increase of air inleakages into the steam turbine unit vacuum chamber, the pressure difference at the initial and total air inleakages at the ejector suction varies according to a linear law and that in the condenser according to an exponential law. By using the measurement system, the condenser's and ejector's dynamic characteristics were determined. It has been found that the pressure growth rate at the ejector suction increases with increasing the amount of air admitted into the condenser. The time taken for the pressure to become stable remains approximately the same. However, the pressure growth rate in the condenser does not depend on the amount of air admitted, and the time taken for the pressure to become stable increases exponentially with increasing the amount of air admitted. For diagnosing the vacuum system malfunctions in controlling the steam turbine unit's operation mode, it is recommended to provide indication of the ejector suction pressure on the turbine control board. As regards the pressure sensor, it is proposed to install it on the common pipeline supplying steam–air mixture to the ejectors. The investigation of the condenser–ejector system dynamic characteristics will make it possible to improve the turbine vacuum protection, which is one of the turbine protection system components.

Keywords: steam turbine, condenser, multistage steam jet ejector, dynamic characteristics, slope factor, ejector suction, steam-air mixture, dry air

Modeling of R-142b Saturated Vapor Condensation in a Horizontal Tube Using the VOF Method in the Wall Conjugate Statement

G. G. Yan'kov^{a, b}, K. B. Minko^{b, *}, O. O. Mil'man^{a, c}, and V. I. Artemov^{a, b}

^a *Tsiolkovsky Kaluga State University, Kaluga, 248023 Russia*

^b *National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow, 111250 Russia*

^c *Turbokon Research and Production Implementation Enterprise (ZAO NPVP), Kaluga, 248010 Russia*

**e-mail: minkokb@gmail.com*

Abstract—Owing to the modern level of powerful computational fluid dynamics (CFD) codes and developed models and algorithms, numerical simulation has become an efficient tool for studying two-phase flows, analyzing the entire totality of the processes occurring in them, and obtaining the data on flow local characteristics, which are poorly amenable for direct measurement. Active efforts taken for incorporating new models into various CFD codes should be accompanied by their cross-verification, the results of which can serve as a basis for selecting the most accurate, efficient, and universal models and algorithms. In this article, the results obtained from the solution of the problem about the condensation of R142b refrigerant saturated vapor in a horizontal tube in the wall conjugate statement using two CFD codes, ANES and ANSYS Fluent, are analyzed. The copper tube's inner diameter is 28 mm, its length is 2.75 m, wall thickness is 2 mm, and the vapor mass velocity is 47 kg/(m² s). The studies are of relevance for heat recovery installations based on the organic Rankine cycle. The calculations were carried out using the modified Lee model that we suggested previously, and which has been implemented in the ANES CFD code developed at the NRU MPEI Chair of Engineering Thermal Physics. The cross verification of the VOF algorithms implemented in the ANES and ANSYS Fluent codes has shown that the results of modeling the saturated vapor condensation in a horizontal tube obtained using the above-mentioned codes are in good agreement with each other and are close to the empirical dependences recommended in the literature sources (M. Shah) for calculating the condensation in a horizontal channel. Data on the distribution of local heat-transfer characteristics over the tube's inner wall are presented, which demonstrate that the heat-transfer coefficient features an essential nonuniformity over both the tube length and perimeter.

Keywords: condensation, horizontal tube, numerical simulation, VOF method, conjugate statement, wall temperature nonuniformity, local heat transfer

Nucleate Boiling Heat Transfer of Dielectric Liquid HFE-7100 in Horizontal Layers at Various Pressures

A. E. Brester^{a, b, *}, D. A. Shvetsov^{a, b}, V. I. Zhukov^{a, b}, and A. N. Pavlenko^a

^a *Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

^b *Novosibirsk State Technical University, Novosibirsk, 630073 Russia*

**e-mail: brester94@gmail.com*

Abstract—Experimental data are presented on nucleate boiling heat transfer of dielectric liquid HFE-7100 in horizontal layers. The liquid layer height was varied in a wide range while changing the pressure in the working chamber. The experiments were performed on a flat surface of a 120-mm outer diameter stainless-steel plate in an experimental heat-transfer vacuum setup whose working chamber was a thermal syphon. The experimental data were compared with the Yagov and Gogonin correlations which had been obtained for pool boiling. The Gogonin correlation has been demonstrated to properly generalize the experimental data in all ranges of reduced pressures and liquid layer heights. This correlation explicitly describes the influence of such parameters as the heating surface roughness and the ratio of the thermophysical properties of the liquid and the heat-transfer wall, which have a pronounced effect on the heat-transfer coefficient during boiling of dielectric liquids. Besides, this correlation is convenient since it can be used with parameters that can be monitored during the experiment. A generalization is presented of experimental data by the Pioro empirical correlation recommended for generalizing data on nucleate boiling in thin liquid layers. It has been demonstrated that the Pioro correlation with carefully selected coefficients and power exponents can generalize with an acceptable accuracy the experimental data obtained under given conditions on a heat-transfer wall exposed to a working fluid. To quantitatively assess the agreement between the computational correlations and experimental data on nucleate boiling of dielectric liquid HFE-7100 in horizontal layers, the mean error and rms deviation were used.

Keywords: dielectric liquid HFE-7100, thin liquid layer, heat transfer, boiling, reduced pressure, heat-transfer vacuum setup, mean error, rms deviation

CFD-Simulation of Bulk Condensation Considering the Finite Rate of Interphase Heat Transfer

A. A. Sidorov^{a, *} and A. K. Yastrebov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: AlexSid-MPEI@yandex.ru

Abstract—The work is devoted to simulation of the bulk condensation in a supersonic flow of a vapor-gas mixture through the Laval nozzle considering the finite rate of the interphase heat transfer. Numerical methods are examined for predicting the temperature of droplets using the improved VOF (Volume of Fluid) and Eulerian multiphase models. It has been demonstrated that, compared to the Eulerian model, the VOF model more accurately predicts the known experimental data and provides the numerical solution whose stability is less susceptible to the effect of high intensity source terms. Comparison of the predictions with the experimental data of other authors has revealed that the two-temperature model more accurately describes the flow with bulk condensation than the single-temperature model does. The application of a single-temperature approximation is justified when the impurity content in the mixture does not exceed 2% (by weight) since the zone of the active condensation onset is relocated considerably compared to its relocation in the case of the two-temperature approximation. However, the single-temperature approximation is recommended only for calculating the overall heat release level that could be beneficial, for example, for quick assessment of the effect of bulk condensation on turbine stage performance. The previously obtained estimates confirmed the applicability of the single-temperature formulation at an impurity content as high as 5 wt %, but solving this problem in 3D formulation improved the accuracy of these estimates. It has been revealed that the assumption about the flow homogeneity along the channel height (as one of the assumptions employed in one-dimensional calculations) during bulk condensation in a slot-type Laval nozzle is not valid on changing-over to a three-dimensional two-temperature formulation: supersaturation persists at the phase boundary, as a result of which the droplet growth process continues at the circumference of the flow.

Keywords: bulk condensation, multiphase flow, multiphase model, finite volume simulation, CFD-software package, kinetic equation

Renovation of Grid-Tied Solar Photovoltaic Plants: Problems and Prospects

A. B. Tarasenko^a and S. V. Kiseleva^{a, b, *}

^a *Joint Institute for High Temperatures, Russian Academy of Sciences (JIHT RAS), Moscow, 125412 Russia*

^b *Moscow State University, Moscow, 119991 Russia*

**e-mail: k_sophia_v@mail.ru*

Abstract—Rapid development of energy technologies results, in particular, in that photovoltaic modules often become obsolete even before the end of their assigned service life. It is sufficient to say that, for the period from 2014 to nowadays, the average efficiency of photovoltaic modules has increased from 14–15 to 21%. The prices for photovoltaic products also continue to decrease. In this connection, the possibility of substituting the equipment of existing solar power plants with more advanced components is of interest. Photovoltaic module replacement versions, as well as technical and economic aspects of this process, are discussed taking Russia's first grid-tied photovoltaic plant Kosh-Agach-1 as an example. The modern types of photovoltaic modules and the options of using them for solar plant renovation purposes are analyzed. The prime cost of the electricity generated is estimated with taking into account the replacements of modules and inverters. Special attention is paid to the compatibility of new modules with the old support structures and inverter equipment. The decrease of electricity prime cost after installing the new modules serves as the main renovation feasibility criterion. It is shown that the refurbishment of plants equipped with thin-film silicon modules by replacing them with domestically produced or Chinese modules consisting of silicon photovoltaic plates 166×166 mm in size looks to be the most promising option. The minimal prime cost of generated electricity is achieved in the case of using heterojunction modules and modules on the basis of photovoltaic converters with a rear contact.

Keywords: photovoltaic energy, crystalline photovoltaic modules, thin-film photovoltaic modules, inverters, grid-tied photovoltaic power plants, renovation

Processing Carbon Dioxide Into Ethanol based on Thermal Energy Supported by Solar Energy

U. Das^a, T. H. Dar^a, and C. Nandi^{a, *}

^a *Department of Electrical Engineering, Tripura University, Agartala, Tripura, 799022 India*

**e-mail: chmpnandi@gmail.com*

Abstract—The thermal power plant recognized as the most pollutants emitted power plant in the world. The use of the solar systems is essential for reducing carbon emissions from thermal power plants. Such hybrid systems need a skillful energy management technology as well as incorporation of carbon conversion technology that will help to run the system expertly to maintain the power generation-demand balance and make the thermal plant more cleaner than before respectively. This work describes a fuzzy logic-based energy management system for a thermal-solar hybrid system and a carbon conversion technology to convert the captured carbon into the chemical products after calculating the environmental impact of a stand-alone thermal power plant through life cycle assessment (LCA) tool. The results of a case study demonstrate that the suggested schemes are feasible, effective and environmentally acceptable. Thermal-solar-based hybrid power plant can work environmentally harmlessly if the carbon produced from the plant is converted into the chemical product.

Keywords: thermal-solar hybrid power plant, energy management controller, carbon conversion technology, fuzzy logic approach, environment

Investigation into Operation of a Semitower Boiler of a 158-MW Power Unit and Prospects for Application of Such Boilers in Russia

V. M. Supranov^{a,*}, B. R. Sosa^{b,**}, B. Kh. F. Sosa^a, and K. A. Pleshanov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b Carlos Manuel Cespedes TPP, Cienfuegos, Republic of Cuba

*e-mail: svm-mpei@mail.ru

**e-mail: rafaelosabeltran@gmail.com

Abstract—Steam boilers of various arrangements (or profiles) exist in the world. The most widely used ones include, for example, semitower boilers (or L-paso boilers). In Russia, there is not sufficient experience in designing such boilers, especially in their practical application. The paper analyzes advantages and disadvantages of semitower boilers. As with tower boilers, their main advantage is a small footprint. However, compared to tower boilers, the L-paso boilers have a lower height. According to the performed analysis, the semitower configuration is best suited to boilers fired with gaseous or liquid fuel. In Russia, due to its climatic conditions, semitower boilers can be used for replacements of obsolete (type E) natural circulation gas-and-fuel oil-fired boilers with a steam output of 210–420 t/h. As an example, the paper presents a brief description of the L-paso (type Ep) natural circulation reheat boiler manufactured by the well-known Babcock-Wilcox Co. This boiler, which is a part of a 158-MW power unit, has been successfully fired with sulfur fuel oil for many years. A customized numerical model of the boiler was developed in the Boiler Designer software package. Multivariant calculations of the boiler were performed on the basis of this model. An analysis of the predictions has confirmed that the boiler can operate in a wide range of loads while maintaining the design steam conditions. The furnace heat release rate q_F , the furnace cross-section heat release rate q_V , and the flue gas temperature at the furnace outlet ϑ_T'' have been demonstrated to considerably exceed the values allowed by the applicable Russian regulations for similar boilers. This fact is explained. The gas velocities in the boiler gas ducts are noticeably higher, and the gas and air velocities in the air heater are approximately the same as in the Russian-made boilers. The steam enthalpy increments Δh and the mass velocity ρw in the superheater stages basically correspond to the concepts of Russian specialists.

Keywords: semitower boiler, L-paso, sulfur fuel oil, gas recirculation, thermal design, Boiler Designer, Power Plant Simulator & Designer, furnace thermal characteristics

Development of Adsorbent out of Waste from a Thermal Power Plant's Water-Treatment Plant for Removal of Carbon Dioxide

A. A. Filimonova^a, A. Yu. Vlasova^{a, *}, N. D. Chichirova^a, and R. F. Kamaliev^a

^a Kazan State Power Engineering University, Kazan, 420066 Russia

*e-mail: vlasovaay@mail.ru

Abstract—It is possible at present to reduce the emission of harmful substances into the environment during the operation of industrial enterprises by cleaning emissions and modernizing existing technological equipment. A survey of purification plants showed that sorption technologies are more accessible and simpler. Adsorption is an effective physical and chemical process for capturing carbon dioxide. The modern market offers a wide range of adsorbents that can be used to capture harmful substances, but, as a rule, for reasons of economic efficiency, it is more profitable to use secondary resources: production waste. At energy sector enterprises, various wastes are generated during the generation of thermal and electrical energy. Thus, when preparing a heat carrier at water-treatment plants, wastewater after clarifiers and ion exchange filters can be utilized to create a sorption material capable of capturing carbon dioxide, one of the main greenhouse gases. Obtaining adsorbents from waste from water-treatment plants will reduce the volume of sludge-storage facilities or eliminate their use altogether. Industrial waste is a secondary raw material and, as a rule, is inferior in its original form to traditional industrial adsorbents in terms of the activity indicator, which characterizes the ability to capture carbon dioxide. Therefore, to obtain high absorption capacity, waste is combined and activated. An adsorbent obtained from waste from water-treatment plants of thermal power plants is presented. The waste used was sludge water discharges and spent regeneration solutions after the softening filter. The component composition of the adsorbent and the method of its preparation by activation and preparation of waste are described. The efficiency of the developed adsorbent was tested on a laboratory setup. Comparative results of laboratory studies with the most frequently used adsorbents are presented. The results of determining the strength, porosity, permeability coefficient, and specific surface area of the studied adsorbents are presented.

Keywords: carbon dioxide, waste from water-treatment plant, adsorbent, sludge collector, permeability coefficient, activation, sludge water, regeneration solutions