

Contents

Vol. 72, No. 3, 2025

Steam-Turbine, Gas-Turbine and Combined-Cycle Power Plants, and Their Auxiliary Equipment

The Use of Carbon Dioxide as Working Fluid for a Single-Stage
Mixed-Flow Turbine

*Gong Bowen, Hua Lun, Xu Guisheng, Afzal Umar, M. A. Laptev,
V. V. Barskov, V. A. Rassokhin, and A. G. Pulin*

5

Design of Turbine Blade Internal Cooling: a Thermofluidic Study
on the Influence of Varying Cooling Channel Numbers
and Configurations

*A. Otmani, N. Benmehidi, M. S. Kahaleras,
H. Khatir, and S.-E. Azzouz*

14

Nuclear Power Plants

A Study of the Possibility to Uprate an NPP with a VVER-1200 Reactor
through Feedwater Heating in an Economizer with Installing
an Additional Turbine

R. Z. Aminov, M. V. Garievskii, and A. S. Sahharov

27

Environment Protection

Processing of Ash and Slag Waste from Coal-Fired Thermal Power Plants and Extraction
of Commercial Products from the Waste (Review)

*L. M. Delitsyn, R. V. Kulumbegov, O. S. Popel',
Yu. A. Borisov, and Sh. A. Gadzhiev*

39

Acoustic-Aerodynamic Processes in the Macroporous Modules Used in the Silencers
of Noise from Steam Dumps at Thermal Power Plants

Yu. G. Sukhorukov, E. O. Tass, and L. R. Yablonik

59

Renewable Energy Sources, Hydropower

Comparative 4E-analysis of A KCS11 with and without Solar Energy for Fluegas
Waste Heat Recovery in a Coal-fired Power Plant

*Goutam Khankari, Sumit Srivastava, Rajib Khan,
D. V. Rajan, and Dinesh Kr. Singh*

67

Heat and Mass Transfer and Properties of Working Fluids and Materials

A Model for Determining the Rate of Interfacial Heat and Mass Transfer Using
the VOF Method for Numerically Solving Evaporation and Condensation Problems

*K. B. Minko, G. G. Yan'kov, T. A. Gataulin,
V. I. Artemov, and A. P. Zheleznov*

80

Simulation of R-21 Saturated Vapor Condensation in a Fragment
of a Tube Bundle Using the 3D VOF Method

K. B. Minko, M. V. Minko, and A. A. Klement'ev

94

The Use of Carbon Dioxide as Working Fluid for a Single-Stage Mixed-Flow Turbine

Gong Bowen^a, Hua Lun^b, Xu Guisheng^b, Afzal Umar^b, M. A. Laptev^a,
V. V. Barskov^a, V. A. Rassokhin^a, and A. G. Pulin^{a,*}

^a Higher School of Power Engineering, Peter the Great St. Petersburg Polytechnic University,
St. Petersburg, 195251 Russia

^b Suzhou Automobile Research Institute Tsinghua University (TSARI), Suzhou, Jiangsu Province, 215200 China

*e-mail: pulin.anton.g@gmail.com

Abstract—The article considers the use of supercritical carbon dioxide (sCO₂) as working fluid in the turbine stage consisting of a vane row and a mixed-flow blade row. The operation of the existing turbine on natural gas combustion products and on supercritical carbon dioxide is analyzed by way of comparison. The numerical simulation results show that the use of supercritical carbon dioxide makes it possible to increase the turbine power output to 14.3 MW. This is more than a factor of 30 higher than the power output of the same turbine operating on natural gas combustion products. Such a significant increase of power output is achieved without changing the turbine stage design, which points to the possibility of modernizing the existing units without the need to make essential changes of the design. The turbine stage efficiency during its operation on supercritical carbon dioxide was estimated at 0.87, and that during operation on natural gas combustion products was 0.88. Despite an insignificant drop of the efficiency, the total increase of the power output results in that the use of sCO₂ is economically feasible. Based on the data obtained, a conclusion has been drawn that it is advisable to use the existing turbine stages for operation on supercritical carbon dioxide. This opens the prospects in achieving more efficient operation of power systems without the need to develop new types of turbines, decreasing capital outlays, and more rapidly introducing new technologies. The transition for using supercritical carbon dioxide as working fluid can result in obtaining a significantly higher output of turbine units while retaining high efficiency indicators and making minor changes in the equipment design.

Keywords: power industry, carbon dioxide, distributed generation, numerical simulation, mixed-flow turbine, turbine machinery, gas dynamic calculation, comparative analysis

Design of Turbine Blade Internal Cooling: a Thermofluidic Study on the Influence of Varying Cooling Channel Numbers and Configurations

A. Otmani^{a, b, *}, N. Benmehidi^c, M. S. Kahaleras^a, H. Khatir^a, and S.-E. Azzouz^{a, b}

^a National Higher School of Technology and Engineering, Department of Process and Energy Engineering, 2000 PD Sidi Amar, Annaba, 23005 Algeria

^b LR3MI, Badji Mokhtar University of Annaba, Badji Mokhtar University of Annaba, P.O. Box 12, Annaba, DZ-23000 Algeria

^c Civil Engineering Department, Badji Mokhtar University of Annaba, Badji Mokhtar University of Annaba, P.O. Box 12, Annaba, DZ-23000 Algeria

*e-mail: a.otmani@ensti-annaba.dz

Abstract—This paper explores the effect of varying the number and configuration of internal cooling channels on the thermal performance of gas turbine blades. The findings demonstrate the significance of this parameter for improving blade cooling efficiency. Actually, such a study is lacking in the currently available literature. Therefore, six internal cooling configurations were designed using Autodesk Inventor employing the real turbojet airfoil RS1S. The high-pressure gas turbine rotor blades were designed with an 11° twist angle in order to predict the actual behavior of the blade cooling under operating conditions. A series of numerical tests were carried out by coupling the CAD software with COMSOL Multiphysics. A conjugate heat transfer and computational fluid dynamics model were performed. Convective heat flux (CHF), temperature, Nusselt number, air velocity, Reynolds number, and friction force were evaluated for each studied case. The findings showed that adding a second cooling channel to the trailing edge improved the convective heat flux by 63%. On the other hand, creating a new cooling channel increased the blade's thermal inertia, leading to a cooling limitation. It was also observed that hot spots on the blade surface can develop as a result of air thermal saturation due to extended residence time in the blade channels. In fact, the blade average temperature decreased by 8% using five disconnected channels rather than five serpentine channels. The blade temperature and CHF were reduced by 16 and 22%, respectively, as a result of adding a third channel in the blade mid-zone. Overall, this paper highlighted the potential for improving blade internal cooling through the careful optimization of the number and configuration of internal channels.

Keywords: convective cooling, gas turbine blade, thermo-fluid, numerical simulation, blade internal cooling, heat transfer, CFD

A Study of the Possibility to Uprate an NPP with a VVER-1200 Reactor through Feedwater Heating in an Economizer with Installing an Additional Turbine

R. Z. Aminov^{a, *}, M. V. Garievskii^{a, b}, and A. S. Sahharov^{a, b}

^a *Federal Research Center Saratov Scientific Center, Russian Academy of Sciences, Saratov, 410054 Russia*

^b *Gagarin Saratov State Technical University, Saratov, 410054 Russia*

**e-mail: oepran@inbox.ru*

Abstract—A search of efficient ways for uprating the existing NPPs deserves close attention owing to significant saving of expenditures for implementing them in comparison with construction of new NPPs. In this connection, a new method for uprating an NPP with water-cooled reactors is proposed and discussed, which involves heating of feedwater in an economizer prior to supplying it to the steam generators by using the reactor coolant from the steam generator's outlet. This results in an increased main steam output from the steam generator without changing its thermal power capacity, and a decrease in the average coolant temperature in the reactor core without changing it at the reactor outlet helps increase the core reactivity. With excess steam supplied to an additional steam turbine unit, it becomes possible to decrease the total costs for a power unit's modernization and enhance the NPP safety through providing backup power supply for power plant auxiliaries in case of an emergency involving station blackout. A process cycle circuit of an NPP with a VVER-1200 reactor involving feedwater heating in an economizer upstream of the steam generator is developed and substantiated. The economizer main characteristics required for feedwater heating to 245 and 265°C are determined. The effect from installing the economizer on the reactor coolant pump operation and on the reactor coolant circuit as a whole is determined. It is shown that the power output of the NPP unit with a VVER-1200 reactor and with an additional turbine increases by 37.17 and 95.88 MW, respectively, with feedwater heated to 245 and 265°C.

Keywords: nuclear power plant, power uprating, pressurized water reactor, economizer, feedwater, net present value, capital investments

Processing of Ash and Slag Waste from Coal-Fired Thermal Power Plants and Extraction of Commercial Products from the Waste (Review)

L. M. Delitsyn^{a, *}, R. V. Kulumbegov^a, O. S. Popel^a, Yu. A. Borisov^a, and Sh. A. Gadzhiev^a

^a *Joint Institute for High Temperatures of the Russian Academy of Sciences (JIHT RAS), Moscow, 125412 Russia*

**e-mail: delitzin@ihed.ras.ru*

Abstract—Ash dumps of 170 large Russian coal-fired thermal power plants (TPPs) store more than 2 billion t of ash and slag waste (ASW) at present. They occupy approximately 50 000 ha and represent main sources of environmental pollution. The amount of ASW increases by approximately 20 million t every year. Besides the recorded amount of ASW, there is also waste that is not recorded in official documents. At the same time, the latter waste is man-made sources of commercial products. Direct large-scale application of ash is limited by the instability of its properties and its noncompliance with the applicable technical requirements for the products of its processing employed in various applications in power, metallurgical, chemical, construction, and other industries. Processing of ash and slag waste and gradual removal of ash dumps are a crucial state problem whose solution requires the development of appropriate industrial processes. The review examines modern methods of large-scale processing of ash and slag waste from coal-fired TPPs with extraction of commercial materials suitable for application in various industries. The emergence of a wide range of physical, chemical, and biological processes for ash processing enables the problem of reclamation of most ash dumps to be successfully solved. The attention was focused on such technologies as flotation enrichment, magnetic separation, and thermochemical methods. The mechanism of adsorption of functional groups of various collectors on the surface of carbon ash particles is examined. A large section of the review is devoted to acid, alkaline, and thermochemical methods of extracting alumina from ash and belite sludge. Attention is also focused on works dealing with the extraction of precious and rare earth metals from ash. Some new developing areas of microbiological extraction of metals from ash are also presented.

Keywords: ash and slag from coal-fired thermal power plants, unburned coal, iron-rich concentrate, alumina, belite sludge, flotation, leaching, sintering, desilication

Acoustic-Aerodynamic Processes in the Macroporous Modules Used in the Silencers of Noise from Steam Dumps at Thermal Power Plants

Yu. G. Sukhorukov^{a, *}, E. O. Tass^a, and L. R. Yablonik^a

^a *Polzunov Research and Production Association for Investigation and Design of Power-Generating Equipment (NPO TsKTI), St. Petersburg, 191167 Russia*

**e-mail: teploobmen@ckti.ru*

Abstract—Steam dumps from thermal power plants (TPPs) into the atmosphere are among the most powerful man-induced noise sources. The protection, by means of silencers, against the noise produced by high-pressure steam dumps includes, in the general case, implementation of low-noise throttling and installation of sound-absorbing components. The comparative efficiency of the silencer throttling and sound-absorbing components depends on the location and intensity of physical noise sources, which are determined by the steam dumping pipeline's operating and geometrical parameters. The use of macroporous modules in steam dump silencers is of significant interest owing to their relative simplicity and good performance. Such modules can be used as continuously operating throttling devices; in addition, they have certain sound-absorption properties. The aerodynamic and acoustic properties of macroporous modules used as part of the silencers of noise produced by the TPP steam dumps are analyzed. The main sources causing noise from the TPP steam dumps are considered, and analytical relations for comparing their intensities are formulated. Proceeding from the performed assessments, methods for protection from the noise produced by steam dumps are suggested, which involve the use of silencers equipped with macroporous modules. In discussing matters concerned with the aerodynamics relating to continuous throttling of gaseous medium in macroporous channels of various shapes, it is shown that correct profiling of channels in coordination with the characteristic pore sizes is important for practical applications. Assessments of sound absorption in a macroporous medium are carried out. Recommendations on shaping the macroporous modules of silencers are given, and methods for calculating their efficiency in solving problems of protection from noise caused by dumping high-pressure steam into the atmosphere are presented.

Keywords: steam dumps from TPPs, silencers, macroporous modules, noise sources, throttling, throttle channel, sound absorption, porosity, Raschig rings, profiling

Comparative 4E-analysis of A KCS11 with and without Solar Energy for Fluegas Waste Heat Recovery in a Coal-fired Power Plant

Goutam Khankari^{a,*}, Sumit Srivastava^b, Rajib Khan^b, D. V. Rajan^c, and Dinesh Kr. Singh^b

^a R&D Section, Damodar Valley Corporation (DVC), Kolkata, 700054 India

^b RE & EE Department, Damodar Valley Corporation (DVC), Kolkata, 700054 India

^c HR Department, Damodar Valley Corporation (DVC), Kolkata, 700054 India

*e-mail: goutam.khankari@dvc.gov.in

Abstract—A comparative performance analysis of a Kalina Cycle System 11 (KCS11) without and with solar energy is done based on 4E-analysis (energy, exergy, environment, and economic) for generating additional electricity from fluegas waste energy of a 660 MWe Supercritical (SupC) coal-fired power plant. The result shows that the integration of solar assisted KCS11 with main steam power plant increases the net plant energy and exergy efficiencies by about 0.04 and 0.03% points, respectively due to additional electricity generation of 647.43 kW at 40 K of superheat. Condenser and evaporator are the maximum contributor of energy and exergy losses, respectively in the proposed systems. Energetic performance of solar assisted Kalina cycle is higher than the standalone KCS11 due to decrease in turbine exhaust pressure and additional poor exergetic performance of solar heater causes less exergy efficient of solar assisted KCS11 compared to standalone KCS11. Use of solar integrated KCS11 reduces the annual CO₂ emission by about 1089.58 t at full load which is nearly 1.25 times higher than the standalone KCS11. The Levelized Cost of Electricity (LCoE) for producing additional electricity by solar energy at 40 K of super-heat is about 0.13 \$/kWh which is 8.5% lower value compared to the solar thermal power plant.

Keywords: coal-fired power plant, environment, economic, fluegas heat, solar heater, supercritical, KCS11, binary mixture, carbon dioxide, capital cost, cost of power generation

A Model for Determining the Rate of Interfacial Heat and Mass Transfer Using the VOF Method for Numerically Solving Evaporation and Condensation Problems

K. B. Minko^{a, *}, G. G. Yan'kov^{a, b}, T. A. Gataulin^a, V. I. Artemov^{a, b}, and A. P. Zheleznov^{b, c}

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b Tsiolkovski Kaluga State University, Kaluga, 248023 Russia

^c ZAO Scientific-and-Production Implementation Enterprise (NPVK) Turbokon, Kaluga, 248010 Russia

*e-mail: minkokb@gmail.com

Abstract—The volume-of-fluid (VOF) method, supplemented by models of interfacial heat and mass transfer, is a universal and very effective tool for simulation and detailed analysis of intricate processes occurring in systems with phase transitions. The key feature of this method is that it can quite accurately and in detail describe the physical pattern of running processes in the presence of a clearly seen phase boundary and provide quantitative data on the distribution of local heat-transfer characteristics and the dynamics of the inter-phase boundary and associated phenomena, thereby making the VOF method advantageous in researches and engineering practice. Development and improvement of heat and mass transfer models and efficient numerical VOF algorithms, as well as preparation of recommendations for the application of these approaches, are an urgent problem. This paper proposes an approach to the prediction of interfacial heat and mass transfer rate, which is based on the analysis of phase transitions in single-component systems using the linear theory of nonequilibrium processes. The results are presented of verification calculations performed for several standard problems. The classical problems of one-dimensional boiling and condensation (the Stefan problem) are examined as are such problems as vapor condensation in tubes of different orientations, condensation from stagnant or moving vapor on the surface of smooth horizontal tubes, and film boiling on the surface of horizontal cylinders. The predictions are verified against classical solutions and available experimental data. Calculations were carried out for fluids with different thermophysical properties, including water, pentane, propane, R-113, R-21, and R-142b. The maximum ratio of the densities of liquid and vapor phases was as high as 1600 (water at atmospheric pressure). The simulation results demonstrate the versatility of the proposed approach, which allows us to recommend it for solving a variety of engineering problems.

Keywords: model of heat and mass transfer at interphase boundary, numerical simulation, VOF method, condensation, film boiling, moving vapor

Simulation of R-21 Saturated Vapor Condensation in a Fragment of a Tube Bundle Using the 3D VOF Method

K. B. Minko^{a, *}, M. V. Minko^a, and A. A. Klement'ev^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: minkokb@gmail.com

Abstract—The Volume of Fluid (VOF) method supplemented with heat and mass transfer models at the interphase boundary is actively employed in the investigation of film condensation and film boiling, in the calculation of evaporators, for predicting the dynamics of vapor collapse in a pool of subcooled liquid, or for other purposes. The original VOF algorithm proposed by Hirt is intended for the simulation of a single-phase incompressible liquid with a free boundary at which a constant pressure is specified. The extension of the VOF-algorithm to a two-phase fluid, especially with mass transfer, is not a common problem from the standpoint of the rigor of mathematical formulation. In our previous studies, approaches have been developed to the 2D and 3D simulation of heat and mass transfer processes during vapor condensation on the surface of horizontal smooth tubes, and condensation on a smooth tube bundle was simulated in 2D formulation. This paper presents the results of 3D simulation of R-21 refrigerant condensation in a small-sized tube bundle. Characteristics of the tube bundle are the same as those of the tube bundle tested at the Institute of Thermophysics of the Siberian Branch of the Russian Academy of Sciences (SB RAS) (tube diameter is 16 mm, transverse pitch is 26 mm, longitudinal pitch is 15 mm). The condensation was examined in saturated vapor flow at a temperature of $T_{sat} = 333.15$ K incoming onto the tube bundle at a velocity of up to 0.9 m/s. The 3D predictions agree qualitatively and quantitatively with the 2D predictions and the experimental data. The distribution of condensate in the tube bundle is presented. The spectrums of fluctuations in the average heat transfer for tubes are analyzed. It is pointed out that the thermal boundary layer development region induced by the condensate falling from the upper to lower tubes should be considered.

Keywords: VOF method, Lee model, condensation, numerical simulation, control volume, horizontal smooth tube bundle, moving vapor, interphase boundary, heat-transfer coefficient