

Contents

Vol. 72, No. 4, 2025

Nuclear Power Plants

Horizontal Steam Generators: Design Improvement and Experimental-and-Computational Studies (Review) <i>V. N. Blinkov, A. V. Dedov, I. V. Elkin, V. I. Melikhov, O. I. Melikhov, S. M. Nikonov, and A. S. Nikulin</i>	3
Computational and Experimental Studies of Reflooding Processes in a Large-Scale Model of a VVER Fuel Assembly <i>M. A. Bykov, Yu. A. Migrov, M. V. Sazontova, and A. N. Churkin</i>	29
Experimental Study of the Core Cooling at the Reflooding Stage of a Large Break Loss-of-Coolant Accident <i>A. N. Churkin, A. G. Karetnikov, M. A. Bykov, A. S. Bogdanov, and Yu. A. Bezrukov</i>	39
The Field of Acoustic Standing Waves in the VVER Reactor Coolant Circuits <i>G. V. Arkadov and M. T. Slepov</i>	51

Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment

Determining the Profile Loss of Flow Kinetic Energy in Turbine Cascades with the Use of Neural Networks <i>V. A. Tishchenko, A. A. Belousova, P. M. Nesterov, and A. O. Smirnov</i>	64
--	----

Heat and Mass Transfer and Properties of Working Fluids and Materials

Heat-Conduction Problems with Time-Variable Heat-Transfer Coefficients <i>V. A. Kudinov, E. V. Kotova, S. V. Zaitsev, and E. V. Stefnjuk</i>	78
---	----

Steam Boilers, Power Plant Fuel, Burners, and Boiler Auxiliary Equipment

A Second-Order Mixed Finite Element Method for Convection-Radiation Flows in Furnaces with Burners <i>Jaafar Albadr, Mofdi El-Amrani, and Mohammed Seaid</i>	86
---	----

Horizontal Steam Generators: Design Improvement and Experimental-and-Computational Studies (Review)

V. N. Blinkov^a, A. V. Dedov^b, I. V. Elkin^{c, d}, V. I. Melikhov^{b, c, *},
O. I. Melikhov^{b, c}, S. M. Nikonov^{b, c}, and A. S. Nikulin^b

^a AO Rosenergoatom Concern, Moscow, 115191 Russia

^b National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^c AO Elektrogorsk Research and Engineering Center for NPP Safety (AO ENITs), Elektrogorsk, 142530 Russia

^d National Research Center Kurchatov Institute, Moscow, 123182 Russia

*e-mail: MelikhovVI@mpei.ru

Abstract—A review is presented of designs of horizontal steam generators (SG) for nuclear power plants (NPP) with water-moderated water-cooled reactors (VVERs) and of experimental-and-computational studies of thermohydraulic processes running in them. Horizontal SGs are examined from the first commercial design of the PGV-440 SG and the most widely used today PGV-1000M SG to the steam generators developed for the new generation reactor units of types VVER-1200 and VVER-TOI as well as for the high-power VVER-1500 reactor. A comparative analysis was carried out of the experimental facilities developed for the investigation of thermohydraulic processes occurring in a horizontal steam generator. Each of the examined experimental facilities has limitation related to the capabilities for the simulation of a full-scale SG caused by either geometric characteristics or thermohydraulic conditions. Nevertheless, it has been demonstrated that we have at present a sufficiently large experimental database suitable for validating computational codes simulating thermohydraulic characteristics of a horizontal steam generator. A review of the available computational codes is presented. The STEG code in which the two-phase flow is described by multifluid models is examined in more detail. The validation of the STEG code against experimental data on void fraction, pressure drop, and water velocity demonstrated high accuracy of the predictions. One of the problems to be solved in designing horizontal steam generators for new generation reactor units is the improvement of the equalization ability of the submerged and steam-receiving perforated sheets due to the enhanced nonuniformity of the steam load on the evaporation surface and of the steam flow in the steam space. The results are presented of the experimental-and-computational investigation of the equalization ability of perforated sheets, which corroborate the possibility of its improvement by application of a variable perforation ratio. The areas of further experimental investigations into thermohydraulic processes in a horizontal steam generator and ideas for improving the computational codes are formulated.

Keywords: horizontal steam generator, thermohydraulic processes, experiment, simulation, computational code

Computational and Experimental Studies of Reflooding Processes in a Large-Scale Model of a VVER Fuel Assembly

M. A. Bykov^{a, *}, Yu. A. Migrov^b, M. V. Sazontova^b, and A. N. Churkin^a

^a AO OKB Gidropress, Podolsk, 142103 Russia

^b Federal State Unitary Enterprise Alexandrov Research Institute of Technology (FGUP NITI), Sosnovy Bor, 188540 Russia

*e-mail: bykov@grpress.podolsk.ru

Abstract—The paper presents a brief review of experimental and computational studies of the reflooding processes occurring during large break LOCAs in the primary circuits with subsequent supply of the coolant in pressurized water-moderated water-cooled power reactors (VVER). The results of the PREMIUM project, carried out by OECD (CSNI), on the assessment of the prediction of reflooding parameters using the most well-known computational codes (RELAP5, CATHARE, ATHLET, APROS, MARS) are analyzed. The calculations were performed using data from one of the experimental regimes simulated at the FEBA test facility (Germany) for reflooding simulation. It is stated that the uncertainty of the estimate of the maximum temperature of fuel rods obtained by known system computational codes can attain 100°C as follows from the results of validation calculations. Based on a statistically significant set of experiments conducted on a unique reflooding test facility at OKB Gidropress with several cooling water supply options, the domestic KORSAR computational code was validated, including the gravity reflooding when water is supplied to the upper part of the reactor pressure plenum model. It has been demonstrated that the KORSAR code is not poorer than the best foreign equivalents in terms of the accuracy of the predicted maximum temperature of fuel-rod simulators and flooding time for the experimental fuel assembly.

Keywords: reflooding, experiment, calculation, code validation, error estimation, fuel assembly, large leak, KORSAR software package

Experimental Study of the Core Cooling at the Reflooding Stage of a Large Break Loss-of-Coolant Accident

A. N. Churkin^{a, *}, A. G. Karetnikov^a, M. A. Bykov^a, A. S. Bogdanov^a, and Yu. A. Bezrukov^a

^a AO OKB Hidropress, Podolsk, 142103 Russia

*e-mail: churkin.an@mail.ru

Abstract—The paper presents a description of the experimental facility at OKB Hidropress designed to study thermohydraulic phenomena during the core reflooding caused by a large break loss of a coolant accident in a water-moderated water-cooled (VVER) power reactor. The performed studies yielded a statistically significant amount of experimental data on the time-dependence of the temperature of the fuel-rod simulator cladding at several sections of the fuel-assembly (FA) model that is necessary for the validation of computational codes. The experiments were carried out with two fuel-assembly models with uniform and nonuniform heat release distribution along the height. Each model included 120 heated fuel-rod simulators, 13 spacer grids, six guide channel simulators, and a fuel assembly's upper end fitting. In the experiments, five options of cooling water supply—bottom, gravity-driven bottom, top, combined, combined gravity-driven—were implemented. To confirm the reproducibility of the experiments, most of them were repeated three to five times. The fuel-assembly models, fuel-rod simulators, used instrumentation items, and experimental procedure are described. Examples are presented of the cooling dynamics of the fuel-rod simulators for different methods of cooling water supply to the reactor model, and the features of each flooding pattern are outlined. The data on the flooding time of the fuel-assembly model are generalized in the form of linear dependencies of this parameter on the relative power of the fuel element simulators.

Keywords: VVER, large break accident, emergency core cooling systems, reflooding, experimental facility, fuel-assembly model, fuel-rod simulator, flooding time

The Field of Acoustic Standing Waves in the VVER Reactor Coolant Circuits

G. V. Arkadov^{a, *} and M. T. Slepov^{b, **}

^a *Noncommercial Partnership RISE for Fostering the Development of System Engineering, Moscow, 111141 Russia*

^b *Novovoronezh NPP, Branch of Rosenergoatom Joint-Stock Company, Novovoronezh, 396071 Russia*

**e-mail: arkgen47@gmail.com*

***e-mail: slepovmt@nvnpp1.rosenergoatom.ru*

Abstract—Many research teams and groups pay much attention to matters concerned with hydrodynamic impacts exerted on the equipment of nuclear power facilities (NPFs), which is reflected in numerous publications: monographs, articles, and reviews. However, despite the availability of theoretical works on this problem, matters concerned with applied investigations, i.e., immediately with direct measurements, still remain beyond the scope of scientific interests of Russian and foreign scientists. The need of studying them for practical applications is mainly stemming from the complexity of interpreting various revealed abnormalities, requirements for precise adjustment of various models, and essentially different spectral images of equipment not only within the framework of various designs of reactor plants (RPs), but in the power units of the same type within one NPP. These problems cannot be solved using solely theoretical or calculation methods, or using simulation software tools. The situation is also aggravated by the fact that the process of carrying out investigations is an exceptionally complex problem in terms of both selecting the data sources and interpreting the information obtained. In all likelihood, it is exactly these factors due to which an essentially weakened interest in experimental works on vibroacoustic topic in various RPs both in Russia and other countries can be explained. The article briefly presents some results of studying the fields of acoustic standing waves (ASWs) in the reactor coolant circuit (RCC) of a reactor plant equipped with a pressurized water reactor (VVER-1200) taking as an example power unit 1 at the Novovoronezh-2 NPP; in addition, the main ASW types are described.

Keywords: acoustic standing wave, reactor coolant circuit, reactor coolant pump set, VVER-1200, nuclear reactor digital acoustic model, vibration, pressure pulsation sensor

Determining the Profile Loss of Flow Kinetic Energy in Turbine Cascades with the Use of Neural Networks

V. A. Tishchenko^{a, b}, A. A. Belousova^c, P. M. Nesterov^{a, *}, and A. O. Smirnov^{b, **}

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^b Joint Stock Company Power Machines – ZTL, LMZ, Electrosila, Energomachexport, St. Petersburg, 195009 Russia

^c Atomenergoproekt Joint Stock Company, Moscow, 107996 Russia

*e-mail: NesterovPM@mpei.ru

**e-mail: SmirnovAOI@mpei.ru

Abstract—The article addresses matters concerned with the use of neural networks for predicting the gas dynamic characteristics of turbine machinery cascades. The results of elaborating the architecture of deep machine learning models for determining the profile kinetic energy loss downstream of plane nozzle vane and rotor blade (impulse type) turbine cascades are presented. A procedure for preparing the training dataset with using numerical simulation of viscous flows is described. The dataset generated is analyzed; its shortcomings, which should be removed for improving the quality of trainable neural networks are identified. Work on selecting the architecture of neural networks for rotor and nozzle vane cascades was carried out. The studies have shown that the same structure of models is efficient for both nozzle vane and rotor blade cascades. The use of prepared models yielded good agreement between the predicted results and the data available for all types of the cascades considered. It is pointed out that the neural networks yield incorrect predictions in transonic and supersonic operation conditions near the theoretical Mach number downstream of the cascade equal to unity. This stems from the lack of information on such operation conditions in the training dataset. After the models had been additionally trained under supersonic operation conditions, it became possible to “trace” the influence of the flow wave structure on the power performance characteristics downstream of the cascade. The data obtained served as a basis for stating the importance of representing curvilinear blade passages in parametric form and the necessity to prepare the training data in a wide variation range of the majority of independent parameters. The neural networks have demonstrated high-efficient performance in solving the stated problem, which made it possible to formulate a number of algorithmic concepts for applying them in solving turbine stage design problems.

Keywords: neural networks, gas dynamics of turbine machinery cascades, profile energy loss, numerical simulation, turbine stages, theoretical Mach number

Heat-Conduction Problems with Time-Variable Heat-Transfer Coefficients

V. A. Kudinov^{a,*}, E. V. Kotova^a, S. V. Zaitsev^a, and E. V. Stefnyuk^a

^a Samara State Technical University, Samara, 443100 Russia

*e-mail: totig@samgtu.ru

Abstract—Based on the definition of additional boundary conditions and an additional sought function (ASF), an approximate analytical solution of the heat-conduction problem for an infinite plate subject to Newton's symmetrical boundary conditions with a time variable heat-transfer coefficient is obtained. In accordance with the integral thermal balance method, the solution is subdivided into two stages in time. The first and the second stage include the time intervals corresponding to an irregular and a regular heat-transfer mode, respectively. At the first stage, a function characterizing the displacement with time of the temperature disturbance front along the ξ coordinate is adopted as the ASF. At the second stage, a function characterizing the change with time of the temperature at the symmetry center, in which the boundary condition of no heat transfer is specified, is considered as the ASF. Owing to the use of ASFs at both stages, it becomes possible to boil down the solution of the initial differential equation with partial derivatives to integration of an ordinary differential equation with respect to the ASF. By solving this equation at the second stage, the eigenvalues are found, which are determined in the classical methods from the Sturm—Liouville boundary value problem, in which a transcendental trigonometric equation is solved for each particular Biot number using a numerical method. Hence, in this case, another technique for determining eigenvalues is considered, which makes it possible to obtain a formula from which eigenvalues for each particular Biot number can be found. The form in which the additional boundary conditions are given is such that their satisfaction in finding the sought solution would be equivalent for the case of solving the initial differential equation at the boundary points. It is shown that the solution of the equation at the boundary points leads to its solution also inside the domain considered; in this case, direct integration of the equation along the spatial variable is excluded and is only limited to fulfilling the thermal balance integral, i.e., the averaged initial differential equation.

Keywords: time-variable heat-transfer coefficient, integral thermal balance method, analytical solution, additional sought function, additional boundary conditions, temperature disturbance front

A Second-Order Mixed Finite Element Method for Convection-Radiation Flows in Furnaces with Burners

Jaafar Albader^{a,*}, Mofdi El-Amrani^b, and Mohammed Seaid^a

^a *Department of Engineering, University of Durham, South Road, Durham, DH1 3LE UK*

^b *Departamento de Matemática Aplicada, Universidad Rey Juan Carlos, Mostoles, Madrid, 28933 Spain*

**e-mail: jnalbader@yahoo.com*

Abstract—We present a class of simplified approximations for modelling heat transfer in a two-dimensional furnace with inclusions. The governing equations are the well-established thermal incompressible Navier – Stokes equations subject to the Boussinesq approximation for modelling the change in density. Simplified P_N -approximations are carried out for the radiative transfer which is coupled with convection. A Taylor – Hood finite elements technique has been adopted to solve the equations using triangular meshes. The Galerkin-characteristics method is accounted for the dominant advection. Numerical results are presented under the operation of different burners and comparisons between simulations without radiation and with radiation are discussed. Results show that the temperature on the sides of the furnace is not equal. This is due to the fact that the unsteady convection-radiation heat draws the unstable heat flow towards the sides at the chosen time. The effect of higher value of Reynolds number as far as heat transfer is concerned, is that an additional mechanism of heat transfer in the azimuthal and radial directions becomes available and higher. This is commonly termed “eddy transport” and is intense, providing much better transfer of energy across the flow at a given position than in lower value of Reynolds number. Another difference worth noting is the extent of the thermal entrance region in which the transverse temperature distribution becomes fully developed. This region is relatively short in operation with 7 and 9 burners (precisely because of the intense turbulent transverse transport of energy), whereas it tends to be long under the operation of 1 and 3 burners.

Keywords: radiative heat transfer, incompressible flows, mixed finite element method, Navier – Stokes equations, Galerkin-characteristic, simplified P_N -approximations