

Contents

Vol. 72, No. 9, 2025

Steam Turbine, Gas Turbine and Combined Cycle Plants, and Their Auxiliary Equipment

Development of a Software System for Estimating the Steam Turbine Condenser Performance

A. G. Shempelev and D. M. Suvorov

Criteria for Assessing the Quality of Fire-Resistant Fluids

R. V. Akulich, E. A. Shorina, and N. C. Arzhinovskaya

Heat and Mass Transfer, Properties of Working Fluid and Materials

Design Calculation of a Shell-and-Tube Condenser in the ORC Unit Operating on Pentane

I. S. Antanenkova, A. A. Antanenkoy, V. I. Kuznetsov, and D. S. Pisarev

Modeling of Film Boiling of Undercooled Liquid on the Surface
of a Smooth Horizontal Cylinder by the VOF Method

K. B. Minko and T. A. Gataullin

Cross-Verification of OpenFOAM Code with Embedded Models for Calculation
of Film Condensation Processes by the VOF Method

A. A. Klementyev, K. B. Minko, and V. I. Artemov

Nuclear Power Plants

An Analysis of Possible Mechanisms of Lead Oxide Vapor Formation
in the Vapor Bubble Volume

M. V. Vorivonchik, N. A. Mosunova, and A. A. Sorokin

Simulating the Behavior of Gaseous Fission Product Bubbles in the Fast Reactor
Lead Coolant in the AEROSOL/LM Module of the EUCLID/V2
Integrated Computer Code

*D. S. Sinitsyn, M. V. Vorivonchik, D. A. Nazarov,
N. A. Mosunova, and A. A. Sorokin*

Renewable Energy Sources, Hydro Power Engineering

Concentrating Solar Energy Technologies in India: Present Status, Challenges
and Directions for Development (a Brief Report)

A. Verma, S. Kumar, and S. Sengupta

Environmental Protection

Selective Noncatalytic NO_x Reduction System at MSW Energy Waste Recycling Plants
in Moscow Oblast: Justification of Decisions Made

V. S. Kireenko, A. N. Tugov, and V. A. Bezrukov

Development of a Software System for Estimating the Steam Turbine Condenser Performance

A. G. Shempelev^a and D. M. Suvorov^{a, *}

^a Vyatka State University, Kirov, 610000 Russia

^{*}e-mail: dmilar@mail.ru

Abstract—A software system for estimating the performance of a steam turbine condenser has been developed on the basis of its mathematical model, which takes into account the condenser interaction with the main ejector. The software system performs a number of key functions for diagnostics of condensing installations; in particular, it ranks the factors causing a growth of pressure in the condenser in comparison with its standard value in their significance and determines the decrease of electric power output resulting from deviation of each of the factors from their standard values. A distinctive feature of the developed software system is that it takes into account the interaction between the condensers and main ejectors in a wide range of steam loads and air in-leakages in the vacuum system, and the effect of this interaction on the turbine unit technical and economic indicators. It has been determined that, according to the results of the accomplished comparison between the predicted and standard data (i.e., verification), the accuracy of computation according to the mathematical models is more than sufficient for settling matters concerned with operational diagnostics of the condensing installation considered. By using the software system, one can analyze the steam turbine unit condenser performance, reveal the main factors causing degradation of its performance indicators, and make provisions for the measures on removing the revealed drawbacks and adjusting the most efficient condenser operation modes. By using the software system, it is also possible to construct the condenser standard and actual characteristics in the entire really permissible range of influencing parameters, diagnose the condenser heat transfer surface condition for any steam turbine units at combined heat and power plants (CHPPs) when specifying the necessary and sufficient input data on the design parameters of condensers and ejectors, and after carrying out the verification.

Keywords: steam turbine unit, condition monitoring, condenser, ejector, diagnostics, mathematical model, performance, software system, verification

Criteria for Assessing the Quality of Fire-Resistant Fluids

R. V. Akulich^{a, *}, E. A. Shorina^a, and N. C. Arzhinovskaya^a

^a *All-Russia Thermal Engineering Institute (VTI), Moscow, 115280 Russia*

^{*}*e-mail: RVAkulich@vti.ru*

Abstract—To date, in the regulatory and technical documents containing requirements for the quality of fire-resistant fluids, there is no unified concept of the rejection indicators of oil, upon reaching the limit values of which the use of the oil is prohibited. In this regard, difficulties arise in making decisions about extending the service life of fire-resistant fluids. Some facilities use oils with an acid number of 3 mg KOH/g and higher, which significantly reduces the reliability of the oil-filled equipment of the power plant, up to the development of emergency situations. The article examines in detail the processes of destruction of fire-resistant fluids based on triaryl phosphates and the conditions for phosphating metals. The results are presented from studies of the surfaces of steel plates after conducting an analysis to determine the corrosion properties of oils in accordance with FR.1.31.2010.08899 Methodology for Measuring the Anticorrosion Characteristics of Samples of Mineral and Fire-Resistant (type OMTI) Turbine Oils (certificate of certification no. MVI 60-09 dated November 17, 2009). It has been shown that, when using oils with a maximum acid number, a film consisting of iron phosphates is formed on the surface of steel coupons, with the simultaneous occurrence of a polycondensation process of oil-decomposition products. Taken together, this leads to an incorrect definition of such an oil quality criterion as corrosion on steel plates. The results of studies of deposits taken from various units of the turbo unit lubrication system are presented, indicating an inevitable decrease in the reliability of the oil system when using oil with a high acid number.

Keywords: fire-retardant fluid, triaryl phosphates, acid number, corrosion on steel plates, metal phosphating, phenol, polycondensation, elemental analysis

Design Calculation of a Shell-and-Tube Condenser in the ORC Unit Operating on Pentane

I. S. Antanenкова^{a, *}, A. A. Antanenkov^a, V. I. Kuznetsov^a, and D. S. Pisarev^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: antanenkovais@mail.ru

Abstract—Units implementing the organic Rankine cycle (ORC) can utilize dozens of low-boiling substances, also called freons or refrigerants, as the working fluid. However, the classic solution for this cycle is the application of pentane and, therefore, this technology is sometimes called pentanoic. One of the main elements of the ORC unit circuit is the condenser, which is often a shell-and-tube heat exchanger cooled with circulating water. In spite of wide application of such apparatuses in steam turbine units, the elaboration of their design on the basis of the pentane technology is a challenging problem. For a prototype of this apparatuses, the KTR shell-and-tube condenser, which was previously often employed in refrigeration units with R12 refrigerant, is adopted in this work. Since chlorofluorocarbons and hydrochlorofluorocarbons have been phased out, equipment items intended for their application are also no longer manufactured by industry, which resulted in a shortage of information on their design and peculiarities of their design process. Hence, the authors carried out a search for and analysis of information about such apparatuses and developed and verified a procedure of design calculation of this equipment. In addition, models for calculating the heat-transfer coefficient during pentane condensation on tube bundles with rolled fins were reviewed, and these models were verified against experimental data on the condensation of propane, one of the closest homologues of pentane. The model proposed by A. Briggs and J.W. Rose has been found to yield the highest accuracy in engineering calculations of pentane condensers. Other models are also examined, which describe the effects of vapor shear and inundation of the lower tubes in the bundle on the heat-transfer coefficient during pentane condensation. It has been demonstrated that considering these effects during condensation of pentane and its homologues in the examined apparatus is impractical. The results of the design calculation of shell-and-tube condensers of pentane with a capacity of 173- and 2280-kW are presented. Recommendations for further optimization calculations are formulated.

Keywords: ORC, shell-and-tube condenser, propane, R290, pentane, condensation, heat-transfer coefficient, calculation procedure, rolled finning

Modeling of Film Boiling of Undercooled Liquid on the Surface of a Smooth Horizontal Cylinder by the VOF Method

K. B. Minko^{a,*} and T. A. Gataullin^a

^a National Research University Moscow Power Engineering Institute (NRE MPEI), Moscow, 111250 Russia

*e-mail: minkokb@gmail.com

Abstract—A study of film-boiling processes of liquid subcooled to saturation state was conducted using numerical modeling based on the Volume of Fluid (VOF) method and the Lee model for describing heat and mass transfer at the interphase boundary. During film boiling, a stable vapor film is formed between the wall and the liquid, eliminating their direct contact, which leads to low heat-transfer intensity. Under conditions of underheating of the liquid to the saturation state, the intensity of film boiling increases significantly. Despite a high-quality understanding of the heat and mass transfer mechanisms underlying this phenomenon, the development of new, more accurate models is actively ongoing. The efforts of researchers are driven by the need to accurately describe the cooling dynamics of high-temperature bodies and predict the conditions for the occurrence of high-intensity boiling regimes. Physical models explaining the emergence of these modes are still at the development stage. To verify and clarify them, there is not enough information about the local characteristics of the vapor film and the features of free convective flow in subcooled liquid. The use of the VOF method allows for detailed tracking of changes in the interphase boundary directly during the numerical simulation process. The article presents the results of modeling film boiling of water on the surface of a cylinder with a diameter of 2 mm with overheating of the wall up to 400 K and underheating of the liquid up to 20 K. The discrepancy between the obtained calculated data and the experimental results published in literary sources does not exceed 10%. Information is provided on the distribution of film thickness, heat flux density on the wall, and the interphase boundary. According to the calculation, even with slight underheating, the vapor is not “evacuated” from the vapor cavity, while evaporation is observed on one part of the interphase surface, and condensation on the other. Results of modeling taking into account buoyancy forces, associated with temperature nonuniformity in an underheated liquid, and without taking them into account practically coincide, which indicates that the lifting current is formed mainly due to mass forces conditioned by difference in phase densities. The obtained data can be useful for creating more accurate empirical models describing the process of stable film boiling in subcooled liquid. All calculations were performed using the ANES CFD code developed at the Department of Engineering Thermal Physics of the National Research University MPEI.

Keywords: film boiling, liquid subcooling, cooled surface, heat exchange, heat-transfer coefficient, heat flow, vapor film, model of heat and mass transfer on the interphase surface, numerical modeling, VOF method

Cross-Verification of OpenFOAM Code with Embedded Models for Calculation of Film Condensation Processes by the VOF Method

A. A. Klementyev^{a, *}, K. B. Minko^a, and V. I. Artemov^a

^a *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

^{*}*e-mail: ya.art-klementiev@yandex.ru*

Abstract—Surface film condensation processes occur in many technical devices. For the calculation of industrial capacitors, empirical methods are usually used, which, however, are insensitive to some factors affecting the intensity of these processes, which limits the range of their application for design. Using existing methods, it is possible for one to calculate the heat-exchange surface area required to maintain the required heat flow, but it is not possible to specify the layout of the tubes in the condenser, which determines the flow of the vapor-liquid mixture in the intertube space and, ultimately, the efficiency of the device. To design more efficient condensers, it is necessary to improve the methods, including those based on data obtained using modern methods of numerical modeling of heat and mass transfer processes. One of the promising methods for calculating surface condensation processes in tube bundles is the Volume of Fluid (VOF) method, supplemented by models for taking into account heat and mass transfer at the interphase surface. The VOF method has been implemented in some commercial codes, but the settings of the code parameters and the choice of a suitable mesh and turbulence model for calculating the condensation processes of moving vapor are not at all obvious. Previously, the authors of this work proposed and implemented a modified model of W.H. Lee in the research CFD code ANES and the commercial CFD code ANSYS Fluent for calculating heat and mass transfer processes at the interphase surface using the VOF method. The model was verified on typical problems and limited data for tube bundles. In this paper, condensation and turbulent vapor flow models are implemented in the open-source CFD code OpenFOAM. The models were validated on Stefan problems and condensation of moving and stationary vapor of various heat carriers, and cross-verification of OpenFOAM, ANES, and ANSYS Fluent codes was carried out.

Keywords: film condensation, horizontal pipe, moving vapor, numerical simulation, VOF method, code cross-verification, OpenFOAM, ANES, ANSYS Fluent

An Analysis of Possible Mechanisms of Lead Oxide Vapor Formation in the Vapor Bubble Volume

M. V. Vorivonchik^{a, *}, N. A. Mosunova^a, and A. A. Sorokin^{a, **}

^a Nuclear Safety Institute, Russian Academy of Sciences (IBRAE RAS), Moscow, 115191 Russia

**e-mail: vorivonchik.mv@ibrae.ac.ru*

***e-mail: sorokin@ibrae.ac.ru*

Abstract—A kinetic model is presented describing the formation of lead oxide vapor in the volume of a vapor bubble in the lead melt with its subsequent dissolution in the lead melt and crystallization in the bubble. The model is implemented in the approximation of homogeneous distribution of reagents and oxidation reaction products in the bubble volume. It is shown that vapor bubbles in the lead melt volume may be considered as chemical “microreactors” producing lead oxide vapor and nanoparticles in the bubble volume. The paper presents the results of calculation by a homogeneous model of the lead oxide vapor concentration in the bubble volume as a function of time and of the conditions for the possible formation of a soluble oxide shell on the bubble surface. The model includes mechanisms controlling lead evaporation and oxidation of lead vapor as it interacts with water vapor in the bubble volume and crystallization of lead vapor on the bubble inside surface with formation of a solid phase shell. Partial transformation of vapor bubbles into gas—vapor bubbles with an oxide shell could potentially affect their further behavior in the lead coolant. However, subsequent transport of the bubbles in the coolant circuit will lead to the dissolution of the oxide shell in the sections with the coolant at a higher temperature that will neutralize this negative effect. Moreover, formation of an oxide shell around the vapor bubbles can cause temporary trapping of hydrogen in the bubble volume.

Keywords: lead coolant, steam generator, vapor bubbles, evaporation, diffusion, oxidation, lead oxide, hydrogen, crystallization, dissolution, dissolved iron, injected water, oxide film

Simulating the Behavior of Gaseous Fission Product Bubbles in the Fast Reactor Lead Coolant in the AEROSOL/LM Module of the EUCLID/V2 Integrated Computer Code

D. S. Sinitcyn^{a, *}, M. V. Vorivonchik^a, D. A. Nazarov^a, N. A. Mosunova^a, and A. A. Sorokin^{a, **}

^a Nuclear Safety Institute, Russian Academy of Sciences (IBRAE RAS), Moscow, 115191 Russia

*e-mail: synitcyn@ibrae.ac.ru

**e-mail: sorokin@ibrae.ac.ru

Abstract—One of the requirements that have to be met is substantiating the safety of newly designed and constructed lead cooled reactors is to evaluate the consequences from possible escape of fission products from nuclear fuel into the coolant during an accident in which part of fuel pins lose their leak tightness. Hence, it is of relevance to develop a model and a computation module based on this model for simulating the interaction of volatile fission products dissolved in the lead melt (iodine and cesium isotopes, and other radionuclides) with the bubbles of gaseous fission products (xenon and krypton isotopes). The consideration of this process is very important in substantiating the safety of lead cooled reactors, because the interaction of volatile fission products dissolved in the lead melt with the bubbles of gaseous fission products has an effect on the content of dissolved radionuclides in the lead melt and on the release of radionuclides into the gas space above the lead melt. The subsequent migration of radionuclides in the reactor gas circuit results in that the activity of radionuclides becomes redistributed in the circuit. It also facilitates the release of activity, as a consequence of loss of leak tightness of the circuit components, into the reactor rooms and the ventilation system. In addition, the bubbles of gaseous fission products in the lead melt interact with the hydrogen isotopes dissolved in the melt (protium and tritium) and facilitate their escape into the reactor gas circuit. The article presents the results from the development of the model and corresponding software unit, and its incorporation into the AEROSOL/LM module, which is part of the EUCLID/V2 integrated code, for calculating the behavior of inert radioactive gas bubbles, including the interaction of bubbles with the radionuclides dissolved in lead melt and the release of bubbles into the reactor gas space. To check how correctly the models are implemented in the code by means of software, the article presents data on the verification of the developed module based on the results of solving test problems.

Keywords: fast reactor, lead coolant, inert gas radionuclides, volatile fission products, gas bubbles, bubble floating-up, gas space, fission product transport

Concentrating Solar Energy Technologies in India: Present Status, Challenges and Directions for Development (a Brief Report)

A. Verma^a, S. Kumar^b, and S. Sengupta^{a,*}

*^a Amity Institute for Advanced Research and Studies (Materials and Devices), Amity University Uttar Pradesh,
Noida, 201301 India*

^b GAP Solar Private Limited, Plot D1, C Block Community Centre Naraina Vihar, New Delhi, 110028 India

**e-mail: ssengupta1@amity.edu*

Abstract—In India, solar energy, especially concentrated solar power (CSP), offers a promising path toward the production of clean, renewable energy. The government's ambitions for increasing the capacity of solar electricity and the abundance of solar resources have brought CSP into further spotlight. Notwithstanding its potential, CSP has encountered noteworthy obstacles impeding its extensive use. These difficulties include the absence of trustworthy data, the limitations of domestic production capacity, and the rivalry posed by photovoltaic (PV) technology. India boasts over 300 clear sky days a year with solar radiation of 1700–1900 kW h per kilowatt peak, making it a country with significant potential for producing electricity from solar power systems per watt. The Indian government has set goals to generate an additional 104 GW of solar electricity by 2025 and 448 GW by 2030. In this review, we try to offer a thorough evaluation of the present status of the CSP in India and discuss the obstacle and future potential of the same. This review aims to provide insightful information for researchers, policymakers, industry stakeholders, and practitioners in the renewable energy field.

Keywords: concentrated solar power (CSP), Indian scenario, obstacles to the use of CSP, future prospect of CSP in India

Selective Noncatalytic NO_x Reduction System at MSW Energy Waste Recycling Plants in Moscow Oblast: Justification of Decisions Made

V. S. Kireenko^{a, *}, A. N. Tugov^{a, **}, and V. A. Bezrukov^{b, ***}

^a All-Russia Heat Engineering Institute, Moscow, 115280 Russia

^b OOO Special Energy, Moscow, 121108 Russia

*e-mail: kireenckovova@yandex.ru

**e-mail: ANTugov@vti.ru

***e-mail: sl4v1k@yandex.ru

Abstract—Due to the continuous growth of municipal solid waste (MSW) volumes, their disposal with minimal negative impact on the environment is becoming a very urgent task. Thermal recycling of MSW is one of the most effective methods of their disposal because it allows not only to significantly reduce the volume of waste but also to obtain thermal and electrical energy. However, this process is accompanied by the formation of nitrogen oxides (NO_x), which contribute to the formation of smog and acid rain and negatively affect the environmental situation and public health. Therefore, the reduction of NO_x emissions is an important task for enterprises burning MSW with the release of electricity and heat to consumers. The article discusses selective noncatalytic reduction (SNCR) technologies used to reduce NO_x emissions at factories in Moscow oblast. The rationale for key technical decisions is presented, including the choice of reducing agent (urea), transport agent (air), and the reagent-injection system through nozzles arranged in three tiers. The results of calculations of the trajectories of the urea–air mixture jets in the cross-flow of flue gases are presented, confirming the effectiveness of the proposed configuration of the reducing agent supply system. It is shown that the use of air as a transporting agent in combination with the adopted nozzle placement scheme ensures uniform distribution of the reagent in the high-temperature zone, which increases the efficiency of NO_x reduction. The obtained results of the calculation studies can be used for further optimization of the SNCR system operation as well as for conducting operational tests at facilities engaged in MSW utilization.

Keywords: municipal solid waste, thermal processing, nitrogen oxides, SNCR, urea, transport agent, nozzles, jet trajectory